

Comments by

American Forest & Paper Association, Inc., American Iron and Steel Institute, America’s Power, Associated Electric Cooperative, Inc., Deseret Electric Power Cooperative, Midwest Ozone Group,¹ National Mining Association, the National Rural Electric Cooperative Association, Ohio Valley Electric Corporation, the Portland Cement Association, and Wabash Valley Power Alliance

on the U.S. Environmental Protection Agency’s Proposed Federal “Good Neighbor Plan” for the 2015 Ozone National Ambient Air Quality Standards; Response to Additional Judicial Stays of SIP Disapproval Action for Certain States

**88 Fed. Reg. 67,102 (Sept. 29, 2023)
Docket ID No. EPA–HQ–OAR–2021–0668**

October 30, 2023

The above-named parties are individual electric generating companies who own and operate electric generating units (“EGUs”) covered by the U.S. Environmental Protection Agency’s (“EPA”) Good Neighbor Plan for the 2015 Ozone National Ambient Air Quality Standards (“Good Neighbor Plan”) and national trade associations whose members own and operate stationary sources regulated by the Good Neighbor Plan, provide fuel to EGUs, and depend on reliable affordable electricity and other products from those sources. As such, these parties have an interest in EPA’s Interim Final Rule entitled: “Federal ‘Good Neighbor Plan’ for the 2015 Ozone National Ambient Air Quality Standards; Response to

¹ The members and participants in the Midwest Ozone Group are listed in Attachment A.

Additional Judicial Stays of SIP Disapproval Action for Certain States” (“Second Interim Final Rule”). 88 Fed. Reg. 67,102 (Sept. 29, 2023).

1. The Second Interim Final Rule properly stays the Good Neighbor Plan in additional states in which EPA’s disapproval of state implementation plans (“SIPs”) has been stayed.

In July 2023, EPA properly stayed the Good Neighbor Plan with respect to the following six states where EPA’s state implementation plan (“SIP”) disapprovals have been stayed by various U.S. Courts of Appeals: Arkansas, Kentucky, Louisiana, Mississippi, Missouri, and Texas. Federal “Good Neighbor Plan” for the 2015 Ozone National Ambient Air Quality Standards; Response to Judicial Stays of SIP Disapproval Action for Certain States, 88 Fed. Reg. 49,295 (July 31, 2023) (“First Interim Final Rule”). Six other states—Alabama, Minnesota, Nevada, Oklahoma, Utah, and West Virginia—have also had their SIP disapprovals stayed by various U.S. Courts of Appeals.

The above-named parties commented on the First Interim Final Rule, explaining that because EPA has no legal authority under the Clean Air Act to implement a federal implementation plan like the Good Neighbor Plan rule in a state in the absence of an effective disapproval of that state’s SIP, CAA § 110(c), 42 U.S.C. § 7410(c), EPA should extend the First Interim Final Rule to the remaining six states in which the SIP disapprovals have been stayed. The Second Interim Final Rule does exactly that.

2. EPA must revise the Second Interim Final Rule to explicitly toll the compliance schedule related to future emission control requirements, as well as the administrative dates leading up to the 2026 deadlines.

In the preamble to the Second Interim Final Rule (88 Fed. Reg. at 67,103-04), EPA offers the following statement addressing the lead time needed to meet certain deadlines in the Good Neighbor Plan rule:

At the time of this rulemaking, the EPA cannot predict how the Agency's future action may affect the amendments being finalized in this action. However, for these States, as well as the States covered by the First Interim Final Rule, the EPA generally anticipates that any future action bringing the Good Neighbor Plan's requirements into effect after a stay would phase in the requirements so as to provide lead times to implement the Good Neighbor Plan's identified emissions control strategies comparable to the lead times that the Good Neighbor Plan would have provided in the absence of the stay, thereby giving parties sufficient time to prepare for implementation.

Such an approach is consistent with EPA's action in connection with the Cross-State Air Pollution Rule in 2014 where the compliance schedule for that rule was tolled for three years by the D.C. Circuit.² Extending each of the Interim Final Rules to explicitly address the tolling of the compliance schedules will ensure that the present stays (and any future stays that may occur) serve their intended purpose to preserve the status quo pending judicial review.

However, the Second Interim Final Rule itself fails to explicitly state that for sources in those states that have had their SIP disapprovals stayed, the timetable for

² Order, Doc. 1518738, *EME Homer City Generation, L.P. v. E.P.A.*, No. 11-1302 (D.C. Cir. October 23, 2014).

compliance with the Good Neighbor Plan rule’s requirements (including both administrative and emission control requirements) is also stayed with respect to both EGUs and non-EGUs. For example, there are several deadlines included in the Good Neighbor Plan that are approaching soon, such as the requirement that a state submit its SIP as early as August 2024.³ Under the Good Neighbor Plan, those states that find that they face “technical impossibility or extreme economic hardship may submit to the Administrator, by August 5, 2024, a request for approval of a case-by-case emissions limit.”⁴ None of the deadlines, including these deadlines, should apply in states that have received stays of their SIP disapprovals. Accordingly, we urge that EPA revise the Second Interim Final Rule to explicitly state in the rule itself that sources in the states covered by either the First or Second Interim Final Rule do not need to take any action at this time to prepare for meeting all of the Good Neighbor Plan rule’s requirements and therefore toll any and all deadlines included in the Good Neighbor Plan.

3. Given that the SIP disapprovals in more than half the states subject to the Good Neighbor Plan have been stayed, EPA should stay the Good Neighbor Plan in its entirety.

While EPA has correctly determined that major portions of the Good Neighbor Plan rule should not be allowed to take effect as the result of the SIP

³ 88 Fed. Reg. at 36,879.

⁴ 40 CFR 52.40(e)(1) (Sept. 29, 2023).

disapproval stays, EPA must do more. The fact of the matter is that every court that has been asked to stay a SIP disapproval related to the Good Neighbor Plan rule has done so; no court has denied such a request. Because the underlying SIP disapprovals have been stayed in 12 states—which is more than half of the total states covered by the Good Neighbor Plan—the Good Neighbor Plan rule is now on life support, existing as a mere shadow of its former self, eroded by the orders of seven U.S. Courts of Appeals. The practical effect of these 12 SIP disapproval stays is that 89 percent of anticipated reductions in emissions of nitrogen oxides (“NO_x”) from EGUs and 60 percent of the anticipated NO_x emission reductions from non-EGUs have been removed from the Good Neighbor Plan. As such, we urge EPA to take the crucial step now of recognizing the flaws underlying the Good Neighbor Plan rule and staying it in its entirety.

EPA cannot move forward with the Good Neighbor Plan under these circumstances. Specifically, only 11 percent of EGU and 40 percent of non-EGU anticipated emission reductions remain in effect as the result of the stays of the SIP disapprovals that have been granted – stays that courts could only have granted if they found that the challenges to the SIP disapprovals were likely to succeed on the merits. At a minimum, EPA must analyze the effect of the SIP disapprovals on mandatory considerations under section 110(a)(2)(D)(i) of the Clean Air Act, including the effect of the removal of these states on significant contribution and

cost-effectiveness. EPA has not conducted such an analysis. And there is no evidence that the Good Neighbor Plan rule can be justified under these conditions. It would be arbitrary, capricious, unlawful, and contrary to due process and the Clean Air Act to allow for the implementation of a rule that has been modified so dramatically following promulgation.

In addition, even with respect to the states for which the First and Second Interim Final Rule stays the effectiveness of EPA's Good Neighbor Plan, these Rules fail in their purported aim to "preserve status quo requirements established in previous [Good Neighbor] rulemakings."⁵ Under the status quo prior to the Good Neighbor Plan, states like Alabama, Arkansas, Mississippi, Missouri, Oklahoma, and Texas participated in the Group 2 allowance trading market with states like Wisconsin. But under either of the Interim Final Rules, the status quo is not restored because EPA is subjecting Wisconsin to the Group 3 allowance market. This is even more true with states like Kentucky and Louisiana, which are being relegated to their own mini-market of emissions allowances, rather than being able to trade with other states in Revised CSAPR's Group 3. The size and scope of these allowance trading markets have a meaningful impact on the price of allowances in each market, and therefore the cost of compliance within each state. The only way to truly restore the pre-Good Neighbor Rule status quo with respect to all states that have received a

⁵ 88 Fed. Reg. at 49,297; 88 Fed. Reg. at 67,106.

judicial stay of their SIP disapprovals is to stay the effectiveness of the *entire* Good Neighbor Plan.

For additional authority supporting the need to stay the entire Good Neighbor Plan rule, please see the Emergency Application for Immediate Stay of Final Agency Action Pending Disposition of Petition for Review that was filed with the United States Supreme Court on October 13, 2023, which is incorporated by reference and included with these comments as Attachment B and the related Appendix that is incorporated by reference and included with these comments as Attachment C Parts 1 and 2.

Conclusion

Given the developments that have given rise to the need for EPA to promulgate not one, but two Interim Final Rules and for the reasons set forth in these comments, we urge that EPA stay the entire Good Neighbor Plan rule pending judicial review of the SIP disapprovals underlying the Good Neighbor Plan rule and the rule itself.

Attachment A

Midwest Ozone Group Members and Participants

Alcoa
Ameren
American Electric Power
American Forest & Paper Association
American Iron and Steel Institute
American Wood Council
Appalachian Region Independent Power Producers Association
Associated Electric Cooperative
Berkshire Hathaway Energy
Big Rivers Electric Corporation
Buckeye Power, Inc.
Citizens Energy Group
City Water, Light & Power (Springfield IL)
Cleveland Cliffs
Council of Industrial Boiler Owners
Duke Energy Corporation
East Kentucky Power Cooperative
ExxonMobil
FirstEnergy Corporation
Hoosier Energy REC, Inc.
Indiana Energy Association
Indiana-Kentucky Electric Corporation
Indiana Municipal Power Agency
Indiana Utility Group
LGE/ KU
Marathon Petroleum Company
National Lime Association
North American Stainless
Nucor Corporation
Ohio Utility Group
Ohio Valley Electric Corporation
Olympus Power
Steel Manufacturers Association
Wabash Valley Power Alliance

Comments by

American Forest & Paper Association, Inc., American Iron and Steel Institute, America's Power, Associated Electric Cooperative, Inc., Deseret Electric Power Cooperative, Midwest Ozone Group, National Mining Association, the National Rural Electric Cooperative Association, Ohio Valley Electric Corporation, the Portland Cement Association, and Wabash Valley Power Alliance

on the U.S. Environmental Protection Agency's Proposed Federal "Good Neighbor Plan" for the 2015 Ozone National Ambient Air Quality Standards; Response to Additional Judicial Stays of SIP Disapproval Action for Certain States

**88 Fed. Reg. 67,102 (Sept. 29, 2023)
Docket ID No. EPA-HQ-OAR-2021-0668**

October 30, 2023

Attachment B

Emergency Application for Immediate Stay of Final Agency Action Pending Disposition of Petition for Review

In the Supreme Court of the United States

AMERICAN FOREST & PAPER ASSOCIATION; AMERICA'S POWER; ASSOCIATED
ELECTRIC COOPERATIVE, INC.; DESERET POWER ELECTRIC COOPERATIVE;
MIDWEST OZONE GROUP; NATIONAL MINING ASSOCIATION; THE NATIONAL
RURAL ELECTRIC COOPERATIVE ASSOCIATION; OHIO VALLEY ELECTRIC
CORPORATION; THE PORTLAND CEMENT ASSOCIATION;
WABASH VALLEY POWER ALLIANCE,

Applicants,

v.

ENVIRONMENTAL PROTECTION AGENCY AND MICHAEL S. REGAN,
ADMINISTRATOR,

Respondents.

**EMERGENCY APPLICATION
FOR IMMEDIATE STAY OF FINAL AGENCY ACTION
PENDING DISPOSITION OF PETITION FOR REVIEW**

To the Honorable John G. Roberts, Jr.,
Chief Justice of the Supreme Court of the United States and Circuit Justice
for the District of Columbia Circuit

Michael B. Schon
LEHOTSKY KELLER COHN LLP
200 Massachusetts Ave NW
Washington, DC 20001
(512) 693-8350

Mithun Mansinghani
LEHOTSKY KELLER COHN LLP
629 W. Main St.
Oklahoma City, OK 73102
(512) 693-8350

*Counsel for National Mining
Association*

Jonathan Y. Ellis
Counsel of Record
Allison D. Wood
Makram B. Jaber
MCGUIREWOODS LLP
888 16th Street N.W., Suite 500
Black Lives Matter Plaza
Washington, DC 20006
(202) 857-2420
jellis@mcguirewoods.com

*Counsel for America's Power, Associated
Electric Cooperative, Inc., Deseret Power
Electric Cooperative, the National Rural
Electric Cooperative Association, Ohio Valley
Electric Corporation, the Portland Cement
Association, Wabash Valley Power Alliance*

David M. Flannery
Kathy G. Beckett
Keeleigh S. Utt
Steptoe & Johnson, PLLC
707 Virginia Street, East
Post Office Box 1588
Charleston, WV 25326
(304) 353-8000
Dave.Flannery@steptoe-johnson.com
Kathy.Beckett@steptoe-johnson.com
Keeleigh.Utt@steptoe-johnson.com

Edward L. Kropp
Steptoe & Johnson PLLC
PO Box 36425
Indianapolis, Indiana 46236
317-946-9882
Skipp.kropp@steptoe-johnson.com

*Counsel for American Forest & Paper
Association and Midwest Ozone Group*

PARTIES TO THE PROCEEDINGS

A. Parties to this Application

- i. D.C. Cir. No. 23-1190, *Am. Forest & Paper Assoc. v. EPA*

Petitioner: American Forest & Paper Association.

Respondents: The United States Environmental Protection Agency; Michael S. Regan, EPA Administrator.

Intervenors: City Utilities of Springfield, Missouri.

- ii. D.C. Cir. No. 23-1191, *Midwest Ozone Group v. EPA*

Petitioner: Midwest Ozone Group.

Respondents: The United States Environmental Protection Agency; Michael S. Regan, EPA Administrator.

Intervenors: City Utilities of Springfield, Missouri

- iii. D.C. Cir. No. 23-1195, *Associated Electric Cooperative, Inc. v. EPA*

Petitioners: Associated Electric Cooperative, Inc.; Deseret Generation & Transmission Co-Operative, d/b/a Deseret Power Electric Cooperative; Ohio Valley Electric Corporation; Wabash Valley Power Association, Inc., d/b/a Wabash Valley Power Alliance; America's Power; National Rural Electric Cooperative Association; Portland Cement Association.

Respondents: The United States Environmental Protection Agency; Michael S. Regan, EPA Administrator.

Intervenors: City Utilities of Springfield, Missouri

- iv. D.C. Cir. No. 23-1199, *National Mining Association v. EPA*

Petitioner: National Mining Association.

Respondents: The United States Environmental Protection Agency; Michael S. Regan, EPA Administrator.

Intervenors: City Utilities of Springfield, Missouri

B. Additional Parties to these Consolidated Cases

i. D.C. Cir. No. 23-1157, *State of Utah v. EPA*

Petitioner: The State of Utah, by and through its Governor, Spencer J. Cox, and its Attorney General, Sean D. Reyes.

Respondents: The United States Environmental Protection Agency; Michael S. Regan, EPA Administrator.

Intervenors: City Utilities of Springfield, Missouri; City of New York; Commonwealth of Massachusetts; Commonwealth of Pennsylvania; District of Columbia; Harris County, Texas; State of Connecticut; State of Delaware; State of Illinois; State of Maryland; State of New Jersey; State of New York; State of Wisconsin; Air Alliance Houston; Appalachian Mountain Club; Center for Biological Diversity; Chesapeake Bay Foundation; Citizens for Pennsylvania's Future; Clean Air Council; Clean Wisconsin; Downwinders at Risk; Environmental Defense Fund; Louisiana Environmental Action Network; Sierra Club; Southern Utah Wilderness Alliance; Utah Physicians for a Healthy Environment.

ii. D.C. Cir. No. 23-1181, *Kinder Morgan v. EPA*

Petitioner: Kinder Morgan, Inc.

Respondents: The United States Environmental Protection Agency; Michael S. Regan, EPA Administrator.

Intervenors: City Utilities of Springfield, Missouri; Commonwealth of Massachusetts; Commonwealth of Pennsylvania; District of Columbia; Harris County, Texas; State of Connecticut; State of Delaware; State of Illinois; State of Maryland; State of New Jersey; State of New York; State of Wisconsin; City of New York.

iii. D.C. Cir. No. 23-1183, *State of Ohio v. EPA*

Petitioners: State of Ohio; State of West Virginia; State of Indiana.

Respondents: The United States Environmental Protection Agency; Michael S. Regan, EPA Administrator.

Intervenors: City Utilities of Springfield, Missouri; City of New York; Commonwealth of Massachusetts; Commonwealth of Pennsylvania; District of Columbia; Harris County, Texas; State of Connecticut; State of Delaware; State of Illinois; State of Maryland; State of New Jersey; State of New York; State of Wisconsin.

iv. D.C. Cir. No. 23-1193, *Interstate Natural Gas Association of America v. EPA*

Petitioners: Interstate Natural Gas Association of America; American Petroleum Institute.

Respondents: The United States Environmental Protection Agency; Michael S. Regan, EPA Administrator.

Intervenors: City Utilities of Springfield, Missouri.

v. D.C. Cir. No. 23-1200, *American Iron and Steel Institute v. EPA*

Petitioners: American Iron and Steel Institute.

Respondents: The United States Environmental Protection Agency; Michael S. Regan, EPA Administrator.

Intervenors: City Utilities of Springfield, Missouri.

vi. D.C. Cir. No. 23-1201, *State of Wisconsin v. EPA*

Petitioners: State of Wisconsin.

Respondents: The United States Environmental Protection Agency; Michael S. Regan, EPA Administrator.

Intervenors: City Utilities of Springfield, Missouri; Sierra Club; Midwest Ozone Group.

vii. D.C. Cir. No. 23-1202, *Enbridge (U.S.) Inc. v. EPA*

Petitioners: Enbridge (U.S.) Inc.

Respondents: The United States Environmental Protection Agency; Michael S. Regan, EPA Administrator.

Intervenors: City Utilities of Springfield, Missouri.

viii. D.C. Cir. No. 23-1203, *American Chemistry Council v. EPA*

Petitioners: American Chemistry Council; American Fuel & Petrochemical Manufacturers.

Respondents: The United States Environmental Protection Agency; Michael S. Regan, EPA Administrator.

Intervenors: City Utilities of Springfield, Missouri.

ix. D.C. Cir. No. 23-1205, *TransCanada Pipeline USA Ltd. v. EPA*

Petitioners: TransCanada Pipeline USA Ltd.

Respondents: The United States Environmental Protection Agency; Michael S. Regan, EPA Administrator.

Intervenors: City Utilities of Springfield, Missouri.

x. D.C. Cir. No. 23-1206, *Hybar LLC v. EPA*

Petitioners: Hybar LLC

Respondents: The United States Environmental Protection Agency; Michael S. Regan, EPA Administrator.

Intervenors: City Utilities of Springfield, Missouri.

xi. D.C. Cir. No. 23-1207, *United States Steel Corporation v. EPA*

Petitioners: United States Steel Corporation.

Respondents: The United States Environmental Protection Agency; Michael S. Regan, EPA Administrator.

Intervenors: City Utilities of Springfield, Missouri.

xii. D.C. Cir. No. 23-1208, *Union Electric Company v. EPA*

Petitioners: Union Electric Company, d/b/a Ameren Missouri.

Respondents: The United States Environmental Protection Agency; Michael S. Regan, EPA Administrator.

Intervenors: City Utilities of Springfield, Missouri.

xiii. D.C. Cir. No. 23-1209, *State of Nevada v. EPA*

Petitioners: State of Nevada.

Respondents: The United States Environmental Protection Agency; Michael S. Regan, EPA Administrator.

Intervenors: City Utilities of Springfield, Missouri.

xiv. D.C. Cir. No. 23-1211, *Arkansas League of Good Neighbors v. EPA*

Petitioners: Arkansas League of Good Neighbors.

Respondents: The United States Environmental Protection Agency; Michael S. Regan, EPA Administrator.

Intervenors: City Utilities of Springfield, Missouri.

CORPORATE DISCLOSURE STATEMENT

Pursuant to Rule 29.6, applicants state as follows:

AMERICAN FOREST & PAPER ASSOCIATION

The American Forest & Paper Association (“AF&PA”) is a continuing association of individuals operated for the purpose of promoting the general interests of its membership. The AF&PA represents nearly 87% of the pulp, paper, packaging, and tissue products industry which employs 925,000 skilled workers. The AF&PA is a trade association and has no outstanding shares or debt securities in the hand of the public. It has no parent company, and no publicly held company has a 10% or greater ownership interest in AF&PA.

AMERICA’S POWER

America’s Power is a nonprofit membership corporation organized under the laws of the District of Columbia and is recognized as a tax-exempt trade association by the Internal Revenue Service under Section 501(c)(6) of the Internal Revenue Code. America’s Power is the only national trade association whose sole mission is to advocate at the federal and state levels on behalf of coal-fueled electricity, the coal fleet, and its supply chain. America’s Power supports policies that promote the use of coal to assure a reliable, resilient, and affordable supply of electricity to meet our nation’s demand for energy.

America’s Power is a trade association. It has no parent corporation, and no publicly held company owns a 10% or greater interest in America’s Power.

ASSOCIATED ELECTRIC COOPERATIVE, INC.

Associated Electric Cooperative, Inc. (“AECI”) is a rural electric cooperative that provides wholesale power and high-voltage transmission to its six regional generation and transmission cooperative member-owners. In addition to providing power sales and transmission service to its member cooperatives, AECI also takes and provides transmission service through enabling transmission agreements with and makes off-system power sales to various counterparties in the United States. These six regional generation and transmission cooperatives, in turn, supply wholesale power to fifty-one distribution cooperatives in Missouri, three distribution cooperatives in southeast Iowa, and nine distribution cooperatives in northeast Oklahoma, serving more than 2,000,000 customers at 910,000 meters. AECI has no parent company, and no publicly held company has a 10% or greater ownership interest in AECI.

DESERET POWER ELECTRIC COOPERATIVE

Deseret Generation & Transmission Co-Operative d/b/a Deseret Power Electric Cooperative (“Deseret”) certifies that it is a nonprofit, regional generation and transmission cooperative, owned by its five member systems, serving approximately 65,000 customers in Utah, Colorado, Wyoming, Nevada, and Arizona. Neither Deseret, nor its member cooperatives issue stock, and therefore no publicly held company owns 10% or more of their stock.

MIDWEST OZONE GROUP

The Midwest Ozone Group (“MOG”) is a continuing association of organizations and individual entities operated to promote the general interests of its membership on matters related to air emissions and air quality. MOG has no parent companies, subsidiaries, or affiliates that have issued shares or debt securities to the public, although specific individuals in the membership of MOG have done so. MOG has no outstanding shares or debt securities in the hands of the public. It has no parent company, and no publicly held company has a 10% or greater ownership interest in MOG.

NATIONAL MINING ASSOCIATION

The National Mining Association (“NMA”) is a nonprofit national trade association that represents the interest of the mining industry, including every major coal company operating in the United States. NMA has approximately 280 members, whose interests it represents before Congress, the administration, federal agencies, the courts, and the media. NMA is not a publicly held corporation. It has no parent corporation, and no publicly held company has 10% or greater ownership interest in NMA.

NATIONAL RURAL ELECTRIC COOPERATIVE ASSOCIATION

The National Rural Electric Cooperative Association (“NRECA”) is the nonprofit national trade association for electric cooperatives. On behalf of its members, NRECA participates in administrative and judicial proceedings involving or affecting its members’ interests. NRECA has no parent company, and no publicly

held company has a 10% or greater ownership interest in NRECA. NRECA is an incorporated entity.

OHIO VALLEY ELECTRIC CORPORATION

The Ohio Valley Electric Corporation (“OVEC”) is a corporation originally formed by a consortium of utility companies for purposes of constructing and operating electric generating units to serve the electric energy needs of uranium processing facilities owned by the United States Department of Energy. OVEC owns the Kyger Creek generating station in Ohio, and OVEC’s wholly owned subsidiary Indiana-Kentucky Electric Corporation owns the Clifty Creek generating station in Indiana. OVEC has no parent company. American Electric Power Company, Inc., and Buckeye Power, Inc., each owns greater than 10% of the equity in OVEC.

PORTLAND CEMENT ASSOCIATION

The Portland Cement Association (“PCA”), founded in 1916, is the premier policy, research, education, and market intelligence organization serving America’s cement manufacturers. PCA represents a majority of U.S. cement production capacity. PCA promotes safety, sustainability, and innovation in all aspects of construction, fosters continuous improvement in cement manufacturing and distribution, and generally promotes economic growth and sound infrastructure investment. PCA is a trade association and has no parent corporation, and no publicly held company owns a 10% or greater interest in PCA.

WABASH VALLEY POWER ALLIANCE

Wabash Valley Power Association, Inc. d/b/a Wabash Valley Power Alliance (“WVPA”) certifies that it is a nonprofit, generation and transmission cooperative, owned by twenty-three member-owned rural cooperative systems, serving more than 330,000 homes, businesses, farms, and schools – impacting more than a million people – across 50 counties in Indiana, 30 counties in Illinois, and four counties in Missouri. Neither WVPA, nor its member cooperatives issue stock, and therefore no publicly held company owns 10% or more of their stock.

TABLE OF CONTENTS

	<u>Page</u>
PARTIES TO THE PROCEEDINGS.....	i
RULE 29.6 STATEMENT.....	vii
INTRODUCTION.....	1
OPINION BELOW.....	4
JURISDICTION.....	4
STATUTORY AND REGULATORY PROVISIONS.....	4
STATEMENT.....	5
I. Statutory Background.....	5
II. EPA’s Promulgation of State Implementation Plan Disapprovals and the Federal Plan.....	6
III. The Federal Plan Before and After the Court-Ordered Stays of the State Plan Disapprovals.....	8
IV. Differences Between the Federal Plan and Past Federal Implementation Plans.....	11
REASONS FOR GRANTING THE APPLICATION.....	12
I. Applicants Are Likely to Succeed on the Merits in this Case, which Warrants this Court’s Discretionary Review.....	13
A. The Federal Plan as Promulgated No Longer Exists, and EPA Never Analyzed or Allowed Comment on the Smaller, Transformed Version.....	14
B. Even if the Federal Plan Still Consisted of All 23 States, It Would Nonetheless Violate the Clean Air Act.....	20
II. Absent a Stay, the Applicants and Their Members Will Suffer Substantial Irreparable Harms.....	25
III. The Balance of Equities and the Public Interest Favor a Stay.....	27
CONCLUSION.....	29

TABLE OF AUTHORITIES

	Page(s)
Cases	
<i>Alabama v. EPA</i> , No. 23-11173 (11th Cir. Aug. 17, 2023)	8
<i>Allele, Inc. v. EPA</i> , No. 23-1776 (8th Cir. July 5, 2023).....	8
<i>Am. Fuel & Petrochemical Manufacturers v. EPA</i> , 3 F.4th 373 (D.C. Cir. 2021)	20
<i>Arkansas v. EPA</i> , No. 23-1320 (8th Cir. May 25, 2023).....	7
<i>Belmont Mun. Light Dep't v. FERC</i> , 38 F.4th 173 (D.C. Cir. 2022)	20
<i>EPA v. EME Homer City Generation, L.P.</i> , 572 U.S. 489 (2014)	2, 6, 9, 13, 15, 16, 21
<i>Hollingsworth v. Perry</i> , 558 U.S. 183 (2010)	13, 27
<i>Kentucky v. EPA</i> , No. 23-3216 (6th Cir. May 31, 2023).....	7, 8
<i>Lucas v. Townsend</i> , 486 U.S. 1301 (1988)	12
<i>Michigan v. EPA</i> , 135 S. Ct. 2699 (2015)	13
<i>Missouri v. EPA</i> , No. 23-1719 (8th Cir. May 26, 2023).....	7
<i>Motor Vehicle Mfrs. Ass'n v. State Farm Mut. Auto. Ins. Co.</i> , 463 U.S. 29 (1983)	19
<i>Nat'l Fuel Gas Supply Corp. v. FERC</i> , 59 F.3d 1281 (D.C. Cir. 1995)	19
<i>Nevada Cement Company v. EPA</i> , No. 23-682 (9th Cir. July 3, 2023).....	8

<i>Nken v. Holder</i> , 556 U.S. 418 (2009)	13
<i>Nken v. Mukasey</i> , 555 U.S. 1042 (2008)	12
<i>In re NTE Connecticut, LLC</i> , 26 F.4th 980 (D.C. Cir. 2022).....	25
<i>Oklahoma v. EPA</i> , No. 23-9514 (10th Cir. July 27, 2023).....	8
<i>Philip Morris v. Scott</i> , 131 S. Ct. 1 (2010)	25
<i>Texas v. EPA</i> , No. 23-60069 (5th Cir. May 1, 2023).....	7, 8, 27
<i>Thunder Basin Coal Co. v. Reich</i> , 510 U.S. 200 (1994)	25
<i>Tulsa Cement et al. v. EPA</i> , No. 23-9551 (10th Cir. July 20, 2023).....	16, 17
<i>Union Elec. Co. v. EPA</i> , 427 U.S. 246 (1976)	5
<i>Utah v. EPA</i> , No. 23-1157 (D.C. Cir. Sept. 22, 2023).....	10, 17
<i>Utah v. EPA</i> , No. 23-9509 (10th Cir. July 27, 2023).....	8
<i>West Virginia v. EPA</i> , 142 S. Ct. 2587 (2022)	13
<i>West Virginia v. EPA</i> , No. 23-1418 (4th Cir. Aug. 10, 2023)	2, 8
Federal Statutes	
Administrative Procedure Act of 1946, 5 U.S.C. §§ 551–559, Pub. L. No. 79–404, 60 Stat. 237 (1946).....	3, 14, 17, 18
5 U.S.C. § 553.....	14, 18
5 U.S.C. § 705.....	4, 12

28 U.S.C. § 1254.....	4, 12
All Writs Act of 1789, 28 U.S.C. § 1651	4, 12
28 U.S.C. § 2101.....	12
42 U.S.C. § 7407(a)	2, 5
42 U.S.C. § 7607.....	4
42 U.S.C. § 7410.....	2, 5, 6
42 U.S.C. § 7607(d)	14, 18

Other Authorities

Air Plan Disapproval; AL, MS, TN; Interstate Transport Requirements for the 2015 8-Hour Ozone National Ambient Air Quality Standards, 87 Fed. Reg. 9545 (Feb. 22, 2022).....	6
Air Plan Disapproval; California; Interstate Transport of Air Pollution for the 2015 8-Hour Ozone National Ambient Air Quality Standards, 87 Fed. Reg. 31,443 (May 24, 2022).....	6
Air Plan Disapprovals; Interstate Transport of Air Pollution for the 2015 8-Hour Ozone National Ambient Air Quality Standards, 88 Fed. Reg. 9336 (Feb. 13, 2023).....	7
Federal “Good Neighbor Plan” for the 2015 Ozone National Ambient Air Quality Standards, 88 Fed. Reg. 36,654 (June 5, 2023).....	2, 4, 7, 8, 10, 11, 15, 16, 18, 21, 23, 24, 27
Federal “Good Neighbor Plan” for the 2015 Ozone National Ambient Air Quality Standards: Response to Additional Judicial Stays of SIP Disapproval Action for Certain States, 88 Fed. Reg. 67,102 (Sept. 9, 2023).....	9
Federal “Good Neighbor Plan” for the 2015 Ozone National Ambient Air Quality Standards: Response to Judicial Stays of SIP Disapproval Action for Certain States, 88 Fed. Reg. 49,295 (July 31, 2023).....	8
Federal Implementation Plan Addressing Regional Ozone Transport for the 2015 Ozone National Ambient Air Quality Standard, 87 Fed. Reg. 20,036 (Apr. 6, 2022).....	7

National Ambient Air Quality Standards for Ozone,
80 Fed. Reg. 65,292 (Oct. 26, 2015) 6

Ozone NAAQS Interstate Transport SIP Disapprovals – Response to
Comment (RTC) Document Document (2015), *available at*
<https://t.ly/ikB1A> 6

**TO THE HONORABLE JOHN G. ROBERTS, JR.,
CHIEF JUSTICE OF THE SUPREME COURT OF THE UNITED
STATES AND CIRCUIT JUSTICE FOR THE DISTRICT OF
COLUMBIA CIRCUIT:**

The Applicants, ten industry parties consisting of national trade associations and individual electric generating companies, respectfully request an immediate stay of the Environmental Protection Agency’s (“EPA”) final rule entitled “Federal ‘Good Neighbor Plan’ for the 2015 Ozone National Ambient Air Quality Standards,” 88 Fed. Reg. 36,654 (June 5, 2023) (“Federal Plan”). The Applicants have petitions for review of the Federal Plan pending in the United States Court of Appeals for the District of Columbia Circuit and, due to the immediate harm from the Federal Plan, moved for a stay pending that court’s review. A divided panel of that court denied the motion, with Judge Walker stating he would have stayed the Federal Plan.

The Applicants agree with and incorporate the Application by Ohio, Indiana, and West Virginia filed with this Court on October 13, 2023. The Applicants will not repeat the States’ arguments here but will amplify the reasons why the Federal Plan merits this Court’s review, is likely unlawful, and poses immediate and irreparable harm to various industries, including electric generation, paper, steel, cement, and mining, as demonstrated in more detail in the declarations accompanying this application.

INTRODUCTION

This case involves a stubborn refusal by EPA to admit that the legal foundation for a massive, multi-state, regulatory program (the “Federal Plan”) is irreparably flawed—as an extraordinary consensus of seven courts of appeals have

recognized. EPA’s willful decision to move forward has simultaneously abrogated the rights of States to regulate air pollution within their borders and improperly forced industries regulated by the Federal Plan into the immediate expenditure of hundreds of millions of dollars pending the lower court’s review, all while jeopardizing the reliability of the electric grid.

The Clean Air Act’s “core principle” is “cooperative federalism.” *EPA v. EME Homer City Generation, L.P.*, 572 U.S. 489, 511 n.14 (2014). States assume “primary responsibility for assuring air quality....” 42 U.S.C. § 7407(a). EPA may step into the role of the States and issue a rule like the Federal Plan only if EPA lawfully determines that a State’s plan violates the statute. *Id.* § 7410(c)(1).

After missing its statutory deadline to review State plans by years, EPA disapproved 21 State plans *en masse*. 88 Fed. Reg. 9336 (Feb. 13, 2023). State and industry commenters informed EPA that those State-plan disapprovals were likely unlawful, and federal courts of appeals began agreeing, swiftly issuing stays of individual state plan disapprovals. Relying on its unlawful state-plan disapprovals as the legal predicate, EPA nevertheless published the Federal Plan for those 21 States, plus an additional two States. 88 Fed. Reg. at 36,654. Ultimately, entities in 12 of the 23 affected States challenged and sought stays of their disapprovals in various courts of appeals. Every single one of those courts (the Fourth,¹ Fifth, Sixth, Eighth, Ninth, Tenth, and Eleventh Circuits) have granted stays.

¹ The stay of the disapproval of West Virginia’s State plan is administrative, pending the Fourth Circuit’s consideration of that State’s stay motion. *West Virginia v. EPA*,

When seven courts of appeals find that the legal prerequisite for the Federal Plan is likely unlawful, EPA should realize that something has gone awry. Rather than admit the error of its ways, however, EPA has pressed forward with implementing its Federal Plan in the remaining 11 States—despite the fact that EPA premised the rule on its applicability to 23 states, arguing “[n]ationwide consistency in approach is particularly important in the context of interstate ozone transport....” *Id.* at 36,673. Because of the removal of the 12 stayed States, the Federal Plan is a shell of its original design, eviscerating EPA’s analysis underpinning the rule, which addressed only a 23-State program as a whole. In other words, EPA is implementing an 11-state mutant rule that it did not analyze, provide notice of, or take comment on. That momentous action to force its multi-state federal plan, heedless of warnings from court after court that its central pillars are fundamentally unsound, violates the Clean Air Act and the Administrative Procedure Act.

Yet, this irredeemably flawed Federal Plan is now in effect. If this Court does not enter a stay, the Federal Plan will continue to harm the sectors of industry subject to it. By EPA’s own estimates, the Federal Plan will cost between \$8.2 and \$13 billion, with regulated entities like Applicants and their members incurring between \$770 and \$910 million per year during the course of litigation. *Id.* at 36,852. Costs on individual entities are crushing and are being imposed with full force in the 11 States where the Federal Plan is in effect. For example, just one regulated source, Applicant

No. 23-1418 (4th Cir. Aug. 10, 2023) (stay pending argument scheduled for October 27, 2023).

Ohio Valley Electric Corporation, states that it “will begin to incur costs within the next six months” and will be “required to spend between \$80-\$100 million in the next two years.” Brown Decl. ¶¶32, 36. A stay from this Court is the only way for sources subject to the Federal Plan to avoid this irreparable harm.

Accordingly, Applicants respectfully request the Court to enter a stay of EPA’s Federal Plan during the pendency of their petitions for review.

OPINION BELOW

The D.C. Circuit’s order denying the Applicants’ motion for a stay is unpublished and may be found at App’x 1. EPA’s Federal Plan is published at 88 Fed. Reg. 36,654 (June 5, 2023) and reprinted beginning at App’x 2. The unpublished order notes that while the majority of the panel comprised of Judges Pillard, Walker, and Childs denied the stay, “Judge Walker would stay the federal implementation plan in question.”

JURISDICTION

This Court has jurisdiction over this Application pursuant to 28 U.S.C. § 1254(1) and authority to grant the Applicants relief under the Administrative Procedure Act, 5 U.S.C. § 705, the Clean Air Act, 42 U.S.C. § 7607, and the All Writs Act, 28 U.S.C. § 1651(a).

STATUTORY AND REGULATORY PROVISIONS

Pertinent statutory and regulatory provisions are reprinted beginning at App’x 268.

STATEMENT

I. Statutory Background

Congress embedded directly into the Clean Air Act the principle of cooperative federalism, expressly stating that “[e]ach State shall have the primary responsibility for assuring air quality within the entire geographic area comprising such State....” 42 U.S.C. § 7407(a). EPA establishes national ambient air quality standards (“NAAQS”) for certain pollutants, including ozone. *Id.* §§ 7408, 7409. Each State then must develop within three years a State implementation plan that “specif[ies] the manner in which [the NAAQS] will be achieved and maintained.” *Id.* §§ 7407(a), 7410(a)(1).

These plans must satisfy several statutory requirements, including the Act’s “Good Neighbor” provision. *Id.* § 7410(a)(2)(D)(i)(I). That provision delegates to each State the task of ensuring no “emissions activity within the State” will emit “in amounts which will ... contribute significantly to nonattainment in, or interfere with maintenance by, any other State with respect to any” NAAQS.” *Id.*

Once a State develops and submits its plan, EPA “shall approve” the plan within 18 months “if it meets all of the applicable requirements of” the Clean Air Act. *Id.* § 7410(k)(3); *see also Union Elec. Co. v. EPA*, 427 U.S. 246, 257 (1976). Only if EPA lawfully determines that a State plan violates the statute may EPA promulgate a “Federal implementation plan” for that State. 42 U.S.C. § 7410(c)(1).

When EPA is permitted to issue a federal plan, it “cannot require a State to reduce its output of pollution by more than is necessary” to ensure the State will not contribute significantly to another State’s inability to attain or maintain the NAAQS.

EME Homer, 572 U.S. at 521-22. If EPA does, it engages in unlawful “over-control.”
Id. “EPA has a statutory duty to avoid over-control....” *Id.* at 523.

II. EPA’s Promulgation of State Implementation Plan Disapprovals and the Federal Plan

In 2015, EPA lowered the NAAQS for ozone from 75 to 70 parts per billion. 80 Fed. Reg. 65,292, 65,293-94 (Oct. 26, 2015). This required States to develop implementation plans for the revised NAAQS, including plans addressing the Good Neighbor provision, within three years (*i.e.*, by October 26, 2018). 42 U.S.C. § 7410(a)(1). After States submitted their plans, EPA had a statutory duty to approve or disapprove them within eighteen months (*i.e.*, no later than April 2020). *Id.* § 7410(k)(1)-(3). After blowing past this statutory deadline by years, EPA issued proposed disapprovals for 19 States on February 22, 2022,² followed by proposed disapprovals for an additional four States on May 24, 2022.³ Commenters repeatedly warned EPA that these proposed disapprovals were unlawful because they were based on unlawful reasoning. *See, e.g.*, EPA, 2015 Ozone NAAQS Interstate Transport SIP Disapprovals – Response to Comment (RTC) Document at 12, 15, 29, 33, 57, 81, 189, *available at* <https://t.ly/ikB1A>.

² 87 Fed. Reg. 9545 (Feb. 22, 2022) (Alabama, Mississippi, Tennessee); 87 Fed. Reg. 9798 (Feb. 22, 2022) (Arkansas, Louisiana, Oklahoma, Texas); 87 Fed. Reg. 9838 (Feb. 22, 2022) (Illinois, Indiana, Michigan, Minnesota, Ohio, Wisconsin); 87 Fed. Reg. 9498 (Feb. 22, 2022) (Kentucky); 87 Fed. Reg. 9463 (Feb. 22, 2022) (Maryland); 87 Fed. Reg. 9533 (Feb. 22, 2022) (Missouri); 87 Fed. Reg. 9484 (Feb. 22, 2022) (New York, New Jersey); 87 Fed. Reg. 9516 (Feb. 22, 2022) (West Virginia). Comments on each of these proposals were due on April 25, 2022.

³ 87 Fed. Reg. 31,443 (May 24, 2022) (California); 87 Fed. Reg. 31,485 (May 24, 2022) (Nevada); 87 Fed. Reg. 31,470 (May 24, 2022) (Utah); 87 Fed. Reg. 31,495 (May 24, 2022) (Wyoming). Comments on each of these proposals were due on July 25, 2022.

Before the deadline for submitting comments on the proposed disapprovals of the State plans had even expired (and before EPA had even proposed to disapprove some of the States' plans), EPA proposed a comprehensive *federal* implementation plan to regulate emission sources through a single multi-state program. 87 Fed. Reg. 20,036, 20,073 (Apr. 6, 2022) (noting it was “promulgating FIPs to address these obligations on a nationwide scale”). Commenters again repeatedly warned EPA that going forward with a federal plan would be unlawful because the state-plan disapprovals—which are the legal predicate of a federal plan under the Clean Air Act—were unlawful. *See* 88 Fed. Reg. at 36,672-75; EPA, Federal “Good Neighbor Plan” for the 2015 Ozone National Ambient Air Quality Standards: Response to Public Comments on Proposed Rule [87 FR 20036, April 6, 2022] at 2-6, 9-11, 145-48, 152-55, *available at* bit.ly/3EaNAi8.

Despite the warnings regarding the unlawful nature of EPA's proposed disapproval, the Agency finalized the disapprovals of the plans for 21 States in February 2023. 88 Fed. Reg. 9336 (Feb. 13, 2023). A mix of states and industry parties in 12 States challenged their state-plan disapprovals in their respective circuits and moved for stays of the disapprovals. By late May 2023, the Fifth Circuit, Sixth Circuit, and the Eighth Circuit had issued stays of the disapprovals for five States,⁴

⁴ *Texas v. EPA*, No. 23-60069 (5th Cir. May 1, 2023) (Texas and Louisiana); *Arkansas v. EPA*, No. 23-1320 (8th Cir. May 25, 2023); *Missouri v. EPA*, No. 23-1719 (8th Cir. May 26, 2023); *Kentucky v. EPA*, No. 23-3216 (6th Cir. May 31, 2023) (administrative stay pending consideration of stay motion that was granted in July 2023, *see infra* note 5).

concluding that EPA’s state plan disapprovals were likely unlawful. Meanwhile, stay motions were pending for various other courts of appeals.

EPA nonetheless moved forward on June 5, 2023, with publishing the Federal Plan, which covers 23 States and became effective August 4, 2023. 88 Fed. Reg. at 36,654. During the time between the publication of the Federal Plan and its effective date, the wave of federal courts of appeals issuing stays of the state plan disapprovals became a tsunami. Every single one of the 12 state-plan disapprovals that was challenged has now been stayed.⁵

In sum, every circuit to have considered the issue—the Fourth, Fifth, Sixth, Eighth, Ninth, Tenth, and Eleventh Circuits—has stayed EPA’s disapprovals, explicitly or implicitly finding that the States and industries challenging those disapprovals are likely to succeed on the merits.

III. The Federal Plan Before and After the Court-Ordered Stays of the State Plan Disapprovals

EPA has recognized in two interim final rules that it cannot impose its plan in the 12 States where EPA’s state-plan disapprovals have been stayed because those state plan disapprovals form the legal predicate for the Federal Plan.⁶ As a result of

⁵ *Texas v. EPA*, No. 23-60069 (5th Cir. June 8, 2023) (Mississippi); *Nevada Cement Company v. EPA*, No. 23-682 (9th Cir. July 3, 2023) (Nevada); *Allete, Inc. v. EPA*, No. 23-1776 (8th Cir. July 5, 2023) (Minnesota); *Kentucky v. EPA*, No. 23-3216 (6th Cir. July 25, 2023); *Oklahoma v. EPA*, No. 23-9514 (10th Cir. July 27, 2023); *Utah v. EPA*, No. 23-9509 (10th Cir. July 27, 2023); *Alabama v. EPA*, No. 23-11173 (11th Cir. Aug. 17, 2023); *West Virginia v. EPA*, No. 23-1418 (4th Cir. Aug. 10, 2023) (administrative stay pending argument scheduled for October 27, 2023).

⁶ Federal “Good Neighbor Plan” for the 2015 Ozone National Ambient Air Quality Standards: Response to Judicial Stays of SIP Disapproval Action for Certain States, 88 Fed. Reg. 49,295 (July 31, 2023) (Arkansas, Kentucky, Louisiana, Mississippi,

the removal of these 12 States from the Federal Plan, however, the plan that EPA is now imposing in the remaining 11 States bears little resemblance to the one it proposed, took comment on, and finalized.

This Court in *EME Homer* described EPA’s chosen methodology for constructing a federal Good Neighbor plan; EPA started with that same methodology for the Federal Plan at issue here. *See id.* at 36,741, 36,748. Under this methodology, EPA identifies the (upwind) States that its air quality modeling predicted would be contributing more than *de minimis* amounts of ozone to (downwind) States that will have difficulty attaining the NAAQS. *See EME Homer*, 572 U.S. at 500-01. It then determines what emissions controls would be “cost-effective” by calculating which controls would produce the “combined effect ... on air quality in downwind States” necessary to eliminate significant upwind ozone contribution, assuming every upwind State uniformly expended the same amounts to control their emissions. *Id.* at 501. “EPA estimated, for example, the amount each upwind State’s [ozone-causing] emissions would fall if all pollution sources within each State employed every control measure available at a cost of \$500 per ton or less.” *Id.* So if upwind States A and B were both linked to downwind State C, EPA’s methodology requires the reductions necessary to make upwind contributions to State C insignificant, assuming both

Missouri, Texas); Federal “Good Neighbor Plan” for the 2015 Ozone National Ambient Air Quality Standards: Response to Additional Judicial Stays of SIP Disapproval Action for Certain States, 88 Fed. Reg. 67,102 (Sept. 9, 2023) (Alabama, Minnesota, Nevada, Oklahoma, Utah, West Virginia).

States A and B expended the same amount per tons of emissions in control measures. *See id.* at 519-20.

Next, “[f]or each regulated upwind State, EPA created an annual emissions ‘budget,’” which “represented the quantity of pollution an upwind State would produce in a given year if its in-state sources implemented all pollution controls available at the chosen cost thresholds.” *Id.* at 502. Thus, the emissions budget for each State stems from EPA’s “cost-effectiveness” methodology, which assumes the same expenditure on emissions controls “applied uniformly to all regulated upwind States” to achieve EPA’s desired “combined effect” downwind. *Id.* at 501-02. Finally, EPA pairs these budgets with a “cap-and-trade” system allocating each upwind State’s “emission budget among its in-state sources” and allowing sources emitting below their allocation to “sell unused ‘allocations’ to sources” in any other upwind State that is part of the federal plan. *Id.* at 503 & n.10.

EPA thus describes the Federal Plan as a “national-scale, multi-state” federal implementation plan to address “interstate transport of ozone-causing pollutants through a series of integrated multi-state emissions allowance trading programs for power plants [and] uniform requirements for certain, high-emitting non-power plant industrial sources.” EPA Resp. to Pet.’s Mot. To Sever, Doc. No. 2018488, *Utah v. EPA*, No. 23-1157 (D.C. Cir. Sept. 22, 2023). Indeed, this is how EPA designed the Federal Plan to operate. *See* 88 Fed. Reg. at 36,673 (“The approach of this [federal implementation plan] ensures both national consistency across all states and consistency and continuity with our prior interstate transport actions for other NAAQS.”); *id.* at 36,691 (noting “the purpose of this rule is to address the interstate

transport of ozone on a national scale” and that “upwind regions associated with each receptor typically span at least two, and often far more, states”).

The Federal Plan that EPA originally designed no longer exists as a result of the court-ordered stays. Nearly 90% of the power plant emissions that EPA contemplated serving as both the basis for its emissions limitations and for a robust emissions allowance trading market have been removed from the program. Similarly, 60% of the emission reductions from all other sources are now excluded from the Federal Plan. *See* EPA, *Good Neighbor Plan for 2015 Ozone NAAQS Maps*, <https://t.ly/zQK9L> (“Good Neighbor Maps”) (App’x 296-97). Moreover, EPA never analyzed the costs, efficacy, and burdens of the version of the rule it is now implementing. Nor did it ever examine the effect of the removal of 12 states on the trading program for electric generating units.

IV. Differences Between the Federal Plan and Past Federal Implementation Plans

While the Federal Plan is similar to prior federal Good Neighbor plans in some respects, it also creates a host of never-before-seen regulatory programs. As with prior plans, EPA’s trading program starts by using “preset emissions budgets” for each State. 88 Fed. Reg. at 36,662. EPA claims the emissions reductions required by each statewide budget are in the amount necessary to eliminate that State’s alleged significant contribution to any downwind State’s inability to attain or maintain the NAAQS. *Id.* at 36,657, 36,667. But on *top* of those budgets, EPA here decided to impose “enhancements” to require that “pollution controls will be operated” even if

the States would no longer contribute significantly to other States' ozone issues without such operation. *Id.* at 36,662.

For the first time in any interstate transport program, EPA also has subjected non-power generating industries to stringent emission limitations. The Federal Plan covers, among others, cement kilns and boilers in iron mills, steel mills, pulp, paper, and paperboard mills, and pipeline engines. *Id.* at 36,658.

REASONS FOR GRANTING THE APPLICATION

This Court should stay the Federal Plan, which has a legal foundation premised on the disapprovals of State plans that seven Circuits have confirmed are likely unlawful. The 11-State Federal Plan now being implemented was never analyzed by EPA nor made available for notice-and-comment rulemaking.

Under the Administrative Procedure Act, this Court—as a “reviewing court ... to which a case may be taken ... on application for certiorari or other writ”—“may issue all necessary and appropriate process to postpone the effective date of an agency action.” 5 U.S.C. § 705; *see also* 28 U.S.C. §§ 1254, 1651, 2101; *Nken v. Mukasey*, 555 U.S. 1042 (2008). And under “well settled” principles, such “equitable relief” is appropriate here. *Lucas v. Townsend*, 486 U.S. 1301, 1304 (1988) (Kennedy, J., in chambers).

In addition, to the extent required for such relief, there is: “(1) a reasonable probability that four Justices will consider the issue sufficiently meritorious to grant certiorari; (2) a fair prospect that a majority of the Court w[ould] vote to reverse [a] judgment below [upholding the Federal Plan]; and (3) a likelihood that irreparable

harm will result from the denial of a stay.” *Hollingsworth v. Perry*, 558 U.S. 183, 190 (2010); see *Nken v. Holder*, 556 U.S. 418, 427-29 (2009).

This Court should stay the Federal Plan pending further review.

I. Applicants Are Likely to Succeed on the Merits in this Case, which Warrants this Court’s Discretionary Review.

Given the wide-ranging impact of the Federal Plan and the faulty foundation of unlawful state plan disapprovals on which it rests, this Court would likely grant certiorari in this case and reverse any decision by the D.C. Circuit upholding the Federal Plan. The Federal Plan is an enormous federal regulation with national importance, which EPA itself estimates will cost between \$8.2 billion and \$13 billion. This Court has granted certiorari in several similarly important Clean Air Act cases arising over the past decade. See, e.g., *West Virginia v. EPA*, 142 S. Ct. 2587 (2022); *Michigan v. EPA*, 135 S. Ct. 2699 (2015); *EME Homer*, 572 U.S. at 506.

More than just the toll on the economy, the Federal Plan also represents an unprecedented abrogation of the congressionally granted rights of States. In remarkable unanimity, seven courts of appeals have found that EPA’s disapprovals of 12 State plans, which formed a crucial basis for the 23-State Federal Plan, were likely unlawful. Despite its Federal Plan being fundamentally undermined, EPA insists it remains viable. And now, this gigantically expensive rule has gone into effect in 11 States and will cause irreparable harm to States, industry, and consumers.

Accordingly, this case merits this Court’s discretionary review and, for the reasons given below, Applicants are likely to succeed on the merits.

A. The Federal Plan as Promulgated No Longer Exists, and EPA Never Analyzed or Allowed Comment on the Smaller, Transformed Version.

The 23-State Federal Plan is likely to be vacated by the D.C. Circuit or by this Court because it rests on a legally faulty foundation—EPA’s disapproval of State plans. Every circuit that has reviewed those disapprovals has issued stays recognizing that EPA’s action was likely unlawful. *See supra* at pp. 7-8 & nn. 4, 5. While EPA has removed the 12 States that are the subject of the stays from the Federal Plan, the Federal Plan was premised on inclusion of those States. It thus cannot lawfully be implemented anywhere consistent with the Clean Air Act and the Administrative Procedure Act.

EPA never noticed, analyzed, or took comment upon the 11-State Federal Plan it is now implementing—a clear violation of all the procedures required under the Clean Air Act and the Administrative Procedure Act for notice-and-comment rulemaking. 42 U.S.C. § 7607(d)(3); 5 U.S.C. § 553. Moreover, EPA’s insistence on moving forward in the remaining States regardless of this fundamental flaw is almost certain to be held arbitrary and capricious. EPA’s attempt to make workable its collapsing Federal Plan by severing the inseverable—as if it would have imposed the same plan on 11 States that it would have if all 23 States were included—is unlawful and contrary to its own statements and analysis justifying its Federal Plan.

1. EPA Premised the Federal Plan on the Inclusion of all 23 States.

The administrative record clearly demonstrates that in many fundamental respects, EPA premised its Federal Plan on the inclusion of all 23 States. EPA’s Federal Plan started by distributing emissions limitations among all upwind States

in the Plan by assuming sources within all of those States would impose controls at the same costs. *See supra* at pp. 9-10. As this Court explained, EPA’s “cost-effective” methodology assumes the same expenditure on emissions controls “applied *uniformly* to *all* regulated upwind States” at a level sufficient to achieve EPA’s desired “*combined effect*” downwind. *EME Homer*, 572 U.S. at 501-02 (emphasis added); *see also* 88 Fed. Reg. at 36,741. EPA justified “[a]pplying these emissions control strategies on a *uniform* basis across *all* linked upwind states” as “an efficient and equitable solution to the problem of allocating upwind-state responsibility for the elimination of significant contribution.” 88 Fed. Reg. at 36,741 (emphasis added). It then sets its emissions “budgets” for each State based on this analysis that assumed all 23 States would be included in its Federal Plan. *See EME Homer*, 572 U.S. at 501-02.

In addition to its interdependent state budgets (the “cap” in its “cap-and-trade” program), another fundamental feature of EPA’s Federal Plan is its interstate emissions allowance trading program (the “trade”). *See id.*, 572 U.S. at 503 & n.10. Necessarily, EPA’s analysis of the benefits and efficiencies of that trading program presumed inclusion of all 23 States in the program. 88 Fed. Reg. at 36,657. EPA itself explained the emissions trading marketplace depended on breadth because “[b]roader marketplaces generally provide greater market liquidity and therefore make trading programs better at providing ... advantages” such as “cost minimization” and “operational flexibility.” *Id.* at 36,766 n.295; *see also id.* at 36,760 (noting EPA was adopting a trading program “because of the inherently greater flexibility that [it] can provide”); *id.* at 36,771 (responding to commenters concerned with grid reliability by

pointing to the interstate trading program). As with any market, the price of emission allowances depends heavily on the supply of those allowances, and therefore the number of States in the program. *See id.* at 36,775. Indeed, EPA recently stated that “the Plan depends on the continuing operation of ‘interdependent’ interstate mechanisms, like the allowance trading program, that reach beyond state or regional borders.” EPA’s Motion to Dismiss or Transfer Petitions for Improper Venue, *Tulsa Cement et al. v. EPA*, at 16, No. 23-9551 (10th Cir. July 20, 2023) (“EPA Motion to Dismiss or Transfer”).

Moreover, EPA justified the Federal Plan based on its claimed benefits: the purported “meaningful” air quality improvements that would result “collectively” from the inclusion of all 23 States in the Federal Plan. *See* 88 Fed. Reg. at 36,683; *accord id.* at 37,648; *see also EME Homer*, 572 U.S. at 502. EPA claimed: “When the effects of these emissions reductions are assessed *collectively* ..., the *cumulative* improvements in ozone levels at downwind receptors ... are both measurable and meaningful....” 88 Fed. Reg. at 36,741 (emphasis added). Indeed, this cumulative analysis was EPA’s basis for showing it was acting within the bounds of the Good Neighbor provision: EPA’s analysis of “whether the rule achieves a full remedy to eliminate ‘significant contribution’ while avoiding over-control” was based on “the identified reductions” from all 23 States in the Federal Plan as “*combined and collectively analyzed* to assess their effects on downwind air quality.” *Id.* at 36,719 (emphasis added); *see id.* at 36,743, 36,747-48 (listing only the “aggregate” and “collective” air quality improvements); *see also EME Homer*, 572 U.S. at 523.

As EPA describes it, its 23-State Federal Plan is one that is “interstate” and “interdependent.” EPA Motion to Dismiss or Transfer at 16. EPA emphasizes that its Federal Plan is a “coordinated, 23-state program ... in a long line of national-scale, multi-state federal implementation plans that have addressed interstate transport of ozone-causing pollutants through a series of integrated multi-state emissions allowance trading programs.” EPA Resp. to Pet.’s Mot to Sever, Doc. #2018488, *Utah v. EPA*, No. 23-1157 (D.C. Cir. Sept. 22, 2023); *see also* EPA Opp. to Admin. Stay, Doc. #2008854, *Utah v. EPA*, No. 23-1157 at 1 (D.C. Cir. July 20, 2023) (describing the Federal Plan as a “coordinated, interstate emissions control program” covering “23 states”). The premise that the Federal Plan would include all 23 States in an interdependent program undergirded everything from EPA’s cost-effectiveness analysis to its benefits determinations and from the emissions caps to the trading program.

2. The Current 11-State Federal Plan Violates the Basic Principles of the Clean Air Act and the Administrative Procedure Act.

EPA is now implementing its interdependent 23-State Federal Plan in only 11 States. It is required to do so because numerous federal courts of appeals have held that EPA likely violated the most basic requirement of the Clean Air Act by undermining the careful balance between state and federal authority that Congress prescribed. *See supra* at p. 5. Despite commenters and courts informing EPA of the Federal Plan’s unlawful foundations—the disapproval of individual State plans—EPA published and is implementing it anyway in 11 States. Applicants are likely to succeed in demonstrating EPA’s actions are unlawful for at least three reasons.

First, the Federal Plan violates basic requirements of the Clean Air Act and the Administrative Procedure Act by failing to provide notice and comment on an 11-State federal implementation plan rather than the 23-State plan originally contemplated. 42 U.S.C. § 7607(d)(1)(B), (3); 5 U.S.C. § 553(b), (c). The stays of the Federal Plan in 12 States have forced EPA to remove those States from its Plan, but EPA's decision to nonetheless implement an 11-State plan is unlawfully enforcing a rule EPA never proposed, received comments on, analyzed, or lawfully promulgated. As explained above, EPA analyzed only a 23-State plan, justifying many fundamental parts of that Plan on the inclusion of all 23 States. The difference is especially stark because removing 12 States with stays from the Federal Plan means nearly 90% of the power plant emissions reductions and 60% of the non-power plant emission reductions that EPA analyzed as part of its rulemaking are now excluded from the Federal Plan. *See Good Neighbor Maps at App'x 296-97.*

The 11-State plan that is currently being implemented has never been analyzed by EPA. For example, EPA never performed an 11-State analysis of: (i) cost-effective emissions controls (the basis for each State's emissions budget); (ii) the efficacy of the trading program; or (iii) the downwind air quality benefits. *See 88 Fed. Reg. at 36,666, Table 1.C-1; EPA, Regulatory Impact Analysis for the Final Federal Good Neighbor Plan Addressing Regional Ozone Transport for the 2015 Ozone National Ambient Air Quality Standard at 24-25, available at <https://t.ly/x6P5l> (examining various scenarios none of which involved removal of more than half the States or a State-level analysis). No one—not States, nor members of the public, nor*

even EPA itself—has analyzed or commented on this completely altered version of a rule that is now imposing enormous costs.

Second, the Federal Plan is arbitrary and capricious because it “entirely fail[s] to consider an important aspect of the problem....” *Motor Vehicle Mfrs. Ass’n v. State Farm Mut. Auto. Ins. Co.*, 463 U.S. 29, 43 (1983). Namely, EPA failed to appreciate that its state plan disapprovals—the necessary legal predicate for the Federal Plan—are likely unlawful and thus not in effect. The agency never considered the likely scenario that a significant number of its state plan disapprovals would be stayed or vacated, rendering large portions of the Federal Plan inoperable. Commenters alerted EPA to the unlawfulness of the state plan disapprovals, those disapprovals were challenged in a dozen states with litigants moving for stays, and now seven courts of appeals have granted those stays, confirming that those disapprovals were likely unlawful. *See supra* at pp. 7-8 nn. 4, 5. Those court-ordered stays did not make EPA’s state plan disapprovals likely unlawful; they simply declared what the law always was, including when EPA finalized the Federal Plan. *See Nat’l Fuel Gas Supply Corp. v. FERC*, 59 F.3d 1281, 1289 (D.C. Cir. 1995). Indeed, three courts stayed the state plan disapprovals in five States *before* EPA published its Federal Plan in the Federal Register. *Supra* at pp. 7-8 & n.4. Yet, EPA entirely failed to reconsider its analysis based on this reality before consummating its final agency action. Despite all of the warnings and everything EPA knew before it published the Federal Plan, EPA charged forward.

This mess is one of EPA’s own making. It proposed the Federal Plan before its state plan disapprovals were finalized (or, in some cases, before the disapprovals of

some states' plans had even been proposed), *see supra* at p. 7, began to finalize the Federal Plan despite warnings that the state plan disapprovals were likely unlawful and court challenges to them began to mount, and published the Federal Plan in the Federal Register even after three courts of appeals started declaring its state disapprovals were likely unlawful. That is arbitrary and capricious.

Third, EPA's rulemaking makes no sense with 12 States excised and is thus arbitrary and capricious for this reason too. These 12 States are not severable from EPA's analysis and justifications for the Federal Plan; those things "cannot function sensibly without" including all 23 States that were part of EPA's uniform cost-thresholds, trading program, downwind benefits justification, and the like. *Belmont Mun. Light Dep't v. FERC*, 38 F.4th 173, 188 (D.C. Cir. 2022). EPA does not and cannot argue that "the agency would have adopted" the same plan for 11 States by, for example, imposing the exact same emissions controls on those 11 States had it known a bevy of upwind States would not also have been subject to those controls. *Am. Fuel & Petrochemical Manufacturers v. EPA*, 3 F.4th 373, 384 (D.C. Cir. 2021). EPA cannot lawfully salvage a rule in shambles by implementing the bits and pieces still left. The Federal Plan is a shell of its original self, rendering the analysis underpinning the rule incoherent and irrelevant. It will likely be vacated after full merits consideration and therefore must be stayed now.

B. Even if the Federal Plan Still Consisted of All 23 States, It Would Nonetheless Violate the Clean Air Act.

Even assuming that the Federal Plan EPA is now implementing is the one that underwent notice-and-comment rulemaking, Applicants are likely to prevail

because the Plan violates the Clean Air Act and this Court’s precedent. It unlawfully “over-controls” emissions and capriciously includes non-power generating industrial sources, contrary to the statutory requirements and EPA’s own analysis.

1. This Court has explained that EPA cannot “over-control”: it “cannot require a State to reduce its output of pollution by more than is necessary to achieve attainment in every downwind State” or by more than would be necessary for a particular state to eliminate all of its “significant[]” contributions to downwind sites. *EME Homer*, 572 U.S. at 521-22. But that is exactly what the Federal Plan is designed to do.

EPA first determined what emissions budgets are necessary to ensure compliance with the Good Neighbor provision, as it had with prior rulemakings. 88 Fed. Reg. at 36,754 (projecting emissions budgets to be a “full remedy” by the conclusion of the 2026 ozone season). Then, on top of that, EPA imposed “enhancements” for power plants to further ratchet the budgets downward—regardless of whether further ratcheting is needed to eliminate significant contribution. *See id.* at 36,764 (explaining “enhancements” are to “better sustain incentives to control emissions over time”); *id.* at 36,751 (declining to evaluate over-control after EPA’s dynamic budget enhancements take effect in 2030); *see also id.* at 36,685.

For example, EPA set each State’s annual emissions budgets for its cap-and-trade program at the level of emissions sufficient to eliminate significant downwind contributions. But beginning in 2030, an enhancement called “dynamic budgeting” will reduce the State’s budget if a power plant shuts down or limits operation, or if a

State otherwise does not use allowances available to it. *Id.* at 36,663. In each of those scenarios, changes on the ground mean a large amount of the emissions that EPA deemed to be “contributing significantly” to downwind ozone are not occurring, making the State’s contribution to downwind locations less significant or possibly insignificant. Nonetheless, dynamic budgeting would shrink the entire budget for the State, making the budgets more stringent and well-below what EPA already determined was necessary to eliminate significant contribution. That facially and systematically over-controls.

Similarly, EPA’s “enhancements” require certain power plants to relinquish some of their unused allowances when they bank more than enough to comply with the cap-and-trade budgets or emit above certain amounts. *Id.* at 36,664, 36,766. EPA tacitly concedes that this is not to prevent significant contribution, but rather to “continuously incentiviz[e] sources to reduce their emissions even when they already hold sufficient emissions allowances....” *Id.* at 36,766. Because those power plants would have already created or purchased sufficient allowances to eliminate significant contribution, however, the Federal Plan facially requires more than is necessary.

2. EPA also capriciously shoe-horned other sectors of the economy into the Federal Plan in excess of its authority.

EPA completely disregarded whether the substantial costs of including those sources could justify the nearly immeasurable benefit on air quality. EPA proposed a “uniform cost” framework to determine the “amount of emissions that is in excess of the emissions control strategies that EPA has deemed cost-effective” to eliminate

significant contributions. 88 Fed. Reg. at 36,676. In other words, it set a threshold (\$7,500 per ton of reduction) above which control measures are too expensive to justify the purported benefit. As other Applicants explain with respect to pipeline engines, EPA then proceeded to ignore it. *See* Emergency Application for Stay of Final Agency Action During Pendency of Petitions for Review, *Kinder Morgan, Inc., et al. v. EPA* (Oct. 13, 2023).

For example, when EPA looked at cement kilns in its proposal, it wrongly assumed the kilns did not already have emissions controls for the relevant pollutants and determined they could achieve substantial reductions below the cost threshold on an industry-wide basis. *See* Portland Cement Association Comments at 9 (June 21, 2022) (“PCA Comments”) (App’x 306) But three-quarters of the kilns EPA evaluated already had controls in place, so the tons of reduction would be much smaller (and therefore, the cost per ton much higher) than EPA predicted. *Id.* Despite being provided actual data on kiln emissions, *id.* at 9-10, EPA doubled down on its false assumptions in the Federal Plan. 88 Fed. Reg. at 36,826; *see also id.* at 36,739 (showing projections of reductions with what EPA falsely assumed would be “additional” controls). If EPA had simply relied on the actual, verifiable data, rather than assumptions, it would have excluded cement kilns.

EPA’s treatment of the costs for the paper industry is similarly baffling. EPA concluded that it could achieve a grand total of 0.0117 parts billion in ozone reductions (recall that the standard is 70 parts per billion) by requiring boilers at pulp and paper mills to install equipment that has never been used on them in the United States. *See* American Forest & Paper Association Comments at 6 (June 21,

2022), Docket ID No. EPA-HQ-OAR-2021-0668-0516 (“AF&PA Comments”) (App’x 335); EPA’s Non-EGU Screening Assessment Memo at 16, Docket ID No. EPA-HQ-OAR-2021-0668-0150, Table 5, *available at* <https://t.ly/pzIM6>; Noe Decl. ¶12. EPA wrongly estimated that it would cost \$3,800 per ton to do so. Noe Decl. ¶10. That was off by an order of magnitude; the industry calculated the average cost at \$37,900 per ton. *Id.* Rather than exclude these boilers, EPA came up with a new cost estimate of \$14,134 per ton, 88 Fed. Reg. at 36,740, Table V.C.2-3, and provided new excuses for exceeding the original \$7,500 per ton threshold, without providing any fair notice or opportunity to comment on this new threshold. *Id.* at 36,746.

Worse still, some of Federal Plan’s requirements are completely unmoored from the proposal. The Federal Plan requires steel industry reheat furnaces to have in place a plan by August 2024 to install equipment called “Low NOx Burners” and to achieve a 40% reduction in nitrogen oxide emissions from those furnaces by 2026. *Id.* at 36,879. But this requirement was not in the proposal at all. So, the steel industry had no opportunity to comment on it. Accordingly, regulated sources need to make immediate decisions in 2023 on whether to upgrade or retire furnaces and natural gas boilers in advance of judicial review of the Federal Plan. Balsarak Decl. ¶¶6-8.

In short, even EPA’s Federal Plan as originally envisioned was fundamentally flawed. Applicants are therefore likely to succeed on the merits for these reasons, too.

II. Absent a Stay, the Applicants and Their Members Will Suffer Substantial Irreparable Harms.

The Applicants and their members will suffer irreparable harm if the Federal Plan is not stayed. “[C]omplying with a regulation later held invalidated almost *always* produces the irreparable harm of nonrecoverable compliance costs.” *Thunder Basin Coal Co. v. Reich*, 510 U.S. 200, 220-21 (1994) (Scalia, J., concurring) (emphasis in original). In *Philip Morris v. Scott*, 131 S. Ct. 1 (2010) (Scalia, J., in chambers), Justice Scalia recognized that “[i]f expenditures cannot be recouped, the resulting loss may be irreparable.” *Id.* at 4. He accordingly found irreparable harm had adequately been demonstrated where the applicants showed they would irrevocably expend \$270 million before the Court could even consider the claim. *Id.* Economic injuries are also irreparable when unlawful agency action deprives companies of “very significant future revenues” which will be “permanently” lost, even if the action is ultimately overturned. *In re NTE Connecticut, LLC*, 26 F.4th 980, 991 (D.C. Cir. 2022).

Applicants and their members face both kinds of irreparable harm. The Federal Plan requires Applicants and their members to reduce emissions drastically. To reach compliance in time, they will have to immediately begin the process of installing prohibitively expensive emissions controls, incurring “hundreds of millions of dollars in capital compliance and construction costs.” Farah Decl. ¶12; *see also* Brown Decl. ¶36; Balserak Decl. ¶¶9-10; Maule Decl. ¶6; Piotrowski Decl. ¶5; Toso Decl. ¶34-36.

Sources that cannot feasibly install new emissions controls will be forced to buy emissions allowances from other parties, decrease their production, or cease

operations altogether. Marshall Decl. at 2-3 (explaining sources may need to “reduce generating hours to meet emission restrictions” if “sufficient allowances” are not available); Balsarak Decl. ¶8 (explaining sources “will need to immediately make a decision ... on whether to upgrade or retire” units); Alban Decl. ¶27 (Federal Plan will “likely force many baseload generation assets to retire”); Brown Decl. ¶21 (explaining the Federal Plan will require OVEC to either transition a unit to only seasonal production or consider retirement); Toso Decl. ¶37 (PCA member has identified a real possibility it may cease operations). And because there will be both fewer emissions allowances and higher demand as a result of 12 States being removed from EPA’s intended Federal Plan, utility sources will be forced to either purchase allowances at a significantly higher premium or curtail operations. Farah Decl. ¶11 (explaining a spike in demand for allowance prices in 2022 imposed an additional \$50 million in operating costs for a single plant); Brown Decl. ¶20 (“OVEC can no longer rely on a viable allowance trading market ... to meet future compliance obligations.”).

Even setting aside the costs of the emissions controls themselves, electric generating units and industrial facilities will incur significant additional costs related to “the process of initiating engineering, design, and procurement” of controls by 2026 that “would be unnecessary” if the Federal Plan is held invalid. Balsarak Decl. at 3-4; *see also* Brown Decl. ¶32 (OVEC must begin the “process immediately” and will “incur costs within the next six months”); Alban Decl. ¶24 (utilities have “very little time to develop power supply plans and environmental compliance plans”); Purvis Decl. ¶32; Farah Decl. ¶15 (“Mon Power will need to take imminent action in order to comply”); Champion Decl. ¶9 (Georgia Pacific will be required to “start

contracting immediately” to comply “with the tight timeframe”); Maule Decl. ¶7; Kotara Decl. ¶5; Piotrowski Decl. ¶7; Toso Decl. ¶30.

The paper industry, in particular, will incur significant costs to design, install, and operate new controls, some of which have never been applied in that industry. Noe Decl. ¶12. The capital costs of these investments for only three units of one company range from \$45 to \$125 million and will impact the market competitiveness of affected mills. Champion Decl. ¶¶6-8; *see also* Kotara Decl. ¶4. The total capital cost for such units in the paper industry would be \$660 million. AF&PA Comments at 2.

As noted above, some companies may cease operations at specific sources altogether. For those sources that must reduce or cease their use of coal to comply with the Federal Plan, the Plan will also drastically harm the coal mine operators that supply those sources with their fuel. Brock Decl. ¶¶15-17; Adams Decl. ¶¶10-13; Hamilton Decl. ¶¶12-14; Bridgeford Decl. ¶¶11-14.

III. The Balance of Equities and the Public Interest Favor a Stay.

“In close cases the Circuit Justice or the Court will balance the equities and weigh the relative harms to the applicant and to the respondent.” *Hollingsworth*, 558 U.S. at 190. Any such balancing also favors a stay. First, a stay will not harm any other parties. EPA ignored its statutory deadline to disapprove the State plans it now proposes to replace for years. It cannot now argue a brief stay will cause sweeping public harms. *See Texas v. EPA*, No. 23-60069, Stay Order, Slip Op. at 24 (5th Cir. May 1, 2023). Despite the Federal Plan’s immediate harms to Applicants, it would not actually result in any significant emission reductions for years. *See* 88 Fed. Reg.

at 36,785-86, Table VI.B.4.c-1. Nor will a stay interfere with projected future declines in nationwide ozone levels due to existing, robust ozone controls and regulations already in place.

Second, the public interest strongly supports a stay. The significant compliance costs to electricity generators that the Federal Plan will inflict may be passed on to ratepayers, including some ratepayers who will not be able to bear additional energy costs. Brown Decl. ¶45; Alban Decl. ¶24; Purvis Decl. ¶¶24, 33, 58; Farah Decl. ¶14.

In addition, if regulated companies reduce operations or stop operating altogether, communities around the country will lose jobs and tax revenue. *See, e.g.*, Fuentes Decl. ¶¶5-7; Purvis Decl. ¶¶33, 35, 58; Farah Decl. ¶10; Brock Decl. ¶15. Because the Federal Plan will require sources to reduce their reliance on the most reliable power—like coal-fired generation—it will increase grid instability and unreliability. Fuentes Decl. ¶¶5, 8; Alban Decl. ¶¶26, 28; Purvis Decl. ¶¶25, 33, 54; Brown Decl. ¶27.

In addition, electric reliability experts and grid operators have noted reliability troubles that the Federal Plan will exacerbate. *See* PJM, Energy Transition in PJM (Feb. 24, 2023) at 7, *available at* bit.ly/3YirOCr (noting the combined result of the Federal Plan and others has “the potential to result” in “significant generation retirements” in a condensed time); North American Electric Reliability Corporation, 2023 Summer Reliability Assessment Infographic (May 2023) (noting reliability concerns), *available at* bit.ly/3qa6Jh4.

Finally, EPA’s disapproval of State plans is being litigated in multiple circuits, and those courts have issued multiple stays. EPA’s decision to forge ahead anyway

threatens an impossible tangle of regulatory obligations on sources, especially since the Federal Plan was designed to work with 23, not 11 States. A stay by this Court will allow orderly review of EPA's unlawful actions.

CONCLUSION

For the foregoing reasons, Applicants respectfully request an immediate stay of EPA's Federal Plan.

Dated: October 13, 2023

Respectfully submitted,

/s/ Mithun Mansinghani

Michael B. Schon
LEHOTSKY KELLER COHN LLP
200 Massachusetts Ave NW
Washington, DC 20001
(512) 693-8350
mike@lkcfirm.com

Mithun Mansinghani
LEHOTSKY KELLER COHN LLP
629 W. Main St.
Oklahoma City, OK 73102
(512) 693-8350
mithun@lkcfirm.com

*Counsel for National Mining
Association*

/s/ Jonathan Y. Ellis

Jonathan Y. Ellis
Counsel of Record
Allison D. Wood
Makram B. Jaber
Aaron M. Flynn
MCGUIREWOODS LLP
888 16th Street N.W., Suite 500
Black Lives Matter Plaza
Washington, DC 20006
jellis@mcguirewoods.com
awood@mcguirewoods.com
mjaber@mcguirewoods.com
aflynn@mcguirewoods.com

*Counsel for America's Power, Associated
Electric Cooperative, Inc., Deseret Power
Electric Cooperative, the National Rural
Electric Cooperative Association, Ohio
Valley Electric Corporation, the Portland
Cement Association, Wabash Valley Power
Alliance*

/s/ David M. Flannery

David M. Flannery
Kathy G. Beckett
Keeleigh S. Utt
STEPTOE & JOHNSON, PLLC
707 Virginia Street, East
Post Office Box 1588
Charleston, WV 25326
(304) 353-8000
Dave.Flannery@steptoe-johnson.com
Kathy.beckett@steptoe-johnson.com

Edward L. Kropp
STEPTOE & JOHNSON PLLC
PO Box 36425
Indianapolis, Indiana 46236
317-946-9882
Skipp.kropp@steptoe-johnson.com

*Counsel for American Forest & Paper
Association and Midwest Ozone Group*

Comments by

American Forest & Paper Association, Inc., American Iron and Steel Institute, America's Power, Associated Electric Cooperative, Inc., Deseret Electric Power Cooperative, Midwest Ozone Group, National Mining Association, the National Rural Electric Cooperative Association, Ohio Valley Electric Corporation, the Portland Cement Association, and Wabash Valley Power Alliance

on the U.S. Environmental Protection Agency's Proposed Federal "Good Neighbor Plan" for the 2015 Ozone National Ambient Air Quality Standards; Response to Additional Judicial Stays of SIP Disapproval Action for Certain States

**88 Fed. Reg. 67,102 (Sept. 29, 2023)
Docket ID No. EPA-HQ-OAR-2021-0668**

October 30, 2023

Attachment C Part 1

Appendix to Emergency Application for Immediate Stay of Final Agency Action Pending Disposition of Petition for Review

Pages 1 - 444

APPENDIX

Order Denying Stay Pending Review No. 23-1157 (D.C. Cir. Sept. 25, 2023)	App'x 1
Federal "Good Neighbor Plan" for the 2015 Ozone National Ambient Air Quality Standards, Fed. Reg. Vol 88, No. 107, 34454-36918 (June 5, 2023)	App'x 3
The Clean Air Act, 42 U.S.C. § 7407, 6908-6913, (1970).....	App'x 268
The Clean Air Act, 42 U.S.C. § 7408, 6913- 6916, (1970).....	App'x 273
The Clean Air Act, 42 U.S.C. § 7409, 6916-6917, (1970).....	App'x 277
The Clean Air Act, 42 U.S.C. § 7410, 6917-6925, (1970).....	App'x 279
Declaration of J. Michael Brown (July 17, 2023).....	App'x 289
Federal "Good Neighbor Plan" for the 2015 Ozone NAAQS Maps (June 5, 2023).....	App'x 296
Comments from Portland Cement Association (June 21, 2022).....	App'x 298
Comments from American Forest and Paper Association (June 21, 2022).....	App'x 328
Declaration of Paul R. Noe (July 14, 2023).....	App'x 374
Declaration of Paul Balserek (July 19, 2023).....	App'x 383
Declaration of George J. Farah (July 18, 2023).....	App'x 387
Declaration of Jeff Maule (July 19, 2023).....	App'x 394
Declaration of John Piotrowski (July 19, 2023).....	App'x 397

Declaration of Massimo Toso (Aug. 1, 2023).....	App’x 402
Declaration of John Marshall (July 25, 2023).....	App’x 407
Declaration of Thomas M. Alban (July 24, 2023).....	App’x 410
Declaration of Jerry Purvis (May 19, 2023).....	App’x 417
Declaration of Bryant T. Champion (July 20, 2023).....	App’x 425
Declaration of Chris F. Kotara (July 19, 2023).....	App’x 430
Declaration of Jeffery D. Brock (July 28, 2023).....	App’x 434
Declaration of Matthew Adams (July 31, 2023).....	App’x 439
Declaration of Chris R. Hamilton (July 28, 2023).....	App’x 445
Declaration of Tawney Bridgeford (July 28, 2023).....	App’x 453
Declaration of Cristobal Fuentes (July 18, 2023).....	App’x 460
Declaration of Dudley Zahn (March 3, 2023).....	App’x 464
Declaration of Randall J. Talley (March 2, 2023).....	App’x 473
Declaration of Dwayne W. Rickerson (March 2, 2023).....	App’x 500

United States Court of Appeals
FOR THE DISTRICT OF COLUMBIA CIRCUIT

No. 23-1157

September Term, 2023

EPA-88FR36654

Filed On: September 25, 2023

State of Utah, by and through its Governor,
Spencer J. Cox, and its Attorney General,
Sean D. Reyes,

Petitioner

v.

Environmental Protection Agency and
Michael S. Regan, Administrator, U.S. EPA,

Respondents

City of New York, et al.,
Intervenors

Consolidated with 23-1181, 23-1183,
23-1190, 23-1191, 23-1193, 23-1195,
23-1199, 23-1200, 23-1201, 23-1202,
23-1203, 23-1205, 23-1206, 23-1207,
23-1208, 23-1209, 23-1211

BEFORE: Pillard, Walker*, and Childs, Circuit Judges

ORDER

Upon consideration of the motions for stay in Nos. 23-1181, 23-1183, 23-1190, 23-1191, 23-1193, 23-1195, 23-1199, 23-1202, and 23-1205, the oppositions thereto, the replies, and the amicus briefs, it is

ORDERED that the motions for stay be denied. Petitioners have not satisfied the stringent requirements for a stay pending court review. See *Nken v. Holder*, 556

* Judge Walker would stay the federal implementation plan in question.

United States Court of Appeals
FOR THE DISTRICT OF COLUMBIA CIRCUIT

No. 23-1157

September Term, 2023

U.S. 418, 434 (2009); D.C. Circuit Handbook of Practice and Internal Procedures 33 (2021).

Per Curiam

FOR THE COURT:
Mark J. Langer, Clerk

BY: /s/
Tatiana Magruder
Deputy Clerk

ENVIRONMENTAL PROTECTION AGENCY**40 CFR Parts 52, 75, 78, and 97**

[EPA-HQ-OAR-2021-0668; FRL-8670-02-OAR]

RIN 2060-AV51

Federal “Good Neighbor Plan” for the 2015 Ozone National Ambient Air Quality Standards**AGENCY:** Environmental Protection Agency (EPA).**ACTION:** Final rule.

SUMMARY: This action finalizes Federal Implementation Plan (FIP) requirements to address 23 states’ obligations to eliminate significant contribution to nonattainment, or interference with maintenance, of the 2015 ozone National Ambient Air Quality Standards (NAAQS) in other states. The U.S. Environmental Protection Agency (EPA) is taking this action under the “good neighbor” or “interstate transport” provision of the Clean Air Act (CAA or Act). The Agency is defining the amount of ozone-precursor emissions (specifically, nitrogen oxides) that constitute significant contribution to nonattainment and interference with maintenance from these 23 states. With respect to fossil fuel-fired power plants in 22 states, this action will prohibit those emissions by implementing an allowance-based trading program beginning in the 2023 ozone season. With respect to certain other industrial stationary sources in 20 states, this action will prohibit those emissions through emissions limitations and associated requirements beginning in the 2026 ozone season. These industrial source types are: reciprocating internal combustion engines in Pipeline Transportation of Natural Gas; kilns in Cement and Cement Product Manufacturing; reheat furnaces in Iron and Steel Mills and Ferroalloy Manufacturing; furnaces in Glass and Glass Product Manufacturing; boilers in Iron and Steel Mills and Ferroalloy Manufacturing, Metal Ore Mining, Basic Chemical Manufacturing, Petroleum and Coal Products Manufacturing, and Pulp, Paper, and Paperboard Mills; and combustors and incinerators in Solid Waste Combustors and Incinerators.

DATES: This final rule is effective on August 4, 2023.**ADDRESSES:** The EPA has established a docket for this rulemaking under Docket ID No. EPA-HQ-OAR-2021-0668. All documents in the docket are listed in the <https://www.regulations.gov> index. Although listed in the index, some

information is not publicly available, e.g., Confidential Business Information or other information whose disclosure is restricted by statute. Certain other material, such as copyrighted material, will be publicly available only in hard copy. Publicly available docket materials are available either electronically at <https://www.regulations.gov> or in hard copy at the U.S. Environmental Protection Agency, EPA Docket Center, William Jefferson Clinton West Building, Room 3334, 1301 Constitution Ave. NW, Washington, DC. The Public Reading Room is open from 8:30 a.m. to 4:30 p.m., Monday through Friday, excluding legal holidays. The telephone number for the Public Reading Room is (202) 566-1744, and the telephone number for the Office of Air and Radiation Docket is (202) 566-1742.

FOR FURTHER INFORMATION CONTACT: Ms. Elizabeth Selbst, Air Quality Policy Division, Office of Air Quality Planning and Standards (C539-01), Environmental Protection Agency, 109 TW Alexander Drive, Research Triangle Park, NC 27711; telephone number: (312) 886-4746; email address: selbst.elizabeth@epa.gov.

SUPPLEMENTARY INFORMATION:**Preamble Glossary of Terms and Abbreviations**

The following are abbreviations of terms used in the preamble.

2016v1 2016 Version 1 Emissions Modeling Platform
 2016v2 2016 Version 2 Emissions Modeling Platform
 4-Step Framework 4-Step Interstate Transport Framework
 ABC Associated Builders and Contractors
 ACS American Community Survey
 ACT Alternative Control Techniques
 AEO Annual Energy Outlook
 AQAT Air Quality Assessment Tool
 AQS Air Quality System
 BACT Best Available Control Technology
 BART Best Available Retrofit Technology
 BOF Basic Oxygen Furnace
 BPT Benefit Per Ton
 C1C2 Category 1 and Category 2
 C3 Category 3
 CAA or Act Clean Air Act
 CAIR Clean Air Interstate Rule
 CBI Confidential Business Information
 CCR Coal Combustion Residual
 CDC Centers for Disease Control and Prevention
 CDX Central Data Exchange
 CEDRI Compliance and Emissions Data Reporting Interface
 CEMS Continuous Emissions Monitoring Systems
 CES Clean Energy Standards
 CFB Circulating Fluidized Bed Units
 CHP Combined Heat and Power
 CMDB Control Measures Database
 CMV Commercial Marine Vehicle

CoST Control Strategy Tool
 CPT Cost Per Ton
 CRA Congressional Review Act
 CSAPR Cross-State Air Pollution Rule
 DAHS Data Acquisition and Handling System
 DOE Department of Energy
 EAF Electric Arc Furnace
 EGU Electric Generating Unit
 EIA U.S. Energy Information Agency
 EIS Emissions Inventory System
 EISA Energy Independence and Security Act
 ELG Effluent Limitation Guidelines
 E.O. Executive Order
 EPA or the Agency United States Environmental Protection Agency
 ERT Electronic Reporting Tool
 FERC Federal Energy Regulatory Commission
 FFS Findings of Failure to Submit
 FIP Federal Implementation Plan
 GIS Geographic Information System
 g/hp-hr grams per horsepower per hour
 HDGHG Greenhouse Gas Emissions and Fuel Efficiency Standards for Medium- and Heavy-Duty Engines and Vehicles
 HEDD High Electricity Demand Days
 ICI Industrial, Commercial, and Institutional
 I/M Inspection and Maintenance
 IPM Integrated Planning Model
 IRA Inflation Reduction Act
 LAER Lowest Achievable Emission Rate
 LDC Local Distribution Company
 LME Low Mass Emissions
 LNB Low-NO_x Burners
 MATS Mercury and Air Toxics Standards
 MCM Menu of Control Measures
 MDA8 Maximum Daily Average 8-Hour
 MJO Multi-Jurisdictional Organization
 MOU Memorandum of Understanding
 MOVES Motor Vehicle Emissions Simulator
 MSAT2 Mobile Source Air Toxics Rule
 MWC Municipal Waste Combustor
 NAAQS National Ambient Air Quality Standards
 NACAA National Association of Clean Air Agencies
 NAICS North American Industry Classification System
 NEEDS National Electric Energy Data System
 NEI National Emissions Inventory
 NERC North American Electric Reliability Corporation
 NESHAP National Emissions Standards for Hazardous Air Pollutants
 NMB Normalized Mean Bias
 NME Normalized Mean Error
 No SISNOSE No Significant Economic Impact on a Substantial Number of Small Entities
 Non-EGU Non-Electric Generating Unit
 NODA Notice of Data Availability
 NO_x Nitrogen Oxides
 NREL National Renewable Energy Lab
 NSCR Non-Selective Catalytic Reduction
 NSPS New Source Performance Standard
 NSR New Source Review
 NTTAA National Technology Transfer and Advancement Act
 OFA Over-Fire Air
 OMB United States Office of Management and Budget

OSAT/APCA Ozone Source Apportionment Technology/Anthropogenic Precursor Culpability Analysis

OTC Ozone Transport Commission

OTR Ozone Transport Region

OTSA Oklahoma Tribal Statistical Area

PDF Portable Document Format

PEMS Predictive Emissions Monitoring Systems

PM_{2.5} Fine Particulate Matter

ppb parts per billion

ppm parts per million

ppmv parts per million by volume

ppmvd parts per million by volume, dry

PRA Paperwork Reduction Act

PSD Prevention of Significant Deterioration

PTE Potential to Emit

RACT Reasonably Available Control Technology

RATA Relative Accuracy Test Audit

RCF Relative Contribution Factor

RFA Regulatory Flexibility Act

RICE Reciprocating Internal Combustion Engines

ROP Rate of Progress

RPS Renewable Portfolio Standards

RRF Relative Response Factor

RTC Response to Comments

RTO Regional Transmission Organization

SAFETEA Safe, Accountable, Flexible, Efficient, Transportation Equity Act

SCC Source Classification Code

SCR Selective Catalytic Reduction

SIL Significant Impact Level

SIP State Implementation Plan

SMOKE Sparse Matrix Operator Kernel Emissions

SNCR Selective Non-Catalytic Reduction

SO₂ Sulfur Dioxide

tpd ton per day

TAS Treatment as State

TSD Technical Support Document

UMRA Unfunded Mandates Reform Act

VMT Vehicle Miles Traveled

VOCs Volatile Organic Compounds

WRAP Western Regional Air Partnership

WRF Weather Research and Forecasting

Table of Contents

I. Executive Summary

- A. Purpose of the Regulatory Action
 1. Emissions Limitations for EGUs Established by the Final Rule
 2. Emissions Limitations for Industrial Stationary Point Sources Established by the Final Rule
- B. Summary of the Regulatory Framework of the Rule
- C. Costs and Benefits

II. General Information

- A. Does this action apply to me?
- B. What action is the Agency taking?
- C. What is the Agency's legal authority for taking this action?
- D. What actions has the EPA previously issued to address regional ozone transport?

III. Air Quality Issues Addressed and Overall Rule Approach

- A. The Interstate Ozone Transport Air Quality Challenge
 1. Nature of Ozone and the Ozone NAAQS
 2. Ozone Transport
 3. Health and Environmental Effects
- B. Final Rule Approach
 1. The 4-Step Interstate Transport Framework

- a. Step 1 Approach
 - b. Step 2 Approach
 - c. Step 3 Approach
 - d. Step 4 Approach
2. FIP Authority for Each State Covered by the Rule
- C. Other CAA Authorities for This Action
 1. Withdrawal of Proposed Error Correction for Delaware
 2. Application of Rule in Indian Country and Necessary or Appropriate Finding
 - a. Indian Country Subject to Tribal Jurisdiction
 - b. Indian Country Subject to State Implementation Planning Authority
 - D. Severability
- #### IV. Analyzing Downwind Air Quality Problems and Contributions From Upwind States
- A. Selection of Analytic Years for Evaluating Ozone Transport Contributions to Downwind Air Quality Problems
 - B. Overview of Air Quality Modeling Platform
 - C. Emissions Inventories
 1. Foundation Emissions Inventory Data Sets
 2. Development of Emissions Inventories for EGUs
 - a. EGU Emissions Inventories Supporting This Rule
 - b. Impact of the Inflation Reduction Act on EGU Emissions
 3. Development of Emissions Inventories for Stationary Industrial Point Sources
 4. Development of Emissions Inventories for Onroad Mobile Sources
 5. Development of Emissions Inventories for Commercial Marine Vessels
 6. Development of Emissions Inventories for Other Nonroad Mobile Sources
 7. Development of Emissions Inventories for Nonpoint Sources
 - D. Air Quality Modeling To Identify Nonattainment and Maintenance Receptors
 - E. Methodology for Projecting Future Year Ozone Design Values
 - F. Pollutant Transport From Upwind States
 1. Air Quality Modeling To Quantify Upwind State Ozone Contributions
 2. Application of Ozone Contribution Screening Threshold
 - a. States That Contribute Below the Screening Threshold
 - b. States That Contribute Above the Screening Threshold
 - G. Treatment of Certain Monitoring Sites in California and Implications for Oregon's Good Neighbor Obligations for the 2015 Ozone NAAQS

V. Quantifying Upwind-State NO_x Emissions Reduction Potential To Reduce Interstate Ozone Transport for the 2015 Ozone NAAQS

- A. The Multi-Factor Test for Determining Significant Contribution
- B. Identifying Control Stringency Levels
 1. EGU NO_x Mitigation Strategies
 - a. Optimizing Existing SCRs
 - b. Installing State-of-the-Art NO_x Combustion Controls
 - c. Optimizing Already Operating SNCRs or Turning on Idled Existing SNCRs
 - d. Installing New SNCRs

- e. Installing New SCRs
 - f. Generation Shifting
 - g. Other EGU Mitigation Measures
2. Non-EGU or Stationary Industrial Source NO_x Mitigation Strategies
 3. Other Stationary Sources NO_x Mitigation Strategies
 - a. Municipal Solid Waste Units
 - b. Electric Generating Units Less Than or Equal to 25 MW
 - c. Cogeneration Units
 4. Mobile Source NO_x Mitigation Strategies
 - C. Control Stringencies Represented by Cost Threshold (\$ per ton) and Corresponding Emissions Reductions
 1. EGU Emissions Reduction Potential by Cost Threshold
 2. Non-EGU or Industrial Source Emissions Reduction Potential
 - D. Assessing Cost, EGU and Industrial Source NO_x Reductions, and Air Quality
 1. EGU Assessment
 2. Stationary Industrial Sources Assessment
 3. Combined EGU and Non-EGU Assessment
 4. Over-Control Analysis
- #### VI. Implementation of Emissions Reductions
- A. NO_x Reduction Implementation Schedule
 1. 2023–2025: EGU NO_x Reductions Beginning in 2023
 2. 2026 and Later Years: EGU and Stationary Industrial Source NO_x Reductions Beginning in 2026
 - a. EGU Schedule for 2026 and Later Years
 - b. Non-EGU or Industrial Source Schedule for 2026 and Later Years
 - B. Regulatory Requirements for EGUs
 1. Trading Program Background and Overview of Revisions
 - a. Current CSAPR Trading Program Design Elements and Identified Concerns
 - b. Enhancements To Maintain Selected Control Stringency Over Time
 - i. Revised Emissions Budget-Setting Process
 - ii. Allowance Bank Recalibration
 - c. Enhancements To Improve Emissions Performance at Individual Units
 - i. Unit-Specific Backstop Daily Emissions Rates
 - ii. Unit-Specific Emissions Limitations Contingent on Assurance Level Exceedances
 - d. Responses to General Comments on the Revisions to the Group 3 Trading Program
 2. Expansion of Geographic Scope
 3. Applicability and Tentative Identification of Newly Affected Units
 4. State Emissions Budgets
 - a. Methodology for Determining Preset State Emissions Budgets for the 2023 through 2029 Control Periods
 - b. Methodology for Determining Dynamic State Emissions Budgets for Control Periods in 2026 Onwards
 - c. Final Preset State Emissions Budgets
 5. Variability Limits and Assurance Levels
 6. Annual Recalibration of Allowance Bank
 7. Unit-Specific Backstop Daily Emissions Rates
 8. Unit-Specific Emissions Limitations Contingent on Assurance Level Exceedances

- 9. Unit-Level Allowance Allocation and Recordation Procedures
 - a. Set-Asides of Portions of State Emissions Budgets
 - b. Allocations to Existing Units, Including Units That Cease Operation
 - c. Allocations From Portions of State Emissions Budgets Set Aside for New Units
 - d. Incorrectly Allocated Allowances
- 10. Monitoring and Reporting Requirements
 - a. Monitor Certification Deadlines
 - b. Additional Recordkeeping and Reporting Requirements
- 11. Designated Representative Requirements
- 12. Transitional Provisions
 - a. Prorating Emissions Budgets, Assurance Levels, and Unit-Level Allowance Allocations in the Event of an Effective Date After May 1, 2023
 - b. Creation of Additional Group 3 Allowance Bank for 2023 Control Period
 - c. Recall of Group 2 Allowances for Control Periods After 2022
- 13. Conforming Revisions to Regulations for Other CSAPR Trading Programs
- C. Regulatory Requirements for Stationary Industrial Sources
 - 1. Pipeline Transportation of Natural Gas
 - 2. Cement and Concrete Product Manufacturing
 - 3. Iron and Steel Mills and Ferroalloy Manufacturing
 - 4. Glass and Glass Product Manufacturing
 - 5. Boilers at Basic Chemical Manufacturing, Petroleum and Coal Products Manufacturing, Pulp, Paper, and Paperboard Mills, Iron and Steel and Ferroalloys Manufacturing, and Metal Ore Mining Facilities
 - a. Coal-fired Industrial Boilers
 - b. Oil-fired Industrial Boilers
 - c. Natural gas-fired Industrial Boilers
 - 6. Municipal Waste Combustors
- D. Submitting a SIP
 - 1. SIP Option To Modify Allocations for 2024 under EGU Trading Program
 - 2. SIP Option To Modify Allocations for 2025 and Beyond Under EGU Trading Program
 - 3. SIP Option To Replace the Federal EGU Trading Program With an Integrated State EGU Trading Program
 - 4. SIP Revisions That Do Not Use the New Trading Program
 - 5. SIP Revision Requirements for Non-EGU or Industrial Source Control Requirements
- E. Title V Permitting
 - 1. Title V Permitting Considerations for EGUs
 - 2. Title V Permitting Considerations for Industrial Stationary Sources
- F. Relationship to Other Emissions Trading and Ozone Transport Programs
 - 1. NO_x SIP Call
 - 2. Acid Rain Program
 - 3. Other CSAPR Trading Programs

- VIII. Costs, Benefits, and Other Impacts of the Final Rule
- IX. Summary of Changes to the Regulatory Text for the Federal Implementation Plans and Trading Programs for EGUs
 - A. Amendments to FIP Provisions in 40 CFR Part 52
 - B. Amendments to Group 3 Trading Program and Related Regulations
 - C. Transitional Provisions
 - D. Clarifications and Conforming Revisions
- X. Statutory and Executive Order Reviews
 - A. Executive Order 12866: Regulatory Planning and Review and Executive Order 13563: Improving Regulation and Regulatory Review
 - B. Paperwork Reduction Act (PRA)
 - 1. Information Collection Request for EGUs
 - 2. Information Collection Request for Non-EGUs
 - C. Regulatory Flexibility Act (RFA)
 - D. Unfunded Mandates Reform Act (UMRA)
 - E. Executive Order 13132: Federalism
 - F. Executive Order 13175: Consultation and Coordination With Indian Tribal Governments
 - G. Executive Order 13045: Protection of Children From Environmental Health Risks and Safety Risks
 - H. Executive Order 13211: Actions Concerning Regulations That Significantly Affect Energy Supply, Distribution or Use
 - I. National Technology Transfer and Advancement Act (NTTAA)
 - J. Executive Order 12898: Federal Actions To Address Environmental Justice in Minority Populations and Low-Income Populations
 - K. Congressional Review Act
 - L. Determinations Under CAA Section 307(b)(1) and (d)

I. Executive Summary

This final rule resolves the interstate transport obligations of 23 states under CAA section 110(a)(2)(D)(i)(I), referred to as the “good neighbor provision” or the “interstate transport provision” of the Act, for the 2015 ozone NAAQS. On October 1, 2015, the EPA revised the primary and secondary 8-hour standards for ozone to 70 parts per billion (ppb).¹ States were required to submit to EPA ozone infrastructure State Implementation Plan (SIP) revisions to fulfill interstate transport obligations for the 2015 ozone NAAQS by October 1, 2018. The EPA proposed the subject rule to address outstanding interstate ozone transport obligations for the 2015 ozone NAAQS in the **Federal Register** on April 6, 2022 (87 FR 20036).

The EPA is making a finding that interstate transport of ozone precursor emissions from 23 upwind states (Alabama, Arkansas, California, Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, Minnesota, Mississippi, Missouri, Nevada, New

Jersey, New York, Ohio, Oklahoma, Pennsylvania, Texas, Utah, Virginia, West Virginia, and Wisconsin) is significantly contributing to nonattainment or interfering with maintenance of the 2015 ozone NAAQS in downwind states, based on projected ozone precursor emissions in the 2023 ozone season. The EPA is issuing FIP requirements to eliminate interstate transport of ozone precursor emissions from these 23 states that significantly contributes to nonattainment or interferes with maintenance of the NAAQS in downwind states. The EPA is not finalizing its proposed error correction for Delaware’s ozone transport SIP, and we are deferring final action at this time on the proposed FIPs for Tennessee and Wyoming pending further review of the updated air quality and contribution modeling and analysis developed for this final action. As discussed in section III of this document, the EPA’s updated analysis of 2023 suggests that the states of Arizona, Iowa, Kansas, and New Mexico may be significantly contributing to one or more nonattainment or maintenance receptors. The EPA is not making any final determinations with respect to these states in this action but intends to address these states, along with Tennessee and Wyoming, in a subsequent action or actions.

The EPA is finalizing FIP requirements for 21 states for which the Agency has, in a separate action, disapproved (or partially disapproved) ozone transport SIP revisions that were submitted for the 2015 ozone NAAQS: Alabama, Arkansas, California, Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, Minnesota, Mississippi, Missouri, Nevada, New Jersey, New York, Ohio, Oklahoma, Texas, Utah, West Virginia, and Wisconsin. *See* 88 FR 9336. In this final rule, the EPA is issuing FIPs for two states—Pennsylvania and Virginia—for which the EPA issued Findings of Failure to Submit for 2015 ozone NAAQS transport SIPs. *See* 84 FR 66612 (December 5, 2019). Under CAA section 301(d)(4), the EPA is extending FIP requirements to apply in Indian country located within the upwind geography of the final rule, including Indian reservation lands and other areas of Indian country over which the EPA or a tribe has demonstrated that a tribe has jurisdiction.²

This final rule defines ozone season nitrogen oxides (NO_x) emissions

² In general, specific tribal names or reservations are not identified separately in this final rule except as needed. *See* section III.C.2 of this document for further discussion about the application of this rule in Indian Country.

¹ *See* 80 FR 65291 (October 26, 2015).

performance obligations for Electric Generating Unit (EGU) sources and fulfills those obligations by implementing an allowance-based ozone season trading program beginning in 2023. This rule also establishes emissions limitations beginning in 2026 for certain other industrial stationary sources (referred to generally as “non-Electric Generating Units” (non-EGUs)). Taken together, these regulatory requirements will fully eliminate the amount of emissions that constitute the covered states’ significant contribution to nonattainment and interference with maintenance in downwind states for purposes of the 2015 ozone NAAQS.

This final rule implements the necessary emissions reductions as follows. Under the FIP requirements, EGUs in 22 states (Alabama, Arkansas, Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, Minnesota, Mississippi, Missouri, Nevada, New Jersey, New York, Ohio, Oklahoma, Pennsylvania, Texas, Utah, Virginia, West Virginia, and Wisconsin) are required to participate in a revised version of the Cross-State Air Pollution Rule (CSAPR) NO_x Ozone Season Group 3 Trading Program that was previously established in the Revised CSAPR Update.³ In addition to reflecting emissions reductions based on the Agency’s determination of the necessary control stringency in this rule, the revised trading program includes several enhancements to the program’s design to better ensure achievement of the selected control stringency on all days of the ozone season and over time. For 12 states already required to participate in the CSAPR NO_x Ozone Season Group 3 Trading Program (Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, New Jersey, New York, Ohio, Pennsylvania, Virginia, and West Virginia) under the Revised CSAPR Update (with respect to the 2008 ozone NAAQS), the FIPs are amended by the revisions to the Group 3 trading program regulations. For seven states currently covered by the CSAPR NO_x Ozone Season Group 2 Trading Program under SIPs or FIPs, the EPA is issuing new FIPs for two states (Alabama and Missouri) and amending existing FIPs for five states (Arkansas, Mississippi, Oklahoma, Texas, and Wisconsin) to transition EGU sources in these states from the Group 2 program to the revised Group 3 trading program, beginning with the 2023 ozone season. The EPA is

issuing new FIPs for three states not currently covered by any CSAPR NO_x ozone season trading program: Minnesota, Nevada, and Utah.

This rulemaking requires emissions reductions in the selected control stringency to be achieved as expeditiously as practicable and, to the extent possible, by the next applicable nonattainment dates for downwind areas for the 2015 ozone NAAQS. Thus, initial emissions reductions from EGUs will be required beginning in the 2023 ozone season and prior to the August 3, 2024, attainment date for areas classified as Moderate nonattainment for the 2015 ozone NAAQS.

The remaining emissions reduction obligations will be phased in as soon as possible thereafter. Substantial additional reductions from potential new post-combustion control installations at EGUs as well as from installation of new pollution controls at non-EGUs, also referred to in this action as industrial sources, will phase in beginning in the 2026 ozone season, associated with the August 3, 2027, attainment date for areas classified as Serious nonattainment for the 2015 ozone NAAQS. The EPA had proposed to require all emissions reductions to eliminate significant contribution to be in place by the 2026 ozone season. While we continue to view 2026 as the appropriate analytic year for purposes of applying the 4-step interstate transport framework, as discussed in section V.D.4 and VI.A.2 of this document, the final rule will allow individual facilities limited additional time to fully implement the required emissions reductions where the owner or operator demonstrates to the EPA’s satisfaction that more rapid compliance is not possible. For EGUs, the emissions trading program budget stringency associated with retrofit of post-combustion controls will be phased in over two ozone seasons (2026–2027). For industrial sources, this final rule provides a process for individual facilities to seek a one year extension, with the possibility of up to two additional years, based on a specific showing of necessity.

The EGU emissions reductions are based on the feasibility of control installation for EGUs in 19 states that remain linked to downwind nonattainment and maintenance receptors in 2026. These 19 states are: Arkansas, Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, Mississippi, Missouri, Nevada, New Jersey, New York, Ohio, Oklahoma, Pennsylvania, Texas, Utah, Virginia, and West Virginia. The emissions reductions required for EGUs in these

states are based primarily on the potential retrofit of additional post-combustion controls for NO_x on most coal-fired EGUs and a portion of oil/gas-fired EGUs that are currently lacking such controls.

The EPA is finalizing, with some modifications from proposal in response to comments, certain additional features in the allowance-based trading program approach for EGUs, including dynamic adjustments of the emissions budgets and recalibration of the allowance bank over time as well as backstop daily emissions rate limits for large coal-fired units. The purpose of these enhancements is to better ensure that the emissions control stringency the EPA found necessary to eliminate significant contribution at Step 3 of the 4-step interstate transport framework is maintained over time in Step 4 implementation and is durable to changes in the power sector. These enhancements ensure the elimination of significant contribution is maintained both in terms of geographical distribution (by limiting the degree to which individual sources can avoid making emissions reductions) and in terms of temporal distribution (by better ensuring emissions reductions are maintained throughout each ozone season, year over year). As we further discuss in section V.D of this document, these changes do not alter the stringency of the emissions trading program over time. Rather, they ensure that the trading program (as the method of implementation at Step 4) remains aligned with the determinations made at Step 3. These enhancements are further discussed in section VI.B of this document.

The EPA is making a finding that NO_x emissions from certain non-EGU sources are significantly contributing to nonattainment or interfering with maintenance of the 2015 ozone NAAQS and that cost-effective controls for NO_x emissions reductions are available in certain industrial source categories that would result in meaningful air quality improvements in downwind receptors. The EPA is establishing emissions limitations beginning in 2026 for non-EGU sources located within 20 states: Arkansas, California, Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, Mississippi, Missouri, Nevada, New Jersey, New York, Ohio, Oklahoma, Pennsylvania, Texas, Utah, Virginia, and West Virginia. The final rule establishes NO_x emissions limitations during the ozone season for the following unit types for sources in

³ As explained in section V.C.1 of this document, the EPA is making a finding that EGU sources within the State of California are sufficiently controlled such that no further emissions reductions are needed from them to eliminate significant contribution to downwind states.

non-EGU industries:⁴ reciprocating internal combustion engines in Pipeline Transportation of Natural Gas; kilns in Cement and Cement Product Manufacturing; reheat furnaces in Iron and Steel Mills and Ferroalloy Manufacturing; furnaces in Glass and Glass Product Manufacturing; boilers in Iron and Steel Mills and Ferroalloy Manufacturing, Metal Ore Mining, Basic Chemical Manufacturing, Petroleum and Coal Products Manufacturing, and Pulp, Paper, and Paperboard Mills; and combustors and incinerators in Solid Waste Combustors and Incinerators.

A. Purpose of the Regulatory Action

The purpose of this rulemaking is to protect public health and the environment by reducing interstate transport of certain air pollutants that significantly contribute to nonattainment, or interfere with maintenance, of the 2015 ozone NAAQS in downwind states. Ground-level ozone has detrimental effects on human health as well as vegetation and ecosystems. Acute and chronic exposure to ozone in humans is associated with premature mortality and certain morbidity effects, such as asthma exacerbation. Ozone exposure can also negatively impact ecosystems by limiting tree growth, causing foliar injury, and changing ecosystem community composition. Section III of this document provides additional evidence of the harmful effects of ozone exposure on human health and the environment. Studies have established that ozone air pollution can be transported over hundreds of miles, with elevated ground-level ozone concentrations occurring in rural and metropolitan areas.^{5 6} Assessments of ozone control approaches have concluded that control strategies targeting reduction of NO_x emissions are an effective method to reduce regional-scale ozone transport.⁷

CAA section 110(a)(2)(D)(i)(I) requires states to prohibit emissions that will contribute significantly to nonattainment or interfere with maintenance in any other state with

⁴ We use the terms “emissions limitation” and “emissions limit” to refer to both numeric emissions limitations and control technology requirements that specify levels of emissions reductions to be achieved.

⁵ Bergin, M.S. et al. (2007) Regional air quality: local and interstate impacts of NO_x and SO₂ emissions on ozone and fine particulate matter in the eastern United States. *Environmental Sci & Tech.* 41: 4677–4689.

⁶ Liao, K. et al. (2013) Impacts of interstate transport of pollutants on high ozone events over the Mid-Atlantic United States. *Atmospheric Environment* 84, 100–112.

⁷ See 82 FR 51238, 51248 (November 3, 2017) [citing 76 FR 48208, 48222 (August 8, 2011)] and 63 FR 57381 (October 27, 1998).

respect to any primary or secondary NAAQS.⁸ Within 3 years of the EPA promulgating a new or revised NAAQS, all states are required to provide SIP submittals, often referred to as “infrastructure SIPs,” addressing certain requirements, including the good neighbor provision. See CAA section 110(a)(1) and (2). The EPA must either approve or disapprove such submittals or make a finding that a state has failed to submit a complete SIP revision. As with any other type of SIP under the Act, when the EPA disapproves an interstate transport SIP or finds that a state failed to submit an interstate transport SIP, the CAA requires the EPA to issue a FIP to directly implement the measures necessary to eliminate significant contribution under the good neighbor provision. See generally CAA section 110(k) and 110(c). As such, in this rule, the EPA is finalizing requirements to fully address good neighbor obligations for the covered states for the 2015 ozone NAAQS under its authority to promulgate FIPs under CAA section 110(c). By eliminating significant contribution from these upwind states, this rule will make substantial and meaningful improvements in air quality by reducing ozone levels at the identified downwind receptors as well as many other areas of the country. At any time after the effective date of this rule, states may submit a Good Neighbor SIP to replace the FIP requirements contained in this rule, subject to EPA approval under CAA section 110(a).

The EPA conducted air quality modeling for the 2023 and 2026 analytic years to identify (1) the downwind areas identified as “receptors” (which are associated with monitoring sites) that are expected to have trouble attaining or maintaining the 2015 ozone NAAQS in the future and (2) the contribution of ozone transport from upwind states to the downwind air quality problems. We use the term “downwind” to describe those states or areas where a receptor is located, and we use the term “upwind” to describe states whose emissions are linked to one or more receptors. States may be both downwind and upwind depending on the receptor or linkage in question. Section IV of this document provides a full description of the results of the EPA’s updated air quality modeling and relevant analyses for the rulemaking, including a discussion of how updates to the modeling and air quality analysis following the proposed rule have resulted in some modest changes in the overall geography of the final rule. Based on the EPA’s air quality

⁸ 42 U.S.C. 7410(a)(2)(D)(i)(I).

analysis, the 23 upwind states covered in this action are linked above the 1 percent of the NAAQS threshold to downwind air quality problems in downwind states. The EPA intends to expeditiously review the updated air quality modeling and related analyses to address potential good neighbor requirements of six additional states—Arizona, Iowa, Kansas, New Mexico, Tennessee, and Wyoming—in a subsequent action. The EPA had previously approved 2015 ozone transport SIPs submitted by Oregon and Delaware, but in the proposed FIP action the EPA found these states potentially to be linked in the modeling supporting our proposal. We proposed to issue an error correction for our prior approval of Delaware’s 2015 ozone transport SIP; however, in this final rule, the EPA is withdrawing the proposed error correction and the proposed FIP for Delaware, because our updated modeling for this final rule confirms that Delaware is not linked above the 1 percent of NAAQS threshold (see section III.C.1 of this document for additional information). The EPA is deferring finalizing a finding at this time for Oregon (see section IV.G of this document for additional information).

1. Emissions Limitations for EGUs Established by the Final Rule

In this rule, the EPA is issuing FIP requirements that apply the provisions of the CSAPR NO_x Ozone Season Group 3 Trading Program as revised in the rule to EGU sources within the borders of the following 22 states: Alabama, Arkansas, Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, Minnesota, Mississippi, Missouri, Nevada, New Jersey, New York, Ohio, Oklahoma, Pennsylvania, Texas, Utah, Virginia, West Virginia, and Wisconsin. Implementation of the revised trading program provisions begins in the 2023 ozone season.

The EPA is expanding the CSAPR NO_x Ozone Season Group 3 Trading Program beginning in the 2023 ozone season. Specifically, the FIPs require power plants within the borders of the 22 states listed in the previous paragraph to participate in an expanded and revised version of the CSAPR NO_x Ozone Season Group 3 Trading Program created by the Revised CSAPR Update. Affected EGUs within the borders of the following 12 states currently participating in the Group 3 Trading Program under existing FIPs remain in the program, with revised provisions beginning in the 2023 ozone season, under this rule: Illinois, Indiana, Kentucky, Louisiana, Maryland,

Michigan, New Jersey, New York, Ohio, Pennsylvania, Virginia, and West Virginia. The FIPs also require affected EGUs within the borders of the following seven states currently covered by the CSAPR NO_x Ozone Season Group 2 Trading Program (the “Group 2 trading program”) under existing FIPs or existing SIPs to transition from the Group 2 program to the revised Group 3 trading program beginning with the 2023 control period: Alabama, Arkansas, Mississippi, Missouri, Oklahoma, Texas, and Wisconsin.⁹ Finally, the EPA is issuing new FIPs for EGUs within the borders of three states not currently covered by any existing CSAPR trading program for seasonal NO_x emissions: Minnesota, Nevada, and Utah. Sources in these states will enter the Group 3 trading program in the 2023 control period following the effective date of the final rule.¹⁰ Refer to section VI.B of this document for details on EGU regulatory requirements.

2. Emissions Limitations for Industrial Stationary Point Sources Established by the Final Rule

The EPA is issuing FIP requirements that include new NO_x emissions limitations for industrial or non-EGU sources in 20 states, with sources expected to demonstrate compliance no later than 2026. The EPA is requiring emissions reductions from non-EGU sources to address interstate transport obligations for the 2015 ozone NAAQS for the following 20 states: Arkansas, California, Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, Mississippi, Missouri, Nevada, New Jersey, New York, Ohio, Oklahoma, Pennsylvania, Texas, Utah, Virginia and West Virginia.

The EPA is establishing emissions limitations for the following unit types in non-EGU industries: reciprocating internal combustion engines in Pipeline Transportation of Natural Gas; kilns in Cement and Cement Product Manufacturing; reheat furnaces in Iron and Steel Mills and Ferroalloy

⁹ Five of these seven states (Arkansas, Mississippi, Oklahoma, Texas, and Wisconsin) currently participate in the Federal Group 2 trading program pursuant to the FIPs finalized in the CSAPR Update. The FIPs required under this rule amend the existing FIPs for these states. The other two states (Alabama and Missouri) have already replaced the FIPs finalized in the CSAPR Update with approved SIP revisions that require their EGUs to participate in state Group 2 trading programs integrated with the Federal Group 2 trading program, so the FIPs required in this action constitute new FIPs for these states. The EPA will cease implementation of the state Group 2 trading programs included in the two states’ SIPs on the effective date of this rule.

¹⁰ Three states, Kansas, Iowa, and Tennessee, will remain in the Group 2 Trading Program.

Manufacturing; furnaces in Glass and Glass Product Manufacturing; boilers in Iron and Steel Mills and Ferroalloy Manufacturing, Metal Ore Mining, Basic Chemical Manufacturing, Petroleum and Coal Products Manufacturing, and Pulp, Paper, and Paperboard Mills; and combustors and incinerators in Solid Waste Combustors and Incinerators. Refer to Table II.A–1 for a list of North American Industry Classification System (NAICS) codes for each entity included for regulation under this rule.

B. Summary of the Regulatory Framework of the Rule

The EPA is applying the 4-step interstate transport framework developed and used in CSAPR, the CSAPR Update, the Revised CSAPR Update, and other previous ozone transport rules under the authority provided in CAA section 110(a)(2)(D)(i)(I). The 4-step interstate transport framework provides a stepwise method for the EPA to define and implement good neighbor obligations for the 2015 ozone NAAQS. The four steps are as follows: (Step 1) identifying downwind receptors that are expected to have problems attaining or maintaining the NAAQS; (Step 2) determining which upwind states contribute to these identified problems in amounts sufficient to “link” them to the downwind air quality problems (*i.e.*, in this rule as in prior transport rules beginning with CSAPR in 2011, above a contribution threshold of 1 percent of the NAAQS); (Step 3) for states linked to downwind air quality problems, identifying upwind emissions that significantly contribute to downwind nonattainment or interfere with downwind maintenance of the NAAQS through a multifactor analysis; and (Step 4) for states that are found to have emissions that significantly contribute to nonattainment or interfere with maintenance of the NAAQS in downwind areas, implementing the necessary emissions reductions through enforceable measures. The remainder of this section provides a general overview of the EPA’s application of the 4-step framework as it applies to the provisions of the rule; additional details regarding the EPA’s approach are found in section III of this document.

To apply the first step of the 4-step framework to the 2015 ozone NAAQS, the EPA performed air quality modeling to project ozone concentrations at air quality monitoring sites in 2023 and 2026.¹¹ The EPA evaluated projected

¹¹ These 2 analytic years are the last full ozone seasons before, and thus align with, upcoming attainment dates for the 2015 ozone NAAQS:

ozone concentrations for the 2023 analytic year at individual monitoring sites and considered current ozone monitoring data at these sites to identify receptors that are anticipated to have problems attaining or maintaining the 2015 ozone NAAQS. This analysis of projected ozone concentrations was then repeated for 2026.

To apply the second step of the framework, the EPA used air quality modeling to quantify the contributions from upwind states to ozone concentrations in 2023 and 2026 at downwind receptors.¹² Once quantified, the EPA then evaluated these contributions relative to a screening threshold of 1 percent of the NAAQS (*i.e.*, 0.70 ppb).¹³ States with contributions that equaled or exceeded 1 percent of the NAAQS were identified as warranting further analysis at Step 3 of the 4-step framework to determine if the upwind state significantly contributes to nonattainment or interference with maintenance in a downwind state. States with contributions below 1 percent of the NAAQS were considered not to significantly contribute to nonattainment or interfere with maintenance of the NAAQS in downwind states.

Based on the EPA’s most recent air quality modeling and contribution analysis using 2023 as the analytic year, the EPA finds that the following 23 states have contributions that equal or exceed 1 percent of the 2015 ozone NAAQS, and, thereby, warrant further analysis of significant contribution to nonattainment or interference with maintenance of the NAAQS: Alabama, Arkansas, California, Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, Minnesota, Mississippi, Missouri, Nevada, New Jersey, New York, Ohio, Oklahoma, Pennsylvania, Texas, Utah, Virginia, West Virginia, and Wisconsin.

There are locations in California to which Oregon contributes greater than 1 percent of the NAAQS; the EPA

August 3, 2024, for areas classified as Moderate nonattainment, and August 3, 2027, for areas classified as Serious nonattainment. *See* 83 FR 25776.

¹² The EPA performed air quality modeling for 2032 in the proposed rulemaking, but did not perform contribution modeling for 2032 since contribution data for this year were not needed to identify upwind states to be analyzed in Step 3. The modeling of 2032 done at proposal using the 2016v2 platform does not constitute or represent any final agency determinations respecting air quality conditions or regulatory judgments with respect to good neighbor obligations or any other CAA requirements.

¹³ *See* section IV.F of this document for explanation of EPA’s use of the 1 percent of the NAAQS threshold in the Step 2 analysis.

proposed that downwind areas represented by these monitoring sites in California should not be considered interstate ozone transport receptors at Step 1. However, the EPA is deferring finalizing a finding at this time for Oregon (*see* section IV.G of this document for additional information).

Based on the air quality analysis presented in section IV of this document, the EPA finds that, with the exception of Alabama, Minnesota, and Wisconsin, the states found linked in 2023 will continue to contribute above the 1 percent of the NAAQS threshold to at least one receptor whose nonattainment and maintenance concerns persist through the 2026 ozone season. As a result, the EPA's evaluation of significantly contributing emissions at Step 3 for Alabama, Minnesota, and Wisconsin is limited to emissions reductions achievable by the 2023 and 2024 ozone seasons.

At the third step of the 4-step framework, the EPA applied a multifactor test that incorporates cost, availability of emissions reductions, and air quality impacts at the downwind receptors to determine the amount of ozone precursor emissions from the linked upwind states that "significantly" contribute to downwind nonattainment or maintenance receptors. The EPA is applying the multifactor test described in section V.A of this document to both EGU and industrial sources. The EPA assessed the potential emissions reductions in 2023 and 2026,¹⁴ as well as in intervening and later years to determine the emissions reductions required to eliminate significant contribution in 2023 and future years where downwind areas are projected to have potential problems attaining or maintaining the 2015 ozone NAAQS.

For EGU sources, the EPA evaluated the following set of widely-available NO_x emissions control technologies: (1) fully operating existing selective catalytic reduction (SCR) controls, including both optimizing NO_x removal by existing operational SCRs and turning on and optimizing existing idled SCRs; (2) installing state-of-the-art NO_x

combustion controls; (3) fully operating existing selective non-catalytic reduction (SNCR) controls, including both optimizing NO_x removal by existing operational SNCRs and turning on and optimizing existing idled SNCRs; (4) installing new SCRs; (5) installing new SCRs; and (6) generation shifting. For the reasons explained in section V of this document and supported by the "Technical Support Document (TSD) for the Final Federal Good Neighbor Plan for the 2015 Ozone National Ambient Air Quality Standard, Docket ID No. EPA-HQ-OAR-2021-0668, EGU NO_x Mitigation Strategies Final Rule TSD" (Mar. 2023), hereinafter referred to as the EGU NO_x Mitigation Strategies Final Rule TSD, included in the docket for this action, the EPA determines that for the regional, multi-state scale of this rulemaking, only fully operating and optimizing existing SCRs and existing SNCRs (EGU NO_x emissions controls options 1 and 3 in the list earlier) are possible for the 2023 ozone season. The EPA determined that state-of-the-art NO_x combustion controls at EGUs (emissions control option 2 in the list above) are available by the beginning of the 2024 ozone season. *See* section V.B.1 of this document for a full discussion of EPA's analysis of NO_x emissions mitigation strategies for EGU sources.

The EPA is requiring control stringency levels that offer the most incremental NO_x emissions reduction potential from EGUs—among the uniform mitigation measures assessed for the covered region—and the most corresponding downwind ozone air quality improvements to the extent feasible in each year analyzed. The EPA is making a finding that the required controls provide cost-effective reductions of NO_x emissions that will provide substantial improvements in downwind ozone air quality to address interstate transport obligations for the 2015 ozone NAAQS in a timely manner. These controls represent greater stringency in upwind EGU controls than in the EPA's most recent ozone transport rulemakings, such as the CSAPR Update and the Revised CSAPR Update. However, programs to address interstate ozone transport based on the retrofit of post-combustion controls are by no means unprecedented. In prior ozone transport rulemakings such as the NO_x SIP Call and the Clean Air Interstate Rule (CAIR), the EPA established EGU budgets premised on the widespread availability of retrofitting EGUs with post-combustion

emissions controls such as SCR.¹⁵ While these programs successfully drove many EGUs to retrofit post-combustion controls, other EGUs throughout the present geography of linked upwind states continue to operate without such controls and continue to emit at relatively high rates more than 20 years after similar units reduced these emissions under prior interstate ozone transport rulemakings.

Furthermore, the CSAPR Update provided only a partial remedy for eliminating significant contribution for the 2008 ozone NAAQS, as needed to obtain available reductions by the 2017 ozone season. In that rule, the EPA made no determination regarding the appropriateness of more stringent EGU NO_x controls that would be required for a *full* remedy for interstate transport for the 2008 ozone NAAQS. Following the remand of the CSAPR Update in *Wisconsin v. EPA*, 938 F.3d 303 (D.C. Cir. 2019) (*Wisconsin*), the EPA again declined to require the retrofit of new post-combustion controls on EGUs in the Revised CSAPR Update, but that determination was based on a specific timing consideration: downwind air quality problems under the 2008 ozone NAAQS were projected to resolve before post-combustion control retrofits could be accomplished on a fleetwide, regional scale. *See* 86 FR 23054, 23110 (April 30, 2021).

In this rulemaking, the EPA is addressing good neighbor obligations for the more protective 2015 ozone NAAQS, and the Agency observes ongoing and persistent contribution from upwind states to ozone nonattainment and maintenance receptors in downwind states under that NAAQS. As further discussed in section V of this document, the nature of this contribution warrants a greater degree of control stringency than the EPA determined to be necessary to eliminate significant contribution of ozone transport in prior CSAPR rulemakings. In this rule, the EPA is requiring emissions performance levels for EGU NO_x control strategies commensurate with those determined to be necessary in the NO_x SIP Call and CAIR.

Based on the Step 3 analysis described in section V of this document, the EPA finds that emissions reductions commensurate with the full operation of all existing post-combustion controls (both SCRs and SNCRs) and state-of-the-art combustion control upgrades constitute the Agency's selected control stringency for EGUs within the borders of 22 states linked to downwind

¹⁴ The EPA included emissions reductions from the potential installation of SCRs at all affected large coal-fired EGUs in the 2026 analytic year for the purposes of assessing significant contribution to nonattainment and interference with maintenance, which is consistent with the associated attainment date. However, in response to comments identifying potential supply chain and outage scheduling challenges if the full breadth of these assumed SCR installations were to occur, the EPA is implementing half of this emissions reduction potential in 2026 ozone-season NO_x budgets for states containing these EGUs and the other half of this emissions reduction potential in 2027 ozone-season NO_x budgets for those states.

¹⁵ *See, e.g.*, 70 FR 25162, 25205–06 (May 12, 2005).

nonattainment or maintenance in 2023 (Alabama, Arkansas, Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, Minnesota, Mississippi, Missouri, Nevada, New Jersey, New York, Ohio, Oklahoma, Pennsylvania, Texas, Utah, Virginia, West Virginia, and Wisconsin). For 19 of those states that are also linked in 2026 (Arkansas, Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, Mississippi, Missouri, Nevada, New Jersey, New York, Ohio, Oklahoma, Pennsylvania, Texas, Utah, Virginia, and West Virginia), the EPA is determining that the selected EGU control stringency also includes emissions reductions commensurate with the retrofit of SCR at coal-fired units of 100 MW or greater capacity (excepting circulating fluidized bed units (CFB)), new SNCR on coal-fired units of less than 100 MW capacity and on CFBs of any capacity size, and SCR on oil/gas steam units greater than 100 MW that have historically emitted at least 150 tons of NO_x per ozone season.

To identify appropriate control strategies for non-EGU sources to achieve NO_x emissions reductions that would result in meaningful air quality improvements in downwind areas, for the proposed FIP, the EPA evaluated air quality modeling information, annual emissions, and information about potential controls to determine which industries, beyond the power sector, could have the greatest impact in providing ozone air quality improvements in affected downwind states. Once the EPA identified the industries, the EPA used its Control Strategy Tool to identify potential emissions units and control measures and to estimate emissions reductions and compliance costs associated with application of non-EGU emissions control measures. The technical memorandum *Screening Assessment of Potential Emissions Reductions, Air Quality Impacts, and Costs from Non-EGU Emissions Units for 2026* lays out the analytical framework and data used to prepare proxy estimates for 2026 of potentially affected non-EGU facilities and emissions units, emissions reductions, and costs.^{16 17} This

¹⁶ The memorandum is available in the docket at <https://www.regulations.gov/document/EPA-HQ-OAR-2021-0668-0150>.

¹⁷ This screening assessment was not intended to identify the specific emissions units subject to the proposed emissions limits for non-EGU sources but was intended to inform the development of the proposed rule by identifying proxies for (1) non-EGU emissions units that had emissions reduction potential, (2) potential controls for and emissions reductions from these emissions units, and (3) control costs from the potential controls on these

information helped shape the proposal and final rule. To further evaluate the industries and emissions unit types identified by the screening assessment and to establish the applicability criteria and proposed emissions limits, the EPA reviewed Reasonably Available Control Technology (RACT) rules, New Source Performance Standards (NSPS) rules, National Emissions Standards for Hazardous Air Pollutants (NESHAP) rules, existing technical studies, rules in approved SIPs, consent decrees, and permit limits. That evaluation is detailed in the “Technical Support Document (TSD) for the Proposed Rule, Docket ID No. EPA-HQ-OAR-2021-0668, Non-EGU Sectors TSD” (Dec. 2021), hereinafter referred to as the Proposed Non-EGU Sectors TSD, prepared for the proposed FIP.¹⁸

In this final rule, the EPA is retaining the industries and many of the emissions unit types included in the proposal in its findings of significant contribution at Step 3, as discussed in section V of this document. As discussed in the memorandum for the final rule, titled “Summary of Final Rule Applicability Criteria and Emissions Limits for Non-EGU Emissions Units, Assumed Control Technologies for Meeting the Final Emissions Limits, and Estimated Emissions Units, Emissions Reductions, and Costs,” the EPA uses the 2019 emissions inventory, the list of emissions units estimated to be captured by the applicability criteria, the assumed control technologies that would meet the emissions limits, and information on control efficiencies and default cost/ton values from the Control Measures Database,¹⁹ to estimate NO_x emissions reductions and costs for the year 2026. In this final rule, the EPA made changes to the applicability criteria and emissions limits following consideration of comments on the proposal and reassessed the overall non-EGU emissions reduction strategy based on the factors at Step 3 to render a judgment as to whether the level of emissions control that would be achievable from these units meets the criteria for “significant contribution.” In the final rule, we affirm our proposed determinations of which industries and emissions units are potentially

emissions units. This information helped shape the proposed rule.

¹⁸ The TSD is available in the docket at <https://www.regulations.gov/document/EPA-HQ-OAR-2021-0668-0145>.

¹⁹ More information about the control measures database (CMDB) can be found at the following link: <https://www.epa.gov/economic-and-cost-analysis-air-pollution-regulations/cost-analysis-modelstools-air-pollution>.

impactful and warrant further analysis at Step 3, and we find that the available emissions reductions are cost-effective and make meaningful improvements at the identified downwind receptors. For a detailed discussion of the changes, between the proposal and this final rule, in emissions unit types included and in emissions limits, see section VI.C. of this document.

The EPA performed air quality analysis using the Ozone Air Quality Assessment Tool (AQAT) to evaluate the air quality improvements anticipated to result from the implementation of the selected EGU and non-EGU emissions reduction strategies. See section V.D of this document.²⁰ We also used AQAT to determine whether the emissions reductions for both EGUs and non-EGUs potentially create an “over-control” scenario. As in prior transport rules following the holdings in *EME Homer City*, overcontrol would be established if the record indicated that, for any given state, there is a less stringent emissions control approach for that state, by which (1) the expected ozone improvements would be sufficient to resolve all of the downwind receptor(s) to which that state is linked; or (2) the expected ozone improvements would reduce the upwind state’s ozone contributions below the screening threshold (*i.e.*, 1 percent of the NAAQS or 0.70 ppb) to all of linked receptors. The EPA’s over-control analysis, discussed in section V.D.4 of this document, shows that the control stringencies for EGU and non-EGU sources in this final rule do not over-control upwind states’ emissions either with respect to the downwind air quality problems to which they are linked or with respect to the 1 percent of the NAAQS contribution threshold, such that over-control would trigger re-evaluation at Step 3 for any linked upwind state.

Based on the multi-factor test applied to both EGU and non-EGU sources and

²⁰ The use of AQAT and other simplified modeling tools to generate “appropriately reliable projections of air quality conditions and contributions” when there is limited time to conduct full-scale photochemical grid modeling was upheld by the D.C. Circuit in *MOG v. EPA*, No. 21–1146 (D.C. Cir. March 3, 2023). The EPA has used AQAT for the purpose of air quality and overcontrol assessments at Step 3 in the prior CSAPR rulemakings, and we continue to find it reliable for such purposes. We discuss the calibration of AQAT for this action and the multiple sensitivity checks we performed to ensure its reliability in the Ozone Transport Policy Analysis Final Rule TSD in the docket. Because we were able to conduct a photochemical grid modeling run of the 2026 final rule policy scenario, these results are also included in the docket and confirm the regulatory conclusions reached with AQAT. See section VIII of this document and Appendix 3A of the Final Rule RIA for more information.

our subsequent assessment of over-control, the EPA finds that the selected EGU and non-EGU control stringencies constitute the elimination of significant contribution and interference with maintenance, without over-controlling emissions, from the 23 upwind states subject to EGU and non-EGU emissions reductions requirements under the rule. For additional details about the multi-factor test and the over-control analysis, see the document titled “Technical Support Document (TSD) for the Final Federal Good Neighbor Plan for the 2015 Ozone National Ambient Air Quality Standard, Docket ID No. EPA–HQ–OAR–2021–0668, Ozone Transport Policy Analysis Proposed Rule TSD” (Mar. 2023), hereinafter referred to as Ozone Transport Policy Analysis Final Rule TSD, included in the docket for this rulemaking.

In this fourth step of the 4-step framework, the EPA is including enforceable measures in the promulgated FIPs to achieve the required emissions reductions in each of the 23 states. Specifically, the FIPs require covered power plants within the borders of 22 states (Alabama, Arkansas, Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, Minnesota, Mississippi, Missouri, Nevada, New Jersey, New York, Ohio, Oklahoma, Pennsylvania, Texas, Utah, Virginia, West Virginia, and Wisconsin) to participate in the CSAPR NO_x Ozone Season Group 3 Trading Program created by the Revised CSAPR Update. Affected EGUs within the borders of the following 12 states currently participating in the Group 3 Trading Program will remain in the program, with revised provisions beginning in the 2023 ozone season, under this rule: Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, New Jersey, New York, Ohio, Pennsylvania, Virginia, and West Virginia. Affected EGUs within the borders of the following seven states currently covered by the CSAPR NO_x Ozone Season Group 2 Trading Program (the “Group 2 trading program”)—Alabama, Arkansas, Mississippi, Missouri, Oklahoma, Texas, and Wisconsin—will transition from the Group 2 program to the revised Group 3 trading program beginning with the 2023 control period,²¹ and affected

EGUs within the borders of three states not currently covered by any CSAPR trading program for seasonal NO_x emissions—Minnesota, Nevada, and Utah—will enter the Group 3 trading program in the 2023 control period following the effective date of the final rule. In addition, the EPA is revising other aspects of the Group 3 trading program to better ensure that this method of implementation at Step 4 provides a durable remedy for the elimination of the amount of emissions deemed to constitute significant contribution at Step 3 of the interstate transport framework. These enhancements, summarized later in this section, are designed to operate together to maintain that degree of control stringency over time, thus improving emissions performance at individual units and offering a necessary measure of assurance that NO_x pollution controls will be operated throughout each ozone season, as described in section VI.B of this document. This rulemaking does not revise the budget stringency and geography of the existing CSAPR NO_x Ozone Season Group 1 trading program. Aside from the seven states moving from the Group 2 trading program to the Group 3 trading program under the final rule, this rule otherwise leaves unchanged the budget stringency of the existing CSAPR NO_x Ozone Season Group 2 trading program.

The EPA is establishing preset ozone season NO_x emissions budgets for each ozone season from 2023 through 2029, using generally the same Group 3 trading program budget-setting methodology used in the Revised CSAPR Update, as explained in section VI.B of this document and as shown in Table I.B–1. The preset budgets for the 2026 through 2029 ozone seasons incorporate EGU emissions reductions to eliminate significant contribution and also take into account a substantial number of known retirements over that period to ensure the elimination of significant contribution is maintained as intended by this rule. These budgets serve as floors and may be supplanted by a budget that the EPA calculates for that control period using more recent information (a “dynamic budget”) if that dynamic budget yields a higher level of allowable emissions—still consistent with the Step 3 level of emissions control stringency—than the preset budget. As reflected in Table I.B–1, and accounting for both the stringency of the rule and known fleet change, the 2026 preset budget is 23 percent lower than the 2025 preset budget; the 2027 preset budget is 20 percent lower than the 2026 preset budget; the 2028 preset

budget is 4 percent lower than the 2027 preset budget; and the 2029 preset budget is 8 percent lower than the 2028 preset budget.

While it is possible that additional EGUs may seek to retire in this 2026–2029 period than are currently scheduled and captured in the preset emissions budgets, it is also possible that EGUs with currently scheduled retirements may adjust their retirement timing to accommodate the timing of replacement generation and/or transmission upgrades necessitated by their retirement. While the EPA designed this final rule to provide preset budgets through 2029 to incorporate known retirement-related emissions reductions to ensure the elimination of significant contribution as identified at Step 3 is maintained over time, the use of these floors also provides generators and grid operators enhanced certainty regarding the minimum amount of allowable NO_x emissions for reliability planning through the 2020s. By providing the opportunity for dynamic budgets to subsequently calibrate budgets to any unforeseen increases in fleet demand, it also ensures this rule will not interfere with ongoing retirement scheduling or adjustments and thus is robust to future uncertainty during a transition period.

The EPA also believes the likelihood and magnitude of a scenario in which a state’s preset emissions budgets during this period would authorize more emissions than the corresponding dynamic budget is low. As described elsewhere, dynamic budgets are incorporated to best calibrate the rule’s stringency to future unknown changes to the fleet. The circumstances in which a dynamic budget would produce a level of allowable emissions less than preset budgets is most pronounced for future periods in which there is a high degree of unknown retirements (increasing the risk that budgets are not appropriately calibrated to the reduced fossil fuel heat input post retirement). However, the 2026–2029 period presents a case where retirement planning has been announced with greater lead time than normal due to a combination of utility 2030 decarbonization commitments, and Effluent Limitation Guideline (ELG) and Coal Combustion Residual (CCR) alternative compliance pathways available to units planning to cease combustion of coal by December 31, 2028. For each of these existing rules, facilities that are planning to retire have already conveyed that intention to EPA in order to take advantage of the alternative compliance pathways

²¹ The EPA will deem participation in the Group 3 trading program by the EGUs in these seven states as also addressing the respective states’ good neighbor obligations with respect to the 2008 ozone NAAQS (for all seven states), the 1997 ozone NAAQS (for all the states except Texas), and the 1979 ozone NAAQS (for Alabama and Missouri) to the same extent that those obligations are currently being addressed by participation of the states’ EGUs in the Group 2 trading program.

available to such facilities.²² Therefore, the likelihood of unknown retirements—leading to lower dynamic budgets—is much lower than typical for this time horizon. This makes EPA’s balanced use of preset emissions budgets or dynamic budgets if they exceed preset levels a reasonable

mechanism to accommodate planning and fleet transition dynamics during this period. The need and reasoning for the limited-period preset budget floor is further discussed in section VI.B.4. For control periods in 2030 and thereafter, the emissions budgets will be the amounts calculated for each state and noticed to the public roughly one

year before the control period, using the dynamic budget-setting methodology. In this manner, the stringency of the program will be secured and sustained in the dynamic budgets of this program, regardless of whatever EGU transition activities ultimately occur in this 2026–2029 transition period.

TABLE I.B–1—PRESET CSAPR NO_x OZONE SEASON GROUP 3 STATE EMISSIONS BUDGETS (TONS) FOR 2023 THROUGH 2029 CONTROL PERIODS *

State	2023 State budget	2024 State budget	2025 State budget	2026 State budget **	2027 State budget **	2028 State budget **	2029 State budget **
Alabama	6,379	6,489	6,489	6,339	6,236	6,236	5,105
Arkansas	8,927	8,927	8,927	6,365	4,031	4,031	3,582
Illinois	7,474	7,325	7,325	5,889	5,363	4,555	4,050
Indiana	12,440	11,413	11,413	8,410	8,135	7,280	5,808
Kentucky	13,601	12,999	12,472	10,190	7,908	7,837	7,392
Louisiana	9,363	9,363	9,107	6,370	3,792	3,792	3,639
Maryland	1,206	1,206	1,206	842	842	842	842
Michigan	10,727	10,275	10,275	6,743	5,691	5,691	4,656
Minnesota	5,504	4,058	4,058	4,058	2,905	2,905	2,578
Mississippi	6,210	5,058	5,037	3,484	2,084	1,752	1,752
Missouri	12,598	11,116	11,116	9,248	7,329	7,329	7,329
Nevada	2,368	2,589	2,545	1,142	1,113	1,113	880
New Jersey	773	773	773	773	773	773	773
New York	3,912	3,912	3,912	3,650	3,388	3,388	3,388
Ohio	9,110	7,929	7,929	7,929	7,929	6,911	6,409
Oklahoma	10,271	9,384	9,376	6,631	3,917	3,917	3,917
Pennsylvania	8,138	8,138	8,138	7,512	7,158	7,158	4,828
Texas	40,134	40,134	38,542	31,123	23,009	21,623	20,635
Utah	15,755	15,917	15,917	6,258	2,593	2,593	2,593
Virginia	3,143	2,756	2,756	2,565	2,373	2,373	1,951
West Virginia	13,791	11,958	11,958	10,818	9,678	9,678	9,678
Wisconsin	6,295	6,295	5,988	4,990	3,416	3,416	3,416
Total	208,119	198,014	195,259	151,329	119,663	115,193	105,201

* Further information on the state-level emissions budget calculations pertaining to Table I.B–1 is provided in section VI.B.4 of this document as well as the Ozone Transport Policy Analysis Final Rule TSD. Further information on the approach for allocating a portion of Utah’s emissions budget for each control period to the existing EGU in the Uintah and Ouray Reservation within Utah’s borders is provided in section VI.B.9 of this document.

** As described in section VI of this document, the budget for these years will be subsequently determined and equal the greater of the value above or that derived from the dynamic budget methodology.

The budget-setting methodology that the EPA will use to determine dynamic budgets for each control period starting with 2026 is an extension of the methodology used to determine the preset budgets and will be used routinely to determine emissions budgets for each future control period in the year before that control period, with each emissions budget reflecting the latest available information on the composition and utilization of the EGU fleet at the time that emissions budget is determined. The stringency of the dynamic emissions budgets will simply reflect the stringency of the emissions control strategies selected in the rulemaking more consistently over time and ensure that the annual updates would eliminate emissions determined to be unlawful under the good neighbor

provision. As already noted, for the control periods in which both preset budgets and dynamic budgets are determined for a state (*i.e.*, 2026 through 2029), the state’s dynamic budget will apply only if it is higher than the state’s preset budget. *See* section VI.B of this document for additional discussion of the EPA’s method for adjusting emissions budgets to ensure elimination of significant contribution from EGU sources in the linked upwind states.

In conjunction with the levels of the emissions budgets, the carryover of unused allowances for use in future control periods as banked allowances affects the ability of a trading program to maintain the rule’s selected control stringency and related EGU effective emissions rate performance level as the EGU fleet evolves over time.

Unrestricted banking of allowances allows what might otherwise be temporary surpluses of allowances in some individual control periods to accumulate into a long-term allowance surplus that reduces allowance prices and weakens the trading program’s incentives to control emissions. To prevent this outcome, the EPA is also revising the Group 3 trading program by adding provisions that establish a routine recalibration process for banked allowances using a target percentage of 21 percent for the 2024–2029 control periods and 10.5 percent for control periods in 2030 and later years.

As an enhancement to the structure of the trading program originally promulgated in the Revised CSAPR Update, the EPA is also establishing backstop daily emissions rates for coal

²² Notices of Planned Participation for the ELG Reconsideration Rule were due October 31, 2021

(85 FR 64708, 64679). For the CCR Action, facilities

had to indicate their future plans to cease receipt of waste by April 11, 2021 (85 FR 53517).

steam EGUs greater than or equal to 100 MW in covered states. Starting with the 2024 control period, a 3-for-1 allowance surrender ratio (instead of the usual 1-for-1 surrender ratio) will apply to emissions during the ozone season from any large coal-fired EGU with existing SCR controls exceeding by more than 50 tons a daily average NO_x emissions rate of 0.14 lb/mmBtu. The daily average emissions rate provisions will apply to large coal-fired EGUs without existing SCR controls starting with the second control period in which newly installed SCR controls are operational at the unit, but not later than the 2030 control period.

The backstop daily emissions rates work in tandem with the ozone season emissions budgets to ensure the elimination of significant contribution as determined at Step 3 is maintained over time and more consistently throughout each ozone season. They will offer downwind receptor areas a necessary measure of assurance that they will be protected on a daily basis during the ozone season by more continuous and consistent operation of installed pollution controls. The EPA's experience with the CSAPR trading programs has revealed instances where EGUs have reduced their SCR's performance on a given day, or across the entire ozone seasons in some cases, including high ozone days.²³ In addition to maintaining a mass-based seasonal requirement, this rule will achieve a much more consistent level of emissions control in line with our Step 3 determination of significant contribution while maintaining

compliance flexibility consistent with that determination. These trading program improvements will promote consistent emissions control performance across the power sector in the linked upwind states, which protects communities living in downwind ozone nonattainment areas from exceedances of the NAAQS that might otherwise occur.

The EPA is including enforceable emissions control requirements that will apply during the ozone season (annually from May to September) for nine non-EGU industries in the promulgated FIPs to achieve the required emissions reductions in 20 states with remaining interstate transport obligations for the 2015 ozone NAAQS in 2026: Arkansas, California, Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, Mississippi, Missouri, Nevada, New Jersey, New York, Ohio, Oklahoma, Pennsylvania, Texas, Utah, Virginia, and West Virginia. These requirements would apply to all existing emissions units and to any future emissions units constructed in the covered states that meet the relevant applicability criteria. Thus, the emissions limitations for non-EGU sources and associated compliance requirements would apply in all 20 states listed in this paragraph, even if some of these states do not currently have any existing emissions units meeting the applicability criteria for the identified industries.

Based on our evaluation of the time required to install controls at the types of non-EGU sources covered by this rule, the EPA has identified the 2026 ozone season as a reasonable

compliance date for industrial sources. The EPA is therefore finalizing control requirements for non-EGU sources that take effect in 2026. However, in recognition of comments and additional information indicating that not all facilities may be capable of meeting the control requirements by that time, the final rule provides a process by which the EPA may grant compliance extensions of up to 1 year, which if approved by the EPA, would require compliance no later than the 2027 ozone season, followed by an additional possible extension of up to 2 more years, where specific criteria are met. For sources located in the 20 states listed in the previous paragraph, the EPA is finalizing the NO_x emissions limits listed in Table I.B-2 for reciprocating internal combustion engines in Pipeline Transportation of Natural Gas; the NO_x emissions limits listed in Table I.B-3 for kilns in Cement and Cement Product Manufacturing; the NO_x emissions limits listed in Table I.B-4 for reheat furnaces in Iron and Steel Mills and Ferroalloy Manufacturing; the NO_x emissions limits listed in Table I.B-5 for furnaces in Glass and Glass Product Manufacturing; the NO_x emissions limits listed in Table I.B-6 for boilers in Iron and Steel Mills and Ferroalloy Manufacturing, Metal Ore Mining, Basic Chemical Manufacturing, Petroleum and Coal Products Manufacturing, and Pulp, Paper, and Paperboard Mills; and the NO_x emissions limits listed in Table I.B-7 for combustors and incinerators in Solid Waste Combustors or Incinerators.

TABLE I.B-2—SUMMARY OF NO_x EMISSIONS LIMITS FOR PIPELINE TRANSPORTATION OF NATURAL GAS

Engine type and fuel	NO _x emissions limit (g/hp-hr)
Natural Gas Fired Four Stroke Rich Burn	1.0
Natural Gas Fired Four Stroke Lean Burn	1.5
Natural Gas Fired Two Stroke Lean Burn	3.0

TABLE I.B-3—SUMMARY OF NO_x EMISSIONS LIMITS FOR KILN TYPES IN CEMENT AND CONCRETE PRODUCT MANUFACTURING

Kiln type	NO _x emissions limit (lb/ton of clinker)
Long Wet	4.0
Long Dry	3.0
Preheater	3.8
Precalciner	2.3
Preheater/Precalciner	2.8

²³ See 86 FR 23090. The EPA highlighted the Miami Fort Unit 7 (possessing a SCR) more than

tripled its ozone-season NO_x emission rate between 2017 and 2019.

Based on evaluation of comments received, the EPA is not, at this time, finalizing the source cap limit as proposed at 87 FR 20046 (see section VII.C.2 of the April 6, 2022, Proposal).

TABLE I.B-4—SUMMARY OF NO_x CONTROL REQUIREMENTS FOR IRON AND STEEL AND FERROALLOY EMISSIONS UNITS

Emissions unit	NO _x emissions standard or requirement (lb/mmBtu)
Reheat furnace	Test and set limit based on installation of Low-NO _x Burners.

TABLE I.B-5—SUMMARY OF NO_x EMISSIONS LIMITS FOR FURNACE UNIT TYPES IN GLASS AND GLASS PRODUCT MANUFACTURING

Furnace type	NO _x emissions limit (lb/ton of glass produced)
Container Glass Manufacturing Furnace	4.0
Pressed/Blown Glass Manufacturing Furnace or Fiberglass Manufacturing Furnace	4.0
Flat Glass Manufacturing Furnace	7.0

TABLE I.B-6—SUMMARY OF NO_x EMISSIONS LIMITS FOR BOILERS IN IRON AND STEEL AND FERROALLOY MANUFACTURING, METAL ORE MINING, BASIC CHEMICAL MANUFACTURING, PETROLEUM AND COAL PRODUCTS MANUFACTURING, AND PULP, PAPER, AND PAPERBOARD MILLS

Unit type	Emissions limit (lbs NO _x /mmBtu)
Coal	0.20
Residual oil	0.20
Distillate oil	0.12
Natural gas	0.08

TABLE I.B-7—SUMMARY OF NO_x EMISSIONS LIMITS FOR COMBUSTORS AND INCINERATORS IN SOLID WASTE COMBUSTORS OR INCINERATORS

Combustor or incinerator, averaging period	NO _x emissions limit (ppmvd)
ppmvd on a 24-hour block averaging period	110
ppmvd on a 30-day rolling averaging period	105

Section VI.C of this document provides an overview of the applicability criteria, compliance assurance requirements, and the EPA’s rationale for establishing these emissions limits and control requirements for each of the non-EGU industries covered by the rule.

The remainder of this preamble is organized as follows: section II of this document outlines general applicability criteria and describes the EPA’s legal authority for this rule and the relationship of the rule to previous interstate ozone transport rulemakings. Section III of this document describes the human health and environmental challenges posed by interstate transport contributions to ozone air quality problems, as well as the EPA’s overall approach for addressing interstate transport for the 2015 ozone NAAQS in this rule. Section IV of this document describes the Agency’s analyses of air quality data to inform this rulemaking, including descriptions of the air quality

modeling platform and emissions inventories used in the rule, as well as the EPA’s methods for identifying downwind air quality problems and upwind states’ ozone transport contributions to downwind states. Section V of this document describes the EPA’s approach to quantifying upwind states’ obligations in the form of EGU NO_x control stringencies and non-EGU emissions limits. Section VI of this document describes key elements of the implementation schedule for EGU and non-EGU emissions reductions requirements, including details regarding the revised aspects of the CSAPR NO_x Group 3 trading program and compliance deadlines, as well as regulatory requirements and compliance deadlines for non-EGU sources. Section VII of this document discusses the environmental justice analysis of the rule, as well as outreach and engagement efforts. Section VIII of this document describes the expected costs, benefits, and other impacts of this rule.

Section IX of this document provides a summary of changes to the existing regulatory text applicable to the EGUs covered by this rule; and section X of this document discusses the statutory and executive orders affecting this rulemaking.

C. Costs and Benefits

A summary of the key results of the cost-benefit analysis that was prepared for this final rule is presented in Table I.C-1. Table I.C-1 presents estimates of the present values (PV) and equivalent annualized values (EAV), calculated using discount rates of 3 and 7 percent as recommended by OMB’s Circular A-4, of the health and climate benefits, compliance costs, and net benefits of the final rule, in 2016 dollars, discounted to 2023. The estimated monetized net benefits are the estimated monetized benefits minus the estimated monetized costs of the final rule. These results present an incomplete overview of the effects of the rule because important

categories of benefits—including benefits from reducing other types of air pollutants, and water pollution—were

not monetized and are therefore not reflected in the cost-benefit tables. We anticipate that taking non-monetized

effects into account would show the rule to be more net beneficial than this table reflects.

TABLE I.C–1—ESTIMATED MONETIZED HEALTH AND CLIMATE BENEFITS, COMPLIANCE COSTS, AND NET BENEFITS OF THE FINAL RULE, 2023 THROUGH 2042
[Millions 2016\$, discounted to 2023]^a

	3% Discount rate	7% Discount rate
Present Value:		
Health Benefits ^b	\$200,000	\$130,000
Climate Benefits ^c	15,000	15,000
Compliance Costs ^d	14,000	9,400
Net Benefits	200,000	140,000
Equivalent Annualized Value:		
Health Benefits	13,000	12,000
Climate Benefits	970	970
Compliance Costs	910	770
Net Benefits	13,000	12,000

^a Rows may not appear to add correctly due to rounding.

^b The annualized present value of costs and benefits are calculated over a 20-year period from 2023 to 2042. Monetized benefits include those related to public health associated with reductions in ozone and PM_{2.5} concentrations. The health benefits are associated with two point estimates and are presented at real discount rates of 3 and 7 percent. Several categories of benefits remain unmonetized and are thus not reflected in the table.

^c Climate benefits are calculated using four different estimates of the social cost of carbon (SC-CO₂ (model average at 2.5 percent, 3 percent, and 5 percent discount rates; 95th percentile at 3 percent discount rate). For presentational purposes in this table, the climate benefits associated with the average SC-CO₂ at a 3-percent discount rate are used in the columns displaying results of other costs and benefits that are discounted at either a 3-percent or 7-percent discount rate.

^d The costs presented in this table are consistent with the costs presented in Chapter 4 of the *Regulatory Impact Analysis (RIA)*. To estimate these annualized costs for EGUs, the EPA uses a conventional and widely accepted approach that applies a capital recovery factor (CRF) multiplier to capital investments and adds that to the annual incremental operating expenses. Costs were calculated using a 3.76 percent real discount rate consistent with the rate used in IPM's objective function for cost-minimization. For further information on the discount rate use, please see Chapter 4, Table 4–8 in the RIA.

As shown in Table I.C–1, the PV of the monetized health benefits, associated with reductions in ozone and PM_{2.5} concentrations, of this final rule, discounted at a 3-percent discount rate, is estimated to be about \$200 billion (\$200,000 million), with an EAV of about \$13 billion (\$13,000 million). At a 7-percent discount rate, the PV of the monetized health benefits is estimated to be \$130 billion (\$130,000 million), with an EAV of about \$12 billion

(\$12,000 million). The PV of the monetized climate benefits, associated with reductions in GHG emissions, of this final rule, discounted at a 3-percent discount rate, is estimated to be about \$15 billion (\$15,000 million), with an EAV of about \$970 million. The PV of the monetized compliance costs, discounted at a 3-percent rate, is estimated to be about \$14 billion (\$14,000 million), with an EAV of about \$910 million. At a 7-percent discount

rate, the PV of the compliance costs is estimated to be about \$9.4 billion (\$9,400 million), with an EAV of about \$770 million.

II. General Information

A. Does this action apply to me?

This rule affects EGU and non-EGU sources, and regulates the groups identified in Table II.A–1.

TABLE II.A–1—REGULATED GROUPS

Industry group	NAICS
Fossil fuel-fired electric power generation	221112
Pipeline Transportation of Natural Gas	4862
Metal Ore Mining	2122
Cement and Concrete Product Manufacturing	3273
Iron and Steel Mills and Ferroalloy Manufacturing	3311
Glass and Glass Product Manufacturing	3272
Basic Chemical Manufacturing	3251
Petroleum and Coal Products Manufacturing	3241
Pulp, Paper, and Paperboard Mills	3221
Solid Waste Combustors and Incinerators	562213

This table is not intended to be exhaustive, but rather provides a guide for readers regarding entities likely to be regulated by this rule. This table lists the types of entities that the EPA is now aware could potentially be regulated by this rule. Other types of entities not

listed in the table could also be regulated. To determine whether your EGU entity is regulated by this rule, you should carefully examine the applicability criteria found in 40 CFR 97.1004, which are unchanged in this rule. If you have questions regarding the

applicability of this rule to a particular entity, consult the person listed in the **FOR FURTHER INFORMATION CONTACT** section.

B. What action is the Agency taking?

The EPA evaluated whether interstate ozone transport emissions from upwind states are significantly contributing to nonattainment, or interfering with maintenance, of the 2015 ozone NAAQS in any downwind state using the same 4-step interstate transport framework that was developed in previous ozone transport rulemakings. The EPA finds that emissions reductions are required from EGU and non-EGU sources in a total of 23 upwind states to eliminate significant contribution to downwind air quality problems for the 2015 ozone standard under the interstate transport provision of the CAA. The EPA will ensure that these NO_x emissions reductions are achieved by issuing FIP requirements for 23 states: Alabama, Arkansas, California, Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, Minnesota, Mississippi, Missouri, Nevada, New Jersey, New York, Ohio, Oklahoma, Pennsylvania, Texas, Utah, Virginia, West Virginia, and Wisconsin.

The EPA is revising the existing CSAPR Group 3 Trading Program to include additional states beginning in the 2023 ozone season. EGUs in three states not currently covered by any CSAPR trading program for seasonal NO_x emissions—Minnesota, Nevada, and Utah—will be added to the CSAPR Group 3 Trading Program under this rule. EGUs in twelve states currently participating in the Group 3 Trading Program will remain in the program under this rule: Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, New Jersey, New York, Ohio, Pennsylvania, Virginia, and West Virginia. EGUs in seven states (Alabama, Arkansas, Mississippi, Missouri, Oklahoma, Texas, and Wisconsin) will transition from the CSAPR Group 2 Trading Program to the CSAPR Group 3 Trading Program under this rule beginning in the 2023 ozone season. The EPA is establishing control stringency levels reflecting installation of state-of-the-art combustion controls on certain covered EGU sources in emissions budgets beginning in the 2024 ozone season. The EPA is establishing control stringency levels reflecting installation of new SCR or SNCR controls on certain covered EGU sources in emissions budgets beginning in the 2026 ozone season.

As a complement to the ozone season emissions budgets, the EPA is also establishing a backstop daily emissions rate of 0.14 lb/mmBtu for coal-fired steam units greater than or equal to 100 MW in covered states. The backstop emissions rate will first apply in 2024

for coal-fired steam sources with existing SCRs, and in the second control period in which a new SCR operates, but not later than 2030, for those currently without SCRs.

This rule establishes emissions limitations for non-EGU sources in 20 states: Arkansas, California, Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, Mississippi, Missouri, Nevada, New Jersey, New York, Ohio, Oklahoma, Pennsylvania, Texas, Utah, Virginia, and West Virginia. In these states, the EPA is establishing control requirements for the following unit types in non-EGU industries: reciprocating internal combustion engines in Pipeline Transportation of Natural Gas; kilns in Cement and Cement Product Manufacturing; reheat furnaces in Iron and Steel Mills and Ferroalloy Manufacturing; furnaces in Glass and Glass Product Manufacturing; boilers in Iron and Steel Mills and Ferroalloy Manufacturing, Metal Ore Mining, Basic Chemical Manufacturing, Petroleum and Coal Products Manufacturing, and Pulp, Paper, and Paperboard Mills; and combustors and incinerators in Solid Waste Combustors and Incinerators. See Table II.A–1 in this document for a list of NAICS codes for each entity included for regulation in this rule.

This rule reduces the transport of ozone precursor emissions to downwind areas, which is protective of human health and the environment because acute and chronic exposure to ozone are both associated with negative health impacts. Ozone exposure is also associated with negative effects on ecosystems. Additional information on the air quality issues addressed by this rule are included in section III of this document.

C. What is the Agency's legal authority for taking this action?

The statutory authority for this rule is provided by the CAA as amended (42 U.S.C. 7401 *et seq.*). Specifically, sections 110 and 301 of the CAA provide the primary statutory underpinnings for this rule. The most relevant portions of CAA section 110 are subsections 110(a)(1), 110(a)(2) (including 110(a)(2)(D)(i)(I)) and 110(c)(1).

CAA section 110(a)(1) provides that states must make SIP submissions “within 3 years (or such shorter period as the Administrator may prescribe) after the promulgation of a national primary ambient air quality standard (or any revision thereof),” and that these SIP submissions are to provide for the “implementation, maintenance, and

enforcement” of such NAAQS.²⁴ The statute directly imposes on states the duty to make these SIP submissions, and the requirement to make the submissions is not conditioned upon the EPA taking any action other than promulgating a new or revised NAAQS.²⁵

The EPA has historically referred to SIP submissions made for the purpose of satisfying the applicable requirements of CAA sections 110(a)(1) and 110(a)(2) as “infrastructure SIP” or “iSIP” submissions. CAA section 110(a)(1) addresses the timing and general requirements for iSIP submissions, and CAA section 110(a)(2) provides more details concerning the required content of these submissions.²⁶ It includes a list of specific elements that “[e]ach such plan” must address.²⁷

CAA section 110(c)(1) requires the Administrator to promulgate a FIP at any time within 2 years after the Administrator: (1) finds that a state has failed to make a required SIP submission; (2) finds a SIP submission to be incomplete pursuant to CAA section 110(k)(1)(C); or (3) disapproves a SIP submission. This obligation applies unless the state corrects the deficiency through a SIP revision that the Administrator approves before the FIP is promulgated.²⁸

CAA section 110(a)(2)(D)(i)(I), also known as the “good neighbor” provision, provides the primary basis for this rule.²⁹ It requires that each state SIP include provisions sufficient to “prohibit[], consistent with the provisions of this subchapter, any source or other type of emissions activity within the State from emitting any air pollutant in amounts which will—(I) contribute significantly to nonattainment in, or interfere with maintenance by, any other State with respect to any [NAAQS].”³⁰ The EPA often refers to the emissions reduction requirements under this provision as “good neighbor obligations” and submissions addressing these requirements as “good neighbor SIPs.”

²⁴ 42 U.S.C. 7410(a)(1).

²⁵ See *EPA v. EME Homer City Generation, L.P.*, 572 U.S. 489, 509–10 (2014).

²⁶ 42 U.S.C. 7410(a)(2).

²⁷ The EPA's general approach to infrastructure SIP submissions is explained in greater detail in individual notices acting or proposing to act on state infrastructure SIP submissions and in guidance. See, e.g., Memorandum from Stephen D. Page on Guidance on Infrastructure State Implementation Plan (SIP) Elements under Clean Air Act Sections 110(a)(1) and 110(a)(2) (September 13, 2013).

²⁸ 42 U.S.C. 7410(c)(1).

²⁹ 42 U.S.C. 7410(a)(2)(D)(i)(I).

³⁰ *Id.*

Once the EPA promulgates a NAAQS, the EPA must designate areas as being in “attainment” or “nonattainment” of the NAAQS, or “unclassifiable.” CAA section 107(d).³¹ For ozone, nonattainment is further split into five classifications based on the severity of the violation—Marginal, Moderate, Serious, Severe, or Extreme. Higher classifications provide states with progressively more time to attain while imposing progressively more stringent control requirements. See CAA sections 181, 182.³² In general, states with nonattainment areas classified as Moderate or higher must submit plans to the EPA to bring these areas into attainment according to the statutory schedule. CAA section 182.³³ If an area fails to attain the NAAQS by the attainment date associated with its classification, it is “bumped up” to the next classification. CAA section 181(b).³⁴

Section 301(a)(1) of the CAA gives the Administrator the general authority to prescribe such regulations as are necessary to carry out functions under the Act.³⁵ Pursuant to this section, the EPA has authority to clarify the applicability of CAA requirements and undertake other rulemaking action as necessary to implement CAA requirements. CAA section 301 affords the Agency any additional authority that may be needed to make certain other changes to its regulations under 40 CFR parts 52, 75, 78, and 97, to effectuate the purposes of the Act. Such changes are discussed in section IX of this document.

Tribes are not required to submit state implementation plans. However, as explained in the EPA’s regulations outlining Tribal Clean Air Act authority, the EPA is authorized to promulgate FIPs for Indian country as necessary or appropriate to protect air quality if a tribe does not submit, and obtain the EPA’s approval of, an implementation plan. See 40 CFR 49.11(a); see also CAA section 301(d)(4).³⁶ In the proposed rule, the EPA proposed an “appropriate or necessary” finding under CAA section 301(d) and proposed tribal FIP(s) as necessary to implement the relevant requirements. The EPA is finalizing these determinations, as further discussed in section III.C.2 of this document.

D. What actions has the EPA previously issued to address regional ozone transport?

The EPA has issued several previous rules interpreting and clarifying the requirements of CAA section 110(a)(2)(D)(i)(I) with respect to the regional transport of ozone. These rules, and the associated court decisions addressing these rules, summarized here, provide important direction regarding the requirements of CAA section 110(a)(2)(D)(i)(I).

The “NO_x SIP Call,” promulgated in 1998, addressed the good neighbor provision for the 1979 1-hour ozone NAAQS.³⁷ The rule required 22 states and the District of Columbia to amend their SIPs to reduce NO_x emissions that contribute to ozone nonattainment in downwind states. The EPA set ozone season NO_x budgets for each state, and the states were given the option to participate in a regional allowance trading program, known as the NO_x Budget Trading Program.³⁸ The D.C. Circuit largely upheld the NO_x SIP Call in *Michigan v. EPA*, 213 F.3d 663 (D.C. Cir. 2000), cert. denied, 532 U.S. 904 (2001).

The EPA’s next rule addressing the good neighbor provision, CAIR, was promulgated in 2005 and addressed both the 1997 fine particulate matter (PM_{2.5}) NAAQS and 1997 ozone NAAQS.³⁹ CAIR required SIP revisions in 28 states and the District of Columbia to reduce emissions of sulfur dioxide (SO₂) or NO_x—important precursors of regionally transported PM_{2.5} (SO₂ and annual NO_x) and ozone (summer-time NO_x). As in the NO_x SIP Call, states were given the option to participate in regional trading programs to achieve the reductions. When the EPA promulgated the final CAIR in 2005, the EPA also issued findings that states nationwide had failed to submit SIPs to address the requirements of CAA section 110(a)(2)(D)(i) with respect to the 1997

PM_{2.5} and 1997 ozone NAAQS.⁴⁰ On March 15, 2006, the EPA promulgated FIPs to implement the emissions reductions required by CAIR.⁴¹ CAIR was remanded to EPA by the D.C. Circuit in *North Carolina v. EPA*, 531 F.3d 896 (D.C. Cir.), modified on reh’g, 550 F.3d 1176 (D.C. Cir. 2008). For more information on the legal issues underlying CAIR and the D.C. Circuit’s holding in *North Carolina*, refer to the preamble of the CSAPR rule.⁴²

In 2011, the EPA promulgated CSAPR to address the issues raised by the remand of CAIR. CSAPR addressed the two NAAQS at issue in CAIR and additionally addressed the good neighbor provision for the 2006 PM_{2.5} NAAQS.⁴³ CSAPR required 28 states to reduce SO₂ emissions, annual NO_x emissions, or ozone season NO_x emissions that significantly contribute to other states’ nonattainment or interfere with other states’ abilities to maintain these air quality standards.⁴⁴ To align implementation with the applicable attainment deadlines, the EPA promulgated FIPs for each of the 28 states covered by CSAPR. The FIPs require EGUs in the covered states to participate in regional trading programs to achieve the necessary emissions reductions. Each state can submit a good neighbor SIP at any time that, if approved by EPA, would replace the CSAPR FIP for that state.

CSAPR was the subject of an adverse decision by the D.C. Circuit in August 2012.⁴⁵ However, this decision was reversed in April 2014 by the Supreme Court, which largely upheld the rule, including the EPA’s approach to addressing interstate transport in CSAPR. *EPA v. EME Homer City Generation, L.P.*, 572 U.S. 489 (2014) (*EME Homer City I*). The rule was remanded to the D.C. Circuit to consider claims not addressed by the Supreme Court. *Id.* In July 2015 the D.C. Circuit

⁴⁰ 70 FR 21147 (April 25, 2005).

⁴¹ 71 FR 25328 (April 28, 2006).

⁴² *Federal Implementation Plans: Interstate Transport of Fine Particulate Matter and Ozone and Correction of SIP Approvals*, 76 FR 48208, 48217 (August 8, 2011).

⁴³ 76 FR 48208.

⁴⁴ CSAPR was revised by several rulemakings after its initial promulgation to revise certain states’ budgets and to promulgate FIPs for five additional states addressing the good neighbor obligation for the 1997 ozone NAAQS. See 76 FR 80760 (December 27, 2011); 77 FR 10324 (February 21, 2012); 77 FR 34830 (June 12, 2012).

⁴⁵ On August 21, 2012, the D.C. Circuit issued a decision in *EME Homer City Generation, L.P. v. EPA*, 696 F.3d 7 (D.C. Cir. 2012), vacating CSAPR. The EPA sought review with the D.C. Circuit *en banc* and the D.C. Circuit declined to consider the EPA’s appeal *en banc*. *EME Homer City Generation, L.P. v. EPA*, No. 11–1302 (D.C. Cir. January 24, 2013), ECF No. 1417012 (denying EPA’s motion for rehearing *en banc*).

³¹ 42 U.S.C. 7407(d).

³² 42 U.S.C. 7511, 7511a.

³³ 42 U.S.C. 7511a.

³⁴ 42 U.S.C. 7511(b).

³⁵ 42 U.S.C. 7601(a)(1).

³⁶ 42 U.S.C. 7601(d)(4).

³⁷ *Finding of Significant Contribution and Rulemaking for Certain States in the Ozone Transport Assessment Group Region for Purposes of Reducing Regional Transport of Ozone*, 63 FR 57356 (Oct. 27, 1998). As originally promulgated, the NO_x SIP Call also addressed good neighbor obligations under the 1997 8-hour ozone NAAQS, but EPA subsequently stayed and later rescinded the rule’s provisions with respect to that standard. See 84 FR 8422 (March 8, 2019).

³⁸ “Allowance Trading,” sometimes referred to as “cap and trade,” is an approach to reducing pollution that has been used successfully to protect human health and the environment. The design elements of the EPA’s most recent trading programs are discussed in section VI.B.1.a of this document.

³⁹ *Rule To Reduce Interstate Transport of Fine Particulate Matter and Ozone (Clean Air Interstate Rule); Revisions to Acid Rain Program; Revisions to the NO_x SIP Call*, 70 FR 25162 (May 12, 2005).

generally affirmed the EPA's interpretation of various statutory provisions and the EPA's technical decisions. *EME Homer City Generation, L.P. v. EPA*, 795 F.3d 118 (2015) (*EME Homer City II*). However, the court remanded the rule without vacatur for reconsideration of the EPA's emissions budgets for certain states, which the court found may have over-controlled those states' emissions with respect to the downwind air quality problems to which the states were linked. *Id.* at 129–30, 138. For more information on the legal issues associated with CSAPR and the Supreme Court's and D.C. Circuit's decisions in the *EME Homer City* litigation, refer to the preamble of the CSAPR Update.⁴⁶

In 2016, the EPA promulgated the CSAPR Update to address interstate transport of ozone pollution with respect to the 2008 ozone NAAQS.⁴⁷ The final rule updated the CSAPR ozone season NO_x emissions budgets for 22 states to achieve cost-effective and immediately feasible NO_x emissions reductions from EGUs within those states.⁴⁸ The EPA aligned the analysis and implementation of the CSAPR Update with the 2017 ozone season to assist downwind states with timely attainment of the 2008 ozone NAAQS.⁴⁹ The CSAPR Update implemented the budgets through FIPs requiring sources to participate in a revised CSAPR NO_x ozone season trading program beginning with the 2017 ozone season. As under CSAPR, each state could submit a good neighbor SIP at any time that, if approved by the EPA, would replace the CSAPR Update FIP for that state. The final CSAPR Update also addressed the remand by the D.C. Circuit of certain states' CSAPR phase 2 ozone season NO_x emissions budgets in *EME Homer City II*.

In December 2018, the EPA promulgated the CSAPR "Close-Out," which determined that no further enforceable reductions in emissions of

NO_x were required with respect to the 2008 ozone NAAQS for 20 of the 22 eastern states covered by the CSAPR Update.⁵⁰

The CSAPR Update and the CSAPR Close-Out were both subject to legal challenges in the D.C. Circuit. *Wisconsin v. EPA*, 938 F.3d 303 (D.C. Cir. 2019) (*Wisconsin*); *New York v. EPA*, 781 Fed. App'x 4 (D.C. Cir. 2019) (*New York*). In September 2019, the D.C. Circuit upheld the CSAPR Update in virtually all respects but remanded the rule because it was partial in nature and did not fully eliminate upwind states' significant contribution to nonattainment or interference with maintenance of the 2008 ozone NAAQS by "the relevant downwind attainment deadlines" in the CAA. *Wisconsin*, 938 F.3d at 313–15. In October 2019, the D.C. Circuit vacated the CSAPR Close-Out on the same grounds that it remanded the CSAPR Update in *Wisconsin*, specifically because the Close-Out rule did not address good neighbor obligations by "the next applicable attainment date" of downwind states. *New York*, 781 Fed. App'x at 7.⁵¹

In response to the *Wisconsin* remand of the CSAPR Update and the *New York* vacatur of the CSAPR Close-Out, the EPA promulgated the Revised CSAPR Update on April 30, 2021.⁵² The Revised CSAPR Update found that the CSAPR Update was a full remedy for nine of the covered states. For the 12 remaining states, the EPA found that their projected 2021 ozone season NO_x emissions would significantly contribute to downwind states' nonattainment or maintenance problems. The EPA issued new or amended FIPs for these 12 states and required implementation of revised emissions budgets for EGUs beginning

with the 2021 ozone season. Based on the EPA's assessment of remaining air quality issues and additional emissions control strategies for EGUs and emissions sources in other industry sectors (non-EGUs), the EPA determined that the NO_x emissions reductions achieved by the Revised CSAPR Update fully eliminated these states' significant contributions to downwind air quality problems for the 2008 ozone NAAQS. As under the CSAPR and the CSAPR Update, each state can submit a good neighbor SIP at any time that, if approved by the EPA, would replace the Revised CSAPR Update FIP for that state.

On March 3, 2023, the D.C. Circuit Court of Appeals denied the Midwest Ozone Group's (MOG) petition for review of the Revised CSAPR Update. *MOG v. EPA*, No. 21–1146 (D.C. Cir. March 3, 2023). The court noted that it has "exhaustively" addressed the interstate transport framework before, citing relevant cases, and "incorporate them herein by reference." Slip Op. 1 n.1. In response to MOG's arguments, the court upheld the Agency's air quality analysis. *Id.* at 10–11. The court noted that in light of the statutory timing framework and court-ordered schedule the EPA was under, the Agency's methodological choices were reasonable and provided "an appropriately reliable projection of air quality conditions and contributions in 2021." *Id.* at 11–12.

III. Air Quality Issues Addressed and Overall Rule Approach

A. The Interstate Ozone Transport Air Quality Challenge

1. Nature of Ozone and the Ozone NAAQS

Ground-level ozone is not emitted directly into the air but is created by chemical reactions between NO_x and volatile organic compounds (VOCs) in the presence of sunlight. Emissions from electric utilities and industrial facilities, motor vehicles, gasoline vapors, and chemical solvents are some of the major sources of NO_x and VOCs.

Because ground-level ozone formation increases with temperature and sunlight, ozone levels are generally higher during the summer months. Increased temperature also increases emissions of volatile man-made and biogenic organics and can also indirectly increase NO_x emissions (e.g., increased electricity generation for air conditioning).

On October 1, 2015, the EPA strengthened the primary and secondary ozone standards to 70 ppb as an 8-hour

⁴⁶ *Cross-State Air Pollution Rule Update for the 2008 Ozone NAAQS*, 81 FR 74504, 74511 (October 26, 2016).

⁴⁷ 81 FR 74504.

⁴⁸ One state, Kansas, was made newly subject to ozone season NO_x requirements by the CSAPR Update. All other CSAPR Update states were already subject to ozone season NO_x requirements under CSAPR.

⁴⁹ 81 FR 74516. The EPA's final 2008 Ozone NAAQS SIP Requirements Rule, 80 FR 12264, 12268 (March 6, 2015), revised the attainment deadline for ozone nonattainment areas designated as Moderate to July 20, 2018. See 40 CFR 51.1103. To demonstrate attainment by this deadline, states were required to rely on design values calculated using ozone season data from 2015 through 2017, since the July 20, 2018, deadline did not afford enough time for measured data of the full 2018 ozone season.

⁵⁰ *Determination Regarding Good Neighbor Obligations for the 2008 Ozone National Ambient Air Quality Standard*, 83 FR 65878, 65882 (December 21, 2018). After promulgating the CSAPR Update and before promulgating the CSAPR Close-Out, the EPA approved a SIP from Kentucky resolving the Commonwealth's good neighbor obligations for the 2008 ozone NAAQS. 83 FR 33730 (July 17, 2018). In the Revised CSAPR Update, the EPA made an error correction under CAA section 110(k)(6) to convert this approval to a disapproval, because the Kentucky approval relied on the same analysis which the D.C. Circuit determined to be unlawful in the CSAPR Close-Out.

⁵¹ Subsequently, the D.C. Circuit made clear in a decision reviewing the EPA's denial of a petition under CAA section 126 that the holding in *Wisconsin* regarding alignment with downwind area's attainment schedules applies with equal force to the Marginal area attainment date established under CAA section 181(a). See *Maryland v. EPA*, 958 F.3d 1185, 1203–04 (D.C. Cir. 2020).

⁵² *Revised Cross-State Air Pollution Rule Update for the 2008 Ozone NAAQS*, 86 FR 23054 (April 30, 2021).

level.⁵³ Specifically, the standards require that the 3-year average of the fourth highest 24-hour maximum 8-hour average ozone concentration may not exceed 70 ppb as a truncated value (*i.e.*, digits to right of decimal removed).⁵⁴ In general, areas that exceed the ozone standard are designated as nonattainment areas, pursuant to the designations process under CAA section 107(d), and are subject to heightened planning requirements depending on the severity of their nonattainment classification, *see* CAA sections 181, 182.

In the process of setting the 2015 ozone NAAQS, the EPA noted that the conditions conducive to the formation of ozone (*i.e.*, seasonally-dependent factors such as ambient temperature, strength of solar insolation, and length of day) differ by location, and that the Agency believes it is important that ozone monitors operate during all periods when there is a reasonable possibility of ambient levels approaching the level of the NAAQS. At that time, the EPA stated that ambient ozone concentrations in many areas could approach or exceed the level of the NAAQS, more frequently and during more months of the year compared with the historical ozone season monitoring lengths. Consequently, the EPA extended the ozone monitoring season for many locations. *See* 80 FR 65416 for more details.

Furthermore, the EPA stated that in addition to being affected by changing emissions, future ozone concentrations may also be affected by climate change. Modeling studies in the EPA's Interim Assessment (U.S. EPA, 2009a) that are cited in support of the 2009 Greenhouse Gas Endangerment Finding under CAA section 202(a) (74 FR 66496, Dec. 15, 2009) as well as a recent assessment of potential climate change impacts (Fann et al., 2015) project that climate change may lead to future increases in summer ozone concentrations across the contiguous U.S.⁵⁵ (80 FR 65300). The U.S. Global Change Research Program's *Impacts of Climate Change on Human Health in the United States: A Scientific Assessment*⁵⁶ and *Impacts, Risks, and*

*Adaptation in the United States: Fourth National Climate Assessment, Volume II*⁵⁷ reinforced these findings. The increase in ozone results from changes in local weather conditions, including temperature and atmospheric circulation patterns, as well as changes in ozone precursor emissions that are influenced by meteorology (Nolte et al., 2018). While the projected impact may not be uniform, climate change has the potential to increase average summertime ozone relative to a future without climate change.^{58 59 60} Climate change has the potential to offset some of the improvements in ozone air quality, and therefore some of the improvements in public health, that are expected from reductions in emissions of ozone precursors (80 FR 65300). The EPA responds to comments received on the impacts of climate change on ozone formation in section 11 of the *Response to Comments (RTC)* document.

2. Ozone Transport

Studies have established that ozone formation, atmospheric residence, and transport occur on a regional scale (*i.e.*, thousands of kilometers) over much of the U.S.⁶¹ While substantial progress has been made in reducing ozone in many areas, the interstate transport of ozone precursor emissions remains an

Assessment. Crimmins, A., J. Balbus, J.L. Gamble, C.B. Beard, J.E. Bell, D. Dodgen, R.J. Eisen, N. Fann, M.D. Hawkins, S.C. Herring, L. Jantarasami, D.M. Mills, S. Saha, M.C. Sarofim, J. Trtanj, and L. Ziska, Eds. U.S. Global Change Research Program, Washington, DC, 312 pp. <https://dx.doi.org/10.7930/JOR49NQX>.

⁵⁷ USGCRP, 2018: *Impacts, Risks, and Adaptation in the United States: Fourth National Climate Assessment, Volume II* [Reidmiller, D.R., C.W. Avery, D.R. Easterling, K.E. Kunkel, K.L.M. Lewis, T.K. Maycock, and B.C. Stewart (eds.)]. U.S. Global Change Research Program, Washington, DC, USA, 1515 pp. doi: 10.7930/NCA4.2018.

⁵⁸ Fann NL, Nolte CG, Sarofim MC, Martinich J, Nassikas NJ. Associations Between Simulated Future Changes in Climate, Air Quality, and Human Health. *JAMA Netw Open*. 2021;4(1):e2032064. doi:10.1001/jamanetworkopen.2020.32064

⁵⁹ Christopher G Nolte, Tanya L Spero, Jared H Bowden, Marcus C Sarofim, Jeremy Martinich, Megan S Mallard. Regional temperature-ozone relationships across the U.S. under multiple climate and emissions scenarios. *J Air Waste Manag Assoc*. 2021 Oct;71(10):1251–1264. doi: 10.1080/10962247.2021.1970048.

⁶⁰ Nolte, C.G., P.D. Dolwick, N. Fann, L.W. Horowitz, V. Naik, R.W. Pinder, T.L. Spero, D.A. Winner, and L.H. Ziska, 2018: Air Quality. In *Impacts, Risks, and Adaptation in the United States: Fourth National Climate Assessment, Volume II* [Reidmiller, D.R., C.W. Avery, D.R. Easterling, K.E. Kunkel, K.L.M. Lewis, T.K. Maycock, and B.C. Stewart (eds.)]. U.S. Global Change Research Program, Washington, DC, USA, pp. 512–538. doi: 10.7930/NCA4.2018.CH13

⁶¹ Bergin, M.S. et al. (2007) Regional air quality: Local and interstate impacts of NO_x and SO₂ emissions on ozone and fine particulate matter in the eastern United States. *Environmental Sci & Tech*. 41: 4677–4689.

important contributor to peak ozone concentrations and high-ozone days during the summer ozone season.

The EPA has previously concluded in the NO_x SIP Call, CAIR, CSAPR, the CSAPR Update, and the Revised CSAPR Update that a regional NO_x control strategy would be effective in reducing regional-scale transport of ozone precursor emissions. NO_x emissions can be transported downwind as NO_x or as ozone after transformation in the atmosphere. In any given location, ozone pollution levels are impacted by a combination of background ozone concentration, local emissions, and emissions from upwind sources resulting from ozone transport, in conjunction with variable meteorological conditions. Downwind states' ability to meet health-based air quality standards such as the NAAQS is challenged by the transport of ozone pollution across state borders. For example, ozone assessments conducted for the October 2015 Regulatory Impact Analysis of the Final Revisions to the National Ambient Air Quality Standards for Ground-Level Ozone⁶² continue to show the importance of NO_x emissions for ozone transport. This analysis is included in the docket for this rulemaking.

Further, studies have found that EGU NO_x emissions reductions can be effective in reducing individual 8-hour peak ozone concentrations and in reducing 8-hour peak ozone concentrations averaged across the ozone season. For example, a study of the EGU NO_x reductions achieved under the NO_x Budget Trading Program (*i.e.*, the NO_x SIP Call) shows that regulating NO_x emissions in that program was highly effective in reducing ozone concentrations during the ozone season.⁶³

Previous regional ozone transport efforts, including the NO_x SIP Call, CAIR, CSAPR, the CSAPR Update, and the Revised CSAPR Update, required ozone season NO_x reductions from EGU sources to address interstate transport of ozone. Together with NO_x, the EPA has also identified VOCs as a precursor in forming ground-level ozone. Ozone formation chemistry can be “NO_x-limited,” where ozone production is primarily determined by the amount of NO_x emissions or “VOC-limited,” where ozone production is primarily

⁶² Available in the docket for the October 2015 Revisions to the National Ambient Air Quality Standards for Ground-Level Ozone at <https://www.regulations.gov/docket/EPA-HQ-OAR-2008-0699>.

⁶³ Butler, et al., “Response of Ozone and Nitrate to Stationary Source Reductions in the Eastern USA.” *Atmospheric Environment*, 2011.

⁵³ 80 FR 65291.

⁵⁴ 40 CFR part 50, appendix P.

⁵⁵ These modeling studies are based on coupled global climate and regional air quality models and are designed to assess the sensitivity of U.S. air quality to climate change. A wide range of future climate scenarios and future years have been modeled and there can be variations in the expected response in U.S. O₃ by scenario and across models and years, within the overall signal of higher summer O₃ concentrations in a warmer climate.

⁵⁶ U.S. Global Change Research Program (USGCRP), 2016: *The Impacts of Climate Change on Human Health in the United States: A Scientific*

determined by the amount of VOC emissions.⁶⁴ The EPA and others have long regarded NO_x to be the more significant ozone precursor in the context of interstate ozone transport.⁶⁵

The EPA has determined that the regulation of VOCs as an ozone precursor is not necessary to eliminate significant contribution of ozone transport to downwind areas in this rule. As described in section V.A of this document, the EPA examined the results of the contribution modeling performed for this rule to identify the portion of the ozone contribution attributable to anthropogenic NO_x emissions versus VOC emissions from each linked upwind state to each downwind receptor. Our analysis of the ozone contribution from upwind states subject to regulation demonstrates that regional ozone concentrations affecting the vast majority of the downwind areas of air quality concern are NO_x-limited, rather than VOC-limited. Therefore, the rule's strategy for reducing regional-scale transport of ozone targets NO_x emissions from stationary sources to achieve the most effective reductions of ozone transport over the geography of the affected downwind areas. The potential impacts of NO_x mitigation strategies from other sources are discussed in section V.B of this document.

In section V of this document, the EPA describes the multi-factor test that is used to determine NO_x emissions reductions that are cost-effective and reduce interstate transport of ground-level ozone. Our analysis indicates that the EGU and non-EGU control requirements included in this rule will provide meaningful improvements in air quality at the downwind receptors. Based on the implementation schedule established in section VI.A of this document, the EPA finds that the regulatory requirements included in the rule are as expeditious as practicable and are aligned with the attainment schedule of downwind areas.

3. Health and Environmental Effects

Exposure to ambient ozone causes a variety of negative effects on human health, vegetation, and ecosystems. In humans, acute and chronic exposure to ozone is associated with premature mortality and certain morbidity effects, such as asthma exacerbation. In ecosystems, ozone exposure causes visible foliar injury, decreases plant growth, and affects ecosystem

community composition. See EPA's October 2015 Regulatory Impact Analysis of the Final Revisions to the National Ambient Air Quality Standards for Ground-Level Ozone⁶⁶ in the docket for this rulemaking for more information on the human health and ecosystem effects associated with ambient ozone exposure.

Commenters on prior ozone transport rules have asserted that VOC emissions harm underserved and overburdened communities experiencing disproportionate environmental health burdens and facing other environmental injustices. The EPA acknowledges that VOCs can contain toxic chemicals that are detrimental to public health. The EPA conducted a demographic analysis as part of the regulatory impact analysis for the 2015 revisions to the primary and secondary ozone NAAQS. This analysis, which is included in the docket for this rulemaking, found greater representation of minority populations in areas with poor air quality relative to the revised ozone standard than in the U.S. as a whole. The EPA concluded that populations in these areas would be expected to benefit from implementation of future air pollution control actions from state and local air agencies in implementing the strengthened standard. This rule is an example of air pollution control actions implemented by the Federal Government in support of the more protective 2015 ozone NAAQS, and populations living in downwind ozone nonattainment and maintenance areas are expected to benefit from improved air quality that will result from reducing ozone transport. Further discussion of the environmental justice analysis of this rule is located in section VII of this document and in the accompanying regulatory impact analysis, titled "Regulatory Impact Analysis for Final Federal Good Neighbor Plan Addressing Regional Ozone Transport for the 2015 Ozone National Ambient Air Quality Standard" [EPA-452/D-22-001], which is available in the docket for this rulemaking.

The Agency regulates exposure to toxic pollutant concentrations and ambient exposure to criteria pollutants other than ozone through other sections of the Act, such as the regulation of hazardous air pollutants under CAA section 112 or the process for revising and implementing the NAAQS under CAA sections 107-110. The purpose of the subject rulemaking is to protect public health and the environment by eliminating significant contribution

from 23 states to nonattainment or maintenance of the 2015 ozone NAAQS to meet the requirements of the CAA's interstate transport provision. In this rule, the EPA continues to observe that requiring NO_x emissions reductions from stationary sources is an effective strategy for reducing regional ozone transport in the U.S.

The EPA responds to other comments received on the health and environmental impacts of ozone exposure in section 11 of the *RTC* document.

B. Final Rule Approach

1. The 4-Step Interstate Transport Framework

The EPA first developed a multi-step process to address the requirements of the good neighbor provision in the 1998 NO_x SIP Call and the 2005 CAIR. The Agency built upon this framework and further refined the methodology for addressing interstate transport obligations in subsequent rules such as CSAPR in 2011, the CSAPR Update in 2016, and the Revised CSAPR Update in 2021.⁶⁷ In CSAPR, the EPA first articulated a "4-step framework" within which to assess interstate transport obligations for ozone. In this rule to address interstate transport obligations for the 2015 ozone NAAQS, the EPA is again utilizing the 4-step interstate transport framework. These steps are: (1) identifying downwind receptors that are expected to have problems attaining the NAAQS (nonattainment receptors) or maintaining the NAAQS (maintenance receptors); (2) determining which upwind states are "linked" to these identified downwind receptors based on a numerical contribution threshold; (3) for states linked to downwind air quality problems, identifying upwind emissions on a statewide basis that significantly contribute to downwind nonattainment or interfere with downwind maintenance of the NAAQS, considering cost- and air quality-based factors; and (4) for upwind states that are found to have emissions that significantly contribute to nonattainment or interfere with maintenance of the NAAQS in any downwind state, implementing the necessary emissions reductions through enforceable measures.

Comment: The EPA received comments supporting the Agency's use of the 4-step interstate transport framework as a permissible method for assigning the required amount of

⁶⁴ "Ozone Air Pollution." *Introduction to Atmospheric Chemistry*, by Daniel J. Jacob, Princeton University Press, Princeton, New Jersey, 1999, pp. 231-244.

⁶⁵ 81 FR 74514.

⁶⁶ Available at <https://www.epa.gov/sites/default/files/2016-02/documents/20151001ria.pdf>.

⁶⁷ See CSAPR, Final Rule, 76 FR 48208, 48248-48249 (August 8, 2011); CSAPR Update, Final Rule, 81 FR 74504, 74517-74521 (October 26, 2016).

emissions reductions necessary to eliminate upwind states' significant contribution. Commenters also noted that the 4-step interstate transport framework was reviewed by the Supreme Court in *EPA vs. EME Homer City Generation*, 572 U.S. 489 (2014), and upheld. However, other commenters took exception to the overall approach of this proposed action. These commenters alleged that the EPA is ignoring the "flexibility" in addressing good neighbor obligations that it had purportedly suggested to states would be permissible in memoranda that the EPA issued in 2018. Commenters also raised concerns that the air quality modeling (2016v2) the EPA used to propose to disapprove SIP submittals and as the basis for the proposed FIP was not available to states at the time they made their submissions and that the changes in results at Steps 1 and 2 from prior rounds of modeling rendered the new modeling unreliable. Commenters also raised a number of arguments that the EPA should allow states an additional opportunity to submit SIPs before promulgating a FIP, advocated that the EPA should issue a "SIP call" under CAA section 110(k)(5), asked for the EPA to issue new or more specific guidance, or otherwise suggested that the EPA should defer acting to promulgate a FIP at this time.

Response: As an initial matter, comments regarding the EPA's basis for disapproving SIPs are beyond the scope of this action.⁶⁸ To the extent these comments relate to the legal basis for the EPA to promulgate a FIP, the EPA disagrees that it is acting in a manner contrary to the memoranda it released in 2018 related to good neighbor obligations for the 2015 ozone NAAQS. Arguments that the EPA must or should allow states to re-submit SIP submissions based on the most recent modeling information before the EPA promulgates a FIP ignore the plain language of the statute and relevant caselaw. CAA section 110(c) authorizes the EPA to promulgate a FIP "at any time within 2 years" of a SIP disapproval. No provision of the Act requires the EPA to give states an additional opportunity to prepare a new SIP submittal once the EPA has proposed a FIP or proposed disapproval of a SIP submittal. Comments regarding the timing of the EPA's actions and calls

⁶⁸ We nonetheless further respond to comments regarding the timing and sequence of the EPA's SIP and FIP actions, the relevance of judicial consent decrees, the requests for a SIP call, and related comments—to the extent any of these issues are within scope of the present action—in Sections 1 and 2 of the *RTC* document located in the docket for this action.

for the EPA to allow time for states to resubmit SIPs are further addressed in *RTC* sections 1.1 and 2.4.

With regard to the need for the EPA to develop and issue guidance in addressing good neighbor obligations, in *EPA v. EME Homer City Generation, L.P.*, the Supreme Court held that "nothing in the statute places the EPA under an obligation to provide specific metrics to States before they undertake to fulfill their good neighbor obligations."⁶⁹ While we have taken a different approach in some prior rulemakings by providing states with an opportunity to submit a SIP after we quantified the states' budgets (e.g., the NO_x SIP Call and CAIR⁷⁰), the CAA does not require such an approach.

2018 Memoranda. As commenters point out, the EPA issued three "memoranda" in 2018 to provide some assistance to states in developing these SIP submittals.⁷¹ Each memorandum made clear that the EPA's action on SIP submissions would be through a separate notice-and-comment rulemaking process and that SIP submissions seeking to rely on or take advantage of any so-called "flexibilities" in these memoranda would be carefully reviewed against the relevant legal requirements and technical information available to the EPA at the time it would take such rulemaking action. Further, certain aspects of discussions in those memoranda were specifically identified as not constituting agency guidance (especially Attachment A to the March

⁶⁹ 572 U.S. 489, 510 (2014). "Nothing in the Act differentiates the Good Neighbor Provision from the several other matters a State must address in its SIP. Rather, the statute speaks without reservation: Once a NAAQS has been issued, a State 'shall' propose a SIP within three years, § 7410(a)(1), and that SIP 'shall' include, among other components, provisions adequate to satisfy the Good Neighbor Provision, § 7410(a)(2)." *EPA v. EME Homer City Generation, L.P.*, 572 U.S. at 515.

⁷⁰ For information on the NO_x SIP call see 63 FR 57356 (October 27, 1998). For information on CAIR see 70 FR 25162 (May 12, 2005).

⁷¹ See Information on the Interstate Transport State Implementation Plan Submissions for the 2015 Ozone National Ambient Air Quality Standards under Clean Air Act Section 110(a)(2)(D)(i)(I) (March 27, 2018) ("March 2018 memorandum"); Analysis of Contribution Thresholds for Use in Clean Air Act Section 110(a)(2)(D)(i)(I) Interstate Transport State Implementation Plan Submissions for the 2015 Ozone National Ambient Air Quality Standards, August 31, 2018 ("August 2018 memorandum"); Considerations for Identifying Maintenance Receptors for Use in Clean Air Act Section 110(a)(2)(D)(i)(I) Interstate Transport State Implementation Plan Submissions for the 2015 Ozone National Ambient Air Quality Standards, October 19, 2018 ("October 2018 memorandum"). These are available in the docket or at <https://www.epa.gov/airmarkets/memo-and-supplemental-information-regarding-interstate-transport-sips-2015-ozone-naaqs>.

2018 memorandum, which comprised an unvetted list of external stakeholders' ideas). And, although outside the scope of this action, as the EPA has explained in disapproving states' SIP submittals, those submittals did not meet the terms of the August 2018 or October 2018 memoranda addressing contribution thresholds and maintenance receptors, respectively.

Commenters mistakenly view Attachment A to the March 2018 memorandum as constituting agency guidance. This memorandum was primarily issued to share modeling results for 2023 that represented the best information available to the Agency as of March 2018, while Attachment A then listed certain ideas from certain stakeholders that the EPA said could be further discussed among states and stakeholders. The EPA disagrees with commenters' characterization of the EPA's stance regarding these so-called "flexibilities" listed (without analysis) in Attachment A. The March 2018 memorandum provided, "While the information in this memorandum and the associated air quality analysis data could be used to inform the development of these SIPs, the information is not a final determination regarding states' obligations under the good neighbor provision." The EPA again affirms that the concepts listed in Attachment A to the March 2018 memorandum require unique consideration, and these ideas do not constitute agency guidance with respect to transport obligations for the 2015 ozone NAAQS. Attachment A to the March 2018 memorandum identified a "Preliminary List of Potential Flexibilities" that could potentially inform SIP development. However, the EPA made clear in both the March 2018 memorandum⁷² and in Attachment A that the list of ideas was not endorsed by the Agency but rather "comments provided in various forums" on which the EPA sought "feedback from interested stakeholders."⁷³ Further, Attachment A stated, "EPA is not at this time making any determination that the ideas discussed below are consistent with the requirements of the CAA, nor are we specifically recommending that states use these approaches."⁷⁴ Attachment A to the March 2018 memorandum, therefore, does not

⁷² "In addition, the memorandum is accompanied by Attachment A, which provides a preliminary list of potential flexibilities in analytical approaches for developing a good neighbor SIP that may warrant further discussion between EPA and states." March 2018 memorandum at 1.

⁷³ March 2018 memorandum, Attachment A at A-1.

⁷⁴ *Id.*

constitute agency guidance, but was intended to generate further discussion around potential approaches to addressing ozone transport among interested stakeholders. The EPA emphasized in these memoranda that such alternative approaches must be technically justified and appropriate in light of the facts and circumstances of each particular state's submittal. To the extent states sought to develop or rely on one or more of these ideas in support of their SIP submissions, the EPA reviewed their technical and legal justifications for doing so.⁷⁵

Regarding the October 2018 memorandum, that document recognized that states may be able to demonstrate in their SIPs that conditions exist that would justify treating a monitoring site as not being a maintenance receptor despite results from our modeling methodology identifying it as such a receptor. The EPA explained that this demonstration could be appropriate under two circumstances: (1) the site currently has "clean data" indicating attainment of the 2015 ozone NAAQS based on measured air quality concentrations, or (2) the state believes there is a technical reason to justify using a design value from the baseline period that is lower than the maximum design value based on monitored data during the same baseline period. To justify such an approach, the EPA anticipated that any such showing would be based on an analytical demonstration that (1) meteorological conditions in the area of the monitoring site were conducive to ozone formation during the period of clean data or during the alternative base period design value used for projections; (2) ozone concentrations have been trending downward at the site since 2011 (and ozone precursor emissions of NO_x and VOC have also decreased); and (3) emissions are expected to continue to decline in the upwind and downwind states out to the attainment date of the receptor. Although this is beyond the scope of this action, the EPA explained in its final SIP disapproval action that no state successfully demonstrated that one of these alternative approaches is justified. In this action, our analysis of the air quality data and projections in section IV of this document indicate that trends in historic measured data do not necessarily support adopting a less

stringent approach for identifying maintenance receptors for purposes of the 2015 ozone NAAQS. In fact, as explained in section III.B.1.a and IV.D of this document, the EPA has found in its analysis for this final rule that, in general, recent measured data from regulatory ambient air quality ozone monitoring sites suggest that a number of receptors with elevated ozone levels will persist in 2023 even though our traditional methodology at Step 1 did not identify these monitoring sites as receptors in 2023. Thus, the EPA is not acting inconsistently with that memorandum—the factual conditions that would need to exist for the suggested approaches of that memorandum to be applicable have not been demonstrated as being applicable or appropriate based on the relevant data.

Regarding the August 2018 memorandum, as discussed in section IV.F.2 of this document, for purposes of Step 2 of our ozone transport evaluation framework, we are applying a 1 percent of NAAQS threshold rather than a 1 ppb threshold, as this memorandum had suggested might be appropriate for states to apply as an alternative. The EPA is finalizing its proposed approach of consistently using a 1 percent of the NAAQS contribution threshold at Step 2 to evaluate whether states are linked to downwind nonattainment and maintenance concerns for purposes of this FIP.

The approach of this FIP ensures both national consistency across all states and consistency and continuity with our prior interstate transport actions for other NAAQS. Further, in this action the EPA is promulgating FIPs under the authority of CAA section 110(c). In doing so, the EPA has exercised its discretion to determine how to define and apply good neighbor obligations in place of the discretion states otherwise would exercise (subject to the EPA's approval as compliant with the Act). In general, the EPA is applying the 4-step interstate transport framework it devised over the course of its prior good neighbor rulemakings, including applying a consistent definition of nonattainment and maintenance-only receptors, and applying the 1 percent of NAAQS threshold at Step 2. The basis for these decisions is further explained in sections IV.F.1 and IV.F.2 of the document. These policy judgments reflect consistency with relevant good neighbor case law and past agency practice implementing the good neighbor provision as reflected in the original CSAPR, CSAPR Update, Revised CSAPR Update, and related rulemakings. Nationwide consistency in

approach is particularly important in the context of interstate ozone transport, which is a regional-scale pollution problem involving the collective emissions of many smaller contributors. Effective policy solutions to the problem of interstate ozone transport dating back to the NO_x SIP Call (63 FR 57356 (October 27, 1998)) have necessitated the application of a uniform framework of policy judgments, and the EPA's framework applied here has been upheld as ensuring an "efficient and equitable" approach. See *EME Homer City Generation, LP v. EPA*, 572 U.S. 489, 519 (2014).

Updated modeling. The EPA had originally provided 2023 modeling results in its March 2018 memorandum, which used a 2011-based platform. Many states used this modeling in providing good neighbor SIP submittals for the 2015 ozone NAAQS. While our action on the SIP submittals is not within scope of this action, commenters claim the use of new modeling or other information not available to states at the time they made their submittals renders this action promulgating a FIP unlawful. Notwithstanding whether that is an accurate characterization of the EPA's basis for disapproving the SIPs, we note that the court in *Wisconsin* rejected this precise argument against the CSAPR Update FIPs as a collateral attack on the SIP disapprovals. 938 F.3d at 336 ("That is the hallmark of an improper collateral attack. The true gravamen of the claim lies in the agency's failure to timely act upon the States' SIP submissions and, relatedly, its reliance on data compiled after the SIP action deadline. Both go directly to the legitimacy of the SIP denials.").

Nonetheless, we offer the following explanation of the evolution of the EPA's understanding of projected air quality conditions and contributions in 2023 resulting from the iterative nature of our modeling efforts. These modeling efforts are further addressed in section IV of this document. We acknowledge that to evaluate transport SIPs and support our proposed FIP the EPA reassessed receptors at Step 1 and states' contribution levels at Step 2 through additional modeling (2016v2) before proposing this action and have reassessed again to inform the final action (2016v3). At proposal, we relied on CAMx Version 7.10 and the 2016v2 emissions platform to make updated determinations regarding which receptors would likely exist in 2023 and which states are projected to contribute above the contribution threshold to those receptors. As explained in the preamble of the EPA's proposed FIP and further detailed in the "Air Quality

⁷⁵ E.g., 87 FR 64423–64425 (Alabama); 87 FR 31453–31454 (California); 87 FR 9852–9854 (Illinois); 87 FR 9859–9860 (Indiana); 87 FR 9508, 9515 (Kentucky); 87 FR 9861–9862 (Michigan); 87 FR 9869–9870 (Ohio); 87 FR 9798, 9818–9820 (Oklahoma); 87 FR 31477–31481 (Utah); 87 FR 9526–9527 (West Virginia).

Modeling Technical Support Document for the Federal Implementation Plan Addressing Regional Ozone Transport for the 2015 Ozone National Ambient Air Quality Standards Proposed Rulemaking” (Dec. 2021), hereinafter referred to as Air Quality Modeling Proposed Rule TSD, and the “Technical Support Document (TSD): Preparation of Emissions Inventories for the 2016v2 North American Emissions Modeling Platform” (Dec. 2021), hereinafter referred to as the 2016v2 Emissions Inventory TSD, both available in the docket for this action (docket ID no. EPA-HQ-OAR-2021-0668), this modeling built off of previous modeling iterations used to support the EPA’s action on interstate transport obligations. The EPA periodically refines its modeling to ensure the results are as indicative as possible of air quality in future years. This includes making any necessary adjustments to our modeling platform and updating our emissions inventories to reflect current information, including information submitted during public comments on proposed actions.

For this final rule, the EPA has evaluated a raft of technical information and critiques of its 2016v2 modeling provided by commenters on this action (as well as comments on the SIP actions) and has responded to those comments and incorporated updates into the version of the modeling used to support this final rule (2016v3). As explained in section IV.B of the document, in response to additional information provided by stakeholders following a solicitation of feedback during the release of the 2016v2 emissions inventory and during the comment periods on the proposed SIP actions, the EPA has reviewed and revised its 2016v2 modeling platform and input since the platform was made available for comment. The new modeling platform 2016v3 was developed from this input, and the modeling results using platform 2016v3 are available with this action. See section IV of this document for further discussion. Thus, the EPA’s final rule is based on a comprehensive record of data and technical evaluation, including the updated modeling information used at proposal (2016v2), the comments received on that modeling, and the latest modeling used in this final rule (2016v3).

The changes in projected outcomes at Steps 1 and 2 are a product of these changes; these updates between the data released in 2018 to now are an outgrowth of this iterative process, including updating the platform from a 2011 to a 2016 base year, updates to the

emissions inventory information and other updates. It is reasonable for the Agency to improve its understanding of a situation before taking final action, and the Agency uses the best information available to it in taking this action.

Further, these modeling updates have not uniformly resulted in new linkages—the 2016v2 modeling, for instance, corroborated the proposed approval of Montana and supported approval of Colorado’s SIP in October of 2022.⁷⁶ Although some commenters indicate that our modeling iterations have provided differing outcomes and are therefore unreliable, this is not what the overall record indicates. Rather, in general, although the specifics of states’ linkages may have changed to some extent, our modeling on the whole has provided consistent outcomes regarding which states are linked to downwind air quality problems. For example, the EPA’s modeling shows that most states that were linked to one or more receptors using the 2011-based platform (*i.e.*, the March 2018 data release) are also linked to one or more receptors using the newer 2016-based platform. Because the new platform uses different meteorology (*i.e.*, 2016 instead of 2011), it is not unexpected that an upwind state would be linked to different receptors using 2011 versus 2016 meteorology. In addition, although a state may be linked to a different set of receptors, those receptors are within the same areas that have historically had a persistent air quality problem. Only three upwind states included in the FIP went from being unlinked to being linked in 2023 between the 2011-based modeling provided in the March 2018 memorandum and the 2016v3-based modeling—Alabama, Minnesota, and Nevada.

Additionally, we disagree with commenters who claim that the 2016v2 modeling results were sprung upon the states with the publication of the proposed SIP disapprovals. In fact, states had prior access to a series of data and modeling releases beginning as early as the publication of the 2016v1 modeling with the proposed Revised CSAPR Update in October 2020. States could have reviewed and used this technical information to understand and track how the EPA’s modeling updates were affecting the list of potential receptors and linkages for the 2015 ozone NAAQS in the 2023 analytic year.

⁷⁶ 87 FR 6095, 6097 at n. 15 (February 3, 2022) (Montana proposal); 87 FR 27050, 27056 (May 6, 2022) (Colorado, proposal); 87 FR 61249 (October 11, 2022) (Colorado, final).

The 2016-based meteorology and boundary conditions used in the modeling have been available through the 2016v1 platform, which was used for the Revised CSAPR Update (proposed, 85 FR 68964; October 30, 2020). The updated emissions inventory files used in the current modeling were publicly released September 21, 2021, for stakeholder feedback, and have been available on our website since that time.⁷⁷ The CAMx modeling software that the EPA used has likewise been publicly available for over a year before this final rule was proposed on April 6, 2022. CAMx version 7.10 was released by the model developer, Ramboll, in December 2020. On January 19, 2022, we released on our website and notified a wide range of stakeholders of the availability of both the modeling results for 2023 and 2026 (including contribution data) along with many key underlying input files.⁷⁸

By providing the 2016 meteorology and boundary conditions (used in the 2016v1 version) in fall of 2020, and by releasing updated emissions inventory information used in 2016v2 in September of 2021,⁷⁹ we gave states and other interested parties multiple opportunities prior to proposal of this rule on April 6, 2022, to consider how our modeling updates could affect their status for purposes of evaluating potential linkages for the 2015 ozone NAAQS. In this final rule, we have updated our modeling to 2016v3, incorporating and reflecting the feedback and additional information we received through the multiple public comment opportunities the EPA made available on the 2016v2 modeling.

The EPA’s development of and reliance on newer modeling is reasonable and is simply another iteration of the EPA’s longstanding scientific and technical work to improve our understanding of air quality issues and causes going back many decades.

Comment: Commenters asserted that the EPA lacks authority under the good neighbor provision to do more than establish state-wide emissions budgets, which states may then implement through their own choice of emissions controls. The commenters claim that the EPA lacks authority to directly regulate emissions sources under the good neighbor provision, and they cite to case law that they view as establishing a “federalism bar” to direct Federal regulation. Commenters assert that the

⁷⁷ See <https://www.epa.gov/air-emissions-modeling/2016v2-platform>.

⁷⁸ See <https://www.epa.gov/scram/photochemical-modeling-applications>.

⁷⁹ <https://www.epa.gov/air-emissions-modeling/2016v2-platform>.

term “amounts” as used in the good neighbor provision prevents the agency from establishing emissions limits at individual sources, such as the non-EGU industrial units that the EPA proposed to regulate or implementing “enhancements” in its mass-based emissions trading approach for EGUs as it had proposed. Commenters claim these aspects of the rule are an unlawful or arbitrary and capricious departure from the EPA’s prior transport rulemakings, which they claim only set mass-based emissions budgets as the means to eliminate “significant contribution.”

Response: To the extent these comments challenge the EPA’s disapproval of states’ 2015 ozone NAAQS good neighbor SIP submissions, they are out of scope of this action, which promulgates a FIP under the authority of CAA section 110(c)(1). To the extent commenters assert that the EPA does not have the authority to directly implement source-specific emissions control requirements or other emissions control measures, means, or techniques, including emissions trading programs, in the exercise of that FIP authority, the EPA disagrees. While the courts have long recognized that the states have wide discretion in the design of SIPs to attain and maintain the NAAQS, *see, e.g., Union Electric Co v. EPA*, 427 U.S. 246 (1976), when the EPA promulgates a FIP to cure a defective SIP, the Act, including the definition of a FIP in section 302(y), provides for the EPA to directly implement the Act’s requirements. The EPA is granted authority to choose among a broad range of “emission limitations or other control measures, means, or techniques (including economic incentives, such as marketable permits or auctions of emissions allowances)” CAA section 302(y); *see also* CAA section 110(a)(2) (empowering states to implement an identical set of emissions control mechanisms).

The courts have also recognized that the EPA has broad authority to cure a defective SIP, that the EPA may exercise its own, independent regulatory authority in implementing a FIP in accordance with the CAA, and that the EPA in effect steps into the shoes of a state when it promulgates a FIP. *See, e.g., Central Ariz. Water Conservation Dist. v. EPA*, 990 F.2d 1531 (9th Cir. 1993); *South Terminal Corp. v. EPA*, 504 F.2d 646 (1st Cir. 1974). *Accord Virginia v. EPA*, 108 F.3d 1397, 1406–07 (D.C. Cir. 1997) (“The Federal Plan ‘provides an additional incentive for state compliance because it rescinds state authority to make the many sensitive and policy choices that a

pollution control regime demands.’”) (quoting *Natural Resources Defense Council v. Browner*, 57 F.3d 1122, 1124 (D.C. Cir. 1995)). *Cf. District of Columbia v. Train*, 521 F.2d 971 (D.C. Cir. 1975), *vacated sub nom. EPA v. Brown*, 431 U.S. 99 (1977) (“[W]here cooperation [from states] is not forthcoming, we believe that the recourse contemplated by the commerce clause is direct federal regulation of the offending activity”).

These same principles apply where the EPA must promulgate a FIP to address good neighbor requirements under CAA section 110(a)(2)(D)(i)(I). The EPA has promulgated a series of FIPs in the past to address the relevant requirements for prior ozone and PM NAAQS. *See, e.g.,* CAIR FIP, 71 FR 25328 (April 28, 2006); CSAPR, 76 FR 48208 (August 8, 2011); the CSAPR Update, 81 FR 74504 (October 26, 2016); and the Revised CSAPR Update, 86 FR 23054 (April 30, 2021). Courts have upheld the EPA’s exercise of this authority. *See EME Homer City Generation v. EPA*, 572 U.S. 489 (2014); *Wisconsin v. EPA*, 938 F.3d 303 (D.C. Cir. 2019). Indeed, in *EME Homer City*, the U.S. Supreme Court held that the EPA is not obligated to provide guidance to states before acting on their good neighbor submissions or give states a second chance at correcting the deficiencies before promulgating a FIP, and the EPA may promulgate a FIP at any time after finalizing its disapproval of SIP submissions. 572 U.S. at 508–11.

The cases cited by commenters, which they refer to as establishing the *Train-Virginia* federalism bar, were not reviewing the exercise of the EPA’s authority in promulgating a FIP under CAA section 110(c)(1) but rather were describing the scope of the EPA’s authority in acting on SIP submissions under CAA section 110(k)(3) or in issuing a “SIP call” under section 110(k)(5). In those latter contexts, the courts have held that the EPA may not dictate the specific control measures states must implement to meet the Act’s requirements. *See Virginia*, 108 F.3d at 1409–10. In *Michigan*, the D.C. Circuit upheld the EPA’s exercise of CAA section 110(k)(5) authority in issuing the “NO_x SIP Call,” because, “EPA does not tell the states how to achieve SIP compliance. Rather, EPA looks to section 110(a)(2)(D) and merely provides the levels to be achieved by state-determined compliance mechanisms. . . . However, EPA made clear that states do not have to adopt the control scheme that EPA assumed for budget-setting purposes.” *Michigan v. EPA*, 213 F.3d 663, 687–88 (D.C. Cir. 2000).

Commenters’ position that the EPA must provide similar flexibility to the states in this action (*i.e.*, only provide a general emissions reduction target and leave to states how to meet that target) is a non sequitur. The EPA is implementing a FIP in this action and *must* directly implement the necessary emissions controls. The EPA is not empowered to require states to implement FIP mandates. Such an approach would conflict with constitutional anti-commandeering principles, is not provided for in the Act, and would only constitute a partial implementation of FIP obligations in contravention of the holding in *Wisconsin v. EPA*, 938 F.3d at 313–20.

Commenters’ attempt to contrast the implementation of source-specific emissions limitations at industrial sources with the establishment of a specific mass-based budget (as the EPA has set for power plants in prior good neighbor FIPs) is unavailing. CAA section 110(c)(1) and 302(y) authorize the EPA in promulgating a FIP to establish “enforceable emission limitations” in addition to other types of control measures like mass-based trading programs. Further, in this action, the EPA has developed an emissions control strategy that prohibits the “amount” of pollution that significantly contributes to nonattainment and/or interferes with maintenance. We determine that amount, as we have in prior transport actions, at Step 3 of the analysis, by applying a multifactor analysis that includes considering cost and downwind air quality effects. *See* section V.A of this document. With the implementation of the selected controls (at Step 4) through both an emissions trading program for power plants and source-specific emissions limitations for industrial sources, those “amounts” that had been emitted prior to imposition of the controls will be eliminated.

The Act does not mandate that the EPA must set a specific mass-based budget for each state to eliminate significant contribution based on the use of the term “amounts” in CAA section 110(a)(2)(D)(i). As the Supreme Court recognized, the statute “requires States to eliminate those ‘amounts’ of pollution that ‘contribute significantly to nonattainment’ in downwind States,” and it delegates to states or EPA acting in their stead discretion to determine *how* to apportion responsibility among those upwind states. 572 U.S. at 514 (emphasis added). The statute does not define the term “amount” in the way commenters suggest (or in any other way), and neither the Agency nor any court has reached that conclusion. The

Supreme Court itself has recognized that the language of the good neighbor provision is amenable to different types of metrics for quantification of “significant contribution.” See *EME Homer City Generation, L.P.*, 572 U.S. at 514 (“How is EPA to divide responsibility among the . . . States? Should the Agency allocate reductions proportionally . . . , on a per capita basis, on the basis of the cost of abatement, or by some other metric? . . . The Good Neighbor Provision does not answer that question for EPA.”); see also *Michigan v. EPA*, 213 F.3d 663, 677 D.C. Cir. 2000 (“Nothing in the text of . . . the statute spells out a criterion for classifying ‘emissions activity’ as ‘significant.’”); *id.* at 677 (“Must EPA simply pick some flat ‘amount’ of contribution . . . ?”). When the State of Delaware petitioned the Agency under CAA section 126(b) to establish daily emissions rates for EGUs to remedy what it saw as continuing violations of the good neighbor provision for the 2008 ozone NAAQS, neither the EPA nor the reviewing court questioned whether the Agency had the statutory authority to do so. The EPA’s decision not to was upheld on record grounds. See *Maryland v. EPA*, 958 F.3d 1185, 1207 D.C. Cir. 2020 (“In other words, Delaware’s concern makes sense but has not been observed in practice.”).⁸⁰

The term “amounts” can be interpreted to refer to any number of metrics, and in fact the CAA uses the term in several contexts where it is clear Congress did not intend the term to refer to a fixed, mass-based quantity of emissions. For example, in the definition of “lowest achievable emission rate” (LAER) in CAA section 171, the Act provides that the application of LAER shall not permit a proposed new or modified source to emit any pollutant in excess of “the amount allowable under applicable new source standards of performance [NSPS].” NSPS may be, and usually are, set as emissions standards or limitations that are rate- or concentration-based. See, e.g., 40 CFR part 60, subpart KKKK, table I (establishing concentration-based and rate-based emissions limits for stationary combustion turbines).⁸¹ Congress has elsewhere used the term “amount” in the CAA to refer to

concentration-based standards. For example, in CAA section 163(b), Congress provided that maximum allowable increases in concentrations of certain pollutants “shall not exceed the following amounts,” with a list of allowable increases provided that are expressed in micrograms per cubic meter.⁸² As a third example, in the 1990 CAA Amendments, Congress provided that ozone nonattainment areas classified as Serious must provide a reasonable further progress demonstration of reductions in VOC emissions “equal to the following amount,” which is then described as a percentage reduction from baseline emissions. CAA section 182(c)(2)(B). These examples illustrate that the word “amounts” is amenable to a variety of meanings depending on what is being measured or quantified. It would therefore be highly unlikely that Congress could have intended that “amount” as used in the good neighbor provision must signify only a fixed mass budget of emissions for each state expressed as total tons per ozone season.

Such an approach would, in fact, fail to address an important aspect of the problem of interstate transport. As explained in sections III.B.1.d, V.D.4, and VI.B.1, the EPA in this rule seeks to better address the need for emissions reductions on each day of the ozone season, reflecting the daily, but unpredictably recurring, nature of the air pollution problem, short-term health impacts, and the form of the 2015 ozone NAAQS, wherein nonattainment for downwind areas (and thus heightened regulatory requirements) could be based on ozone exceedances on just a few days of the year. The expression of the “amount” of pollution that should be eliminated to address upwind states’ “significant contribution” to that type of air pollution problem may appropriately take into account those aspects of the problem, and the EPA may appropriately conclude, as we do here, that a single, fixed, emissions budget covering an entire ozone season is not sufficient to the task at hand.

In this action, the EPA reasonably applies the good neighbor provision, including the term “amount,” through the 4-step interstate transport framework. Under this approach, the EPA here, as it has in prior transport rulemakings for regional pollutants like

ozone, identifies a uniform level of emissions reduction that the covered sources in the linked upwind states can achieve that cost-effectively delivers improvement in air quality at downwind receptors on a regional scale. The “amount” of pollution that is identified for elimination at Step 3 of the framework is therefore that amount of emissions that is in excess of the emissions control strategies the EPA has deemed cost-effective. Contrary to commenters’ views, in prior transport rules utilizing emissions trading, the mass budgets through which the elimination of significant contribution was effectuated did not constitute the “amounts” to be eliminated but rather the residual emissions remaining following the elimination of significant contribution through the control stringency selected based on our multifactor assessment at Step 3. Nor did the EPA consider a mass-based budget to be the sole expression, even indirectly, of what constituted “significant contribution.” See, e.g., CSAPR, 76 FR 48256–57 (discussing the evaluation of the control strategies that would eliminate significant contribution for the 1997 ozone NAAQS, including combustion controls, and explaining, “[I]t would be inappropriate for a state linked to downwind nonattainment or maintenance areas to stop operating existing pollution control equipment (which would increase their emissions and contribution).”).

In other actions the EPA has taken to implement good neighbor obligations, the EPA has required or allowed for reliance on source-specific emissions limitations rather than defining significant contribution as a mass-based budget. For example, the EPA imposed unit-specific emissions limitations in granting a CAA section 126(b) petition from the State of New Jersey in 2011. Final Response to Petition From New Jersey Regarding SO₂ Emissions From the Portland Generating Station, 76 FR 69052, 69063–64 (Nov. 7, 2011) (discussing the analytical basis for the establishment of emissions limits at specific units). This action was upheld by the Third Circuit in *Genon Rema LLC v. EPA*, 722 F.3d 513, 526 (3d. Cir. 2013).⁸³

⁸³ In CAA section 126(c), Congress provided for the EPA to directly impose “emission limitations” to eliminate prohibited significant contribution. Notably, the statute affords the EPA and states flexibility in how an “emissions limitation” may be expressed, including as a “quantity, rate, or concentration,” see CAA section 302(k). It would make little sense that the EPA could only establish a mass-based definition of “amounts” under CAA section 110(a)(2)(D)(i)(I), when the statute provides for rate- or concentration-based limitations in CAA section 126, which directly incorporates

⁸⁰ The Agency’s view of the basis for backstop daily emissions rates for certain EGUs within the trading program has changed since the time of its action on Delaware’s petition, as explained in section VI.B.

⁸¹ The EPA has interpreted the term “amount” as used in CAA section 111(a)(4) in the definition of the term “modifications” as an increase in a rate of emissions expressed as kilograms per hour. 40 CFR 60.14(b).

⁸² Notably, both the provisions of CAA section 171 and section 163 given as examples here were added by the CAA Amendments of 1977, in the same set of amendments that Congress first strengthened the good neighbor provision and added the term “amounts.” See Public Law 95–95, 91 Stat. 685, 693, 732, 746.

Even where the EPA has provided for implementation of good neighbor requirements through mass-based budgets, it has recognized that other approaches may be acceptable as providing an equivalent degree of emissions reduction to eliminate significant contribution. *See, e.g.*, NO_x SIP Call, 63 FR 57378–79 (discussing approvability of rate-based emissions limit approaches for implementing NO_x SIP Call and providing, “the 2007 overall budget is an important accounting tool. However, the State is not required to demonstrate that it has limited its total NO_x emissions to the budget amounts. Thus, the overall budget amount is not an independently enforceable requirement.”); CAIR, 70 FR 25261–62 (discussing ways states could implement CAIR obligations, including through emission-rate limitations, so long as adequately demonstrated to achieve comparable reductions to CAIR’s emissions budgets).

Finally, as it has in its prior transport FIP actions, the EPA has in this action provided guidance for states on methods by which they could replace this FIP with SIPs, and in so doing, continues to recognize substantial state flexibility in achieving an equivalent degree of emissions reduction that would successfully eliminate significant contribution for the 2015 ozone NAAQS. *See* section VI.D of this document. While the EPA has exercised the responsibility it has under CAA section 110(c)(1) to step into the shoes of the covered states and directly implement good neighbor requirements through a particular set of regulatory mechanisms in this action, we anticipate that states may identify alternative, equivalent mechanisms that we would be bound to evaluate and approve if satisfactory, should states seek to replace this FIP with a SIP.

For these reasons, the EPA disagrees with the contention that it is constrained by the good neighbor provision to define upwind state obligations solely by reference to a fixed, mass budget. We find it reasonable in this action to again determine the amount of “significant contribution” at Step 3 by reference to uniform levels of cost-effective emissions controls that can be applied across the upwind sources. And, we find it appropriate to implement those emissions reductions at Step 4 through

mechanisms that go beyond fixed, mass-based, ozone-season long budgets.

The EPA’s authority for its industrial source control strategies is further discussed in sections II.C. and III.B.1.c of this document. The relationship of the control strategy to the assessment of overcontrol is discussed in section V.D.4 of this document. The relationship of our FIP authority to state authorities and SIP calls under CAA section 110(k)(5) is further discussed in *RTC* sections 1 and 2.

a. Step 1 Approach

As proposed, the EPA applies the same basic method of the CSAPR Update and the Revised CSAPR Update for identifying nonattainment and maintenance receptors. However, we received comments arguing that the outcome of applying our methodology to identify receptors in 2023 appears overly optimistic in light of current measured data from the network of ambient air quality monitors across the country. These commenters suggest that the EPA give greater weight to current measured data as part of the method for identifying projected receptors. As discussed further in section IV.D of this document, the EPA has modified its approach for identifying receptors for this final rule in response to these comments.

This concern is more evident given that the 2023 ozone season is just a few months away, and the most recent measured ozone values in many areas strongly suggest that these areas will not likely see the substantial reduction in ozone levels that the 2016v2 and 2016v3 modeling continue to project.

It would not be reasonable to ignore recent measured ozone levels in many areas that are clearly not fully consistent with certain concentrations in the Step 1 analysis for 2023. Therefore, the EPA has developed an additional maintenance-only receptor category, which includes what we refer to as “violating monitor” receptors, based on current ozone concentrations measured by regulatory ambient air quality monitoring sites. We acknowledge that the traditional modeling plus monitoring methodology we used at proposal and in prior ozone transport rules would otherwise have identified such sites as being in attainment in 2023. Despite the implications of the current measured data suggesting there will be a nonattainment problem at these sites in 2023, we cannot definitively establish that such sites will be in nonattainment in 2023 in light of our modeling projections. In the face of this uncertainty, we regard our ability to consider such sites as receptors for

purposes of good neighbor analysis under CAA section 110(a)(2)(D)(i)(I) to be a function of the requirement to prohibit emissions that interfere with maintenance of the NAAQS; even if our transport modeling projects that an area may reach attainment in 2023, we have other information indicating that there is an identified risk that attainment will not in fact be achieved in 2023. The EPA’s analysis of these additional receptors further is explained in section IV.D of this document.

However, because we did not identify this basis for receptor-identification at proposal, in this final action we are only using this receptor category on a confirmatory basis. That is, for states that we find linked based on our traditional modeling-based methodology in 2023, we find in this final analysis that the linkage at Step 2 is strengthened and confirmed if that state is also linked to one or more “violating monitor” receptors. If a state is only linked to a violating-monitor receptor in this final analysis, we are deferring promulgating a final FIP (and we have also deferred taking final action on that state’s SIP submittal). This is the case for the State of Tennessee. Among the states that previously had their transport SIPs fully approved for the 2015 ozone NAAQS, the EPA has also identified a linkage to violating-monitor receptors for the State of Kansas. The EPA intends to further review its air quality modeling results and recent measured ozone levels, and we intend to address these states’ good neighbor obligations as expeditiously as practicable in a future action.

b. Step 2 Approach

The EPA applies the same approach for identifying which states are contributing to downwind nonattainment and maintenance receptors as it has applied in the three prior CSAPR rulemakings. CSAPR, the CSAPR Update, and the Revised CSAPR Update used a screening threshold of 1 percent of the NAAQS to identify upwind states that were “linked” to downwind air pollution problems. States with contributions greater than or equal to the threshold for at least one downwind nonattainment or maintenance receptor identified in Step 1 were identified in these rules as needing further evaluation of their good neighbor obligations to downwind states at Step 3.⁸⁴ The EPA evaluated each state’s contribution based on the average relative downwind impact calculated

⁸⁴ For ozone, the impacts include those from VOC and NO_x from all sectors.

110(a)(2)(D)(i)(I). (In observing this, we do not concede that an “emissions limitation” itself could not also be expressed through a mass-based approach, which may be read as authorized by the term “quantity,” a term also used in CAA section 302(k).)

over multiple days.⁸⁵ States whose air quality impacts to all downwind receptors were below this threshold did not require further evaluation for measures to address transport. In other words, the EPA determined that these states did not contribute to downwind air quality problems and therefore had no emissions reduction obligations under the good neighbor provision. The EPA applies a relatively low contribution screening threshold because many downwind ozone nonattainment and maintenance receptors receive transport contributions from multiple upwind states. While the proportion of contribution from a single upwind state may be relatively small, the effect of collective contribution resulting from multiple upwind states may substantially contribute to nonattainment of or interference with maintenance of the NAAQS in downwind areas. The preambles to the proposed and final CSAPR rules discuss the use of the 1 percent threshold for CSAPR. *See* 75 FR 45237 (August 2, 2010); 76 FR 48238 (August 8, 2011). The same metric is discussed in the CSAPR Update, *see* 81 FR 74538, and in the Revised CSAPR Update, *see* 86 FR 23054. In this final rule, the EPA has updated the air quality modeling data used for determining contributions at Step 2 of the 4-step interstate transport framework using the 2016v3 modeling platform. The EPA continues to find that this threshold is appropriate to apply for the 2015 ozone NAAQS. This rule's application of the Step 2 approach is comprehensively described in section IV of this document.

Many commenters challenged the use of a 1 percent of NAAQS threshold or otherwise raised issues with the EPA's Step 2 methodology. These comments are addressed in section IV.F of this document and in the *RTC* document.

⁸⁵ The number of days used in calculating the average contribution metric has historically been determined in a manner that is generally consistent with the EPA's recommendations for projecting future year ozone design values. Our ozone attainment demonstration modeling guidance at the time of CSAPR recommended using all model-predicted days above the NAAQS to calculate future year design values (<https://www3.epa.gov/ttn/scram/guidance/guide/final-03-pm-rh-guidance.pdf>). In 2014, the EPA issued draft revised guidance that changed the recommended number of days to the top-10 model predicted days (https://www3.epa.gov/ttn/scram/guidance/guide/Draft-O3-PM-RH-Modeling_Guidance-2014.pdf). For the CSAPR Update, the EPA transitioned to calculating design values based on this draft revised approach. The revised modeling guidance was finalized in 2019 and, in this regard, the EPA is calculating both the ozone design values and the contributions based on a top-10 day approach (https://www3.epa.gov/ttn/scram/guidance/guide/O3-PM-RH-Modeling_Guidance-2018.pdf).

c. Step 3 Approach

The EPA continues to apply the same approach as the prior three CSAPR rulemakings for evaluating "significant contribution" at Step 3.⁸⁶ For states that are linked at Step 2 to downwind air quality problems, CSAPR, the CSAPR Update, and the Revised CSAPR Update evaluated NO_x reduction potential, cost, and downwind air quality improvements available at various mitigation technology breakpoints (represented by cost thresholds) in the multi-factor test. In CSAPR, the CSAPR Update, and the Revised CSAPR Update, the EPA selected the technology breakpoint (represented by a cost threshold) that, in general, maximized cost-effectiveness—*i.e.*, that achieved a reasonable balance of incremental NO_x reduction potential and corresponding downwind ozone air quality improvements, relative to the other emissions budget levels evaluated. *See, e.g.*, 81 FR 74550. The EPA determined the level of emissions reductions associated with that level of control stringency to constitute significant contribution to nonattainment or interfere with maintenance of a NAAQS downwind. *See, e.g.*, 86 FR 23116. This approach was upheld by the U.S. Supreme Court in *EPA v. EME Homer City*.⁸⁷

In this action, the EPA applies this approach to identify EGU and non-EGU NO_x control stringencies necessary to address significant contribution for the 2015 ozone NAAQS. The EPA applies a multifactor assessment using cost-thresholds, total emissions reduction potential, and downwind air quality effects as key factors in determining a reasonable balance of NO_x controls in light of the downwind air quality problems. The EPA's evaluation of available NO_x mitigation strategies for EGUs focuses on the same core set of measures as prior transport rules, and

⁸⁶ For simplicity, the EPA (and courts) at times will refer to the Step 3 analysis as determining "significant contribution"; however, the EPA's approach at Step 3 also implements the "interference with maintenance" prong of the good neighbor provision by also addressing emissions that impact the maintenance receptors identified at Step 1. *See* 86 FR 23074 ("In effect, EPA's determination of what level of upwind contribution constitutes 'interference' with a maintenance receptor is the same determination as what constitutes 'significant contribution' for a nonattainment receptor. Nonetheless, this continues to give independent effect to prong 2 because the EPA applies a broader definition for identifying maintenance receptors, which accounts for the possibility of problems maintaining the NAAQS under realistic potential future conditions."). *See also EME Homer City*, 795 F.3d 118, 136 (upholding this approach to prong 2).

⁸⁷ *EPA v. EME Homer City Generation, L.P.*, 572 U.S. 489 (2014).

the EPA finalizes a control stringency for EGUs from these measures that is commensurate with the nature of the ongoing ozone nonattainment and maintenance problems observed for the 2015 ozone NAAQS. Similarly, in this action, the EPA includes other industrial sources (non-EGUs) in its Step 3 analysis and finalizes emissions limitations for certain non-EGU sources as needed to eliminate significant contribution and interference with maintenance. The available reductions and cost-levels for the non-EGU stringency is commensurate with the control strategy for EGUs.

In CSAPR, the CSAPR Update, and the Revised CSAPR Update, the EPA focused its Step 3 analysis on EGUs. In the Revised CSAPR Update, in response to the *Wisconsin* decision's finding that the EPA had not adequately evaluated potential non-EGU reductions, *see* 938 F.3d at 318, the EPA determined that the available NO_x emissions reductions from non-EGU sources, for purposes of addressing good neighbor obligations for the 2008 ozone NAAQS, at a comparable cost threshold to the required EGU emissions reductions (for which the EPA used an adjusted representative cost of \$1,800 per ton), and based on the timing of when such measures could be implemented, did not provide a sufficiently meaningful and timely air quality improvement at the downwind receptors before those receptors were projected to resolve. *See* 86 FR 23110. On that basis, the EPA made a finding that emissions reductions from non-EGU sources were not required to eliminate significant contribution to downwind air quality problems under the interstate transport provision for the 2008 ozone NAAQS. In this rule, the EPA's "significant contribution" analysis at Step 3 of the 4-step framework includes a comprehensive evaluation of major stationary source non-EGU industries in the linked upwind states. The EPA finds that emissions from certain non-EGU sources in the upwind states significantly contribute to downwind air quality problems for the 2015 ozone NAAQS, and that cost-effective emissions reductions from these sources are required to eliminate significant contribution under the interstate transport provision. Therefore, this rule requires emissions reductions from non-EGU sources in upwind states to fulfill interstate transport obligations for the 2015 ozone NAAQS. This analysis is described fully in section V of this document.

In this rule, the EPA also continues to apply its approach for assessing and avoiding "over-control." In *EME Homer*

City, the Supreme Court held that “EPA cannot require a State to reduce its output of pollution by more than is necessary to achieve attainment in every downwind State or at odds with the one-percent threshold the Agency has set.” 572 U.S. at 521. The Court acknowledged that “instances of ‘over-control’ in particular downwind locations may be incidental to reductions necessary to ensure attainment elsewhere.” *Id.* at 492.

Because individual upwind States often ‘contribute significantly’ to nonattainment in multiple downwind locations, the emissions reductions required to bring one linked downwind State into attainment may well be large enough to push other linked downwind States over the attainment line. As the Good Neighbor Provision seeks attainment in every downwind State, however, exceeding attainment in one State cannot rank as ‘over-control’ unless unnecessary to achieving attainment in any downwind State. Only reductions unnecessary to downwind attainment anywhere fall outside the Agency’s statutory authority. *Id.* at 522 (footnotes omitted).

The Court further explained that “while EPA has a statutory duty to avoid over-control, the Agency also has a statutory obligation to avoid ‘under-control,’ *i.e.*, to maximize achievement of attainment downwind.” *Id.* at 523. Therefore, in the CSAPR Update and Revised CSAPR Update, the EPA evaluated possible over-control by considering whether an upwind state is linked solely to downwind air quality problems that can be resolved at a lower cost threshold, or if upwind states would reduce their emissions at a lower cost threshold to the extent that they would no longer meet or exceed the 1 percent air quality contribution threshold. *See, e.g.*, 81 FR 74551–52. *See also Wisconsin*, 938 F.3d at 325 (over-control must be proven through a “‘particularized, as-applied challenge’”) (quoting *EME Homer City Generation*, 572 U.S. at 523–24). The EPA continues to apply this framework for assessing over-control in this rule, and, as discussed in section V.D.4 of this document, does not find any over-control at the final control stringency selected.

This evaluation of cost, NO_x reductions, and air quality improvements, including consideration of whether there is proven over-control, results in the EPA’s determination of the appropriate level of upwind control stringency that would result in elimination of emissions that significantly contribute to nonattainment or interfere with maintenance of the NAAQS in downwind areas.

Comment: Commenters alleged that the EPA lacks authority to regulate EGUs under the good neighbor provision of the CAA, or at least in the manner proposed, because in their view, this regulation would intrude into areas of regulation that are reserved to other Federal agencies or are beyond the EPA’s expertise. They focused in particular on the EGU trading program enhancements, which they alleged would threaten electric grid reliability, and asserted that EPA lacks authority or expertise to dictate the mix of electricity generation in the country.

Response: The EPA disagrees that the regulation of EGUs in this action is unlawful or unsupported. The Agency has consistently and successfully regulated EGUs’ ozone season NO_x emissions under the good neighbor provision for over 25 years, beginning with the 1997 NO_x SIP Call. This action does not intrude on other Federal agencies’ authorities and responsibilities with respect to managing the electric power grid and ensuring reliable electricity. While other agencies such as the Federal Energy Regulatory Commission (FERC) have primary responsibility for ensuring reliability of the bulk electric system, the EPA has ensured that its final rule here will not create electric reliability concerns. See section VI.B.1.d of this document. Thus, to the extent commenters are raising a record-based issue that the EPA through this action has created a reliability concern, we disagree. The EPA engaged in a series of stakeholder meetings with Reliability Coordinators who commented on the proposed rule, including several Regional Transmission Organizations (RTOs) as well as non-RTO entities throughout the rulemaking process.⁸⁸

To the extent commenters maintain that—despite this record of collaboration and sensitivity to the need to ensure reliability in the implementation of its mandates, including in this rule—the EPA nonetheless fundamentally lacks authority to regulate the electric-power sector in any way that “impact[s] national electricity and energy markets,” the EPA disagrees. The EPA has successfully regulated interstate ozone-precursor emissions from the power sector since the NO_x SIP Call and the establishment of the NO_x Budget Trading Program. *See generally Michigan v. EPA*, 213 F.3d 663 (D.C. Cir.

⁸⁸ See Documents no. EPA-HQ-OAR-2021-0668-0938, EPA-HQ-OAR-2021-0668-0940, EPA-HQ-OAR-2021-0668-0941, EPA-HQ-OAR-2021-0668-0942, EPA-HQ-OAR-2021-0668-0943, EPA-HQ-OAR-2021-0668-0944, and EPA-HQ-OAR-2021-0668-0945 in the docket for this rulemaking.

2000); *Appalachian Power Co. v. EPA*, 249 F.3d 1032 (D.C. Cir. 2001). In fact, each of the EPA’s interstate ozone transport rulemakings has focused on the regulation of ozone-precursor emissions from the power sector (all but the NO_x SIP Call exclusively), because substantial, cost-effective reductions in ozone-precursor emissions have been and continue to be available from fossil-fuel fired EGUs. *See, e.g.*, 63 FR 57399–400 (NO_x SIP Call); 70 FR 25165 and 71 FR 25343 (CAIR and CAIR FIP); 76 FR 48210–11 (CSAPR); 81 FR 74507 (CSAPR Update); 86 FR 23061 (Revised CSAPR Update).⁸⁹

This rule, like all prior EPA ozone-transport rulemakings, regulates only one aspect of the operation of fossil-fuel fired EGUs, that is, the emissions of NO_x as an ozone-precursor pollutant during the ozone season. This rule limits EGU NO_x emissions that interfere with downwind states’ ability to attain and maintain the 2015 ozone NAAQS. The rule does not regulate any other aspect of energy generation, distribution, or sale. For these reasons, the rule does not intrude on FERC’s power under the Federal Power Act, 16 U.S.C. 791a, *et seq.* And, as in prior transport rules, the EPA implements this regulation through a proven, flexible mass-based emissions trading program that integrates well with, and in no way intrudes upon, the management of the power sector under other state and Federal authorities. This rule will not alter the procedures system operators employ to dispatch resources or force changes to FERC-jurisdictional electricity markets, nor have commenters offered any explanation in this regard themselves.

The actual compliance requirement that the EGUs must meet in the allowance trading system finalized here—just as in all prior interstate transport trading programs—is simply to hold sufficient allowances to cover emissions during a given control period, not to undertake any specific

⁸⁹ There are myriad other examples of effective power sector regulation under the CAA and other environmental statutes, including for example, new source performance standards (NSPS), best available retrofit technology (BART) requirements, and mercury and air toxics standards (MATS) under the CAA; effluent limitation guidelines (ELGs) under the Clean Water Act; and coal combustion residuals (CCR) requirements under the Resource Conservation and Recovery Act. Whether implemented through unit- or facility-level pollution control requirements or through emissions-trading or other market-based programs, these regulations have been effective in reducing air and water pollution while not intruding into the regulatory arenas of other state and Federal entities. *See* Section 1 of the *RTC* for further discussion.

compliance strategy.⁹⁰ The owner or operator of an EGU has flexibility in determining how it will meet this requirement, whether through the add-on emissions controls that the EPA has selected in our Step 3 analysis, or through some other method or methods of compliance. The costs of meeting this allowance-holding requirement—just like the cost associated with meeting any other regulatory requirements—could possibly then be factored into what that unit bids in the wholesale electricity market (or in regulated jurisdictions, would factor into utility regulators' determinations of what can be cost-recovered).

Those costs could, in turn, result in a reduction in electricity generation from higher-emitting sources and an increase in electricity generation from lower-emitting or zero-emitting generators, but that kind of generation shifting (not mandated but occurring as an economic choice by the regulated sources) is consistent, and in no way interferes with, the existing security-constrained economic dispatch protocols of the modern electrical grid. Further, this type of "impact" on electricity markets—merely incidental, not mandated or even intended—is of the same type that results from any other kind of regulation, environmental or otherwise. Indeed, the U.S. Supreme Court recognizes that regulatory actions that may have some "effect," or impact, in electricity markets do not on that basis alone intrude into authorities reserved to electricity rate-setting regulators by the Federal Power Act. *See FERC v. Electric Power Supply Ass'n*, 577 U.S. 260, 282–84 (2016) (distinguishing between actions that have an effect on retail rates and actual intrusion into retail rate-setting itself); *see also Hughes v. Talen*, 578 U.S. 150, 166 (2016). The Supreme Court again recognized this distinction between "incidental" effects caused by lawfully issued environmental regulations and

⁹⁰ The EPA has included in this trading program certain "enhancements" to ensure that the program continues to eliminate the emissions the EPA has determined constitute "significant contribution" over the entire life of the trading program. While one of the enhancements elevates a type of conduct that was already strongly discouraged into an enforceable violation, the other enhancements all simply modify the traditional allowance-based program structure to revise how the specific quantities of allowances that must be surrendered or the specific quantities of allowances available for surrender are determined. In finalizing this rule, the EPA has made a number of changes to its proposed enhancements to the trading program in response to comment and in part to ensure no impact on system reliability. Nonetheless, with these changes, the EPA has determined that the enhanced trading program can be implemented without impacting grid reliability. *See* section VI.B.1.d of this document.

attempts to mandate a particular energy mix in *West Virginia v. EPA*. *See* 142 S. Ct. 2587, 2613 n.4 (2022) ("[T]here is an obvious difference between (1) issuing a rule that may end up causing an incidental loss of coal's market share, and (2) simply announcing what the market share of coal, natural gas, wind, and solar must be . . .").

This rule is squarely in the former camp; as the most stringent component of its emissions controls strategy for EGUs, the EPA has determined that to eliminate significant contribution to harmful levels of ozone in other states, certain fossil-fuel fired EGUs in "linked" upwind states that do not already have selective catalytic reduction (SCR) post-combustion control technology, should install it (or achieve emissions reductions commensurate with that technology). SCR is a well-established at-the-source NO_x control technology already in use by EGUs representing roughly 60 percent of the existing coal-fired generating capacity in the United States. This technology can be installed and operated to reduce NO_x emissions without forcing the retirement or reduced utilization of any EGU. However, if market conditions are such that an EGU faced with this mandate (again, as expressed through an emissions trading budget) finds it more economic to comply with the mandate through the purchase of allowances, installation of other types of pollution control, reduced utilization, and/or retirement, rather than installing SCR technology, that is a choice that the EGU owner/operator can freely make under this rule.⁹¹ Security constrained economic dispatch is thereby maintained and is in no way interfered with.

The EPA recognizes that cost to operate generators is one of the major factors that system operators utilize to determine "merit" order in dispatching resources. However, this rule does not intrude in any way into that process. To the extent that compliance with environmental regulations is a kind of cost that may need to be factored into generators' bids, this rule is no different

⁹¹ As explained in section V.B of this document, the imposition of a backstop emissions rate beginning in 2030 for units that do not already have SCR installed could lead the owner of a given unit to decide that the unit's continued operation would be uneconomic without installation of SCR, but the establishment of technology-based emissions rates that require such decisions is consistent with decades of the EPA's rulemaking and permitting actions requiring source-specific pollution controls. Further, the backstop rate in this program is implemented through an enhanced allowance-surrender ratio, thus preserving some degree of flexibility through the emissions-trading program as the mechanism of compliance.

than many other such requirements EGUs are already subject to. Further, as in prior transport rules, this rule applies a uniform control stringency to EGUs within the covered upwind states. EGUs that may have enjoyed a competitive advantage in the past through not bearing the costs of installing and running state-of-the-art emissions control technology now must bear that cost just as their competitors with that technology already are. *Cf. EME Homer City*, 572 U.S. 489, 519 (CSAPR is "[e]quitable because, by imposing uniform cost thresholds on regulated States, EPA's rule subjects to stricter regulation those States that have done relatively less in the past to control their pollution. Upwind States that have not yet implemented pollution controls of the same stringency as their neighbors will be stopped from free riding on their neighbors' efforts to reduce pollution. They will have to bring down their emissions by installing devices of the kind in which neighboring States have already invested.").

Finally, we note that this final rule does not include "generation shifting" as a component of the budget-setting process, even in the limited way that it had been used in prior transport rules like CSAPR and the CSAPR Update, *i.e.*, to ensure the budget provided adequate incentive to ensure implementation of the selected emission-control strategy. *See* section V.B.1.f of this document. Further comments regarding legal authority for "generation shifting," relationship to state authorities, and expertise associated with grid reliability are addressed in section 1.3 of the *RTC*. We further discuss our consideration of grid reliability concerns and adjustments in the approach to the EGU emissions trading program from proposal in section VI.B.1.d of this document.

Comment: Commenters generally challenged the EPA's authority to establish emissions control requirements for non-EGU industrial sources in this action, or argued that such controls are unnecessary or unsupported, or run contrary to the EPA's prior actions under the good neighbor provision.

Response: The states and the EPA have authority under CAA section 110(a)(2)(D)(i)(I) to prohibit emissions from "any source or other type of emissions activity" that are found to significantly contribute to nonattainment or interfere with maintenance of the NAAQS in downwind states. This language is not limited only to power plant emissions, nor is it limited only to "major" sources or "stationary" sources. Thus, as a legal

matter, the emissions control requirements for certain large “non-EGU” industrial sources in this action are grounded in unambiguous statutory authority, in particular the statute’s use of the broad term “any source.” Whereas the Act elsewhere includes definitions of “major stationary source,” “small source,” and “stationary source,” see, e.g., CAA section 302(j), (x), and (z), no such qualifying terms are used with respect to the term “any source” at CAA section 110(a)(2)(D)(i). Rather, the scope of authority in this provision expands to encompass “other type of emissions activity” in addition to “any source.” The EPA has previously included non-EGU industrial sources in findings quantifying states’ obligations under the good neighbor provision, in the 1998 NO_x SIP Call, see 63 FR 57365.⁹² See also *Michigan v. EPA*, 213 F.3d 663, 690–93 (upholding the inclusion of certain non-EGU boilers in the NO_x SIP Call). The EPA’s determinations in prior transport rules not to regulate sources beyond the power sector were grounded in considerations not related to the Agency’s statutory authority. For example, in the original CSAPR rulemaking, the EPA determined that the analytical effort needed to regulate non-EGU industrial sources would substantially delay the implementation of emissions reductions from the power sector. See, e.g., 76 FR 48247–48 (“[D]eveloping the additional information needed to consider NO_x emissions from non-EGU source categories to fully quantify upwind state responsibility with respect to the 1997 ozone NAAQS would substantially delay promulgation of the Transport Rule. . . . [W]e do not believe that effort should delay the emissions reductions and large health benefits this final rule will deliver[.]”). The EPA acknowledged that by not addressing non-EGUs, it may not have promulgated a complete remedy to good neighbor obligations in CSAPR, *id.* at 48248. Nonetheless, the EPA went on to explain that there were limited emissions reductions available from non-EGUs at the cost thresholds the EPA determined would deliver

⁹² Specifically, in the NO_x SIP Call, the EPA set statewide budgets while states could determine which sectors to regulate. The EPA recommended that states regulate certain types of non-EGUs and quantified the statewide budgets based in part on the emissions reductions from those types of non-EGUs. In the parallel rule that followed under the EPA’s CAA section 126(b) authority to directly regulate emissions to eliminate significant contribution, we promulgated an emissions trading program that would have included these same types of non-EGUs. Before this rule was implemented, all states adopted equivalent state trading programs using the NO_x SIP Call model rule.

substantial reductions from power plants. See *id.* at 48249 (the EPA’s “preliminary assessment in the rule proposal suggested that there likely would be very large emissions reductions available from EGUs before costs reach the point for which non-EGU sources have available reductions”). The EPA revisited these non-EGU reduction cost levels in this final rulemaking and verified that there are little or no reductions available from non-EGUs at costs lower than the thresholds that EPA has chosen”). The EPA noted in CSAPR that states retained the authority to regulate non-EGUs as a method of addressing their good neighbor obligations. *Id.* at 48320. The EPA also noted in CSAPR that “potentially substantial” non-EGU emissions reductions could be available in future rulemakings applying a higher cost threshold. See *id.* at 48256.

Similarly, in the CSAPR Update, which addressed good neighbor obligations for the 2008 ozone NAAQS, the EPA found that regulation of non-EGUs was not warranted as the analysis required could delay the expeditious implementation of power plant reductions. The EPA found that the availability and cost-effectiveness of non-EGU reductions was uncertain and further analysis could delay implementation of the EGU strategy beyond 2017. The EPA acknowledged that it was not promulgating a complete remedy for good neighbor obligations for the 2008 ozone NAAQS and indicated its intention to further review emissions-reduction opportunities from non-EGU and EGU sources. 81 FR 74521–22.

In *Wisconsin*, the court held that the EPA’s deferral of a complete good neighbor remedy by 2017, on the basis, among other things, of uncertainty regarding non-EGU emissions reductions and the need for further regulatory analysis, was unlawful. 938 F.3d at 318–19. The court noted that “the statutes and common sense demand regulatory action to prevent harm, even if the regulator is less than certain.” *Id.* at 319 (quoting *Ethyl Corp. v. EPA*, 541 F.2d 1, 24–25 (D.C. Cir. 1976)), and that agencies can only avoid meeting their statutory obligations where “scientific uncertainty is so profound that it precludes EPA from making a reasoned judgment.” *Id.* (citing *Massachusetts v. EPA*, 549 U.S. 497, 534 (2007)). Further, the court rejected the EPA’s argument that it would have delayed its rulemaking if the EPA needed to complete a non-EGU analysis in a timely manner, holding that “administrative infeasibility” is not sufficient to “justify . . .

noncompliance with the statute.” *Id.* Rather, the Agency would need to “meet the ‘heavy burden to demonstrate the existence of an impossibility.’” *Id.* (quoting *Sierra Club v. EPA*, 719 F.2d 436, 462 (D.C. Cir. 1983)).

Following the remand of the CSAPR Update in *Wisconsin*, in the Revised CSAPR Update, the EPA conducted an analysis of non-EGUs to ensure it had implemented a complete remedy to eliminate significant contribution for the covered states for the 2008 ozone NAAQS. While acknowledging uncertainty in the datasets for non-EGUs, the EPA concluded: “[U]sing the best information currently available to the Agency, . . . the EPA is concluding that there are relatively fewer emissions reductions available at a cost threshold comparable to the cost threshold selected for EGUs. In the EPA’s reasoned judgment, the Agency concludes such reductions are estimated to have a much smaller effect on any downwind receptor in the year by which the EPA finds such controls could be installed.” 86 FR 23059. Therefore, the EPA determined control of non-EGU emissions was not required to eliminate significant contribution for the 2008 ozone NAAQS.

The circumstances that led the EPA to defer or decline regulation of non-EGU sources in CSAPR, the CSAPR Update, and the Revised CSAPR Update, are not present here, and the EPA’s determination in this action that prohibiting certain emissions from certain non-EGU sources is necessary to eliminate significant contribution for the 2015 ozone NAAQS is a logical extension of the analyses and evolution of regulatory policy development spanning its prior good neighbor rules, now applied to implement this more protective NAAQS. As the EPA explained at proposal, unlike in CSAPR and the Revised CSAPR Update, in this action the EPA finds that available reductions and cost-levels for the non-EGU stringency are commensurate with the control strategy for EGUs. Following consideration of comments and after some adjustments in the non-EGU analysis and control strategy, in this final rule, the EPA continues to find this to be the case. See sections V.C and V.D of this document.

In particular, the EPA continues to find that cost-effective emissions reductions are available for non-EGUs at a representative cost-threshold that is lower than the cost-threshold the EPA is applying for EGUs. See section V.C. of this document. These emissions control strategies are generally comparable to the emissions reduction requirements that similar sources in downwind states

are already required to meet. See section V.B.2 of this document. The EPA finds that the implementation of these emissions control strategies at non-EGUs, in conjunction with the strategies for EGU, will make a cost-effective and meaningful improvement in air quality through reducing ozone levels at the identified downwind receptors, and, therefore, the EPA has determined that these strategies will eliminate the amount of upwind emissions needed to address significant contribution under the good neighbor provision. The EPA's action here is focused on the most impactful industries and emissions units as determined by our evaluation of the power sector and the non-EGU screening assessment prepared for the proposal; indeed, of the 41 industries, as identified by North American Industry Classification System codes, we analyzed, only nine industries met the criteria for further evaluation of significant contribution. See section V.B.2 of this document. Further, the EPA finds that these strategies do not result in "overcontrol." See section V.D.4 of this document. As such, the EPA maintains that its final determinations regarding non-EGUs and its inclusion of non-EGU emissions sources within this final rule are statutorily authorized and lawful.⁹³

The EPA disagrees that it should defer regulation of industrial sources to the NSPS program under CAA section 111(b). CAA section 111(b) does not expressly provide for the elimination of "significant contribution" as is required under CAA section 110(a)(2)(D)(i)(I). In particular, commenter's statement that NSPS rulemakings under section 111(b) will appropriately address the emissions that we find must be eliminated in this action is not correct. Standards under section 111(b) apply only to new and modified sources, not existing sources. This action, however, finds that reductions in ongoing emissions from existing sources are needed to eliminate significant contribution. An NSPS standard for new and modified sources would not address such emissions from existing sources. To the extent that covered sources in this action also may be covered by an older NSPS, these sources nonetheless continue to have emissions that the EPA finds significantly contribute and can be eliminated through further emissions control as determined in this action. We further disagree with commenter's separate suggestion that the EPA use

section 111(b) and (d) to regulate both new and existing sources of ozone season NO_x, which is premised on the incorrect notion that the EPA's action here is an attempt to regulate entire source categories nationwide, rather than to eliminate significant contribution pursuant to CAA section 110(a)(2)(D)(i)(I). This action applies only to the extent a state is "linked" to downwind receptors, and therefore this action only regulates covered non-EGU industrial sources in 20 states. Further, this comment ignores that the regulation of criteria pollutant emissions from existing sources under CAA section 111(d) is limited by the criteria pollutant exclusion in CAA section 111(d)(1)(A)(i).

The EPA agrees with the commenters who assert that the EPA's authority to regulate non-EGUs under the good neighbor provision is well-grounded in administrative precedent and case law. Our previous discussion briefly recites several of the most salient aspects of that history. We also agree that the statutory language is not limited only to those sources that emit above 100 tons per year. The EPA's Step 3 and Step 4 analyses in this regard, which establish certain thresholds based on historical actual emissions, potential to emit and/or metrics for unit design capacity, reflect a reasoned judgment by the Agency regarding which emissions can be cost-effectively eliminated to address significant contribution, under the facts and circumstances of this action. That these thresholds are designed to exclude certain smaller or lower-emitting units does not reflect a determination that the EPA lacks legal authority to regulate such sources under different facts and circumstances.

The EPA identified two industry tiers of potential non-EGU emissions reductions in its non-EGU screening assessment at proposal, based on screening metrics intended to capture different kinds of impacts that non-EGU sources may have on identified receptors. The EPA agrees that it is only authorized to prohibit emissions under the good neighbor provision that significantly contribute to nonattainment or interfere with maintenance in downwind states, and we determined that these industries did so. The EPA sought comment on whether additional non-EGU industries significantly contributed to nonattainment or interfered with maintenance in downwind states. The EPA did not receive comments identifying other industrial stationary sources that are more impactful than those the EPA identified. We believed at proposal

and confirm here in our final rule that the methodology used in the screening assessment comported with the factors that we consider at Step 3. Further, the EPA's 4-step interstate transport framework, including the Step 3 analysis and an overcontrol assessment, ensure that the emissions reductions achieved at each source covered by this rule are in fact justified as part of an overall, complete remedy to eliminate significant contribution for the covered states for the 2015 ozone NAAQS. The EPA has decided to finalize emissions limitations for all of the non-EGU industries, with some modifications from proposal reflecting public input, as discussed in section VI.C of this document. The Agency's authority to establish unit- and/or source-specific emissions limitations in exercising our FIP authority is further discussed in section III.B.1 of this document.

Comment: Commenters raise additional issues with the overall approach of the rule at Step 3 to address significant contribution through our evaluation of EGU and non-EGU strategies through parallel but separate analyses. They stated that the EPA failed to establish that the identified non-EGU emissions reductions are needed to eliminate significant contribution. Commenters stated that the identified non-EGU emissions reductions are not impactful of air quality at receptors or that they are much less cost-effective than the EGU emissions reductions. Commenters stated that the EPA grouped all non-EGU emissions reductions together in making a cost-effectiveness determination that is only an average and ignores significant variation in costs associated with controls on different types of non-EGU emissions units. They also stated the EPA did not assess multiple control technologies in the way that it did for EGUs, and they argued there is great variation in the profile of non-EGU industries and emissions unit types in the different upwind states or that individual emissions units do not contribute to an out-of-state air quality problem at all. Commenters argued that certain non-EGU controls were not feasible, or that the EPA had applied a different standard for "feasibility" for non-EGUs than it did for EGUs. Commenters stated that the EPA should have provided a mass-based trading option for non-EGUs just as it had for EGUs. By contrast, other commenters supported the regulation of non-EGUs in this action as necessary to ensure a complete remedy to good neighbor obligations, since the statute is not limited to regulating power plants.

⁹³ Certain changes in the emissions control strategies for non-EGUs reflecting comments and updated information are explained in section VI.C of this document.

Some commenters further stated that EGUs should not face any further emissions reduction obligation because all cost-effective controls have already been identified through prior transport rules, and that any further regulation of EGUs would only lead to the retirement of coal plants, which they believe is the EPA's true objective. Finally, some commenters argued that the EPA had not ensured that it only regulated up to the minimum needed for downwind areas to come into attainment.

Response: Issues related to the specific technical bases for the Agency's determinations of what emissions constitute "significant contribution" at Step 3 of the 4-step framework are addressed in section V of this document. Here, we evaluate commenters' more general assertions that this action addresses non-EGU or EGU emissions in an inconsistent way. First, the EPA agrees with commenters that the task of evaluating significant contribution from the non-EGU industries is complex compared to EGUs in light of the much greater diversity in industries and emissions unit types. This, however, is not a valid basis to avoid emissions control requirements on such sources if needed to eliminate significant contribution. In this respect, the EPA's analysis in this final rule is that the 4-step framework, as upheld by the Supreme Court in *EME Homer City*, can be adequately applied even to this more complex set of sources in a way that parallels the analysis previously conducted only for EGUs. This analysis relies on evaluation of uniform levels of control stringency across all upwind states to find a level of emissions control that is cost-effective and collectively delivers meaningful downwind air quality improvement. For non-EGUs, the EPA identified the most impactful industries and emissions unit types and evaluated emissions control strategies for these units that have been demonstrated or applied across many similar facilities and emissions units. The EPA has evaluated whether these strategies are cost-effective on a cost-per-ton basis, and in particular has compared these strategies to those selected for EGUs. This analysis is set forth in sections V and VI of this document and associated technical support documents.

Commenter's statement that the establishment of a uniform level of control for each group of industrial units across the linked upwind states fails to assess with greater precision or define a state-specific proportion of emissions reduction that is needed for each downwind receptor is effectively an attempt to relitigate *EME Homer City*.

The Court in that case rejected that the EPA must define significant contribution by reference to a specific quantum of reductions that each state must achieve that is proportional to its impact at a downwind receptor. The Court agreed with the EPA's concerns as to why that approach would be problematically complicated or even impossible to apply in light of the complex set of linkages among states for a regional pollutant like ozone. *See* 572 U.S. at 515–17. The Court found that the use of uniform cost thresholds to allocate responsibility for good neighbor obligations to be efficient and equitable, in that it requires those sources that have done less to reduce their emissions to come up to a minimum level of performance to what other sources are already achieving. *Id.* at 519. The EPA's analysis in this action in section V of this document establishes that this continues to be an appropriate means of delivering meaningful air quality improvement to downwind receptors, taking into consideration the complexities of interstate pollution transport.

Not every upwind state has the same mix of non-EGU industries and emissions unit types, and it is also the case that the costs for installation of the selected level of control technology will vary from facility to facility based on site-specific considerations. This is also true for the set of EGU sources regulated here and in previous CSAPR rulemakings. These real-world complexities do not obviate the broader policy and technical judgements that the EPA makes at Step 3 regarding what level of emissions control performance can be achieved on a region-wide basis to resolve significant contribution for a regional-scale pollutant like ozone. The EPA's design of cost thresholds derives from the identification of discrete types of NO_x emissions control strategies. The EPA then identifies a representative cost-effectiveness on a per ton basis for that technology. In the Step 3 analysis, it is not the cost per ton value itself that is inherently meaningful, but rather how that cost-effectiveness value relates to other control stringencies, how many emissions reductions may be obtained, and how air quality is ultimately impacted. The selected level of control stringency reflects a point at which further emissions mitigation strategies become excessively costly on a per-ton basis while also delivering far fewer additional emissions reductions and air quality benefits. This is often referred to as a "knee in the curve" analysis. There are always inherent uncertainties in identifying a representative cost per ton

value for any particular control stringency, but this in itself does not upset the EPA's ability to render an overall policy judgment based on the Step 3 factors as to a set of emissions control strategies that together eliminate significant contribution. *See* 86 FR 23054, 23073 (responding to similar comments on the Revised CSAPR Update).

We note that the EPA has made a number of adjustments to the non-EGU emissions limits identified at Step 4 to accommodate legitimate concerns regarding the ability of certain non-EGU facilities to meet the emissions control requirements that the EPA had proposed. The Agency's determinations regarding feasibility and installation timing for pollution controls are comparable and not inconsistent between EGUs and non-EGUs. The EPA is not establishing a trading program for non-EGUs because the Agency does not have adequate baseline emissions data and information on monitoring currently at many of these emissions units to develop emissions budgets that could reliably implement the Step 3 determinations made in this action. However, for most of the non-EGU industries,⁹⁴ the EPA is not mandating a specific control technology and is instead establishing numeric emissions limits that are uniform across the region and that allow sources to choose how to comply. The EPA's analysis, including review of RACT determinations, consent decrees, and permitting actions, shows that these emissions limits and control requirements are achievable by existing units in the non-EGU industries covered by this final rule. This rule will therefore bring all of these impactful industries and unit types across the region of linked upwind states up to this standard of performance, and thus will result collectively in a relatively substantial decrease in ozone-season NO_x emissions, with associated reductions in ozone levels projected to result at the downwind receptors. This is further discussed in section V.D.

Some commenters alleged that the EPA's EGU control strategy goes beyond the cost-effectiveness determinations of prior transport rules, and they believe that the EPA's true objective is to force the retirement of coal plants. First, we note that the EGU emissions control strategy is premised entirely on at-the-

⁹⁴ For rehear furnaces in the Iron and Steel Mills and Ferroalloy Manufacturing industry, the EPA is establishing requirements to operate low-NO_x burners achieving a specified level of emissions reduction; this approach is needed to allow for unit-specific testing before an appropriate emissions limitation can be set. *See* section VI.C.3 of this document.

source emissions control technologies that are widely available and in use across the EGU fleet. It is not the EPA's intention in this rule to force the retirement of any EGU or non-EGU facilities or emissions units but to identify and eliminate significant contribution under CAA section 110(a)(2)(D)(i)(I) based on cost-effective and proven control technologies that are appropriate in relation to address the problem of interstate transport for the 2015 ozone NAAQS. Further, determinations of cost-effectiveness must be made in relation to the particular statutory provision and its purpose. The EPA recognized in CSAPR, for example, that additional emissions reductions beyond what were determined to be cost-effective in that action could be required to implement good neighbor obligations if a NAAQS were revised to a more protective level. See 76 FR 48210. Here it is not surprising that a more stringent level of control could be found justified in implementing transport obligations for the more protective 2015 ozone NAAQS. Those reductions are projected to deliver meaningful air quality improvement to downwind receptors, as discussed in section V.D of this document. Those air quality benefits continue to compare favorably to the air quality benefits that will be delivered through the combined non-EGU emissions limits, which apply to nine non-EGU industries (see section V.C of this document). We find that the implementation of both the EGU and non-EGU strategies identified in section V of this document together represent the appropriate level of emissions control stringency to eliminate significant contribution under CAA section 110(a)(2)(D)(i)(I).

Finally, the EPA also analyzed for overcontrol and does not identify any. Some commenters misstate the purpose of this rule as bringing downwind receptors into attainment. In line with the statutory directive in CAA section 110(a)(2)(D)(i)(I), this rule eliminates "significant contribution" from upwind states; while the rule has substantial air quality benefits for downwind receptors, in many cases we project that a nonattainment or maintenance problem will continue to persist through 2023 and 2026 despite the emissions reductions achieved by this rule. Commenters alleging overcontrol have not met the requirement that overcontrol be established by particularized evidence through as-applied challenges. The Supreme Court has recognized that the EPA also has an obligation to avoid under-control and

must have some leeway in fulfilling the good neighbor mandate of the Act given uncertainty in making forward projections of air quality and the efficacy or impact of emissions control determinations. See *EME Homer City*, 572 U.S. at 523. This is further addressed in section V.D.4 of this document.

d. Step 4 Approach

The EPA is finalizing an approach similar to its prior transport rulemakings to implement the necessary emissions reductions through permanent and enforceable measures. The EPA is requiring EGU sources to participate in an emissions trading program and is making additional enhancements to the trading regime to maintain the selected control stringency over time and improve emissions performance at individual units, offering a necessary measure of assurance that emissions controls will be operated throughout the ozone season. For non-EGUs, the EPA is finalizing permanent and enforceable emissions rate limits and work practice standards, and associated compliance requirements, for several types of NO_x-emitting combustion units across several industrial sectors. The measures for both EGUs and non-EGUs are required throughout the May 1-September 30 ozone season of each year. The EGU program will begin with the 2023 ozone season, and the non-EGU implementation schedule is targeted to the 2026 ozone season. Refer to section VI.A of this document for details on the implementation schedule.

Based on the EPA's experience in implementing prior transport rulemakings, the Agency is making several enhancements to its trading-program approach for implementing good neighbor requirements for EGUs. In CSAPR, the CSAPR Update, and the Revised CSAPR Update, the EPA established interstate trading programs for EGUs to implement the necessary emissions reductions. In each of these rules, EGUs in each covered state are assigned an emissions budget in each control period for their collective emissions. Emissions allowances are allocated to units covered by the trading program, and the covered units then surrender allowances after the close of the control period, usually in an amount equal to their ozone season EGU NO_x emissions. While these programs have been effective in achieving overall reductions in emissions, experience has shown that these programs may not fully reflect in perpetuity the degree of emissions stringency determined necessary to eliminate significant

contribution in Step 3 and may not adequately ensure the control of emissions throughout all days of the ozone season. At the same time, the EPA continues to find that an interstate-trading program approach delivers substantial benefits at Step 4 in terms of affording an appropriate degree of compliance flexibility, certainty in emissions outcomes, data and performance transparency, and cost-effective achievement of a high degree of aggregate emissions reductions. As such, the EPA is retaining an interstate trading program approach while making several enhancements to that approach.

Thus, in this rulemaking, the EPA is including dynamic budget-setting procedures in the regulations that will allow state emissions budgets for control periods in 2026 and later years to reflect more current data on the composition and utilization of the EGU fleet (e.g., the 2026 budgets will reflect recent data through 2024 data, the 2027 budgets will reflect data through 2025, etc.). These enhancements will enable the trading program to better maintain over time the selected control stringency that was determined to be necessary to address states' good neighbor obligations with respect to the 2015 ozone NAAQS. In prior programs, where state emissions budgets were static across years rather than calibrated to yearly fleet changes, the EPA has observed instances of units idling their emissions controls in the latter years of the program. To provide greater certainty regarding the minimum quantities of allowances that will be available for compliance for the control periods in 2026 through 2029, the EPA is also establishing preset state emissions budgets for these control periods, and a dynamic state emissions budget determined for one of these control periods will apply only if it is higher than the state's preset budget for the control period.

In the trading programs established for ozone season NO_x emissions under CSAPR, the CSAPR Update, and the Revised CSAPR Update, the EPA included assurance provisions to limit state emissions to levels below 121 percent of the state's budget by requiring additional allowance surrenders in the instance that emissions in the state exceed this level. This limit on the degree to which a state's emissions can exceed its budget is designed to allow for a certain level of year-to-year variability in power sector emissions to account for fluctuations in demand and EGU operations and is responsive to previous court decisions (see discussion in section VI.B.5 of this document). In this

action, the EPA is maintaining the existing assurance provisions that limit state emissions to levels below a percentage of the state's budget by requiring additional allowance surrenders in any instance where emissions in the state exceed the specified level, but with adjustments that allow the level to exceed 121 percent of a state's budget in a given control period if necessary to account for actual operational conditions in that control period. In addition, the EPA is also making several additional enhancements to the EGU trading program in this action, including routine recalibrations of the total amount of banked allowances, unit-specific backstop daily emissions rates for certain units, and unit-specific secondary emissions limitations for certain units that contribute to exceedances of the assurance levels, to ensure EGU emissions control operation and associated air quality improvements. Implementation of the EGU emissions reductions using a CSAPR NO_x trading program is further described in section VI.B of this document.

In this rule, the EPA is also establishing emissions limitations for the non-EGU industry sources listed in Table II.A-1. The EPA has the authority to require emissions limitations from stationary sources, as well as from other sources and emissions activities, under CAA section 110(a)(2)(D)(i)(I). The EPA finds that requiring NO_x emissions reductions through emissions rate limits and control technology requirements for certain non-EGU industrial sources that the EPA found at Step 3 to be relatively impactful⁹⁵ on downwind air quality is an effective strategy for reducing regional ozone transport. Therefore, the EPA is establishing NO_x emissions limitations and associated compliance requirements for non-EGU sources to ensure the elimination of significant contribution of ozone precursor emissions required under the interstate transport provision for the 2015 ozone NAAQS.

Finally, the EPA finds that the control measures determined to be required for the identified EGU and non-EGU sources apply to both existing units and any new, modified, or reconstructed units meeting the applicability criteria established in this final rule. This is

⁹⁵ Section III of the Non-EGU Screening Assessment memorandum in the docket for this rulemaking describes the EPA's approach to evaluating impacts on downwind air quality, considering estimated total, maximum, and average contributions from each industry and the total number of receptors with contributions from each industry.

consistent with the EPA's transport actions dating back to the NO_x SIP Call and the NO_x Budget Trading Program. In all CSAPR EGU trading programs, for instance, new EGUs are subject to the program, and the EPA has established provisions for the allocation of allowances to such units through "new unit set asides." See, e.g., 86 FR 23126. In the NO_x SIP Call, the EPA required that states cover new and existing units in the relevant source sectors through an enforceable cap or other emissions limitation. See 40 CFR 51.121(f). The EPA's approach of including new units in the NO_x Budget Trading Program promulgated under the EPA's CAA section 126 authority was upheld by the D.C. Circuit in *Appalachian Power v. EPA*, 249 F.3d 1032 (2001). As the court noted, the EPA explained in its action:

Once EPA has determined that the emissions from the existing sources in an upwind State already make a significant contribution to one or more petitioning downwind States, any additional emissions from a new source in that upwind State would also constitute a portion of that significant contribution, unless the emissions from that new source are limited to the level of highly effective controls.

Id. at 1058 (quoting EPA 1999 RTC at 39). The court affirmed this approach: "Indeed, it would be irrational to enable the EPA to make findings that a group of sources in an upwind state contribute to downwind nonattainment, but then preclude the EPA from regulating new sources that contribute to that same pollution." *Id.* at 1057-58. The EPA is implementing the same court-affirmed approach in this action because this reasoning is equally applicable to addressing interstate transport obligations under CAA section 110(a)(2)(D)(i)(I) for the 2015 ozone NAAQS.

Comment: Commenters took issue with aspects of the EPA's proposed Step 4 approach. Commenters argued the EPA could not set unit- or source-specific emissions limits or other control requirements, for EGUs or non-EGUs. Commenters argued that various aspects of the non-EGU emissions control strategy would not be feasible for their facilities or were otherwise flawed. Many industrial-source and EGU commenters argued that the EPA had not provided sufficient time for sources to come into compliance. Commenters also challenged the EGU trading program "enhancements" as unnecessary or beyond the EPA's authority. In this regard, commenters argued that these changes deviated from the EPA's prior approach, were unnecessary overcontrol, constituted a command-and-control approach, could

not be supported on the basis of environmental justice benefits, or were otherwise unlawful for other reasons. These commenters argue that the EPA's Step 4 dynamic budget approach for EGU regulation purportedly re-defines each state's "significant contribution" annually and independent of any impact (or lack thereof) on air quality. They further argue that under this dynamic budgeting approach, even if a state eliminates the "amount" the EPA has identified as the state's significant contribution by respecting a given control period's emissions budget, sources within that state are expected to continue to make further reductions by operating their controls in a particular manner in subsequent control periods under potentially lower emissions budgets, which these commenters argue is inconsistent with case law on prior CSAPR rules.

Response: Many of these comments regarding Step 4 issues are addressed elsewhere in this document or in the RTC document. The EPA's authority to establish unit- or source-specific emissions rates is addressed in section IV.B.1 of this document. Responses to comments and adjustments in the timing requirements of the final rule compared to proposal are discussed in VI.A. Responses to comments and adjustments in emissions control requirements for non-EGUs in the final rule compared to proposal are in section VI.C of this document.

Responses to comments on the EGU trading program enhancements and adjustments in the final rule are contained in section VI.B of this document. However, here, in light of the changes in the emissions trading program for EGUs that we are finalizing in this action as compared to prior EGU emissions trading programs promulgated to address good neighbor obligations under other NAAQS, we set forth responses to comments specific to this topic.

The EPA finds that these comments confuse Step 3 emissions reduction stringency determinations with Step 4 implementation program details. In this rulemaking's Step 3 analysis, the EPA is measuring emissions reduction potential from improving effective emissions rates across groups of EGUs adopting applicable pollution control measures and selecting a uniform control level whose effective emissions rates deliver an acceptable outcome under the multifactor test (including a finding of no overcontrol at the selected control stringency level). The "amounts" defined as significant contribution to nonattainment and interference with maintenance are

emissions that occur at effective emissions rates above the control stringency level selected at Step 3. That is, if a state's affected EGUs fail to reduce their effective emissions rates in line with the widely available and cost-effective control measures identified, they have therefore failed to eliminate their significant contribution to nonattainment and interference with maintenance of this NAAQS.

In this rule, the EPA is finalizing several "enhancements" to its existing Group 3 emissions trading program for ozone season NO_x, for reasons explained in section VI.B.1 of this document. In general, these changes will ensure that the emissions control program promulgated for EGUs at Step 4 of the EPA's 4-step interstate transport framework is in alignment with the emissions control stringency determinations the EPA made at Step 3. These enhancements reflect lessons learned through the EPA's experience with prior trading programs implemented under the good neighbor provision and ensure that the implementation of the elimination of significant contribution through an emissions trading program remains durable through a period of power sector transition. None of commenters' arguments against the EPA's authority to implement these enhancements are persuasive.

First, the EPA is not mandating that any EGU must install SCR technology. All but one of the enhancements to the trading program continue to be implemented through allowance-holding requirements under the mass-based emissions budget and trading system, including the backstop rate. (The secondary emissions limitation, which is not implemented through allowance-holding requirements under the mass-based emissions budget and trading system, and which is discussed in section VI.B.1.c.ii of this document, merely establishes a stronger deterrent for a type of conduct that was already strongly discouraged under the pre-existing trading program regulations). Nonetheless, the EPA *does* have the authority to impose unit-specific emissions limits under the exercise of its FIP authority, and it has done so in this action for non-EGU industrial sources. This authority is distinct from the EPA's title I permitting authority as discussed by certain commenters, and the scope of that permitting authority is not relevant to this action.

The quantification of emissions budgets in an allowance-based emissions trading program is one of multiple potential Step 4 implementation program design choices

that states and the EPA have authority to select in securing the emissions reductions deemed necessary under Step 3. *See* CAA section 110(a)(2)(A). The EPA and the states routinely determine control stringency on an emissions rate basis in line with demonstrated pollution control opportunities, and both the EPA and the states have implementation program design discretion to determine what compliance requirements, whether expressed on a rate, mass, concentration, or percentage basis, will assure an emissions performance that reflects the control stringency required. Dynamic budgets in the Step 4 implementation of this rule are simply to ensure the trading program continues to incentivize the implementation of the EGU control strategies we find are necessary to eliminate significant contribution at Step 3. The key distinction between dynamic budget approaches and preset budget approaches is not one in stringency or authority, but rather in timing and data resources for determining the suitable mass-based limits that are as well-matched as possible to expected emissions of the affected EGUs achieving the emissions rate-based control stringency deemed necessary under Step 3 to eliminate significant contribution to nonattainment and interference with maintenance of the NAAQS.

The EPA does not agree that the administrative mechanisms by which it will implement "dynamic budgeting" conflict with CAA section 307(d) or the Administrative Procedure Act. The EPA is promulgating a complete FIP in this action, and the codified language of that FIP will not need to be modified as budgets are adjusted. This is because the FIP establishes the formula by which the budgets will be calculated each year (with preset budgets functioning as a floor from 2026 through 2029). This is no different than how the EPA has implemented other calculations such as updating allocations using a rolling set of data in its prior CSAPR trading programs. *See, e.g.,* 87 FR 10786. We view these actions as fundamentally ministerial in nature in that no exercise of Agency discretion is required. This process will rely on notices of availability of the relevant data in the **Federal Register**, coupled with an opportunity for the public to correct any errors they may identify in the data before the EPA sets each updated budget. *See* section VI.B.4 for more detail on how the EPA intends to implement dynamic budgeting. As in prior transport rules, this rule provides

the opportunity for administrative appeal should an interested party identify some flaw in the EPA's updated data. *See* 40 CFR 78.1(b)(19)(i) (2023). That process is coupled with the availability of judicial review should the party remain dissatisfied with the EPA's resolution of complaints. *See* 40 CFR 78.1(a)(2) (requiring administrative adjudication as a prerequisite for judicial review). This administrative process has worked well throughout the history of implementing good neighbor trading programs under Part 97, and no such disputes have necessitated judicial resolution.

Further, because the dynamic budgets simply implement the stringency level reflective of the emissions control performance the EPA has determined at Step 3 for the covered EGUs, the EPA does not agree that any "potential variables" that are unforeseeable now could upset the basis for the formula the EPA is establishing in this action. The EPA has adjusted the role of dynamic budgeting in this final rule as compared to the proposal. *See* sections VI.B.1 and VI.B.4 of the preamble. In particular, the EPA is applying an approach to budget setting through 2029 that will use the greater of either a preset budget based on information known to the Agency at the time of this action, or the dynamic budget to be calculated based upon future data yet to be reported. Thus, through 2029 the imposition of a dynamic budget would only increase rather than diminish the emissions allowed for that control period compared to the preset budgets established in this action. In addition, the EPA will determine each state's dynamic budget based on a rolling 3-year average of the state's heat input, thus smoothing out trends to account for interannual variability in demand and heat input and provide greater certainty and predictability as the budget updates from year to year.

Moreover, the EPA does not agree that the EPA is constrained by the statute to only implement good neighbor obligations through fixed, unchanging, mass-based emissions budgets. *See* section III.B.1 of this document. The EPA finds good reason based on its experience with trading programs using fixed budgets why this approach does not necessarily ensure the elimination of significant contribution in perpetuity. The EPA has already once adjusted its historical approach to better account for known, upcoming changes in the EGU fleet to ensure mass-based emissions budgets adequately incentivize the control strategy determined at Step 3. This adjustment was introduced in the Revised CSAPR Update. *See* 82 FR

23121–22.⁹⁶ The EPA now believes it is appropriate to ensure in a more comprehensive manner, and in perpetuity, that the mass-based emissions budget incentivize continuing implementation of the Step 3 control strategies to ensure significant contribution is eliminated in all upwind states and remains so. The dynamic budget-setting process preserves these incentives over time by calculating the state emissions budgets for each future control period so as to reflect the Step 3 control stringency finalized in this rule as applied to the most current information regarding the composition of the power sector in the control period. This is fully analogous in material respect to an approach to implementation at Step 4 that relies on application of unit-specific emissions rates that apply in perpetuity. The availability of unit-specific emissions rates as a means to eliminate significant contribution is discussed in further detail in section III.B.1 of this document. The EPA also explained this in the proposal. See 87 FR 20095–96. The EPA does not agree that either dynamic budgeting or the backstop rate results in overcontrol. See section V.D.4 of this document.

The EPA is enhancing the trading program to help reconcile the approach of using mass-based budgets to achieve the elimination of significant contribution with the *Wisconsin* directive to provide a complete remedy under the good neighbor provision. This approach also better accords with ensuring measures to attain and maintain the NAAQS are permanent and enforceable. The dynamic budget approach recognizes that the uncertainty around future fleet conditions increases the further into the future one looks (and the EPA must look further under the “full remedy” directive). To preserve its ability to successfully implement its identified Step 3 stringency, the EPA is designing the implementation of this rule’s emissions control program to benefit from the future availability of better data from the regulated sources to inform its

⁹⁶ Further, in the Revised CSAPR Update, the EPA acknowledged that a mechanism like dynamic budgeting could be appropriate for a transport rule with longer time horizons. We stated in response to comments that we were not “in this action, including an adjustment mechanism to further adjust state emission budgets to account for currently unknown or uncertain retirements after the finalization of this rule EPA observes that the commenter’s proposed mechanism would become increasingly valuable for rules where the timeframe extends further into the future where retirement uncertainty is higher.” Revised CSAPR Update Response to Comments, EPA–HQ–OAR–2020–0272–219, at 153.

application of its stringency measures identified in this rule.

The EPA does not agree with commenters who suggest that these enhancements are undertaken for the purpose of a non-statutory “environmental justice” objective. As explained in section VI.B of this document, certain enhancements to the trading program ensure that each EGU is adequately incentivized to continuously operate its emissions controls once those controls are installed. One commenter contends that the backstop emissions rate is not authorized based on environmental justice considerations, since it is not necessary and is overcontrol with respect to the EPA’s statutory authority to address good neighbor obligations. But the EPA disagrees with the premise that these enhancements are unrelated to the statutory obligation to eliminate significant contribution. Taking measures to ensure that each upwind source covered by an emissions trading program to eliminate significant contribution is operating its installed pollution controls on a more continuous and consistent basis throughout the ozone season is entirely appropriate in light of the daily nature of the ozone problem, the impacts to public health and the environment from ozone that can occur through short-term exposure (*e.g.*, over a course of hours), the fact that the 2015 ozone NAAQS is expressed as an 8-hour average, and that only a small number of days in excess of the ozone NAAQS are necessary to place a downwind area in nonattainment, resulting in continuing and/or increased regulatory burden on the downwind jurisdiction. See section III.A of this document.

Further, the D.C. Circuit has held that the EPA must ensure that its good neighbor program has eliminated *each* state’s sources from continuing to significantly contribute to nonattainment or interfere with maintenance in downwind states. See *North Carolina*, 531 F.3d at 921. The commenters neglect to acknowledge the scenario that has frequently borne out in prior programs, in which future fleet changes that were not known at the time of initial setting of state emissions budgets produce unexpected “hot air” in the budget that, if unaccounted for, other units can exploit to forgo identified cost-effective mitigation measures deemed necessary to eliminate significant contribution to nonattainment and interference with maintenance of the NAAQS.

The EPA’s experience is that fixed mass-based budgets that are determined based only on the profile of the power

sector at the time the rule is promulgated, and without any additional requirement for pollution controls operation, can become quickly obsolete if the composition of the group of affected EGUs changes notably over time. As some sources retire, other sources relax their operation of NO_x controls in response to a growing surplus of allowances, even though the EPA had concluded that ongoing operation of those controls is necessary to meet the statutory good neighbor requirements. For instance, under the CSAPR Update, in the 2018–2020 period, the fixed budget approach enabled large, frequently run units with existing SCR controls to not optimize those controls even though the EPA’s assessment (as reflected in the CSAPR Update) was that the optimization of those controls was necessary to eliminate significant contribution. This deterioration in emission rate at SCR-controlled coal plants was widely observed across the CSAPR Update geography as the program advanced into later years and allowance price deteriorated. Whereas coal sources with SCR performed, on average, at a 0.086 lb/mmBtu rate in 2017, that same set of sources saw their environmental performance worsen to a 0.099 lb/mmBtu rate in 2020. A Congressional Research Service Report on EPA prior CSAPR trading programs indicated low prices observed in later years “could lead to some decisions not to run some pollution controls at maximum output. This would, in turn, lead to higher emissions”.⁹⁷

In the case of individual units, this deterioration in performance can be quite pronounced and can occur as quickly as the second or third control period, as in the case of Miami Fort Unit 7 in Ohio in 2019, discussed in section V.B of this document. The absence of a sufficient incentive under the trading program to implement the identified control strategy at Step 3 can even result in collective emissions that exceed state-wide assurance levels. The EPA established these levels beginning with CSAPR, above which enhanced allowance-surrender requirements are triggered, in an effort to ensure sources in each state are held to eliminate their own significant contribution, which the D.C. Circuit has held is legally required, see *North Carolina*, 531 F.3d 896, 906–08 (D.C. Cir. 2008). In four instances over the course of the 2019, 2020, and

⁹⁷ Shouse, Kate. “The Clean Air Act’s Good Neighbor Provision: Overview of Interstate Air Pollution Control”. Congressional Research Services. August 30, 2018. Available at <https://sgp.fas.org/crs/misc/R45299.pdf>.

2021 control periods under the CSAPR Update, sources in Mississippi and Missouri collectively exceeded their state-wide assurance levels in part due to deterioration in emissions performance that can be attributed to a glut of allowances within the CSAPR Update. See section VI.B.8 of the preamble.

Thus, while this trading program structure may achieve some environmental benefit through fixed emissions budgets for initial control periods, over time those fixed budgets cease to have their intended effect, and remaining operating facilities can, and have, increased emissions or even discontinued the operation of their emissions controls. This, in turn, can lead to the continuation (or re-emergence) of significant contribution in terms of a recurrence of excessive emissions that had been slated for permanent elimination under the EPA's determinations at Step 3. Although the EPA has always intended for its trading programs to provide flexibility, the Agency did not expect and has certainly never endorsed the use of that flexibility to stop the operation of controls that have already been installed. See, e.g., 76 FR 48256–57 (“[I]t would be inappropriate for a state linked to downwind nonattainment or maintenance areas to stop operating existing pollution control equipment (which would increase their emissions and contribution).”). Despite the EPA's expectations in CSAPR, the historical data establishes a real risk of “under-control” if the existing trading framework is not improved upon. See *EME Homer City*, 572 U.S. at 523 (“[T]he Agency also has a statutory obligation to avoid ‘under-control,’ i.e., to maximize achievement of attainment downwind.”).

This result is also inconsistent with the statutory mandate to “prohibit” significant contribution and interference with maintenance of the NAAQS in downwind states, as evidenced most clearly in CAA section 126, which makes it unlawful for a source “to operate more than three months after [a finding that the source emits or would emit in violation of the good neighbor provision] has been made with respect to it.” 42 U.S.C. 7426(c)(2) (emphasis added). See also *North Carolina*, 531 F.3d at 906–08 (each state must be held to the elimination of its own significant contribution). The purpose of the Agency's interstate trading programs under the good neighbor provision is to afford sources some flexibility in achieving region-wide emissions reductions; however, there is no justification that can be sustained

within that framework for sources in certain areas within that region, or during periods of high ozone when good emissions performance is most essential, to emit at levels well in excess of the EPA's Step 3 determinations of significant contribution. Significant contribution, according to the statute, must be “prohibited.” CAA section 110(a)(2)(D)(i).

Thus, these trading program enhancements are within the EPA's authority under CAA section 110(a)(2)(D)(i)(I) to eliminate interstate ozone pollution that significantly contributes to nonattainment or interferes with maintenance in downwind states. These enhancements ensure the elimination of significant contribution across all upwind states and throughout each ozone season. We observe in the Ozone Transport Policy Analysis Final Rule TSD, section E, that the trading program enhancements may also benefit underserved and overburdened communities downwind of EGUs in the covered geography of the final rule. See section VI.B of this document. This does not detract from the statutorily-authorized basis for these changes, and the EPA finds nothing impermissible in acknowledging the reality of these potential benefits for underserved and overburdened communities.

The EPA appreciates a commenter's concern that our actions be legally defensible. The EPA acknowledges that the changes to the trading program structure for implementing good neighbor obligations discussed here constitute a change in the policy underlying its prior transport-rule trading programs for EGUs. However, the EPA is confident that these changes are in compliance with the holdings in judicial decisions reviewing prior transport rules. The fact that the EPA is making changes does not somehow render these enhancements legally impermissible or even subject to a heightened standard of review. See *FCC v. Fox Television Stations*, 556 U.S. 502, 514 (2009) (“We find no basis in the Administrative Procedure Act or in our opinions for a requirement that all agency change be subjected to more searching review.”). We have explained previously and elsewhere in the record that there are “good reasons” for the “new policy.” See *id.* at 515. And, we are of course fully aware that we have changed our position. See *id.* at 514–15. Specifically, we have gone from previously treating fixed, mass-based budgets as sufficient to eliminate significant contribution, to an approach for purposes of the 2015 ozone NAAQS reflecting a more nuanced

understanding of how an emissions trading program that does not properly anticipate future fleet conditions at Step 4 may fail to achieve the elimination of emissions that should be prohibited based on our findings at Step 3. Further, we find there to be no “serious reliance interests” that have been or even could have been “engendered” by any prior policy on these issues, see *id.* at 515–16. The EPA is implementing these enhancements for the first time with respect to a new obligation—good neighbor requirements for the 2015 ozone NAAQS. No party reasonably could have invested substantial resources to-date to comply with an obligation that was heretofore undefined; and no commenter has supplied any information to the contrary.

2. FIP Authority for Each State Covered by the Rule

On October 26, 2015, the EPA promulgated a revision to the 2015 8-hour ozone NAAQS, lowering the level of both the primary and secondary standards to 0.070 parts per million (ppm).⁹⁸ These revisions of the NAAQS, in turn, established a 3-year deadline for states to provide SIP submissions addressing infrastructure requirements under CAA sections 110(a)(1) and CAA 110(a)(2), including the good neighbor provision, by October 1, 2018. If the EPA makes a determination that a state failed to submit a SIP, or if EPA disapproves a SIP submission, then the EPA is obligated under CAA section 110(c) to promulgate a FIP for that state within 2 years. For a more detailed discussion of CAA section 110 authority and timelines, refer to section III.C of this document.

The EPA is finalizing this FIP action now to address 23 states' good neighbor obligations for the 2015 ozone NAAQS.⁹⁹ For each state for which the EPA is finalizing this FIP, the EPA either issued final findings of failure to submit or has issued a final disapproval of that state's SIP submission.

Several commenters asserted that the sequence of the EPA's actions, and in particular, the timing of its proposed FIP (which was signed on February 28,

⁹⁸ *National Ambient Air Quality Standards for Ozone*, Final Rule, 80 FR 65292 (Oct. 26, 2015). Although the level of the standard is specified in the units of ppm, ozone concentrations are also described in parts per billion (ppb). For example, 0.070 ppm is equivalent to 70 ppb.

⁹⁹ The EPA notes that it is subject to, and has met through this action, a consent decree deadline to promulgate FIPs addressing 2015 ozone NAAQS good neighbor obligations for the states of Pennsylvania, Utah, and Virginia. See *Sierra Club et al. v. Regan*, No. 3:22-cv-01992-JD (N.D. Cal. entered January 24, 2023).

2022, and published on April 6, 2022) in relation to the timing of its proposed SIP disapprovals (most of which were published on February 22, 2022, four of which were published on May 24, 2022, and one of which was published on October 25, 2022), was either unlawful or unreasonable in light of the sequence of steps required under CAA section 110(k) and (c).

These commenters are incorrect. As an initial matter, concerns about the timing or substance of the EPA's actions on the SIP submittals are beyond the scope of this action. Nor are the timing or contents of merely proposed actions to be considered final agency actions or subject to judicial review. *See In re Murray Energy*, 788 F.3d 330 (D.C. Cir. 2015). With these principles in mind, the timing of this final action is lawful under the Act. First, the EPA is not required to wait to propose a FIP until after the Agency proposes or finalizes a SIP disapproval or makes a finding of failure to submit.¹⁰⁰ CAA section 110(c) authorizes the EPA to promulgate a FIP "at any time within 2 years" of a SIP

¹⁰⁰ The EPA notes there are three consent decrees to resolve three deadline suits related to EPA's duty to act on good neighbor SIP submissions for the 2015 ozone NAAQS. In *New York et al. v. Regan, et al.* (No. 1:21-cv-00252, S.D.N.Y.), the EPA agreed to take final action on the 2015 ozone NAAQS good neighbor SIP submissions from Indiana, Kentucky, Michigan, Ohio, Texas, and West Virginia by April 30, 2022; however, if the EPA proposes to disapprove any SIP submissions and proposes a replacement FIP by February 28, 2022, then EPA's deadline to take final action on that SIP submission is extended to December 30, 2022. In *Downwinders at Risk et al. v. Regan* (No. 21-cv-03551, N.D. Cal.), the EPA agreed to take final action on the 2015 ozone NAAQS good neighbor SIP submissions from Alabama, Arkansas, Connecticut, Florida, Georgia, Illinois, Indiana, Iowa, Kansas, Kentucky, Louisiana, Maryland, Michigan, Minnesota, Mississippi, New Jersey, New York, North Carolina, Ohio, Oklahoma, South Carolina, Tennessee, Texas, West Virginia, and Wisconsin by April 30, 2022; however, if the EPA proposes to disapprove any of these SIP submissions and proposes a replacement FIP by February 28, 2022, then the EPA's deadline to take final action on that SIP submission is December 30, 2022. In this CD, the EPA also agreed to take final action on Hawaii's SIP submission by April 30, 2022, and to take final action on the SIP submissions of Arizona, California, Montana, Nevada, and Wyoming by December 15, 2022. In *Our Children's Earth Foundation v. EPA* (No. 20-8232, S.D.N.Y.), the EPA agreed to take final action on the 2015 ozone NAAQS good neighbor SIP submission from New York by April 30, 2022; however, if the EPA proposes to disapprove New York's SIP submission and proposes a replacement FIP by February 28, 2022, then the EPA's deadline to take final action on New York's SIP submission is extended to December 30, 2022. By stipulation of the parties, the December 15, 2022, date in all three of these consent decrees was extended to January 31, 2023. By further stipulation of the parties in the *Downwinders at Risk* case, the January 31, 2023, date was further extended to December 15, 2023 for the EPA to act on the SIP submissions from the states of Arizona, Tennessee, and Wyoming.

disapproval or making a finding of failure to submit. The Supreme Court recognized in *EME Homer City* that the EPA is not obligated to first define a state's good neighbor obligations or give the state an additional opportunity to submit an approvable SIP before promulgating a FIP: "EPA is not obliged to wait two years or postpone its action even a single day: The Act empowers the Agency to promulgate a FIP 'at any time' within the two-year limit."¹⁰¹ Thus, the EPA may promulgate a FIP contemporaneously with or immediately following predicate final SIP disapproval (or finding no SIP was submitted). To accomplish this, the EPA must necessarily be able to propose a FIP prior to taking final action to disapprove a SIP or make a finding of failure to submit.

Second, and more importantly, the EPA has established predicate authority to promulgate FIPs for all of the covered states through its action with respect to the relevant SIP submittals. A brief history of these actions follows:

On February 22, 2022, the EPA proposed to disapprove 19 good neighbor SIP submissions (Alabama, Arkansas, Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, Minnesota, Mississippi, Missouri, New Jersey, New York, Ohio, Oklahoma, Tennessee, Texas, West Virginia, Wisconsin).¹⁰² Alabama subsequently withdrew its SIP submission and re-submitted a SIP submission on June 22, 2022. The EPA proposed to disapprove that SIP submittal on October 25, 2022.¹⁰³ The EPA proposed to disapprove good neighbor SIP submissions for four additional states, California, Nevada, Utah, and Wyoming, on May 24, 2022.¹⁰⁴

Subsequently, on January 31, 2023, the EPA Administrator signed a single disapproval action for all of the above states, with the exception of Tennessee and Wyoming.¹⁰⁵ This action established the EPA's authority to promulgate FIPs for the disapproved states. (As explained in section IV.F of this document, the Agency is deferring action at this time for Tennessee and Wyoming with respect to its proposed

¹⁰¹ *See EPA v. EME Homer City Generation, L.P.*, 572 U.S. 489, 509 (2014) (citations omitted).

¹⁰² *See* 87 FR 9463 (Maryland); 87 FR 9484 (New Jersey, New York); 87 FR 9498 (Kentucky); 87 FR 9516 (West Virginia); 87 FR 9533 (Missouri); 87 FR 9545 (Alabama, Mississippi, Tennessee); 87 FR 9798 (Arkansas, Louisiana, Oklahoma, Texas); 87 FR 9838 (Illinois, Indiana, Michigan, Minnesota, Ohio, Wisconsin).

¹⁰³ *See* 87 FR 64412.

¹⁰⁴ *See* 87 FR 31443 (California); 87 FR 31485 (Nevada); 87 FR 31470 (Utah); 87 FR 31495 (Wyoming).

¹⁰⁵ *See* 88 FR 9336.

FIP actions for those states. As discussed in section IV.F of this document, the EPA's most recent modeling and air quality analysis indicates that several states may be linked to downwind receptors for which we had not previously proposed disapproval or FIP action. The EPA anticipates addressing remaining interstate transport obligations for the 2015 ozone NAAQS for these in a subsequent rulemaking.)

Additionally, the EPA has taken action that has triggered the EPA's obligation under CAA section 110(c) to promulgate FIPs addressing the good neighbor provision for several downwind states. On December 5, 2019, the EPA published a rule finding that seven states (Maine, New Mexico, Pennsylvania, Rhode Island, South Dakota, Utah, and Virginia) failed to submit or otherwise make complete submissions that address the requirements of CAA section 110(a)(2)(D)(i)(I) for the 2015 ozone NAAQS.¹⁰⁶ This finding triggered a 2-year deadline for the EPA to issue FIPs to address the good neighbor provision for these states by January 6, 2022. As the EPA has subsequently received and taken final action to approve good neighbor SIPs from Maine, Rhode Island, and South Dakota,¹⁰⁷ the EPA currently has authority under the December 5, 2019, findings of failure to submit to issue FIPs for New Mexico, Pennsylvania, Utah, and Virginia. In this final rule, the EPA is issuing FIP requirements for Pennsylvania, Utah, and Virginia.¹⁰⁸

Further information on the procedural history establishing the EPA's authority for this final rule is provided in a document in the docket.¹⁰⁹

¹⁰⁶ *Findings of Failure To Submit a Clean Air Act Section 110 State Implementation Plan for Interstate Transport for the 2015 Ozone National Ambient Air Quality Standards (NAAQS)*, 84 FR 66612 (December 5, 2019, effective January 6, 2020).

¹⁰⁷ *Air Plan Approval; Maine and New Hampshire; 2015 Ozone NAAQS Interstate Transport Requirements*, 86 FR 45870 (August 17, 2021); *Air Plan Approval; Rhode Island; 2015 Ozone NAAQS Interstate Transport Requirements*, 86 FR 70409 (December 10, 2021); *Promulgation of State Implementation Plan Revisions; Infrastructure Requirements for the 2015 Ozone National Ambient Air Quality Standards; South Dakota; Revisions to the Administrative Rules of South Dakota*, 85 FR 29882 (May 19, 2020).

¹⁰⁸ *WildEarth Guardians v. Regan*, No. 1:22-cv-00174 (D.N.M. entered Aug. 16, 2022); *Sierra Club et al. v. EPA*, No. 3:22-cv-01992 (N.D. Cal. entered Jan. 24, 2023).

¹⁰⁹ *See* "Final Rule: Status of CAA Section 110(a)(2)(D)(i)(I) SIP Submissions for the 2015 Ozone NAAQS for States Covered by the Proposed Federal Implementation Plan Addressing Regional Ozone Transport for the 2015 Ozone National Ambient Air Quality Standards." This document updates a prior document of the same title provided

Continued

While the EPA's previous actions are sufficient to establish that the EPA's promulgation of this FIP action at this time is lawful, the timing of this action is all the more reasonable in light of the need for the EPA to address good neighbor obligations consistent with the rest of title I of the CAA. In particular, the D.C. Circuit in *Wisconsin* held that states and the EPA are obligated to fully address good neighbor obligations for ozone "as expeditiously as practical" and in no event later than the next relevant downwind attainment dates found in CAA section 181(a).¹¹⁰ In *Maryland v. EPA*, the D.C. Circuit made clear that *Wisconsin's* and *North Carolina's* holdings are fully applicable to the Marginal area attainment date for the 2015 ozone NAAQS,¹¹¹ which fell on August 3, 2021.¹¹² As discussed in section VI.A of this document, by finalizing this action now, the EPA is able to implement initial required emissions reductions to eliminate significant contribution by the 2023 ozone season, which is the last full ozone season before the next attainment date, the Moderate area attainment date of August 3, 2024. The *Wisconsin* court emphasized that the EPA has the authority under CAA section 110 to structure and time its actions in a manner such that the Agency can ensure necessary reductions are achieved in alignment with the downwind attainment schedule, and that is precisely what the EPA is doing here.¹¹³ The EPA provides further response to the comments on this issue in section 1 of the *RTC* document.

C. Other CAA Authorities for This Action

1. Withdrawal of Proposed Error Correction for Delaware

The EPA proposed at 87 FR 20036 to make an error correction under CAA section 110(k)(6) of its May 1, 2020, approval at 85 FR 25307 of the interstate transport elements for Delaware's October 11, 2018, and December 26,

at proposal (Document no. EPA-HQ-OAR-2021-0668-0131).

¹¹⁰ *Wisconsin v. EPA*, 938 F.3d 303, 313–14 (D.C. Cir. 2019) (citing *North Carolina v. EPA*, 531 F.3d 896, 911–13 (D.C. Cir. 2008)).

¹¹¹ *Maryland v. EPA*, 958 F.3d 1185, 1203–04 (D.C. Cir. 2020).

¹¹² See CAA section 181(a); 40 CFR 51.1303; *Additional Air Quality Designations for the 2015 Ozone National Ambient Air Quality Standards*, 83 FR 25776 (June 4, 2018, effective August 3, 2018).

¹¹³ 938 F.3d at 318 ("When EPA determines a State's SIP is inadequate, EPA presumably must issue a FIP that will bring that State into compliance before upcoming attainment deadlines, even if the outer limit of the statutory timeframe gives EPA more time to formulate the FIP.") (citing *Sierra Club v. EPA*, 294 F.3d 155, 161 (D.C. Cir. 2002)).

2019, ozone infrastructure SIP submissions as satisfying the requirements of CAA section 110(a)(2)(D)(i)(I) for the 2015 ozone NAAQS. The EPA proposed to determine that the basis for the prior SIP approval was invalidated by the Agency's more recent technical evaluation of air quality modeling performed in support of the proposed rule,¹¹⁴ and that Delaware had unresolved interstate transport obligations for the 2015 ozone NAAQS. The EPA also proposed to issue a FIP for Delaware given these unresolved interstate transport obligations. However, based on the updated air quality modeling described in section IV.F. of this document and the technical assessment that informs this final rule, the EPA finds that Delaware is not projected to be linked to any downwind receptor above the 1 percent of the NAAQS threshold in 2023. Thus, based on the record before the Agency now, the original approval of Delaware's SIP submission was not in error, and the EPA is withdrawing its proposed error correction and proposed FIP for Delaware.

2. Application of Rule in Indian Country and Necessary or Appropriate Finding

The EPA is finalizing its determination that this rule will be applicable in all areas of Indian country (as defined at 18 U.S.C. 1151) within the covered geography of the final rule, as defined in this section. Certain areas of Indian country within the geography of the rule are or may be subject to state implementation planning authority. Other areas of Indian country within that geography are subject to tribal planning authority, although none of the relevant tribes have as yet sought eligibility to administer a tribal plan to implement the good neighbor provision.¹¹⁵ As described later, the

¹¹⁴ See the Air Quality Modeling Proposed Rule TSD in the docket for this rule.

¹¹⁵ We note that, consistent with the EPA's prior good neighbor actions in California, the regulatory ozone monitor located on the Morongo Band of Mission Indians ("Morongo") reservation is a projected downwind receptor in 2023. See monitoring site 060651016 in Table IV.D-1. We also note that the Temecula, California, regulatory ozone monitor is a projected downwind receptor in 2023 and in past regulatory actions has been deemed representative of air quality on the Pechanga Band of Luiseño Indians ("Pechanga") reservation. See, e.g., *Approval of Tribal Implementation Plan and Designation of Air Quality Planning Area; Pechanga Band of Luiseño Mission Indians*, 80 FR 18120, at 18121–18123 (April 3, 2015); see also monitoring site 060650016 in Table IV.D-1. The presence of receptors on, or representative of, the Morongo and Pechanga reservations does not trigger obligations for the Morongo and Pechanga Tribes. Nevertheless, these receptors are relevant to the EPA's assessment of

EPA is including all areas of Indian country within the covered geography, notwithstanding whether those areas are currently subject to a state's implementation planning authority or the potential planning authority of a tribe.

a. Indian Country Subject to Tribal Jurisdiction

With respect to areas of Indian country not currently subject to a state's implementation planning authority—*i.e.*, Indian reservation lands (with the partial exception of reservation lands located in the State of Oklahoma, as described further in this section) and other areas of Indian country over which the EPA or a tribe has demonstrated that a tribe has jurisdiction—the EPA here makes a "necessary or appropriate" finding that direct Federal implementation of the rule's requirements is warranted under CAA section 301(d)(4) and 40 CFR 49.11(a) (the areas of Indian country subject to this finding will be referred to as the CAA section 301(d) FIP areas). Indian Tribes may, but are not required to, submit tribal plans to implement CAA requirements, including the good neighbor provision. Section 301(d) of the CAA and 40 CFR part 49 authorize the Administrator to treat an Indian Tribe in the same manner as a state (*i.e.*, TAS) for purposes of developing and implementing a tribal plan implementing good neighbor obligations. See 40 CFR 49.3; see also "Indian Tribes: Air Quality Planning and Management," hereafter "Tribal Authority Rule" (63 FR 7254, February 12, 1998). The EPA is authorized to directly implement the good neighbor provision in the 301(d) FIP areas when it finds, consistent with the authority of CAA section 301—which the EPA has exercised in 40 CFR 49.11—that it is necessary or appropriate to do so.¹¹⁶

any linked upwind states' good neighbor obligations. See, e.g., *Approval and Promulgation of Air Quality State Implementation Plans; California; Interstate Transport Requirements for Ozone, Fine Particulate Matter, and Sulfur Dioxide*, 83 FR 65093 (December 19, 2018). Under 40 CFR 49.4(a), tribes are not subject to the specific plan submittal and implementation deadlines for NAAQS-related requirements, including deadlines for submittal of plans addressing transport impacts.

¹¹⁶ See *Arizona Pub. Serv. Co. v. U.S. E.P.A.*, 562 F.3d 1116, 1125 (10th Cir. 2009) (stating that 40 CFR 49.11(a) "provides the EPA discretion to determine what rulemaking is necessary or appropriate to protect air quality and requires the EPA to promulgate such rulemaking"); *Safe Air For Everyone v. U.S. Env't Prot. Agency*, No. 05–73383, 2006 WL 3697684, at *1 (9th Cir., Dec. 15, 2006) ("The statutes and regulations that enable EPA to regulate air quality on Indian reservations provide EPA with broad discretion in setting the content of such regulations.").

The EPA hereby finds that it is both necessary and appropriate to regulate all new and existing EGU and industrial sources meeting the applicability criteria set forth in this rule in all of the 301(d) FIP areas that are located within the geographic scope of coverage of the rule. For purposes of this finding, the geographic scope of coverage of the rule means the areas of the United States encompassed within the borders of the states the EPA has determined to be linked at Steps 1 and 2 of the 4-step interstate transport framework.¹¹⁷ For EGU applicability criteria, *see* section VI.B of this document; for industrial-source applicability criteria, *see* section VI.C of this document. To EPA's knowledge, only one existing EGU or industrial source is located within the CAA section 301(d) FIP areas: the Bonanza Power Plant, an EGU source, located on the Uintah and Ouray Reservation, geographically located within the borders of Utah.

This finding is consistent with the EPA's prior good neighbor rules. In prior rulemakings under the good neighbor provision, the EPA has included all areas of Indian country within the geographic scope of those FIPs, such that any new or existing sources meeting the rules' applicability criteria would be subject to the rule irrespective of whether subject to state or tribal underlying CAA planning authority. In CSAPR, the CSAPR Update, and the Revised CSAPR Update, the scope of the emissions trading programs established for EGUs extended to cover all areas of Indian country located within the geographic boundaries of the covered states. In these rules, at the time of their promulgation, no existing units were located in the covered areas of Indian country; under the general applicability criteria of the trading programs, however, any new sources locating in such areas would become subject to the programs. Thus, the EPA established a separate allowance allocation that would be available for any new units locating in any of the relevant areas of Indian country. *See, e.g.*, 76 FR 48293 (describing the CSAPR methodology of allowance allocation under the "Indian country new unit set-aside" provisions); *see also id.* at 48217 (explaining the EPA's source of authority for directly regulating in relevant areas of Indian

country as necessary or appropriate). Further, in any action in which the EPA subsequently approved a state's SIP submittal to partially or wholly replace the provisions of a CSAPR FIP, the EPA has clearly delineated that it will continue to administer the Indian country new unit set aside for sources in any areas of Indian country geographically located within a state's borders and not subject to that state's CAA planning authority, and the state may not exercise jurisdiction over any such sources. *See, e.g.*, 82 FR 46674, 46677 (October 6, 2017) (approving Alabama's SIP submission establishing a state CSAPR trading program for ozone season NO_x, but providing, "The SIP is not approved to apply on any Indian reservation land or in any other area where EPA or an Indian tribe has demonstrated that a tribe has jurisdiction.").

In this rule, the EPA is taking an approach similar to the prior CSAPR rulemakings with respect to regulating sources in the CAA section 301(d) FIP areas.¹¹⁸ The EPA believes this approach is necessary and appropriate for several reasons. First, the purpose of this rule is to address the interstate transport of ozone on a national scale, and the technical record establishes that the nonattainment and maintenance receptors located throughout the country are impacted by sources of ozone pollution on a broad geographic scale. The upwind regions associated with each receptor typically span at least two, and often far more, states. Within the broad upwind region covered by this rule, the EPA is applying—consistent with the methodology of allocating upwind responsibility in prior transport rules going back to the NO_x SIP Call—a uniform level of control stringency (as determined separately for linkages existing in 2023, and linkages persisting in 2026). (*See* section V of this document for a discussion of EPA's determination of control stringency for this rule.) Within this approach, consistency in rule requirements across all jurisdictions is vital in ensuring the remedy for ozone transport is, in the words of the Supreme Court, "efficient and equitable," 572 U.S. 489, 519. In particular, as the Supreme Court found in *EME Homer City Generation*, allocating responsibility through uniform levels of control across the

entire upwind geography is "equitable" because, by imposing uniform cost thresholds on regulated States, the EPA's rule subjects to stricter regulation those States that have done relatively less in the past to control their pollution. Upwind States that have not yet implemented pollution controls of the same stringency as their neighbors will be stopped from free riding on their neighbors' efforts to reduce pollution. They will have to reduce their emissions by installing devices of the kind in which neighboring States have already invested. *Id.*

In the context of addressing regional-scale ozone transport in this rule, the importance of a uniform level of stringency that extends to and includes the CAA section 301(d) FIP areas geographically located within the boundaries of the linked upwind states carries significant force. Failure to include all such areas within the scope of the rule creates a significant risk that these areas may be targeted for the siting of facilities emitting ozone-precursor pollutants, to avoid the regulatory costs that would be imposed under this rule in the surrounding areas of state jurisdiction. Electricity generation or the production of other goods and commodities may become more cost-competitive at any EGU or industrial sources not subject to the rule but located in a geography where the same types of sources are subject to the rule. For instance, the affected EGU source located on the Uintah and Ouray Reservation of the Ute Tribe is in an area that is interconnected with the western electricity grid and is owned and operated by an entity that generates and provides electricity to customers in several states. It is both necessary and appropriate, in the EPA's view, to avoid creating, via this rule, a structure of incentives that may cause generation or production—and the associated NO_x emissions—to shift into the CAA section 301(d) FIP areas to escape regulation needed to eliminate interstate transport under the good neighbor provision.

The EPA finds it is appropriate to directly implement the rule's requirements in the CAA section 301(d) FIP areas in this action rather than at a later date. Tribes have the opportunity to seek treatment as a state (TAS) and to undertake tribal implementation plans under the CAA. To date, the one tribe which could develop and seek approval of a tribal implementation plan to address good neighbor obligations with respect to an existing EGU in the CAA section 301(d) FIP areas for the 2015 ozone NAAQS (or for any other NAAQS), the Ute Indian Tribe of the Uintah and Ouray Reservation, has not

¹¹⁷ With respect to any industrial sources located in the CAA section 301(d) FIP areas, the geographic scope of coverage of this rule does not include those states for which the EPA finds, based on air quality modeling, that no further linkage exists by the 2026 analytic year at Steps 1 and 2. The states in this rule not linked in 2026 are Alabama, Minnesota, and Wisconsin.

¹¹⁸ *See* section VI.B.9 of this document for a discussion of revisions that are being made in this rulemaking regarding the point in the allowance allocation process at which the EPA would establish set-asides of allowances for units in Indian country not subject to a state's CAA implementation planning authority.

expressed an intent to do so. Nor has the EPA heard such intentions from any other tribe, and it would not be reasonable to expect tribes to undertake that planning effort, particularly when no existing sources are currently located on their lands. Further, the EPA is mindful that under court precedent, the EPA and states bear an obligation to fully implement any required emissions reductions to eliminate significant contribution under the good neighbor provision as expeditiously as practicable and in alignment with downwind areas' attainment schedule under the Act. As discussed in section VI.A of this document, the EPA is implementing certain required emissions reductions by the 2023 ozone season, the last full ozone season before the 2024 Moderate area attainment date, and other key additional required emissions reductions by the 2026 ozone season, the last full ozone season before the 2027 Serious area attainment date. Absent the application of this FIP in the CAA section 301(d) FIP areas, NO_x emissions from any existing or new EGU or non-EGU sources located in, or locating in, the CAA section 301(d) FIP areas within the covered geography of the rule would remain unregulated for purposes of CAA section 110(a)(2)(D)(i)(I) for the 2015 ozone NAAQS and could continue or potentially increase. This would be inconsistent with the EPA's overall goal of aligning good neighbor obligations with the downwind areas' attainment schedule and to achieve emissions reductions as expeditiously as practicable.

Further, the EPA recognizes that Indian country, including the CAA section 301(d) FIP areas, is often home to communities with environmental justice concerns, and these communities may bear a disproportionate level of pollution burden as compared with other areas of the United States. The EPA's Fiscal Year 2022–2026 Strategic Plan¹¹⁹ includes an objective to promote environmental justice at the Federal, Tribal, state, and local levels and states: "Integration of environmental justice principles into all EPA activities with Tribal governments and in Indian country is designed to be flexible enough to accommodate EPA's Tribal program activities and goals, while at the same time meeting the Agency's environmental justice goals." As described in section X.F of this document, the EPA offered Tribal consultation to 574 Tribes in April of 2022 and received no requests for Tribal

consultation after publication of the proposed rulemaking. By including all areas of Indian country within the covered geography of the rule, the EPA is advancing environmental justice, lowering pollution burdens in such areas, and preventing the potential for "pollution havens" to form in such areas as a result of facilities seeking to locate there to avoid the requirements that would otherwise apply outside of such areas under this rule.

Therefore, to ensure timely alignment of all needed emissions reductions within the timetables of this rule, to ensure equitable distribution of the upwind pollution reduction obligation across all upwind jurisdictions, to avoid perverse economic incentives to locate sources of ozone-precursor pollution in the CAA section 301(d) FIP areas, and to deliver greater environmental justice to tribal communities in line with Executive Order 13985: Advancing Racial Equity and Support for Underserved Communities Through the Federal Government,¹²⁰ the EPA finds it both necessary and appropriate that all existing and new EGU and industrial sources that are located in the CAA section 301(d) FIP areas within the geographic boundaries of the covered states, and which would be subject to this rule if located within areas subject to state CAA planning authority, should be included in this rule. The EPA issues this finding under CAA section 301(d)(4) of the Act and 40 CFR 49.11. Further, to avoid "unreasonable delay" in promulgating this FIP, as required under section 49.11, the EPA makes this finding now, to align emissions reduction obligations for any covered new or existing sources in the CAA section 301(d) FIP areas with the larger schedule of reductions under this rule. Because all other covered EGU and non-EGU sources within the geography of this rule would be subject to emissions reductions of uniform stringency beginning in the 2023 ozone season, and as necessary to fully and expeditiously address good neighbor obligations for the 2015 ozone NAAQS, there is little benefit to be had by not including the CAA section 301(d) FIP areas in this rule now and a potentially significant downside to not doing so.

The Agency recognizes that Tribal governments may still choose to seek TAS to develop a Tribal plan with respect to the obligations under this rule, and this determination does not preclude the tribes from taking such

actions. Although the formal tribal consultation process associated with this action has concluded, the EPA is willing and available to engage with any tribe as this rule is implemented.

b. Indian Country Subject to State Implementation Planning Authority

Following the U.S. Supreme Court decision in *McGirt v. Oklahoma*, 140 S. Ct. 2452 (2020), the Governor of the State of Oklahoma requested approval under section 10211(a) of the Safe, Accountable, Flexible, Efficient Transportation Equity Act of 2005: A Legacy for Users, Public Law 109–59, 119 Stat. 1144, 1937 (August 10, 2005) ("SAFETEA"), to administer in certain areas of Indian country (as defined at 18 U.S.C. 1151) the State's environmental regulatory programs that were previously approved by the EPA for areas outside of Indian country. The State's request excluded certain areas of Indian country further described later. In addition, the State only sought approval to the extent that such approval is necessary for the State to administer a program in light of *Oklahoma Dept. of Environmental Quality v. EPA*, 740 F.3d 185 (D.C. Cir. 2014).¹²¹

On October 1, 2020, the EPA approved Oklahoma's SAFETEA request to administer all the State's EPA-approved environmental regulatory programs, including the Oklahoma SIP, in the requested areas of Indian country.¹²² As requested by Oklahoma, the EPA's approval under SAFETEA does not include Indian country lands, including rights-of-way running through the same, that: (1) qualify as Indian allotments, the Indian titles to which have not been extinguished, under 18 U.S.C. 1151(c); (2) are held in trust by the United States on behalf of an individual Indian or Tribe; or (3) are owned in fee by a Tribe, if the Tribe (a) acquired that fee title to such land, or an area that included such land, in accordance with a treaty with the United States to which such Tribe was a party, and (b) never allotted the land to a member or citizen of the Tribe

¹²¹ In *ODEQ v. EPA*, the D.C. Circuit held that under the CAA, a state has the authority to implement a SIP in non-reservation areas of Indian country in the state, where there has been no demonstration of tribal jurisdiction. Under the D.C. Circuit's decision, the CAA does not provide authority to states to implement SIPs in Indian reservations. *ODEQ* did not, however, substantively address the separate authority in Indian country provided specifically to Oklahoma under SAFETEA. That separate authority was not invoked until the State submitted its request under SAFETEA, and was not approved until the EPA's decision, described in this section, on October 1, 2020.

¹²² Available in the docket for this rulemaking.

¹¹⁹ <https://www.epa.gov/system/files/documents/2022-03/fy-2022-2026-epa-strategic-plan.pdf>.

¹²⁰ Executive Order 13985 (January 20, 2021) (86 FR 7009 (January 25, 2021)); <https://www.govinfo.gov/content/pkg/FR-2021-01-25/pdf/2021-01753.pdf>.

(collectively “excluded Indian country lands”).

The EPA’s approval under SAFETEA expressly provided that to the extent EPA’s prior approvals of Oklahoma’s environmental programs excluded Indian country, any such exclusions are superseded for the geographic areas of Indian country covered by the EPA’s approval of Oklahoma’s SAFETEA request.¹²³ The approval also provided that future revisions or amendments to Oklahoma’s approved environmental regulatory programs would extend to the covered areas of Indian country (without any further need for additional requests under SAFETEA).

In a **Federal Register** document published on February 13, 2023 (88 FR 9336), the EPA disapproved the portion of an Oklahoma SIP submittal pertaining to the state’s interstate transport obligations under CAA section 110(a)(2)(D)(i)(I) for the 2015 ozone NAAQS. Consistent with the D.C. Circuit’s decision in *ODEQ v. EPA* and with the EPA’s October 1, 2020 SAFETEA approval, the EPA has authority under CAA section 110(c) to promulgate a FIP as needed to address the disapproved aspects of Oklahoma’s good neighbor SIP submittal.¹²⁴ In accordance with the previous discussion, the EPA’s FIP authority in this circumstance extends to all Indian country in Oklahoma, other than the excluded Indian country lands, as described previously.¹²⁵ Because—per the State’s request under SAFETEA—EPA’s October 1, 2020 approval does not displace any SIP authority previously exercised by the State under the CAA as interpreted in *ODEQ v. EPA*, the EPA’s FIP authority under CAA section 110(c) also applies to any Indian

¹²³ The EPA’s prior approvals relating to Oklahoma’s SIP frequently noted that the SIP was not approved to apply in areas of Indian country (consistent with the D.C. Circuit’s decision in *ODEQ v. EPA*) located in the state. See, e.g., 85 FR 20178, 20180 (April 10, 2020). Such prior expressed limitations are superseded by the EPA’s approval of Oklahoma’s SAFETEA request.

¹²⁴ The antecedent fact that the state had the authority and jurisdiction to implement requirements under the good neighbor provision, in the EPA’s view, supplies the condition necessary for the Agency to exercise its FIP authority to the extent the EPA has disapproved the state’s SIP submission with respect to those requirements. Under CAA section 110(c), the EPA “stands in the shoes of the defaulting state, and all of the rights and duties that would otherwise fall to the state accrue instead to the EPA.” *Central Ariz. Water Conservation Dist. v. EPA*, 990 F.2d 1531, 1541 (9th Cir. 1993).

¹²⁵ With respect to those areas of Indian country constituting “excluded Indian country lands” in the State of Oklahoma, as defined supra, the EPA applies the same necessary or appropriate finding as set forth above with respect to all other 301(d) FIP areas within the geographic scope of coverage of the rule.

allotments or dependent Indian communities located outside of an Indian reservation over which there has been no demonstration of tribal authority. The EPA’s FIP authority under CAA section 110(c) similarly applies to Indian allotments or dependent Indian communities located outside of an Indian reservation over which there has been no demonstration of tribal authority located in any other state within the geographic scope of this rule.

In light of the relevant legal authorities discussed above regarding the scope of the State of Oklahoma’s regulatory jurisdiction under the CAA, the EPA has FIP authority under CAA section 110(c) with respect to all Indian country in Oklahoma other than excluded Indian country lands. To the extent any change occurs in the scope of Oklahoma’s SIP authority in Indian country following finalization of this rule, and such change affects the exercise of FIP authority provided under section 110(c) of the Act,¹²⁶ then, to the extent any such areas would fall more appropriately within the CAA section 301(d) FIP areas as described in section III.C.2.a of this document, the EPA’s necessary or appropriate finding as set forth above with respect to all other CAA section 301(d) FIP areas within the geographic scope of coverage of the rule would apply.

D. Severability

The EPA regards this action as a complete remedy, which will as expeditiously as practicable implement good neighbor obligations for the 2015 ozone NAAQS for the covered states, consistent with the requirements of the Act. See *North Carolina v. EPA*, 531 F.3d 896, 911–12 (D.C. Cir. 2008); *Wisconsin v. EPA*, 938 F.3d 303, 313–20 (D.C. Cir. 2019); *Maryland v. EPA*, 958 F.3d 1185, 1204 (D.C. Cir. 2020); *New York v. EPA*, 964 F.3d 1214, 1226 (D.C. Cir. 2020); *New York v. EPA*, 781 Fed. App’x 4, 7–8 (D.C. Cir. 2019) (all holding that the EPA must address good neighbor obligations as expeditiously as practicable and by no later than the next applicable attainment date). Yet should a court find any discrete aspect of this document to be invalid, the Agency

¹²⁶ On December 22, 2021, the EPA proposed to withdraw and reconsider the October 1, 2020, SAFETEA approval. See <https://www.epa.gov/ok/proposed-withdrawal-and-reconsideration-and-supporting-information>. The EPA is engaging in further consultation with tribal governments and expects to have discussions with the State of Oklahoma as part of this reconsideration. The EPA also notes that the October 1, 2020, approval is the subject of a pending challenge in Federal court. *Pawnee Nation of Oklahoma v. Regan*, No. 20–9635 (10th Cir.).

believes that the remaining aspects of this rule can and should continue to be implemented to the extent possible. In particular, this action promulgates a FIP for each covered state (and, pursuant to CAA section 301(d), for each area of tribal jurisdiction within the geographic boundaries of those states). Should any jurisdiction-specific aspect of the final rule be found invalid, the EPA views this rule as severable along those state and/or tribal jurisdictional lines, such that the rule can continue to be implemented as to any remaining jurisdictions. This action promulgates discrete emissions control requirements for the power sector and for each of seven other industries. Should any industry-specific aspect of the final rule be found invalid, the EPA views this rule as severable as between the different industries and different types of emissions control requirements. This is not intended to be an exhaustive list of the ways in which the rule may be severable. In the event any part of it is found invalid, our intention is that the remaining portions should continue to be implemented consistent with any judicial ruling.

The EPA’s conclusion that this rule is severable also reflects the important public health and environmental benefits of this rulemaking in eliminating significant contribution and to ensure to the greatest extent possible the ability of both upwind states and downwind states and other relevant stakeholders to be able to rely on this final rule in their planning. Cf. *Wisconsin*, 938 F.3d at 336–37 (“As a general rule, we do not vacate regulations when doing so would risk significant harm to the public health or the environment.”); *North Carolina v. EPA*, 550 F.3d 1176, 1178 (D.C. Cir. 2008) (noting the need to preserve public health benefits); *EME Homer City v. EPA*, 795 F.3d 118, 132 (D.C. Cir. 2015) (noting the need to avoid disruption to emissions trading market that had developed).

IV. Analyzing Downwind Air Quality Problems and Contributions From Upwind States

A. Selection of Analytic Years for Evaluating Ozone Transport Contributions to Downwind Air Quality Problems

In this section, the EPA describes its process for selecting analytic years for air quality modeling and analyses performed to identify nonattainment and maintenance receptors and identify upwind state linkages. For this final rule, the EPA evaluated air quality to identify receptors at Step 1 for two

analytic years: 2023 and 2026. The EPA evaluated interstate contributions to these receptors from individual upwind states at Step 2 for these two analytic years. In selecting these years, the EPA views 2023 and 2026 to constitute years by which key emissions reductions from EGUs and non-EGUs can be implemented “as expeditiously as practicable.” In addition, these years are the last full ozone seasons before the Moderate and Serious area attainment dates for the 2015 ozone NAAQS (ozone seasons run each year from May 1–September 30). To demonstrate attainment by these deadlines, downwind states would be required to rely on design values calculated using ozone data from 2021 through 2023 and 2024 through 2026, respectively. By focusing its analysis, and, potentially, achieving emissions reductions by, the last full ozone seasons before the attainment dates (*i.e.*, in 2023 or 2026), this final rule can assist the downwind areas with demonstrating attainment or receiving extensions of attainment dates under CAA section 181(a)(5). (The EPA explains in detail in sections V and VI of this document its determinations regarding which emissions reduction strategies can be implemented by 2023, and which emissions reduction strategies require additional time beyond that ozone season, or the 2026 ozone season.)

It would not be logical for the EPA to analyze any earlier year than 2023. The EPA continues to interpret the good neighbor provision as forward-looking, based on Congress’s use of the future-tense “will” in CAA section 110(a)(2)(D)(i), an interpretation upheld in *Wisconsin*, 938 F.3d at 322. It would be “anomalous,” *id.*, for the EPA to impose good neighbor obligations in 2023 and future years based solely on finding that “significant contribution” had existed at some time in the past. *Id.*

Applying this framework in the proposal, the EPA recognized that the 2021 Marginal area attainment date had already passed. Further, based on the timing of the proposal, it was not possible to finalize this rulemaking before the 2022 ozone season had also passed. Thus, the EPA has selected 2023 as the first appropriate future analytic year for this final rule because it reflects implementation of good neighbor obligations as expeditiously as practicable and coincides with the August 3, 2024, Moderate area attainment date established for the 2015 ozone NAAQS.

The EPA conducted additional analysis for 2026 to ensure a complete Step 3 analysis for future ozone transport contributions to downwind

areas. As noted above, 2023 and 2026 coincide with the last full ozone seasons before future attainment dates for the 2015 ozone NAAQS. In addition, 2026 coincides with the ozone season by which key additional emissions reductions from EGUs and non-EGUs become available. Thus, the EPA analyzed additional years beyond 2023 to determine whether any additional emissions reductions that are impossible to obtain by the 2024 attainment date could still be necessary to fully address significant contribution. In all cases, implementation of necessary emissions reductions is as expeditiously as practicable, with all possible emissions reductions implemented by the next applicable attainment date.

The timing framework and selection of analytic years set forth above comports with the D.C. Circuit’s direction in *Wisconsin* that implementing good neighbor obligations beyond the dates established for attainment may be justified on a proper showing of impossibility or necessity. *See* 938 F.3d at 320.

Comment: A commenter claims that the EPA has not followed the holdings of *Wisconsin v. EPA*, 938 F.3d 303 (D.C. Cir. 2019), *North Carolina v. EPA*, 550 F.3d 1176 (D.C. Cir. 2008), and *Maryland v. EPA*, 958 F.3d 1185 (D.C. Cir. 2020) in the selection of analytic years, in that commenter interprets those decisions as holding that the EPA must “harmonize” the exact timing of upwind emissions reductions with when downwind states implement their required reductions. Commenter also points to the EPA’s proposed action on New York’s Good Neighbor SIP submission specifically to argue that the EPA is treating upwind and downwind states dissimilarly. Commenter also cites CAA sections 172, 177, and 179 to argue the EPA did not properly align upwind and downwind obligations. Several commenters believe the EPA should defer implementing good neighbor requirements until downwind receptor areas have first implemented their own emissions control strategies.

Response: The EPA maintains that 2023 is an appropriate analytic year and comports with the relevant caselaw. Section VI.A further discusses the compliance schedule for emissions reductions under this rule. Commenter misreads the *North Carolina*, *Wisconsin*, and *Maryland* decisions as calling for good neighbor analysis and emissions controls to be aligned with the timing of the implementation of nonattainment controls by downwind states. However, the D.C. Circuit has held that the *statutory attainment dates* are the

relevant downwind deadlines the EPA must align with in implementing the good neighbor provision. In *Wisconsin*, the court held, “In sum, under our decision in *North Carolina*, the Good Neighbor Provision calls for elimination of upwind States’ significant contributions *on par with the relevant downwind attainment deadlines.*” *Wisconsin*, 938 F.3d. at 321 (emphasis added).

After that decision, the EPA interpreted *Wisconsin* as limited to the attainment dates for Moderate or higher classifications under CAA section 181 on the basis that Marginal nonattainment areas have reduced planning requirements and other considerations. *See, e.g.*, 85 FR 29882, 29888–89 (May 19, 2020) (proposed approval of South Dakota’s 2015 ozone NAAQS good neighbor SIP). However, on May 19, 2020, the D.C. Circuit in *Maryland v. EPA*, 958 F.3d 1185 (D.C. Cir. 2020), applying the *Wisconsin* decision, rejected that argument and held that the EPA must assess air quality at the next downwind attainment date, including Marginal area attainment dates under CAA section 181, in evaluating the basis for the EPA’s denial of a petition under CAA section 126(b). 958 F.3d at 1203–04. After *Maryland*, the EPA acknowledged that the Marginal attainment date is the first attainment date to consider in evaluating good neighbor obligations. *See, e.g.*, 85 FR 67653, 67654 (Oct. 26, 2020) (final approval of South Dakota’s 2015 ozone NAAQS good neighbor SIP).

The D.C. Circuit again had occasion to revisit the Agency’s interpretation of *North Carolina*, *Wisconsin*, and *Maryland*, in a challenge to the Revised CSAPR Update brought by the Midwest Ozone Group (MOG). The court declined to entertain similar arguments to those presented by commenters here and instead in a footnote explained that it had “exhaustively summarized the regulatory framework governing EPA’s conduct” and that it “[drew] on those decisions and incorporate them herein by reference,” citing, among other cases, *Maryland*, 958 F.3d 1185, and *New York*, 781 F. App’x 4. *MOG v. EPA*, No. 21–1146 (D.C. Cir. March 3, 2023), Slip Op. at 3 n.1.

The relevance of CAA sections 172, 177, and 179 to the selection of the analytic year in this action is not clear. Commenter cites these provisions to conclude that the EPA did not appropriately consider downwind attainment deadlines and the timing of upwind good neighbor obligations. These provisions are found in subpart I, and while they may have continuing

relevance or applicability to aspects of ozone nonattainment planning requirements, the nonattainment dates for the 2015 ozone NAAQS flow from subpart 2 of title I of the CAA, and specifically CAA section 181(a). Applying that statutory schedule to the designations for the 2015 ozone NAAQS, the EPA has promulgated the applicable attainment dates in its regulations at 40 CFR 51.1303. The effective date of the initial designations for the 2015 ozone NAAQS was August 3, 2018 (83 FR 25776, June 4, 2018, effective August 3, 2018).¹²⁷ Thus, the first deadline for attainment planning under the 2015 ozone NAAQS was the Marginal attainment date of August 3, 2021, and the second deadline for attainment planning is the Moderate attainment date of August 3, 2024. If a Marginal area fails to attain by the attainment date it is reclassified, or “bumped up,” to Moderate. Indeed, the EPA has just completed a rulemaking action reclassifying many areas of the country from Marginal to Moderate nonattainment, including all of the areas where downwind receptors have been identified in our 2023 modeling as well as many other areas of the country. 87 FR 60897, 60899 (Oct. 7, 2022).

Other than under the narrow circumstances of CAA section 181(a)(5) (discussed further in this section), the EPA is not permitted under the CAA to extend the attainment dates for areas under a given classification. That is, no matter when or if the EPA finalizes a determination that an area failed to attain by its attainment date and reclassifies that area, the attainment date remains fixed, based on the number of years from the area’s initial designation. See, e.g., CAA section 182(i) (authorizing the EPA to adjust any applicable deadlines for newly reclassified areas “other than attainment dates”). As the D.C. Circuit has repeatedly made clear, the statutory attainment schedule of the downwind nonattainment areas under subpart 2 is rigorously enforced and is not subject to change based on policy considerations of the EPA or the states.

[T]he attainment deadlines, the Supreme Court has said, are “the heart” of the Act. *Train v. Nat. Res. Def. Council*, 421 U.S. 60, 66, 95 S.Ct. 1470, 43 L.Ed.2d 731 (1975); see *Sierra Club v. EPA*, 294 F.3d 155, 161 (D.C. Cir. 2002) (“the attainment deadlines are central to the regulatory scheme”) (alteration and internal quotation marks omitted). The Act’s central object is the “attain[ment] [of] air quality of specified standards [within] a specified period of time.” *Train*, 421 U.S. at 64–65, 95 S.Ct. 1470.

¹²⁷ September 24, 2018, for the San Antonio area. 83 FR 35136 (July 25, 2018).

Wisconsin, 938 F.3d at 316. See also *Natural Resources Defense Council v. EPA*, 777 F.3d 456, 466–68 (D.C. Cir. 2014) (holding the EPA cannot adjust the section 181 attainment schedule to run from any other date than from the date of designation); *id.* at 468 (“EPA identifies no statutory provision giving it free-form discretion to set Subpart 2 compliance deadlines based on its own policy assessment concerning the number of ozone seasons within which a nonattainment area should be expected to achieve compliance.”) (citing and quoting *Whitman v. American Trucking Ass’n*, 531 U.S. 457, 484, (2001) (“The principal distinction between Subpart 1 and Subpart 2 is that the latter eliminates regulatory discretion that the former allowed.”). Furthermore, as the court in *NRDC* noted, “[T]he ‘attainment deadlines . . . leave no room for claims of technological or economic infeasibility.’” 777 F.3d at 488 (quoting *Sierra Club*, 294 F.3d at 161) (internal quotation marks and brackets omitted).

With the exception of the Uinta Basin, which is not an identified receptor in this action, no Marginal nonattainment area met the conditions of CAA section 181(a)(5) to obtain a one-year extension of the Moderate area attainment date. 87 FR 60899. Thus, all Marginal areas (other than Uinta) that failed to attain have been reclassified to Moderate. *Id.* (And the New York City Metropolitan nonattainment area was initially classified as Moderate (see following text for further details).) Even if the EPA had extended the attainment date for any of the downwind areas, it is not clear that it would necessarily follow that the EPA must correspondingly extend or delay the implementation of good neighbor obligations. While the *Wisconsin* court recognized extensions under CAA section 181(a)(5) as a possible source of timing flexibility in implementing the good neighbor provision, 938 F.3d at 320, the EPA and the states are still obligated to implement good neighbor reductions as expeditiously as practicable and are also obligated under the good neighbor provision to address “interference with maintenance.” Areas that have obtained an extension under CAA section 181(a)(5) or which are not designated as in nonattainment could still be identified as struggling to maintain the NAAQS, and the EPA is obligated under the good neighbor provision to eliminate upwind emissions interfering with the ability to maintain the NAAQS, as well. *North Carolina*, 531 F.3d at 908–11. Thus, while an extension under CAA section 181(a)(5) may be a source

of flexibility for the EPA to consider in the timing of implementation of good neighbor obligations, as *Wisconsin* recognized, it is not the case that the EPA *must* delay or defer good neighbor obligations for that reason, and neither the D.C. Circuit nor any other court has so held.

Commenter is therefore incorrect to the extent that they argue the selection of 2023 as an analytic year for upwind obligations results in the misalignment of downwind and upwind state obligations. To the contrary, both downwind and upwind state obligations are driven by the statutory attainment date of August 3, 2024 for Moderate areas, and the last year that air quality data may impact whether nonattainment areas are found to have attained by the attainment date is 2023. That is why, in the recent final rulemaking determinations that certain Marginal areas failed to attain by the attainment date, bumping those areas up to Moderate, and giving them SIP submission deadlines, reasonably available control measures (RACM), and reasonably RACT implementation deadlines, the EPA set the attainment SIP submission deadlines for the bumped up Moderate areas to be January 1, 2023. See 87 FR 60897, 60900 (Oct. 7, 2022). The implementation deadline for RACM and RACT is also January 1, 2023. *Id.* This was in large part driven by the EPA’s ozone implementation regulations, 40 CFR 51.1312(a)(3)(i), which previously established a RACT implementation deadline for initially classified Moderate as no later than January 1, 2023, and the modeling and attainment demonstration requirements in 40 CFR 51.1308(d), which require a state to provide for implementation of all control measures needed for attainment no later than the beginning of the attainment year ozone season (*i.e.*, 2023). Given this regulatory history, the EPA can hardly be accused of letting states with nonattainment areas for the 2015 ozone NAAQS avoid or delay their mandatory CAA obligations.

Commenter’s proposal that the EPA align good neighbor obligations with the actual implementation of measures in downwind areas is untethered from the statute, as discussed above. It is also unworkable in practice. It would necessitate coordinating the activities of multiple states and EPA regional and headquarters offices to an impossible degree and effectively could preclude the implementation of good neighbor obligations altogether. Commenter does not explain how the EPA or upwind states should coordinate upwind emissions control obligations for states

linked to multiple downwind receptors whose states may be implementing their requirements on different timetables. Less drastic mechanisms than subjecting people living in downwind receptor areas to continuing high levels of air pollution caused in part by upwind-state pollution are available if the actual implementation of mandatory CAA requirements in the downwind areas is delayed: CAA section 304(a)(2) provides for judicial recourse where there is an alleged failure by the Agency to perform a nondiscretionary duty; that recourse is for the Agency to be placed on a court-ordered deadline to address the relevant obligations. *See Oklahoma v. U.S. EPA*, 723 F.3d 1201, 1223–24 (10th Cir. 2013); *Montana Sulphur and Chemical Co. v. U.S. EPA*, 666 F.3d 1174, 1190–91 (9th Cir. 2012). Commenter focuses on the EPA's evaluation of New York's Good Neighbor SIP submission to argue the EPA is treating upwind and downwind states dissimilarly. The argument conflates New York's role as both a downwind and an upwind state. In evaluating the Good Neighbor SIP submission that New York submitted, the EPA identified as a basis for disapproval that none of the state emissions control programs New York cited included implementation timeframes to achieve the reductions, let alone ensure they were achieved by 2023. 87 FR 9484, 9494 (Feb. 22, 2022). The EPA conducted the same inquiry into other states' claims regarding their existing or proposed state laws or other emissions reductions claimed in their SIP submissions. *See, e.g.*, 87 FR 9472–73 (evaluating claims regarding emissions reductions anticipated under Maryland's state law); 87 FR 9854 (evaluating claims regarding emissions reductions anticipated under Illinois' state law). Consistent with its treatment of the other upwind states included in this action, the EPA in a separate action disapproved New York's good neighbor SIP submission for the 2015 ozone NAAQS because its arguments did not demonstrate that it had fully prohibited emissions significantly contributing to out of state nonattainment or maintenance problems.

Commenter attempts to contrast this evaluation with what it believes is the EPA's permissive attitude toward delays by downwind states, specifically claiming that “certain nonattainment areas have delayed implementation of nonattainment controls until 2025 and beyond.” This apparently references New York's simple cycle and regenerative combustion turbines (SCCT) controls, which commenter cited elsewhere in its comments. New

York's SCCT controls were not included by New York in its good neighbor SIP submission, nor was the prior approval of the SCCT controls reexamined by the EPA or reopened for consideration by the Agency in this action. Although not part of this rulemaking, the EPA notes that the SCCT controls were approved by the EPA as a SIP strengthening measure and not to satisfy any specific planning requirements for the 2015 ozone NAAQS under CAA section 182. 86 FR 43956, 43958 (Aug. 11, 2021). The SCCT controls submitted to the EPA were already a state rule, and the only effect under the CAA of the EPA approving them into New York's SIP was to make them federally enforceable. 86 FR 43956, 43959 (Aug. 11, 2021). In other words, approval of the SCCT controls did not relieve New York of its nonattainment planning obligations for the 2015 ozone NAAQS.

The EPA notes that the New York-Northern New Jersey-Long Island, NY-NJ-CT nonattainment area was initially designated as Moderate nonattainment. 83 FR 25776 (June 4, 2018). Pursuant to this designation, New York was required to submit a RACT SIP submission and an attainment demonstration no later than 24 months and 36 months, respectively, after the effective date of the Moderate designation. CAA section 182; 40 CFR 51.1308(a), 51.1312(a)(2). New York submitted a RACT SIP for the 2015 ozone standards on January 29, 2021,¹²⁸ and the EPA is currently evaluating that submission. New York has not yet submitted its attainment demonstration, which was due August 3, 2021. Further, the New York-Northern New Jersey-Long Island, NY-NJ-CT nonattainment area remains subject to the Moderate nonattainment area date of August 3, 2024. If it fails to attain the 2015 ozone NAAQS by August 3, 2024, it will be reclassified to Serious nonattainment, resulting in additional requirements on the New York nonattainment area.

In any case, regardless of the status of New York's and the EPA's efforts in relation to the New York-Northern New Jersey-Long Island, NY-NJ-CT nonattainment area (which are outside the scope of this action), the EPA's evaluation of 2023 as the relevant analytic year in assessing New York's and other states' good neighbor obligations is consistent with the statutory framework and court decisions calling on the agency to align these obligations with the downwind areas' statutory attainment schedule. The EPA

¹²⁸ https://edap.epa.gov/public/extensions/S4S_Public_Dashboard_2/S4S_Public_Dashboard_2.html.

further responds to these comments in the *RTC* document in the docket.

The remainder of this section includes information on (1) the air quality modeling platform used in support of the final rule with a focus on the base year and future year base case emissions inventories, (2) the method for projecting design values in 2023 and 2026, and (3) the approach for calculating ozone contributions from upwind states. The Agency also provides the design values for nonattainment and maintenance receptors and the largest predicted downwind contributions in 2023 and 2026 from each state. The 2016 base period and 2023 and 2026 projected design values and contributions for all ozone monitoring sites are provided in the docket for this rule. The “Air Quality Modeling Technical Support Document for the Federal Good Neighbor Plan for the 2015 Ozone National Ambient Air Quality Standards Final Rulemaking” (Mar. 2023), hereinafter referred to as the Air Quality Modeling Final Rule TSD, in the docket for this final rule contains more detailed information on the air quality modeling aspects of this rule.

B. Overview of Air Quality Modeling Platform

The EPA used version 3 of the 2016-based modeling platform (*i.e.*, 2016v3) for the air quality modeling for this final rule. This modeling platform includes 2016 base year emissions from anthropogenic and natural sources and anthropogenic emissions projections for 2023 and 2026. The emissions data contained in this platform represent an update to the 2016 version 2 inventories used for the proposal modeling.

The air quality modeling for this final rule was performed for a modeling region (*i.e.*, modeling domain) that covers the contiguous 48 states using a horizontal resolution of 12 x 12 km. The EPA used the CAMx version 7.10 for air quality modeling which is the same model that EPA used for the proposed rule air quality modeling.¹²⁹ Additional information on the 2016-based air quality modeling platform can be found in the Air Quality Modeling Final Rule TSD.

Comment: Commenters noted that the 2016 base year summer maximum daily average 8-hour (MDA8) ozone predictions from the proposal modeling were biased low compared to the corresponding measured concentrations in certain locations. In this regard, commenters said that model

¹²⁹ Ramboll Environment and Health, January 2021, <https://www.camx.com>.

performance statistics for a number of monitoring sites, particularly those in portions of the West and in the area around Lake Michigan, were outside the range of published performance criteria for normalized mean bias (NMB) and normalized mean error (NME) of less than ± 15 percent and less than 25 percent, respectively (Emory, et al., 2017).¹³⁰ The commenters said EPA must investigate the factors contributing to low bias and make necessary corrections to improve model performance in the final rule modeling. Some commenters said that EPA should include NO_x emissions from lightning strikes and assess the treatment of other background sources of ozone to improve model performance for the final rule. Additional information on the comments on model performance can be found in the *RTC* document for this final rule.

Response: In response to these comments EPA examined the temporal and spatial characteristics of model under prediction to investigate the possible causes of under prediction of MDA8 ozone concentrations in different regions of the U.S. in the proposal modeling. EPA's analysis indicates that the under prediction was most extensive during May and June with less bias during July and August in most regions of the U.S. For example, in the Upper Midwest region model under prediction was larger in May and June compared to July through September. Specifically, in the proposal modeling, the normalized mean bias for days with measured concentrations ≥ 60 ppb improved from a 21.4 percent under prediction for May and June to a 12.6 percent under prediction in the period July through September. As described in the Air Quality Modeling Final Rule TSD, the seasonal pattern in bias in the Upper Midwest region improves somewhat gradually with time from the middle of May to the latter part of June. In view of the seasonal pattern in bias in the Upper Midwest and in other regions of the U.S., EPA focused its investigation of model performance on model inputs that, by their nature, have the largest temporal variation within the ozone season. These inputs include emissions from biogenic sources and lightning NO_x, and contributions from transport of international anthropogenic emissions and natural sources into the U.S. Both biogenic and lightning NO_x

emissions in the U.S. dramatically increase from spring to summer.^{131 132} In contrast, ozone transported into the U.S. from international anthropogenic and natural sources peaks during the period March through June, with lower contributions during July through September.^{133 134} To investigate the impacts of these sources, EPA conducted sensitivity model runs which focused on the effects on model performance of adding NO_x emissions from lightning strikes, updating biogenic emissions, and using an alternative approach for quantifying transport of ozone and precursor pollutants into the U.S. from international anthropogenic and natural sources. The development of lightning NO_x emissions and the updates to biogenic emissions, are described in section IV.C of this document. In the proposal modeling the amount of transport from international anthropogenic and natural sources was based on a simulation of the hemispheric version of the Community Multi-scale Air Quality Model (H-CMAQ) for 2016.¹³⁵ The outputs from this hemispheric modeling were then used to provide boundary conditions for national scale air quality modeling at proposal.¹³⁶ Overall, H-CMAQ tends to

¹³¹ Guenther, A.B., 1997. Seasonal and spatial variations in natural volatile organic compound emissions. *Ecol. Appl.* 7, 34–45. [https://doi.org/10.1890/1051-0761\(1997\)007\[0034:SASVIN\]2.0.CO;2](https://doi.org/10.1890/1051-0761(1997)007[0034:SASVIN]2.0.CO;2). Guenther, A., Hewitt, C.N., Erickson, D., Fall, R.

¹³² Kang D, Mathur R, Pouliot GA, Gilliam RC, Wong DC. Significant ground-level ozone attributed to lightning-induced nitrogen oxides during summertime over the Mountain West States. *NPJ Clim Atmos Sci.* 2020 Jan 30;3:6. doi: 10.1038/s41612-020-0108-2. PMID: 32181370; PMCID: PMC7075249.

¹³³ Jaffe DA, Cooper OR, Fiore AM, Henderson BH, Tonnesen GS, Russell AG, Henze DK, Langford AO, Lin M, Moore T. Scientific assessment of background ozone over the U.S.: Implications for air quality management. *Elementa* (Wash DC). 2018;6(1):56. doi: 10.1252/elementa.309. PMID: 30364819; PMCID: PMC6198683.

¹³⁴ Henderson, B.H., P. Dolwick, C. Jang, A., Eyth, J. Vukovich, R. Mathur, C. Hogrefe, N. Possiel, G. Pouliot, B. Timin, K.W. Appel, 2019. Global Sources of North American Ozone. Presented at the 18th Annual Conference of the UNC Institute for the Environment Community Modeling and Analysis System (CMAS) Center, October 21–23, 2019.

¹³⁵ Mathur, R., Gilliam, R., Bullock, O.R., Roselle, S., Pleim, J., Wong, D., Binkowski, F., and 1 Streets, D.: Extending the applicability of the community multiscale air quality model to 2 hemispheric scales: motivation, challenges, and progress. In: Steyn DG, Trini S (eds) *Air 3 pollution modeling and its applications*, XXI. Springer, Dordrecht, pp 175–179, 2012.

¹³⁶ Boundary conditions are the concentrations of pollutants along the north, east, south, and west boundaries of the air quality modeling domain. Boundary conditions vary in space and time and are typically obtained from predictions of global or hemispheric models. Information on how boundary conditions were developed for the final rule

under-predict daytime ozone concentrations at rural and remote monitoring sites across the U.S. during the spring of 2016 whereas the predictions from the GEOS-Chem global model¹³⁷ were generally less biased.¹³⁸ During the summer of 2016 both models showed varying degrees of over prediction with GEOS-Chem showing somewhat greater over-prediction, compared to H-CMAQ. In view of those results, EPA examined the impacts of using GEOS-Chem as an alternative to H-CMAQ for providing boundary conditions for the final rule modeling.

For the lightning NO_x, biogenics, and GEOS-Chem sensitivity runs, EPA reran the proposal modeling using each of these inputs, individually. Results from these sensitivity runs indicate that each of the three updates provides an improvement in model performance. However, by far the greatest improvement in model performance is attributable to the use of GEOS-Chem. In view of these results EPA has included lightning NO_x emissions, updated biogenic emissions, and international transport from GEOS-Chem in the final rule air quality modeling. Details on the results of the individual sensitivity runs can be found in the Air Quality Modeling Final Rule TSD. For the air quality modeling supporting this final action, model performance based on days in 2016 with measured MDA8 ozone ≥ 60 ppb is considerably improved (*i.e.*, less bias and error) compared to the proposal modeling in nearly all regions of the U.S. For example, in the Upper Midwest, which includes monitoring sites along Lake Michigan, the normalized mean bias improved from a 19 percent under prediction to a 6.9 percent under prediction and in the Southwest region, which includes monitoring sites in Denver and Salt Lake City, normalized mean bias improved from a 13.6 percent under prediction to a 4.8 percent under prediction.¹³⁹ In all regions, the

modeling can be found in the Air Quality Modeling Final Rule TSD.

¹³⁷ I. Bey, D.J. Jacob, R.M. Yantosca, J.A. Logan, B.D. Field, A.M. Fiore, Q. Li, H.Y. Liu, L.J. Mickley, M.G. Schultz. Global modeling of tropospheric chemistry with assimilated meteorology: model description and evaluation. *J. Geophys. Res. Atmos.*, 106 (2001), pp. 23073–23095, 10.1029/2001jd000807.

¹³⁸ Henderson, B.H., P. Dolwick, C. Jang, A., Eyth, J. Vukovich, R. Mathur, C. Hogrefe, G., N. Possiel, B. Timin, K.W. Appel, 2022. Meteorological and Emission Sensitivity of Hemispheric Ozone and PM_{2.5}. Presented at the 21st Annual Conference of the UNC Institute for the Environment Community Modeling and Analysis System (CMAS) Center, October 17–19, 2022.

¹³⁹ A comparison of model performance from the proposal modeling to the final modeling for

Continued

¹³⁰ Christopher Emery, Zhen Liu, Armistead G. Russell, M. Talat Odman, Greg Yarwood & Naresh Kumar (2017) Recommendations on statistics and benchmarks to assess photochemical model performance, *Journal of the Air & Waste Management Association*, 67:5, 582–598, DOI: 10.1080/10962247.1265027.

normalized mean bias and normalized mean error statistics for high ozone days based on the final rule modeling are within the range of performance criteria benchmarks (*i.e.*, $< \pm 15$ percent for normalized mean bias and < 25 percent for normalized mean error).¹⁴⁰

Additional information on model performance is provided in the Air Quality Modeling Final Rule TSD. In summary, EPA included emissions of lightning NO_x, as requested by commenters, and investigated and addressed concerns about model performance for the final rule modeling.

C. Emissions Inventories

The EPA developed emissions inventories to support air quality modeling for this final rule, including emissions estimates for EGUs, non-EGU point sources (*i.e.*, stationary point sources), stationary nonpoint sources, onroad mobile sources, nonroad mobile sources, other mobile sources, wildfires, prescribed fires, and biogenic emissions that are not the direct result of human activities. The EPA's air quality modeling relies on this comprehensive set of emissions inventories because emissions from multiple source categories are needed to model ambient air quality and to facilitate comparison of model outputs with ambient measurements.

Prior to air quality modeling, the emissions inventories were processed into a format that is appropriate for the air quality model to use. To prepare the emissions inventories for air quality modeling, the EPA processed the emissions inventories using the Sparse Matrix Operator Kernel Emissions (SMOKE) Modeling System version 4.9 to produce the gridded, hourly, speciated, model-ready emissions for input to the air quality model. Additional information on the development of the emissions inventories and on data sets used during the emissions modeling process are provided in the document titled, "Technical Support Document (TSD): Preparation of Emissions Inventories for the 2016v3 North American Emissions Modeling Platform" (Jan. 2023), hereafter known as the 2016v3

individual monitoring sites can be found in the docket for this final rule.

¹⁴⁰ Christopher Emery, Zhen Liu, Armistead G. Russell, M. Talat Odman, Greg Yarwood & Naresh Kumar (2017) Recommendations on statistics and benchmarks to assess photochemical model performance, *Journal of the Air & Waste Management Association*, 67:5, 582–598, DOI: 10.1080/10962247.1265027.

Emissions Modeling TSD. This TSD is available in the docket for this rule.¹⁴¹

1. Foundation Emissions Inventory Data Sets

The 2016v3 emissions platform is comprised of data from various sources including data developed using models, methods, and source datasets that became available in calendar years 2020 through 2022, in addition to data retained from the Inventory Collaborative 2016 version 1 (2016v1) Emissions Modeling Platform, released in October 2019. The 2016v1 platform was developed through a national collaborative effort between the EPA and state and local agencies along with MJOs. The 2016v2 platform used to support the proposed action included updated data from the 2017 NEI along with updates to models and methods as compared to 2016v1. The 2016v3 platform includes updates to the 2016v2 platform implemented in response to comments along with other updates to the 2016v2 platform such as corrections and the incorporation of updated data sources that became available prior to the 2016v3 inventories being developed. Several commenters noted that the 2016v2 platform did not include NO_x emissions that resulted from lightning strikes. To address this, lightning NO_x emissions were computed and included in the 2016v3 platform.

For this final rule, the EPA developed emissions inventories for the base year of 2016 and the projected years of 2023 and 2026. The 2023 and 2026 inventories represent changes in activity data and of predicted emissions reductions from on-the-books actions, planned emissions control installations, and promulgated Federal measures that affect anthropogenic emissions.¹⁴² The 2016 emissions inventories for the U.S. primarily include data derived from the 2017 National Emissions Inventory (2017 NEI)¹⁴³ and data specific to the year of 2016. The following sections provide an overview of the construct of the 2016v3 emissions and projections. The fire emissions were unchanged between the 2016v2 and 2016v3 emissions platforms. For the 2016v3 platform, the biogenic emissions were

¹⁴¹ See 2016v3 Emissions Modeling TSD, also available at <https://www.epa.gov/air-emissions-modeling/2016v3-platform>.

¹⁴² Biogenic emissions and emissions from wildfires and prescribed fires were held constant between 2016 and the future years because (1) these emissions are tied to the 2016 meteorological conditions and (2) the focus of this rule is on the contribution from anthropogenic emissions to projected ozone nonattainment and maintenance.

¹⁴³ <https://www.epa.gov/air-emissions-inventories/2017-national-emissions-inventory-nei-technical-support-document-tds>.

updated to use the latest available versions of the Biogenic Emissions Inventory System and associated land use data to help address comments related to a degradation in model performance in the 2016v2 platform as compared to the 2016v1 platform. Details on the construction of the inventories are available in the 2016v3 Emissions Modeling TSD. Details on how the EPA responded to comments related to emissions inventories are available in the *RTC* document for this rule.

2. Development of Emissions Inventories for EGUs

a. EGU Emissions Inventories Supporting This Final Rule

Development of emissions inventories for annual NO_x and SO₂ emissions for EGUs in the 2016 base year inventory are based primarily on data from continuous emissions monitoring systems (CEMS) and other monitoring systems allowed for use by qualifying units under 40 CFR part 75, with other EGU pollutants estimated using emissions factors and annual heat input data reported to the EPA. For EGUs not reporting under Part 75, the EPA used data submitted to the NEI by the state, local, and tribal agencies. The Air Emissions Reporting Rule (80 FR 8787; February 19, 2015), requires that Type A point sources large enough to meet or exceed specific thresholds for emissions be reported to the EPA every year, while the smaller Type B point sources must only be reported to EPA every 3 years. Emissions data for EGUs that did not have data submitted to the NEI specific to the year 2016 were filled in with data from the 2017 NEI. For more information on the details of how the 2016 EGU emissions were developed and prepared for air quality modeling, see the 2016v3 Emissions Modeling TSD.

The EPA projected 2023 and 2026 baseline EGU emissions using the version 6—Updated Summer 2021 Reference Case of the Integrated Planning Model (IPM). IPM, developed by ICF Consulting, is a state-of-the-art, peer-reviewed, multi-regional, dynamic, deterministic linear programming model of the contiguous U.S. electric power sector. It provides forecasts of least cost capacity expansion, electricity dispatch, and emissions control strategies while meeting energy demand and environmental, transmission, dispatch, and reliability constraints. The EPA has used IPM for over two decades, including all prior implemented CSAPR rulemakings, to better understand power sector behavior under future business-

as-usual conditions and to evaluate the economic and emissions impacts of prospective environmental policies. The model is designed to reflect electricity markets as accurately as possible. The EPA uses the best available information from utilities, industry experts, gas and coal market experts, financial institutions, and government statistics as the basis for the detailed power sector modeling in IPM. The model documentation provides additional information on the assumptions discussed here as well as all other model assumptions and inputs.¹⁴⁴ The EPA relied on the same model platform at final as it did at proposal, but made substantial updates to reflect public comments on near-term fossil fuel market price volatility and updated fleet information reflecting Summer 2022 U.S. Energy Information Agency (EIA) 860 data, unit-level comments, and additional updates to the National Electric Energy Data System (NEEDS) inventory.

The IPM version 6—Updated Summer 2021 Reference Case incorporated recent updates through the Summer of 2022 to account for updated Federal and state environmental regulations (including Renewable Portfolio Standards (RPS), Clean Energy Standards (CES) and other state mandates), fleet changes (committed EGU retirements and new builds), electricity demand, technology cost and performance assumptions from recent data (for renewables adopting from National Renewable Energy Lab (NREL's) Annual Technology Baseline 2020 and for fossil sources from EIA's Annual Energy Outlook (AEO) 2020. Natural gas and coal price projections reflect data developed in Fall 2020 but updated in summer of 2022 to capture near-term price volatility and current market conditions. The inventory of EGUs provided as an input to the model was the NEEDS fall 2022 version and is available on EPA's website.¹⁴⁵ This version of NEEDS reflects announced retirements and under-construction new builds known as of early summer 2022. This projected base case accounts for the effects of the finalized Mercury and Air Toxics Standards rule, CSAPR, the CSAPR Update, the Revised CSAPR Update, NSR enforcement settlements, the final ELG Rule, CCR Rule, and other on-the-books Federal and state rules

¹⁴⁴ Detailed information and documentation of EPA's Base Case, including all the underlying assumptions, data sources, and architecture parameters can be found on EPA's website at: <https://www.epa.gov/airmarkets/epas-power-sector-modeling-platform-v6-using-ipm-summer-2021-reference-case>.

¹⁴⁵ Available at <https://www.epa.gov/airmarkets/national-electric-energy-data-system-needs-v6>.

(including renewable energy tax credit extensions from the Consolidated Appropriations Act of 2021) through early 2021 impacting SO₂, NO_x, directly emitted particulate matter, CO₂, and power plant operations. It also includes final actions the EPA has taken to implement the Regional Haze Rule and best available retrofit technology (BART) requirements. Documentation of IPM version 6 and NEEDS, along with updates, is in Docket ID No. EPA-HQ-OAR-2021-0668 and available online at <https://www.epa.gov/airmarkets/power-sector-modeling>. IPM has projected output years for 2023 and 2025. IPM year 2025 outputs were adjusted for known retirements to be reflective of year 2026, and IPM year 2030 outputs were used for the year 2032 as is specified by the mapping of IPM output years to specific years.

Additional 2023 through 2026 EGU emissions baseline levels were developed through engineering analytics as an alternative approach that did not involve IPM. The EPA developed this inventory for use in Step 3 of this final rule, where it determines emissions reduction potential and corresponding state-level emissions budgets. IPM includes optimization and perfect foresight in solving for least cost dispatch. Given that this final rule will likely become effective immediately prior to the start of the 2023 ozone season, the EPA adopted a similar approach to the CSAPR Update and the Revised CSAPR Update where it utilized historical data and an engineering analytics approach in Step 3 to avoid overstating optimization and dispatch decisions in state-emissions budget quantification that may not be possible in a short time frame. The EPA does this by starting with unit-level reported data and only making adjustments to reflect known baseline changes such as planned retirements and new builds (for the base case scenarios) and also identified mitigation strategies for determining state emissions budgets. In both the CSAPR Update and in this rule at Step 3, the EPA complemented that projected IPM EGU outlook with an historical (*e.g.*, engineering analytics) perspective based on historical data that only factors in known changes to the fleet. This 2023 engineering analytics data set is described in more detail in the Ozone Transport Policy Analysis Final Rule TSD and corresponding Appendix A: State Emissions Budgets Calculations and Underlying Data. The Engineering Analysis used in Step 3 is also discussed further in section VII.B of this document.

Both IPM and the Engineering Analytics tools are valuable for estimating future EGU emissions and examining the cone of uncertainty around any future sector-level inventory estimate. A key difference between the two tools is that IPM reflects both announced and projected changes in fleet operation, whereas the Engineering Analytics tool only reflects announced changes. By not including projected regional changes that are anticipated in response to market forces and fleet trends, the Engineering Analysis deliberately creates future estimates of the power sector where state estimates are limited to known changes. Throughout all of the CSAPR rules to date, and prior interstate transport actions, the EPA has used IPM at Steps 1 and 2 as it is best suited for projecting emissions in an airshed, at projecting emissions for time horizons more than a few years out (for which changes would not yet be announced and thus projecting changes is critical), and for scenarios where the assumed change in emissions is not being codified into a state emissions reduction requirement. Using IPM at Steps 1 and 2 helps the EPA avoid overstating the current analytic year receptor values (Step 1) and future year linkages (Step 2) by reflecting reductions anticipated to occur within the airshed in the relevant timeframe.

Engineering analytics has been a useful tool for Step 3 state-level emissions reduction estimates in CSAPR rulemaking, because at that step the EPA is dealing with more geographic granularity (state-level as opposed to regional air shed), more near-term (as opposed to medium-term) assessments, and scenarios where reduction estimates are codified into regulatory requirements. Using the Engineering Analytics tool at this step ensures that the EPA is not codifying into the base case, and consequently into state emissions budgets, changes in the power sector that are merely modeled to occur rather than announced by real-world actors.

Finally, both in the Revised CSAPR Update and in this rule, the EPA was able to use the Air Quality Assessment Tool to determine that regardless of which EGU inventory is used, the 2023 geography of the program is not impacted. In other words, regardless of whether a stakeholder takes a more comprehensive view of the EGU future (IPM) or one limited to current data and known changes (Engineering Analysis), the states that are linked to receptors at Steps 1 and 2 would be the same. This finding is consistent with the observation that EGUs are now less than

10 percent of the total ozone-season NO_x inventory and the degree of near-term difference between the IPM and Engineering Analytic regional projections is relatively small on the regional level. The EPA continues to believe that IPM is best suited for Step 1 and Step 2, and engineering analytics is best suited for Step 3 efforts in this rulemaking. The Ozone Transport Policy Analysis Final Rule TSD contains data on 2023 and 2026 AQ impacts of each dataset.

Comment: Some commenters express concern that using IPM for Step 1 and Step 2 captures generation shifting across state lines, which exceeds the EPA's authority. Moreover, the commenters suggest that the resulting proposed baseline EGU inventory may understate emissions levels as it projects economic retirements that are not yet announced or firm. Other commenters more generally allege that the EPA is using different modeling tools at different steps in its analysis, and this introduces confusion or uncertainty into the basis for the EPA's regulatory conclusions.

Response: The EPA believes the first aspect of this comment, in regards to its focus on generation shifting, is misguided in several ways. For Step 1 and Step 2, the EPA models no incremental generation shifting attributable to the implementation of an emissions control policy at Step 3. Rather, any generation patterns are merely a reflection of the model's projection of how regional load requirements will be met with the generation sources serving that region in the baseline. The EPA is not modeling any additional generation shifting, but merely capturing the expected generation dispatch under anticipated baseline market conditions. Electricity generated in one state regularly is transmitted across state boundaries and is used to serve load in other states; IPM is not incentivizing or requiring any additional generation transfer across state lines in this scenario but is merely projecting the pattern of this behavior in the future. Moreover, as noted previously, the EPA affirms its geographic findings at Step 2 (states contributing over 1 percent of the NAAQS to a downwind receptor) using historical data (engineering analysis) in a sensitivity analysis. These historical data reflect the actual generation patterns observed to meet regional load. Therefore, any suggestion by the commenter that the EPA's projected view of baseline grid dispatch is unreasonable, is mooted by the fact that the use of historical reported generation patterns produces the same result.

Additionally, at the time of the proposal's analysis, the 2023 ozone season was still nearly two years away. Therefore, it was appropriate for EPA's modeling to project economic retirements as those retirements—which are regularly occurring—are often not firm or announced two years in advance. However, for this final rule, the 2023 analytic year was close enough to the period in which EPA was conducting its analysis that such retirements would likely be announced. Therefore, the EPA was able to incorporate those announced and firm retirements to occur in the 2023 year. Further, in recognition of this very near timeframe, we deactivated IPM's ability to project additional economic retirements for the 2023 year (reflecting the notion that any retirements occurring by 2023 would be known at this point). This adjustment further accommodates the commenters' concern that the baseline overstates generation shifting (driven by retirements) in the near term, and consequently understates emissions levels. Finally, with respect to comments that the EPA is using different modeling tools at different steps in the framework, we previously explained why these techniques are appropriate for the purposes at each step of the analysis, and they are not incompatible nor do they produce results so different as to call into question their reliability or the bases for our regulatory determinations (EPA notes that the nationwide projected ozone season total NO_x emissions vary by less than 1 percent in the 2023 analytic year). Nonetheless, we also observe that the effect of using engineering analytics to inform analysis at Steps 1 and 2 would tend to produce higher assumed emissions from EGUs in the baseline than IPM would project in 2026 and beyond and therefore only strengthen and further affirm the Step 1 and Step 2 geographic findings. EPA's use of different tools to project EGU scenarios is not inconsistent, but rather it is carefully explained as a deliberate measure taken to preserve—not introduce—consistency across each of the Steps in the 4-step framework. By using IPM at Step 1 and 2, EPA is selecting the more conservative approach for identifying the degree of nonattainment and geography of states contributing above 1 percent. By using Engineering Analytics at Step 3, EPA is selecting the more conservative value to codify into state-level budgets.

b. Impact of the Inflation Reduction Act on EGU Emissions

The EGU modeling used to construct the EGU emissions inventories used to

inform the modeling projections for 2023 and 2026 was conducted prior to the passage of the Inflation Reduction Act (IRA), Public Law 117–169. The EPA did not have time to incorporate updated EGU projections reflecting the passage of the IRA into the primary air quality modeling for this final rule. However, the EPA was able to perform a sensitivity analysis reflecting the IRA in its EGU NO_x emissions inventories. The results from this scenario were run through AQAT and demonstrated that the status of states identified as linked at the 1 percent of NAAQS contribution threshold (based on the modeling and air quality analysis described in this section) would not change regardless of which inventory (with or without IRA) is used. This sensitivity analysis is presented in the Regulatory Impact Analysis accompanying this rule, and that discussion provides additional detail on the emissions consequences of including the IRA in a baseline EGU inventory. The air quality impact of including the IRA in EPA's emissions inventories and in its Step 3 scenarios is discussed in Appendix K of the Ozone Transport Policy Analysis Final Rule TSD.

The results of this analysis are not surprising and accord with what is generally understood to be the overall effect of the IRA over the short to long term. While the IRA is anticipated to have a potentially dramatic effect on reducing both GHG and conventional pollutant emissions from the power sector, it is likely to have a more substantial impact later in the forecast period (*i.e.*, beyond the attainment deadlines by which the emissions reductions under this final rule must occur). This timing reflects a realistic assessment of utilities', regulators', and transmission authorities' planning requirements associated with the addition of substantial new renewable and storage capacity to the grid, as well as the time needed to integrate that capacity and retire existing capacity. Additionally, the IRA incentives span a longer time period (for example, certain tax incentives for clean energy sources are available until the later of 2032 or the year in which power sector emissions are 75 percent below 2022 levels) and therefore there is no IRA-related deadline to build cleaner generation by 2026. Recent analysis by the Congressional Budget Office supports the finding that the majority of power sector EGU emissions reductions expected from the IRA occur well after the 2023 and 2026 analytic years relevant to the attainment dates and this

rulemaking.¹⁴⁶ While the report focuses on CO₂ rather than NO_x, the drivers of the emissions reductions (primarily increased zero-emitting generation) would generally have a downward impact on both pollutants.

We note that important uncertainties remain at this time in the implementation of the IRA that further counsel against over-assuming short-term emissions reductions for purposes of this rule. The legislation provides economic incentives for shifting to cleaner forms of power generation but does not mandate emissions reductions through an enforceable regulatory program. The strength of those incentives will vary to some extent depending on other key market factors (such as the cost of natural gas or renewable energy technologies). Further, some incentives, such as tax credits for carbon capture and storage, could lead EGUs to remain in operation longer, which could in turn result in greater NO_x emissions, if those emissions are not also well controlled.

Nonetheless, while we find that the passage of the IRA does not affect the geography of the rule in terms of which states we identify as linked, the Agency is confident that the incentives toward clean technology provided in the IRA will, in the longer run beyond the 2015 ozone NAAQS attainment deadlines, facilitate ongoing EGU compliance with the emissions reduction requirements of this rule and will reduce costs borne by EGUs and their customers as the U.S. power sector transitions. As discussed in greater detail in section VI.B of this document, we have made several adjustments in the final rule to provide greater flexibility to EGU owners and operators to integrate this rule's requirements with and facilitate the accelerating transition to an overall cleaner electricity-generating sector, which the IRA represents. Despite the uncertainties inherent in the implementation of the IRA at this time, the EPA also has performed a sensitivity analysis on the final rule to confirm that our finding of no overcontrol is robust to a future with the IRA in effect.

3. Development of Emissions Inventories for Stationary Industrial Point Sources

Non-EGU point source emissions are mostly consistent with those in the proposal modeling except where they were updated in response to comments. Several commenters mentioned that

point source emissions carried forward from 2014 NEI were not the best estimates of 2017 emissions. Thus, emissions sources in 2016v2 that had been projected from the 2014 NEI in the proposal were replaced with emissions based on the 2017 NEI. Point source emissions submitted to the 2016 NEI or to the 2016v1 platform development process specifically for the year 2016 were retained in 2016v3. Other 2016 non-EGU updates in 2016v3 include a few sources being moved to the EGU inventory, the addition of some control efficiency information for the year 2016, the replacement of most emissions projected from 2014 NEI with data from 2017 NEI, and the inclusion of point source data for solvent processes that had not been included in the 2016v2 non-EGU inventory.

The 2023 and 2026 non-EGU point source emissions were grown from 2016 to those years using factors based on the AEO 2022 and reflect emissions reductions due to known national and local rules, control programs, plant closures, consent decrees, and settlements that could be computed as reductions to specific units by July 2022.

Aircraft emissions and ground support equipment at airports are represented as point sources and are based on adjustments to emissions in the January 2021 version of the 2017 NEI. The EPA developed and applied factors to adjust the 2017 airport emissions to 2016, 2023 and 2026 based on activity growth projected by the Federal Aviation Administration Terminal Area Forecast 2021¹⁴⁷ data, the latest available version at the time the factors were developed. By basing the factors on the latest available Terminal Area Forecast that was released following the most significant pandemic impacts on the aviation sector, the reduction and rebound impacts of the pandemic on aircraft and ground support equipment were reflected in the 2023 and 2026 airport emissions.

Emissions at rail yards were represented as point sources. The 2016 rail yard emissions are largely consistent with the 2017 NEI rail yard emissions. The 2016 and 2023 rail yard emissions were developed through the 2016v1 Inventory Collaborative process, with the 2026 emissions interpolated between the 2023 and 2028 emissions from 2016v1 rail yard emissions were interpolated from the 2016 and 2023 emissions. Class I rail yard emissions were projected based on the AEO freight

rail energy use growth rate projections for 2023, and 2026 with the fleet mix assumed to be constant throughout the period.

The EPA made multiple updates to point source oil and gas emissions in response to comments. For the final rule, the point source oil and gas emissions for 2016 were based on the 2016v2 point inventory except that most 2014 NEI-based emissions were replaced with 2017 NEI emissions. Additionally, in response to comments, state-provided emissions equivalent to those in the 2016v1 platform were used for Colorado, and some New Mexico emissions were replaced with data backcast from 2020 to 2016. To develop inventories for 2023 and 2026 for the final rule, the year 2016 oil and gas point source inventories were first projected to 2021 values based on actual historical production data, then those 2021 emissions were projected to 2023 and 2026 using regional projection factors based on AEO 2022 projections. This was an update from the proposal approach that used actual data only through the year 2019, because 2021 data were not yet available. NO_x and VOC reductions resulting from co-benefits of NSPS for Stationary Reciprocating Internal Combustion Engines (RICE) are reflected, along with Natural Gas Turbine and Process Heater NSPS NO_x controls and Oil and Gas NSPS VOC controls. In some cases, year 2019 point source inventory data were used instead of the projected future year emissions except for the Western Regional Air Partnership (WRAP) states of Colorado, New Mexico, Montana, Wyoming, Utah, North Dakota, and South Dakota. The WRAP future year inventory¹⁴⁸ was used in these WRAP states in all future years except in New Mexico where the WRAP base year emissions were projected using the EIA historical and AEO forecasted production data. Estimated impacts from the New Mexico Administrative code 20.2.50¹⁴⁹ were also included.

4. Development of Emissions Inventories for Onroad Mobile Sources

Onroad mobile sources include exhaust, evaporative, and brake and tire wear emissions from vehicles that drive on roads, parked vehicles, and vehicle refueling. Emissions from vehicles using regular gasoline, high ethanol gasoline, diesel fuel, and electric vehicles were represented, along with buses that used compressed natural gas. The EPA

¹⁴⁶ "Emissions of Carbon Dioxide In the Electric Power Sector," Congressional Budget Office, December 2022. Available at <https://www.cbo.gov/publication/58860>.

¹⁴⁷ https://www.faa.gov/data_research/aviation/taf/.

¹⁴⁸ http://www.wrapair2.org/pdf/WRAP_OGWG_2028_OTB_RevFinalReport_05March2020.pdf.

¹⁴⁹ <https://www.srca.nm.gov/parts/title20/20.002.0050.html>.

developed the onroad mobile source emissions for states other than California using the EPA's Motor Vehicle Emissions Simulator (MOVES). MOVES3 was released in November 2020 and has been followed by some minor releases that improved the usage of the model but that do not have substantive impacts on the emissions estimates. For the proposal, MOVES3 was run using inputs provided by state and local agencies through the 2017 NEI where available, in combination with nationally available data sets to develop a complete inventory. Onroad emissions were developed based on emissions factors output from MOVES3 runs for the year 2016, coupled with activity data (e.g., vehicle miles traveled and vehicle populations) representing the year 2016. The 2016 activity data were provided by some state and local agencies through the 2016v1 process, and the remaining activity data were derived from those used to develop the 2017 NEI. The onroad emissions were computed within SMOKE by multiplying emissions factors developed using MOVES with the appropriate activity data. Prior to computing the final rule emissions, updates to some onroad inputs were made in response to comments and to implement corrections. Onroad mobile source emissions for California were consistent with the updated emissions data provided by the state for the final rule.

The 2023 and 2026 onroad emissions reflect projected changes to fuel properties and usage, along with the impact of the rules included in MOVES3 for each of those years. MOVES emissions factors for the years 2023 and 2026 were used. A comprehensive list of control programs included for onroad mobile sources is available in the 2016v3 Emissions Modeling TSD. Year 2023 and 2026 activity data for onroad mobile sources were provided by some state and local agencies, and otherwise were projected to 2023 and 2026 by first projecting the 2016 activity to year 2019 based on county level vehicle miles traveled (VMT) from the Federal Highway Administration. Because VMT for onroad mobile sources were substantially impacted by the pandemic and took about two years to rebound to pre-pandemic levels, in the 2016v3 platform no growth in VMT was implemented from 2019 to. The estimated 2021 VMT were then grown from 2021 to 2023 and 2026 using AEO 2022-based factors. Recent updates to inspection and maintenance programs in North Carolina and Tennessee were reflected in the MOVES inputs for the

final rule modeling. The 2023 and 2026 onroad mobile emissions were computed within SMOKE by multiplying the respective emissions factors developed using MOVES with the year-specific activity data. Prior to computing the final rule emissions for 2023, the EPA made updates to some onroad inputs in response to comments and to implement corrections.

5. Development of Emissions Inventories for Commercial Marine Vessels

The commercial marine vessel (CMV) emissions in the 2016 base case emissions inventory for this rule were based on those in the 2017 NEI. Factors were applied to adjust the 2017 NEI emissions backward to represent emissions for the year 2016. The CMV emissions reflect reductions associated with the Emissions Control Area proposal to the International Maritime Organization control strategy (EPA-420-F-10-041, August 2010); reductions of NO_x, VOC, and CO emissions for new category 3 (C3) engines that went into effect in 2011; and fuel sulfur limits that went into effect prior to 2016. The cumulative impacts of these rules through 2023 and 2026 were incorporated into the projected emissions for CMV sources. The CMV emissions were split into emissions inventories from the larger C3 engines, and those from the smaller category 1 and 2 (C1C2) engines. CMV emissions in California are based on emissions provided by the state. The CMV emissions are consistent with the emissions for the 2016v1 platform updated CMV emissions released by February 2020 although they include projected emissions for the years of 2023 and 2026 instead of 2023 and 2028. In addition, in response to comments, the EPA implemented an improved process for spatial allocating CMV emissions along state and county boundaries.

6. Development of Emissions Inventories for Other Nonroad Mobile Sources

The EPA developed nonroad mobile source emissions inventories (other than CMV, locomotive, and aircraft emissions) for 2016, 2023, and 2026 from monthly, county, and process level emissions output from MOVES3. Types of nonroad equipment include recreational vehicles, pleasure craft, and construction, agricultural, mining, and lawn and garden equipment. State-submitted emissions data for nonroad sources were used for California. The nonroad emissions for the final rule were unchanged from those at the

proposal. The nonroad mobile emissions control programs include reductions to locomotives, diesel engines, and recreational marine engines, along with standards for fuel sulfur content and evaporative emissions. A comprehensive list of control programs included for mobile sources is available in the 2016v3 Emissions Modeling TSD.

Line haul locomotives are also considered a type of nonroad mobile source but the emissions inventories for locomotives were not developed using MOVES3. Year 2016 locomotive emissions were developed through the 2016v1 collaborative process and the year 2016 emissions are mostly consistent with those in the 2017 NEI. More information on the development of the Class I, Class II and III, and commuter rail line haul locomotive emissions is available in the 2016v3 Emissions Modeling TSD. The projected locomotive emissions for 2023 and 2026 were developed by applying factors to the 2016 emissions using activity data based on AEO freight rail energy use growth rate projections along with emissions rates adjusted to account for recent historical trends. The emission factors used for NO_x, PM10 and VOC for line haul locomotives in the analytic years were derived from trend lines based on historic line-haul emission factors from the period of 2007 through 2017 and extrapolated to 2023 and 2026.

7. Development of Emissions Inventories for Nonpoint Sources

For stationary nonpoint sources, some emissions in the 2016 base case emissions inventory come directly from the 2017 NEI, others were adjusted from the 2017 NEI to represent 2016 levels, and the remaining emissions including those from oil and gas, fertilizer, and solvents were computed specifically to represent 2016. Stationary nonpoint sources include evaporative sources, consumer products, fuel combustion that is not captured by point sources, agricultural livestock, agricultural fertilizer, residential wood combustion, fugitive dust, and oil and gas sources. The emissions sources derived from the 2017 NEI include agricultural livestock, fugitive dust, residential wood combustion, waste disposal (including composting), bulk gasoline terminals, and miscellaneous non-industrial sources such as cremation, hospitals, lamp breakage, and automotive repair shops. A recent method to compute solvent VOC emissions was used.¹⁵⁰

Where comments were provided about projected control measures or

¹⁵⁰ <https://doi.org/10.5194/acp-21-5079-2021>.

changes in nonpoint source emissions, those inputs were first reviewed by the EPA. Those found to be based on reasonable data for affected emissions sources were incorporated into the projected inventories for 2023 and 2026 to the extent possible. Where possible, projection factors based on the AEO used data from AEO 2022, the most recent AEO at the time available at the time the inventories were developed. Federal regulations that impact the nonpoint sources were reflected in the inventories. Adjustments for state fuel sulfur content rules for fuel oil in the Northeast were included along with solvent controls applicable within the ozone transport region. Details are available in the 2016v3 Emissions Modeling TSD.

Nonpoint oil and gas emissions inventories for many states were developed based on outputs from the 2017 NEI version of the EPA Oil and Gas Tool using activity data for year 2016. Production-related emissions data from the 2017 NEI were used for Oklahoma, 2016v1 emissions were used for Colorado and for Texas production-related sources to response to comments. Data for production-related nonpoint oil and gas emissions in the states of Colorado, Montana, New Mexico, North Dakota, South Dakota, Utah, and Wyoming were obtained from the WRAP baseline inventory.¹⁵¹ A California Air Resources Board-provided inventory was used for 2016 oil and gas emissions in California. Nonpoint oil and gas inventories for 2023 and 2026 were developed by first projecting the 2016 oil and gas inventories to 2021 values based on actual production data. Next, those 2021 emissions were projected to 2023 and 2026 using regional projection factors by product type based on AEO 2022 projections. A 2017–2019 average inventory was used for oil and natural gas exploration emissions in 2023 and 2026 except for California and in the WRAP states in which data from the WRAP future year inventory¹⁵² were used. NO_x and VOC reductions that are co-benefits to the NSPS for RICE are reflected, along with Natural Gas Turbines and Process Heaters NSPS NO_x controls and NSPS Oil and Gas VOC controls. The WRAP future year inventory was used for oil and natural gas production sources in 2023 and 2026 except in New Mexico where the WRAP Base year emissions were projected using the EIA historical and

AEO forecasted production data. Estimated impacts from the New Mexico Administrative Code 20.2.50 were included.

D. Air Quality Modeling To Identify Nonattainment and Maintenance Receptors

In this section, the Agency describes the air quality modeling and analyses performed in Step 1 to identify locations where the Agency expects there to be nonattainment or maintenance receptors for the 2015 ozone NAAQS in the 2023 and 2026 analytic years. Where the EPA's analysis shows that an area or site does not fall under the definition of a nonattainment or maintenance receptor in these analytic years, that site is excluded from further analysis under this rule.

In the proposed rule, the EPA applied the same approach used in the CSAPR Update and the Revised CSAPR Update to identify nonattainment and maintenance receptors for the 2008 ozone NAAQS.¹⁵³ See 86 FR 23078–79. The EPA's approach gives independent effect to both the “contribute significantly to nonattainment” and the “interfere with maintenance” prongs of section 110(a)(2)(D)(i)(I), consistent with the D.C. Circuit's direction in *North Carolina*.¹⁵⁴ Further, in its decision on the remand of the CSAPR from the Supreme Court in the *EME Homer City* case, the D.C. Circuit confirmed that EPA's approach to identifying maintenance receptors in the CSAPR comported with the court's prior instruction to give independent meaning to the “interfere with maintenance” prong in the good neighbor provision. *EME Homer City II*, 795 F.3d at 136.

In the CSAPR Update and the Revised CSAPR Update, the EPA identified nonattainment receptors as those monitoring sites that are projected to have average design values that exceed the NAAQS and that are also measuring nonattainment based on the most recent monitored design values. This approach is consistent with prior transport rulemakings, such as the NO_x SIP Call and CAIR, where the EPA defined nonattainment receptors as those areas that both currently monitor nonattainment and that the EPA projects will be in nonattainment in the future compliance year.¹⁵⁵

¹⁵³ See 86 FR 23078–79.

¹⁵⁴ 531 F.3d at 910–911 (holding that the EPA must give “independent significance” to each prong of CAA section 110(a)(2)(D)(i)(I)).

¹⁵⁵ See 63 FR 57375, 57377 (October 27, 1998); 70 FR 25241 (January 14, 2005). See also *North Carolina*, 531 F.3d at 913–914 (affirming as

The Agency explained in the NO_x SIP Call and CAIR and then reaffirmed in the CSAPR Update that the EPA has the most confidence in our projections of nonattainment for those monitoring sites that also measure nonattainment for the most recent period of available ambient data. The EPA separately identified maintenance receptors as those monitoring sites that would have difficulty maintaining the relevant NAAQS in a scenario that accounts for historical variability in air quality at that site. The variability in air quality was determined by evaluating the “maximum” future design value at each monitoring site based on a projection of the maximum measured design value over the relevant period. The EPA interprets the projected maximum future design value to be a potential future air quality outcome consistent with the meteorology that yielded maximum measured concentrations in the ambient data set analyzed for that receptor (*i.e.*, ozone conducive meteorology). The EPA also recognizes that previously experienced meteorological conditions (*e.g.*, dominant wind direction, temperatures, and air mass patterns) promoting ozone formation that led to maximum concentrations in the measured data may reoccur in the future. The maximum design value gives a reasonable projection of future air quality at the receptor under a scenario in which such conditions do, in fact, reoccur.¹⁵⁶ The projected maximum design value is used to identify upwind emissions that, under those circumstances, could interfere with the downwind area's ability to maintain the NAAQS.

Therefore, applying this methodology in this rule, the EPA assessed the magnitude of the projected maximum design values for 2023 and 2026 at each monitoring site in relation to the 2015 ozone NAAQS and, where such a value exceeds the NAAQS, the EPA determined that receptor to be a “maintenance” receptor for purposes of defining interference with maintenance, consistent with the method used in CSAPR and upheld by the D.C. Circuit in *EME Homer City II*.¹⁵⁷ That is,

reasonable EPA's approach to defining nonattainment in CAIR).

¹⁵⁶ The EPA's air quality modeling guidance identifies the use of the highest of the relevant base period design values as a means to evaluate future year attainment under meteorological conditions that are especially conducive to ozone formation. See U.S. Environmental Protection Agency, 2018. Modeling Guidance for Demonstrating Attainment of Air Quality Goals for Ozone, PM_{2.5}, and Regional Haze, Research Triangle Park, NC.

¹⁵⁷ See 795 F.3d at 136.

¹⁵¹ http://www.wrapair2.org/pdf/WRAP_OGWG_Report_Baseline_17Sep2019.pdf.

¹⁵² http://www.wrapair2.org/pdf/WRAP_OGWG_2028_OTB_RevFinalReport_05March2020.pdf.

monitoring sites with a maximum design value that exceeds the NAAQS are projected to have maintenance problems in the future analytic years.¹⁵⁸

Recognizing that nonattainment receptors are also, by definition, maintenance receptors, the EPA often uses the term “maintenance-only” to refer to receptors that are not also nonattainment receptors. Consistent with the concepts for maintenance receptors, as described previously, the EPA identifies “maintenance-only” receptors as those monitoring sites that have projected average design values above the level of the applicable NAAQS, but that are not currently measuring nonattainment based on the most recent official design values. In addition, those monitoring sites with projected average design values below the NAAQS, but with projected maximum design values above the NAAQS are also identified as “maintenance only” receptors, even if they are currently measuring nonattainment based on the most recent official design values.¹⁵⁹

Comment: The EPA received comments claiming that the projected design values for 2023 were biased low compared to recent measured data.

¹⁵⁸ The EPA issued a memorandum in October 2018, providing additional information to states developing interstate transport SIP submissions for the 2015 8-hour ozone NAAQS concerning considerations for identifying downwind areas that may have problems maintaining the standard at Step 1 of the 4-step interstate transport framework. See Considerations for Identifying Maintenance Receptors for Use in Clean Air Act Section 110(a)(2)(D)(i)(I) Interstate Transport State Implementation Plan Submissions for the 2015 Ozone National Ambient Air Quality Standards, October 19, 2018 (“October 2018 memorandum”), available in Docket No. EPA–HQ–OAR–2021–0668 or at <https://www.epa.gov/airmarkets/memo-and-supplemental-information-regarding-interstate-transport-sips-2015-ozone-naaqs>. EPA is not applying the suggested analytical approaches in that memorandum in this rule, nor would those approaches be appropriate in light of currently available data. Potential alternative approaches would introduce unnecessary and substantial additional analytical burdens that could frustrate timely and efficient implementation of good neighbor obligations. In addition, the information supplied in that memorandum is now outdated due to several additional years of air quality monitoring data and updated modeling results. EPA’s current approach to defining “maintenance” receptors has been upheld and continues to provide an appropriate approach to addressing the “interference with maintenance” prong of the Good Neighbor provision. See *EME Homer City*, 795 F.3d 118, 136–37; *Wisconsin*, 938 F.3d at 325–26.

¹⁵⁹ See <https://www.epa.gov/air-trends/air-quality-design-values> for design value reports. At the time of this action, the most recent reports available are for the calendar year 2021.

Commenters noted that a number of monitoring sites that are projected to be below the NAAQS in 2023 based on the EPA’s modeling for the proposed action are currently measuring nonattainment based on data from 2020 and 2021. One commenter requested that the EPA determine whether its past modeling tends to overestimate or underestimated actual observed design values. If EPA finds that the agency’s model tends to underestimate future year design values, the commenter requests that EPA re-run its ozone modeling, incorporating parameters that account for this tendency.

Response: In response to comments, the EPA compared the projected 2023 design values based on the proposal modeling to recent trends in measured data. As a result of this analysis, the EPA agrees that current data indicate that there are monitoring sites at risk of continued nonattainment in 2023 even though the model projected average and maximum design values at these sites are below the NAAQS (*i.e.*, sites that are not modeling-based receptors). It would not be reasonable to ignore recent measured ozone levels in many areas that are clearly not fully consistent with certain concentrations in the Step 1 analysis for 2023. Therefore, the EPA has also developed an additional maintenance-only receptor category, which includes what we refer to as “violating monitor” receptors, based on current ozone concentrations measured by regulatory ambient air quality monitoring sites.

Specifically, the EPA has identified monitoring sites with measured 2021 and preliminary 2022 design values and 4th high maximum daily 8-hour average (MDA8) ozone in both 2021 and 2022 (preliminary data) that exceed the NAAQS, although projected to be in attainment in 2023, as having the greatest risk of continuing to have a problem attaining the standard in 2023. These criteria sufficiently consider measured air quality data so as to avoid including monitoring sites that have measured nonattainment data in recent years but could reasonably be anticipated to not have a nonattainment or maintenance problem in 2023, in line with our modeling results. Our methodology is intended only to identify those sites that have sufficiently poor ozone levels that there is clearly a reasonable expectation that an ozone nonattainment or maintenance problem will persist in the 2023 ozone season.

Moreover, 2023 is so near in time that recent measured ozone levels can be used to reasonably project whether an air quality problem is likely to persist. We view this approach to identifying additional receptors in 2023 as the best means of responding to the comments on this issue in this action, while also identifying all transport receptors.

For purposes of this action, we treat these violating monitors as an additional type of maintenance-only receptor. Because our modeling did not identify these sites as receptors, we do not believe it is sufficiently certain that these sites will be in nonattainment such that they should be considered nonattainment receptors. Rather, our authority for treating these sites as receptors in 2023 flows from the responsibility in CAA section 110(a)(2)(i)(I) to prohibit emissions that interfere with maintenance of the NAAQS. See, e.g., *North Carolina*, 531 F.3d at 910–11 (failing to give effect to the interfere with maintenance clause “provides no protection for downwind areas that, *despite EPA’s predictions*, still find themselves struggling to meet NAAQS due to upwind interference”) (emphasis added). Recognizing that no modeling can perfectly forecast the future, and “a degree of imprecision is inevitable in tackling the problem of interstate air pollution,” this approach in the Agency’s judgement best balances the need to avoid both “under-control” and “overcontrol,” *EME Homer City*, 572 U.S. at 523.

We acknowledge that the traditional modeling plus monitoring methodology we used at proposal and in prior ozone transport rules would otherwise have identified such sites as being in attainment in 2023. Despite the implications of the current measured data suggesting there will be a nonattainment problem at these sites in 2023, we cannot definitively establish that such sites will be in nonattainment in 2023 in light of our modeling projections. In the face of this uncertainty, we regard our ability to consider such sites as receptors for purposes of good neighbor analysis under CAA section 110(a)(2)(D)(i)(I) to be a function of the requirement to prohibit emissions that interfere with maintenance of the NAAQS; even if an area may be technically in attainment, we have reliable information indicating that there is an identified risk that attainment will not in fact be achieved.

However, because we did not identify this basis for receptor-identification at proposal, in this final action we are only using this receptor category on a confirmatory basis. That is, for states that we find linked based on our traditional modeling-based methodology in 2023, we find in this final analysis that the linkage at Step 2 is strengthened and confirmed if that state is also linked to one or more “violating monitor” receptors. If a state is only linked to a violating-monitor receptor in this final analysis, we are deferring taking final action on that state’s SIP submittal. This is the case for the State of Tennessee. Among the states that previously had their transport SIPs fully approved for the 2015 ozone NAAQS, the EPA has also identified a linkage to violating-monitor receptors for the State of Kansas. The EPA intends to further review its air quality modeling results and recent measured ozone levels, and we intend to address these states’ good neighbor obligations as expeditiously as practicable in a future action.

E. Methodology for Projecting Future Year Ozone Design Values

Consistent with the EPA’s modeling guidance, the 2016 base year and future year air quality modeling results were used in a relative sense to project design values for 2023 and 2026. That is, the ratios of future year model predictions to base year model predictions are used to adjust ambient ozone design values¹⁶⁰ up or down depending on the relative (percent) change in model predictions for each location. The modeling guidance recommends using measured ozone concentrations for the 5-year period centered on the base year as the air quality data starting point for future year projections. This average design value is used to dampen the effects of inter-annual variability in meteorology on ozone concentrations and to provide a reasonable projection of future air quality at the receptor under average conditions. In addition, the Agency calculated maximum design values from within the 5-year base period to represent conditions when meteorology is more favorable than average for ozone formation. Because the base year for the air quality modeling used in this final rule is 2016, measured data for 2014–2018 (*i.e.*, design values for 2016, 2017, and 2018) were used to project average and maximum design values in 2023 and 2026.

¹⁶⁰ The ozone design value at a particular monitoring site is the 3-year average of the annual 4th highest daily maximum 8-hour ozone concentration at that site.

The ozone predictions from the 2016 and future year air quality model simulations were used to project 2016–2018 average and maximum ozone design values to 2023 and 2026 using an approach similar to the approach in EPA’s guidance for attainment demonstration modeling. This guidance recommends using model predictions from the 3 × 3 array of grid cells¹⁶¹ surrounding the location of the monitoring site to calculate a Relative Response Factor (RRF) for that site.¹⁶² However, the guidance also notes that an alternative array of grid cells may be used in certain situations where local topographic or geographical feature (*e.g.*, a large water body or a significant elevation change) may influence model response.

The 2016–2018 base period average and maximum design values were multiplied by the RRF to project each of these design values to each of the three future years. In this manner, the projected design values are grounded in monitored data, and not the absolute model-predicted future year concentrations. Following the approach in the CSAPR Update and the Revised CSAPR Update, the EPA also projected future year design values based on a modified version of the “3 × 3” approach for those monitoring sites located in coastal areas. In this alternative approach, the EPA eliminated from the RRF calculations the modeling data in those grid cells that are dominated by water (*i.e.*, more than 50 percent of the area in the grid cell is water) and that do not contain a monitoring site (*i.e.*, if a grid cell is more than 50 percent water but contains an air quality monitor, that cell would remain in the calculation). The choice of more than 50 percent of the grid cell area as water as the criteria for identifying overwater grid cells is based on the treatment of land use in the Weather Research and Forecasting model (WRF).¹⁶³ Specifically, in the

¹⁶¹ As noted in this section, each model grid cell is 12 × 12 km.

¹⁶² The relative response factor represents the change in ozone at a given site. To calculate the RRF, the EPA’s modeling guidance recommends selecting the 10 highest ozone days in an ozone season at a given monitor in the base year, noting which of the grid cells surrounding the monitor experienced the highest ozone concentrations in the base year, and averaging those ten highest concentrations. The model is then run using the projected year emissions, in this case 2023, with all other model variables held constant. Ozone concentrations from the same ten days, in the same grid cells, are then averaged. The fractional change between the base year (2016 model run) average ozone concentration and the future year (*e.g.*, 2023 model run) average ozone concentration represents the relative response factor.

¹⁶³ <https://www.mnm.ucar.edu/weather-research-and-forecasting-model>.

WRF meteorological model those grid cells that are greater than 50 percent overwater are treated as being 100 percent overwater. In such cases the meteorological conditions in the entire grid cell reflect the vertical mixing and winds over water, even if part of the grid cell also happens to be over land with land-based emissions, as can often be the case for coastal areas. Overlaying land-based emissions with overwater meteorology may be representative of conditions at coastal monitors during times of on-shore flow associated with synoptic conditions or sea-breeze or lake-breeze wind flows. But there may be other times, particularly with off-shore wind flow, when vertical mixing of land-based emissions may be too limited due to the presence of overwater meteorology. Thus, for our modeling the EPA projected average and maximum design values at individual monitoring sites based on both the “3 × 3” approach as well as the alternative approach that eliminates overwater cells in the RRF calculation for near-coastal areas (*i.e.*, “no water” approach). The projected 2023 and 2026 design values using both the “3 × 3” and “no-water” approaches are provided in the docket for this final rule. For this final rule, the EPA is relying upon design values based on the “no water” approach for identifying nonattainment and maintenance receptors.¹⁶⁴

Consistent with the truncation and rounding procedures for the 8-hour ozone NAAQS, the projected design values are truncated to integers in units of ppb.¹⁶⁵ Therefore, projected design values that are greater than or equal to 71 ppb are considered to be violating the 2015 ozone NAAQS. For those sites that are projected to be violating the NAAQS based on the average design values in the future analytic years, the Agency examined the measured design values for 2021, which are the most recent official measured design values at the time of this final rule. As noted earlier, the Agency is identifying nonattainment receptors in this rulemaking as those sites that are violating the NAAQS based on current

¹⁶⁴ Using design values from the “3 × 3” approach, the maintenance-only receptor at site 550590019 in Kenosha County, WI would become a nonattainment receptor because the average design value with the “3 × 3” approach is 72.0 ppb versus 70.8 ppb with the “no water” approach. In addition, the maintenance-only receptor at site 090099002 in New Haven County, CT would become a nonattainment receptor using the “3 × 3” approach because the average design value with the “3 × 3” approach is 71.2 ppb versus 70.5 ppb with the “no water” approach.

¹⁶⁵ 40 CFR part 50, appendix P—Interpretation of the Primary and Secondary National Ambient Air Quality Standards for Ozone.

measured air quality and also have projected average design values of 71 ppb or greater. Maintenance-only receptors include both (1) those sites with projected average design values above the NAAQS that are currently measuring clean data (*i.e.*, ozone design values below the level of the 2015 ozone NAAQS) and (2) those sites with projected average design values below the level of the NAAQS, but with projected maximum design values of 71 ppb or greater. In addition to the maintenance-only receptors, ozone nonattainment receptors are also

maintenance receptors because the maximum design values for each of these sites is always greater than or equal to the average design value. The monitoring sites that the Agency projects to be nonattainment and maintenance receptors for the ozone NAAQS in the 2023 and 2026 base case are used for assessing the contribution of emissions in upwind states to downwind nonattainment and maintenance of the 2015 ozone NAAQS as part of this final rule.¹⁶⁶

Table IV.D–1 contains the 2016-centered¹⁶⁷ base period average and maximum 8-hour ozone design values,

the 2023 base case average and maximum design values and the measured 2021 design values for the sites that are projected to be nonattainment receptors in 2023. Table IV.D–2 contains this same information for monitoring sites that are projected to be maintenance-only receptors in 2023. The design values for all monitoring sites in the U.S. are provided in the docket for this rule. Additional details on the approach for projecting average and maximum design values are provided in the Air Quality Modeling Final Rule TSD.

TABLE IV.D–1—AVERAGE AND MAXIMUM 2016-CENTERED AND 2023 BASE CASE 8-HOUR OZONE DESIGN VALUES AND 2021 DESIGN VALUES (ppb) AT PROJECTED NONATTAINMENT RECEPTORS

Monitor ID	State	County	2016 Centered average	2016 Centered maximum	2023 Average	2023 Maximum	2021
060650016	CA	Riverside	79.0	80.0	72.2	73.1	78
060651016	CA	Riverside	99.7	101.0	91.0	92.2	95
080350004	CO	Douglas	77.3	78	71.3	71.9	83
080590006	CO	Jefferson	77.3	78	72.8	73.5	81
080590011	CO	Jefferson	79.3	80	73.5	74.1	83
090010017	CT	Fairfield	79.3	80	71.6	72.2	79
090013007	CT	Fairfield	82.0	83	72.9	73.8	81
090019003	CT	Fairfield	82.7	83	73.3	73.6	80
481671034	TX	Galveston	75.7	77	71.5	72.8	72
482010024	TX	Harris	79.3	81	75.1	76.7	74
490110004	UT	Davis	75.7	78	72.0	74.2	78
490353006	UT	Salt Lake	76.3	78	72.6	74.2	76
490353013	UT	Salt Lake	76.5	77	73.3	73.8	76
551170006	WI	Sheboygan	80.0	81	72.7	73.6	72

TABLE IV.D–2—AVERAGE AND MAXIMUM 2016-CENTERED AND 2023 BASE CASE 8-HOUR OZONE DESIGN VALUES AND 2021 DESIGN VALUES (ppb) AT PROJECTED MAINTENANCE-ONLY RECEPTORS

Monitor ID	State	County	2016 Centered average	2016 Centered maximum	2023 Average	2023 Maximum	2021
040278011	AZ	Yuma	72.3	74	70.4	72.1	67
080690011	CO	Larimer	75.7	77	70.9	72.1	77
090099002	CT	New Haven	79.7	82	70.5	72.6	82
170310001	IL	Cook	73.0	77	68.2	71.9	71
170314201	IL	Cook	73.3	77	68.0	71.5	74
170317002	IL	Cook	74.0	77	68.5	71.3	73
350130021	NM	Dona Ana	72.7	74	70.8	72.1	80
350130022	NM	Dona Ana	71.3	74	69.7	72.4	75
350151005	NM	Eddy	69.7	74	69.7	74.1	77
350250008	NM	Lea	67.7	70	69.8	72.2	66
480391004	TX	Brazoria	74.7	77	70.4	72.5	75
481210034	TX	Denton	78.0	80	69.8	71.6	74
481410037	TX	El Paso	71.3	73	69.8	71.4	75
482010055	TX	Harris	76.0	77	70.9	71.9	77
482011034	TX	Harris	73.7	75	70.1	71.3	71
482011035	TX	Harris	71.3	75	67.8	71.3	71
530330023	WA	King	73.3	77	67.6	71.0	64
550590019	WI	Kenosha	78.0	79	70.8	71.7	74
551010020	WI	Racine	76.0	78	69.7	71.5	73

¹⁶⁶In addition, there are 71 monitoring sites in California with projected 2023 maximum design values above the NAAQS. With two exceptions, as described in section IV.F of this document, the Agency is not making a determination in this action that these monitors are ozone transport receptors.

The two exceptions are the two monitoring sites that represent air quality impacts to lands of the Morongo and Pechanga tribes. As explained in footnote 110 *supra*, we treat these as transport receptors that are impacted by emissions from California.

¹⁶⁷2016-centered averaged design values represent the average of the design values for 2016, 2017, and 2018. Similarly, the maximum 2016-centered design value is the highest measured design value from these three design value periods.

In total, in the 2023 base case there are a total of 33 projected modeling-based receptors nationwide including 14 nonattainment receptors in 9 different counties and 19 maintenance-only receptors in 13 additional counties (Harris County, TX, has both nonattainment and maintenance-only receptors).¹⁶⁸ Of the 14 nonattainment receptors in 2023, 7 remain nonattainment receptors, 5 are projected to become maintenance-only receptors and 2 are projected to be in attainment in 2026. Of the 19 maintenance-only receptors in 2023, 7 are projected to remain maintenance-only receptors and 12 are projected to be in attainment in 2026. The projected average and maximum design values in 2026 for all receptors are included in the Air Quality Modeling Final Rule TSD.

Comment: EPA received comments saying that the projected design values for 2023 were biased low compared to recent measured data. Commenters noted that a number of monitoring sites that are projected to be below the NAAQS in 2023 based on EPA’s modeling for the proposed rule are currently measuring nonattainment. Because 2023 is only a year later than the most recent measured data some commenters said that EPA should give greater weight to measured data when identifying downwind receptors.

Response: Based on an analysis of model projections for 2023 and recent trends in measured data, the EPA agrees that current data indicate that there are monitoring sites at risk of continued nonattainment in 2023 even though the model projected average and maximum design values at these sites are below the NAAQS (*i.e.*, sites that are not modeling-based receptors).¹⁶⁹ Specifically, the EPA believes that monitoring sites with measured design values and 4th high maximum daily 8-hour average (MDA8) ozone based on 2021 and preliminary 2022 data have

the greatest risk of continuing to have a problem attaining the standard in 2023, even when the modeling projects these sites will attain. These criteria are sufficiently conservative that we avoid including monitoring sites that have measured nonattainment data in recent years but could reasonably be anticipated to not have a nonattainment or maintenance problem in 2023, in line with our modeling results. Our methodology is intended only to identify those sites that have sufficiently poor ozone levels that there is clearly a reasonable expectation that an ozone nonattainment or maintenance problem will persist in the 2023 ozone season. We do not apply this methodology for the 2026 analytic year, because that year is sufficiently farther in the future that we do not believe there would be a reasonable basis to supplement our modeling analysis with this “violating monitor” methodology. By comparison, 2023 is so near in time that recent measured ozone levels can be used reasonably to project whether an air quality problem is likely to persist. We view this approach to identifying additional receptors in 2023 as the best means of responding to the comments on this issue in this action. The monitoring sites that meet these criteria, along with the corresponding measured and modeled data, are provided in Table IV.D–3.

For purposes of this action, we will treat these sites as an additional type of maintenance-only receptor. Because our modeling did not identify these sites as receptors, we do not believe it is sufficiently certain that these sites will be in nonattainment that they should be considered nonattainment receptors for purposes of this final rule. Rather, our authority for treating these sites as receptors in 2023 flows from the responsibility in CAA section 110(a)(2)(i)(I) to prohibit emissions that interfere with maintenance of the

NAAQS. *See, e.g., North Carolina*, 531 F.3d at 910–11 (failing to give effect to the interfere with maintenance clause “provides no protection for downwind areas that, *despite EPA’s predictions*, still find themselves struggling to meet NAAQS due to upwind interference”) (emphasis added). Recognizing that no modeling can perfectly forecast the future, and “a degree of imprecision is inevitable in tackling the problem of interstate air pollution,” this approach in the Agency’s judgement best balances the need to avoid both “under-control” and “overcontrol,” *EME Homer City*, 572 U.S. at 523.

In this action, we identify “violating monitor” maintenance-only receptors for purposes of more firmly establishing that the states we have otherwise identified as linked at Step 2 in our modeling-based methodology can indeed be reasonably anticipated to be linked to air quality problems in downwind states in 2023 for reasons that extend beyond that methodology. In this sense, this approach is “confirmatory” and does not alter the geography of the final rule compared to the application of the modeling-based receptor definitions used at proposal. Rather, it strengthens the analytical basis for our Step 2 findings by establishing that many upwind states covered in this action are also projected to contribute above 1 percent of the NAAQS to these types of receptors. For purposes of this final rule, we will not finalize FIPs for any states that this analysis indicates contribute greater than 1 percent of the NAAQS only to a “violating monitor” receptor. Our analysis suggests this would be the case for two states, Kansas and Tennessee (see section IV.F of this document).¹⁷⁰ We are making no final decisions with respect to these states in this action and intend to address these states in a subsequent action.

TABLE IV.D–3—AVERAGE AND MAXIMUM 2023 BASE CASE 8-HOUR OZONE, AND 2021 AND PRELIMINARY 2022 DESIGN VALUES (ppb) AND 4TH HIGH CONCENTRATIONS AT VIOLATING MONITORS

Monitor ID	State	County	2023 Average	2023 Maximum	2021	2022 P*	2021 4th high	2022 P 4th high
40070010	AZ	Gila	67.9	69.5	77	76	75	74

¹⁶⁸ The EPA’s modeling also projects that three monitoring sites in the Uintah Basin (*i.e.*, monitor 490472003 in Uintah County, Utah, and monitors 490130002 and 490137011 in Duchesne County, Utah) will have average design values above the NAAQS in 2023. However, as noted in the proposed rule, the Uintah Basin nonattainment area was designated as nonattainment for the 2015 ozone NAAQS not because of an ongoing problem with summertime ozone (as is usually the case in other parts of the country), but instead because it violates the ozone NAAQS in winter. The main causes of

the Uintah Basin’s wintertime ozone are sources located at low elevations within the Basin, the Basin’s unique topography, and the influence of the wintertime meteorologic inversions that keep ozone and ozone precursors near the Basin floor and restrict air flow in the Basin. Because of the localized nature of the ozone problem at these sites the EPA has not identified these three monitors as receptors in Step 1 of this final rule.

¹⁶⁹ In addition, we note that comparing the projected 2023 maximum design values at

modeling-based receptors listed in Table IV.D–1 and Table IV.D–2 to the 2021 design values measured at these sites indicates that the projected maximum values are lower than the measured data at most receptors. These differences are particularly evident at receptors in coastal Connecticut and in Denver. (See Air Quality Modeling Final Rule TSD for details).

¹⁷⁰ We have not conducted an analysis in this action to determine whether violating-monitor receptors may exist in California.

TABLE IV.D-3—AVERAGE AND MAXIMUM 2023 BASE CASE 8-HOUR OZONE, AND 2021 AND PRELIMINARY 2022 DESIGN VALUES (ppb) AND 4TH HIGH CONCENTRATIONS AT VIOLATING MONITORS—Continued

Monitor ID	State	County	2023 Average	2023 Maximum	2021	2022 P*	2021 4th high	2022 P 4th high
40130019	AZ	Maricopa	69.8	70.0	75	77	78	76
40131003	AZ	Maricopa	70.1	70.7	80	80	83	78
40131004	AZ	Maricopa	70.2	70.8	80	81	81	77
40131010	AZ	Maricopa	68.3	69.2	79	80	80	78
40132001	AZ	Maricopa	63.8	64.1	74	78	79	81
40132005	AZ	Maricopa	69.6	70.5	78	79	79	77
40133002	AZ	Maricopa	65.8	65.8	75	75	81	72
40134004	AZ	Maricopa	65.7	66.6	73	73	73	71
40134005	AZ	Maricopa	62.3	62.3	73	75	79	73
40134008	AZ	Maricopa	65.6	66.5	74	74	74	71
40134010	AZ	Maricopa	63.8	66.9	74	76	77	75
40137020	AZ	Maricopa	67.0	67.0	76	77	77	75
40137021	AZ	Maricopa	69.8	70.1	77	77	78	75
40137022	AZ	Maricopa	68.2	69.1	76	78	76	79
40137024	AZ	Maricopa	67.0	67.9	74	76	74	77
40139702	AZ	Maricopa	66.9	68.1	75	77	72	77
40139704	AZ	Maricopa	65.3	66.2	74	77	76	76
40139997	AZ	Maricopa	70.5	70.5	76	79	82	76
40218001	AZ	Pinal	67.8	69.0	75	76	73	77
80013001	CO	Adams	63.0	63.0	72	77	79	75
80050002	CO	Arapahoe	68.0	68.0	80	80	84	73
80310002	CO	Denver	63.6	64.8	72	74	77	71
80310026	CO	Denver	64.5	64.8	75	77	83	72
90079007	CT	Middlesex	68.7	69.0	74	73	78	73
90110124	CT	New London	65.5	67.0	73	72	75	71
170310032	IL	Cook	67.3	69.8	75	75	77	72
170311601	IL	Cook	63.8	64.5	72	73	72	71
181270024	IN	Porter	63.4	64.6	72	73	72	73
260050003	MI	Allegan	66.2	67.4	75	75	78	73
261210039	MI	Muskegon	67.5	68.4	74	79	75	82
320030043	NV	Clark	68.4	69.4	73	75	74	74
350011012	NM	Bernalillo	63.8	66.0	72	73	76	74
350130008	NM	Dona Ana	65.6	66.3	72	76	79	78
361030002	NY	Suffolk	66.2	68.0	73	74	79	74
390850003	OH	Lake	64.3	64.6	72	74	72	76
480290052	TX	Bexar	67.1	67.8	73	74	78	72
480850005	TX	Collin	65.4	66.0	75	74	81	73
481130075	TX	Dallas	65.3	66.5	71	71	73	72
481211032	TX	Denton	65.9	67.7	76	77	85	77
482010051	TX	Harris	65.3	66.3	74	73	83	72
482010416	TX	Harris	68.8	70.4	73	73	78	71
484390075	TX	Tarrant	63.8	64.7	75	76	76	77
484391002	TX	Tarrant	64.1	65.7	72	77	76	80
484392003	TX	Tarrant	65.2	65.9	72	72	74	72
484393009	TX	Tarrant	67.5	68.1	74	75	75	75
490571003	UT	Weber	69.3	70.3	71	74	77	71
550590025	WI	Kenosha	67.6	70.7	72	73	72	71
550890008	WI	Ozaukee	65.2	65.8	71	72	72	72

* 2022 preliminary design values are based on 2022 measured MDA8 concentrations provided by state air agencies to the EPA's Air Quality System (AQS), as of January 3, 2023.

F. Pollutant Transport From Upwind States

1. Air Quality Modeling To Quantify Upwind State Contributions

This section documents the procedures the EPA used to quantify the impact of emissions from specific upwind states on ozone design values in 2023 and 2026 for the identified downwind nonattainment and maintenance receptors. The EPA used CAMx photochemical source apportionment modeling to quantify the impact of emissions in specific upwind

states on downwind nonattainment and maintenance receptors for 8-hour ozone. CAMx employs enhanced source apportionment techniques that track the formation and transport of ozone from specific emissions sources and calculates the contribution of sources and precursors to ozone for individual receptor locations. The benefit of the photochemical model source apportionment technique is that all modeled ozone at a given receptor location in the modeling domain is tracked back to specific sources of

emissions and boundary conditions to fully characterize culpable sources.

The EPA performed nationwide, state-level ozone source apportionment modeling using the CAMx Ozone Source Apportionment Technology/ Anthropogenic Precursor Culpability Analysis (OSAT/APCA) technique¹⁷¹ to quantify the contribution of 2023 and 2026 base case NO_x and VOC emissions from all sources in each state to the

¹⁷¹ As part of this technique, ozone formed from reactions between biogenic VOC and NO_x with anthropogenic NO_x and VOC are assigned to the anthropogenic emissions.

corresponding projected ozone design values in 2023 and 2026 at air quality monitoring sites. The CAMx OSAT/APCA model run was performed for the period May 1 through September 30 using the projected future base case emissions and 2016 meteorology for this time period. In the source apportionment modeling the Agency tracked (*i.e.*, tagged) the amount of ozone formed from anthropogenic emissions in each state individually as well as the contributions from other sources (*e.g.*, natural emissions).

In the state-by-state source apportionment model runs, the EPA tracked the ozone formed from each of the following tags:

- States—anthropogenic NO_x and VOC emissions from each state tracked individually (emissions from all anthropogenic sectors in a given state were combined);
- Biogenics—biogenic NO_x and VOC emissions domain-wide (*i.e.*, not by state);
- Boundary Concentrations—concentrations transported into the air quality modeling domain;
- Tribes—the emissions from those tribal lands for which the Agency has point source inventory data in the 2016v3 emissions modeling platform (EPA did not model the contributions from individual tribes);
- Canada and Mexico—anthropogenic emissions from sources in the portions of Canada and Mexico included in the modeling domain (the EPA did not model the contributions from Canada and Mexico separately);

- Fires—combined emissions from wild and prescribed fires domain-wide (*i.e.*, not by state); and

- Offshore—combined emissions from offshore marine vessels and offshore drilling platforms.

The contribution modeling provided contributions to ozone from anthropogenic NO_x and VOC emissions in each state, individually. The contributions to ozone from chemical reactions between biogenic NO_x and VOC emissions were modeled and assigned to the “biogenic” category. The contributions from wildfire and prescribed fire NO_x and VOC emissions were modeled and assigned to the “fires” category. That is, the contributions from the “biogenic” and “fires” categories are not assigned to individual states nor are they included in the state contributions.

For the Step 2 analysis, the EPA calculated a contribution metric that considers the average contribution on the 10 highest ozone concentration days (*i.e.*, top 10 days) in 2023. This average contribution metric is intended to provide a reasonable representation of the contribution from individual states to projected future year design values, based on modeled transport patterns and other meteorological conditions generally associated with modeled high ozone concentrations at the receptor. An average contribution metric constructed in this manner is beneficial since the magnitude of the contributions is directly related to the magnitude of the design value at each site.

The analytic steps for calculating the contribution metric for the 2023 analytic year are as follows:

(1) Calculate the 8-hour average contribution from each source tag to each monitoring site for the time period of the 8-hour daily maximum modeled concentrations in 2023;

(2) Average the contributions and average the concentrations for the top 10 modeled ozone concentration days in 2023;

(3) Divide the average contribution by the corresponding average concentration to obtain a Relative Contribution Factor (RCF) for each monitoring site;

(4) Multiply the 2023 average design values by the 2023 RCF at each site to produce the average contribution metric values in 2023.¹⁷²

This same approach was applied to calculate contribution metric values at individual monitoring sites for 2026.¹⁷³

The resulting contributions from each tag to each monitoring site in the U.S. for 2023 and 2026 can be found in the docket for this final rule. Additional details on the source apportionment modeling and the procedures for calculating contributions can be found in the Air Quality Modeling Final Rule TSD. The EPA’s response to comments on the method for calculating the contribution metric can be found in the *RTC* document for this final rule.

The largest contribution from each state that is the subject of this rule to modeled 8-hour ozone nonattainment and maintenance receptors in downwind states in 2023 and 2026 are provided in Table IV.F–1 and Table IV.F–2, respectively. The largest contribution from each state to a “violating monitor” maintenance-only receptor is provided in Table IV.F–3.

TABLE IV.F–1—LARGEST CONTRIBUTION TO DOWNWIND 8-HOUR OZONE NONATTAINMENT AND MAINTENANCE RECEPTORS IN 2023

[ppb]

Upwind state	Largest contribution to downwind nonattainment receptors	Largest contribution to downwind maintenance-only receptors
Alabama	0.75	0.65
Arizona	0.54	1.69
Arkansas	0.94	1.21
California	35.27	6.31
Colorado	0.14	0.18
Connecticut	0.01	0.01
Delaware	0.44	0.56
District of Columbia	0.03	0.04
Florida	0.50	0.54
Georgia	0.18	0.17
Idaho	0.42	0.41
Illinois	13.89	19.09

¹⁷²Note that a contribution metric value was not calculated for any receptor at which there were fewer than 5 days with model-predicted MDA8 ozone concentrations greater than or equal to 60 ppb in 2023. The monitoring site in Seattle, King

County, Washington (530330023), was the only receptor which did not meet this criterion.

¹⁷³To provide consistency in the contributions for 2023 and 2026, the contribution metric values

for 2026 are based on the 2026 daily contributions for the same days that were used to calculate the contribution metric values for 2023.

TABLE IV.F-1—LARGEST CONTRIBUTION TO DOWNWIND 8-HOUR OZONE NONATTAINMENT AND MAINTENANCE RECEPTORS IN 2023—Continued
[ppb]

Upwind state	Largest contribution to downwind nonattainment receptors	Largest contribution to downwind maintenance-only receptors
Indiana	8.90	10.03
Iowa	0.67	0.90
Kansas	0.46	0.52
Kentucky	0.84	0.79
Louisiana	9.51	5.62
Maine	0.02	0.01
Maryland	1.13	1.28
Massachusetts	0.33	0.15
Michigan	1.59	1.56
Minnesota	0.36	0.85
Mississippi	1.32	0.91
Missouri	1.87	1.39
Montana	0.08	0.10
Nebraska	0.20	0.36
Nevada	1.11	1.13
New Hampshire	0.10	0.02
New Jersey	8.38	5.79
New Mexico	0.36	1.59
New York	16.10	11.29
North Carolina	0.45	0.66
North Dakota	0.18	0.45
Ohio	2.05	1.98
Oklahoma	0.79	1.01
Oregon*	0.46	0.31
Pennsylvania	6.00	4.36
Rhode Island	0.04	0.01
South Carolina	0.16	0.18
South Dakota	0.05	0.08
Tennessee	0.60	0.68
Texas	1.03	4.74
Utah	1.29	0.98
Vermont	0.02	0.01
Virginia	1.16	1.76
Washington	0.16	0.09
West Virginia	1.37	1.49
Wisconsin	0.21	2.86
Wyoming	0.68	0.67

TABLE IV.F-2—LARGEST CONTRIBUTION TO DOWNWIND 8-HOUR OZONE NONATTAINMENT AND MAINTENANCE RECEPTORS IN 2026
[ppb]

Upwind state	Largest contribution to downwind nonattainment receptors	Largest contribution to downwind maintenance-only receptors
Alabama	0.20	0.69
Arizona	0.44	1.34
Arkansas	0.53	1.16
California	34.03	6.16
Colorado	0.04	0.17
Connecticut	0.00	0.01
Delaware	0.43	0.41
District of Columbia	0.03	0.02
Florida	0.46	0.17
Georgia	0.13	0.16
Idaho	0.27	0.36
Illinois	0.63	13.57
Indiana	1.06	8.53
Iowa	0.14	0.62
Kansas	0.14	0.42
Kentucky	0.79	0.76
Louisiana	4.57	9.37

TABLE IV.F-2—LARGEST CONTRIBUTION TO DOWNWIND 8-HOUR OZONE NONATTAINMENT AND MAINTENANCE RECEPTORS
IN 2026—Continued
[ppb]

Upwind state	Largest contribution to downwind nonattainment receptors	Largest contribution to downwind maintenance-only receptors
Maine	0.00	0.01
Maryland	1.06	0.92
Massachusetts	0.06	0.31
Michigan	1.39	1.47
Minnesota	0.15	0.32
Mississippi	0.29	1.15
Missouri	0.29	1.68
Montana	0.06	0.07
Nebraska	0.09	0.19
Nevada	0.67	0.90
New Hampshire	0.01	0.09
New Jersey	8.10	7.04
New Mexico	0.35	0.46
New York	12.65	12.34
North Carolina	0.40	0.42
North Dakota	0.09	0.17
Ohio	1.95	1.93
Oklahoma	0.19	0.74
Oregon *	0.26	0.41
Pennsylvania	5.47	4.94
Rhode Island	0.00	0.03
South Carolina	0.14	0.15
South Dakota	0.03	0.04
Tennessee	0.24	0.54
Texas	0.48	4.34
Utah	1.05	0.81
Vermont	0.01	0.02
Virginia	1.09	1.10
Washington	0.10	0.14
West Virginia	1.36	1.34
Wisconsin	0.17	0.18
Wyoming	0.40	0.59

TABLE IV.F-3—LARGEST CONTRIBUTION TO DOWNWIND 8-HOUR OZONE “VIOLATING MONITOR” MAINTENANCE-ONLY
RECEPTORS
[ppb]

Upwind state	Largest contribution to downwind violating monitor maintenance-only receptors
Alabama	0.79
Arizona	1.62
Arkansas	1.16
California	6.97
Colorado	0.39
Connecticut	0.17
Delaware	0.42
District of Columbia	0.03
Florida	0.50
Georgia	0.31
Idaho	0.46
Illinois	16.53
Indiana	9.39
Iowa	1.13
Kansas	0.82
Kentucky	1.57
Louisiana	5.06
Maine	0.02
Maryland	1.14
Massachusetts	0.39
Michigan	3.47

TABLE IV.F-3—LARGEST CONTRIBUTION TO DOWNWIND 8-HOUR OZONE “VIOLATING MONITOR” MAINTENANCE-ONLY RECEPTORS—Continued
[ppb]

Upwind state	Largest contribution to downwind violating monitor maintenance-only receptors
Minnesota	0.64
Mississippi	1.02
Missouri	2.95
Montana	0.12
Nebraska	0.43
Nevada	1.11
New Hampshire	0.10
New Jersey	8.00
New Mexico	0.34
New York	12.08
North Carolina	0.65
North Dakota	0.35
Ohio	2.25
Oklahoma	1.57
Oregon *	0.36
Pennsylvania	5.20
Rhode Island	0.08
South Carolina	0.23
South Dakota	0.12
Tennessee	0.86
Texas	3.83
Utah	1.46
Vermont	0.03
Virginia	1.39
Washington	0.11
West Virginia	1.79
Wisconsin	5.10
Wyoming	0.42

* Does not include California monitoring sites.

2. Application of Contribution Screening Threshold

In Step 2 of the interstate transport framework, the EPA uses an air quality screening threshold to identify upwind states that contribute to downwind ozone concentrations in amounts sufficient to “link” them to these to downwind nonattainment and maintenance receptors. The contributions from each state to each downwind nonattainment or maintenance receptor that were used for the Step 2 evaluation can be found in the Air Quality Modeling Final Rule TSD.

The EPA applies an air quality screening threshold of 1 percent of the NAAQS, which has been used since the CSAPR rulemaking, including in the CSAPR Update, the Revised CSAPR Update, and numerous actions evaluating states’ transport SIP submittals. The explanation for how this value was originally derived is available in the CSAPR rulemaking from 2011. See 76 FR 48208, 48237–38. As originally explained there, the application of a relatively low threshold

is intended to capture a relatively large percentage of the contribution from upwind states to downwind receptors in light of the regional-scale, collective contribution problem associated with both ozone and PM_{2.5} NAAQS. *Id.* The Agency also explained that the use of a higher threshold in transport rules prior to CSAPR was based on single-day maximum contribution, whereas in CSAPR (and continuing in subsequent rules including this one), the Agency uses a more robust, average contribution metric over multiple days. Thus, it was not the case that 1 percent of NAAQS was substantially more stringent than that prior approach. *Id.* at 48238. In the 2016 CSAPR Update, the EPA reviewed the 1 percent threshold (as coupled with multi-day averaging) and determined it was appropriate to continue to apply this threshold. The EPA compared the 1 percent threshold to a 0.5 percent of NAAQS threshold and a 5 percent of NAAQS threshold. The EPA found that the lower threshold did not capture appreciably more upwind state contribution compared to the 1 percent threshold, while the 5 percent threshold

allowed too much upwind state contribution to drop out from further analysis.¹⁷⁴ The EPA continues to observe that nonattainment and maintenance receptors identified at Step 1 are impacted collectively by emissions from numerous upwind contributors. Therefore, application of a low, uniform screening threshold allows the EPA to identify upwind states that share a responsibility under the interstate transport provision to eliminate their significant contribution.

As we explained at proposal, the EPA recognizes that in 2018 it issued a memorandum indicating the potential for states to use a higher threshold at Step 2 in the development of their good neighbor SIP submissions where it could be technically justified. The August 2018 memorandum stated that “it may be reasonable and appropriate” for states to rely on an alternative 1 ppb threshold at Step 2.¹⁷⁵ (The memorandum also indicated that any

¹⁷⁴ See Final CSAPR Update Air Quality Modeling TSD, at 27–30 (EPA–HQ–OAR–2015–0596–0144). See also 86 FR 23054, 23085.

¹⁷⁵ August 2018 memo at 4.

higher alternative threshold, such as 2 ppb, would likely not be appropriate.) The EPA nonetheless proposed to fulfill its role under CAA section 110(c) in promulgating FIPs to directly implement good neighbor requirements, and in this role, proposed retaining use of the 1 percent threshold for all states. We noted that in several documents proposing transport SIP disapprovals, *see, e.g.*, 87 FR 9498 and 87 FR 9510 (Feb. 22, 2022), we explained that our experience since the issuance of the August 2018 memorandum regarding use of alternative thresholds led the Agency to believe it may not be appropriate to continue to attempt to recognize alternative contribution thresholds at Step 2, either in the context of SIPs or FIPs.

We went on to explain that the EPA's experience since 2018 is that allowing for alternative Step 2 thresholds may be impractical or otherwise inadvisable for a number of additional policy reasons. For a regional air pollutant such as ozone, consistency in requirements and expectations across all states is essential. Using multiple different thresholds at Step 2 with respect to the 2015 ozone NAAQS raises substantial policy consistency and practical implementation concerns.¹⁷⁶ The application of different thresholds at Step 2 has the potential to result in inconsistent determination of good neighbor obligations. From the perspective of ensuring effective regional implementation of good neighbor obligations, the more important analysis is the evaluation of the emissions reductions needed, if any, to address a state's significant contribution after consideration of a multifactor analysis at Step 3, including a detailed evaluation that considers air quality factors and cost. We explained that while alternative thresholds for purposes of Step 2 may be "similar" in terms of capturing the relative amount of upwind contribution (as described in the August 2018 memorandum), nonetheless, use of alternative thresholds would allow certain states to avoid further evaluation of potential emissions controls while other states must proceed to a Step 3 analysis. This could create significant equity and consistency problems among states.

The EPA further proposed that, in promulgating FIPs to address these obligations on a nationwide scale,

national ozone transport policy would not be well-served by applying a single, less stringent threshold at Step 2. The EPA recognized in the August 2018 memo that there was some similarity in the amount of total upwind contribution captured (on a nationwide basis) between 1 percent and 1 ppb. However, the EPA noted at proposal that while this may be true in some sense, that is hardly a compelling basis to move to a 1 ppb threshold. Indeed, the 1 ppb threshold has the disadvantage of losing a certain amount of total upwind contribution for further evaluation at Step 3. Considering the core statutory objective of ensuring elimination of *all* significant contribution to nonattainment or interference of the NAAQS in downwind states and the broad, regional nature of the collective contribution problem with respect to ozone, EPA could not identify a compelling policy imperative to move to a 1 ppb threshold.

In the proposal, we also found consistency with past interstate transport actions such as CSAPR, and the CSAPR Update and Revised CSAPR Update rulemakings (which used a Step 2 threshold of 1 percent of the NAAQS for two less protective ozone NAAQS) to be an important consideration. Continuing to use a 1 percent of NAAQS approach ensures that as the NAAQS are revised and made more stringent, an appropriate increase in stringency at Step 2 occurs, so as to ensure an appropriately larger amount of total upwind-state contribution is captured for purposes of fully addressing interstate transport for the more protective NAAQS.

The Agency also questioned whether it would be a good use of limited resources to attempt to further justify the use of alternative thresholds for certain states at Step 2 for purposes of the 2015 ozone NAAQS. Therefore, while EPA articulated the possibility of an alternative threshold in the August 2018 memorandum, the EPA concluded in the proposal that our experience and further evaluation since the issuance of that memo has revealed substantial programmatic and policy difficulties in attempting to implement this approach, and therefore we proposed to apply the 1 percent of NAAQS threshold.

Comment: Many commenters disagreed with our proposal to continue using a 1 percent of NAAQS threshold. They argued that the EPA was reversing course from its policy as articulated in the August 2018 memorandum and that the EPA was now bound to use a 1 ppb threshold rather than 1 percent of NAAQS, even in promulgating a FIP rather than evaluating SIPs.

Commenters further argued that a 1 ppb threshold would be more consistent with the EPA's "significant impact level" (SIL) guidance related to implementing prevention of significant deterioration (PSD) permitting requirements. They argued that the 1 percent threshold was below precision limits of regulatory ozone monitors, and they argued it was within the "margin of error" of the EPA's modeling.

Response: The EPA is finalizing its proposed approach of consistently using a 1 percent of the NAAQS threshold at Step 2 in this action to determine which states contribute to identified nonattainment and maintenance receptors. This approach ensures both national consistency across all states and consistency and continuity with our prior interstate transport actions for other NAAQS. We do not agree that this approach is inconsistent with or a reversal in policy from the August 2018 memorandum, which only suggested that states in the development of their SIPs "may" be able to establish that 1 ppb could be an appropriate alternative threshold. The EPA has been consistent in that memorandum, and since that time, that final determinations on alternative thresholds would be made through rulemaking action, as the EPA is taking here.

The August 2018 memorandum made clear that the Agency had substantial doubts that any threshold greater than 1 ppb (such as 2 ppb) would be acceptable, and the Agency is affirming that a threshold higher than 1 ppb would not be justified under any circumstance for purposes of this action. No commenter credibly provided a basis for using a threshold even higher than 1 ppb, and so this issue is primarily limited to the difference between a 0.7 ppb threshold (the 1 percent of the NAAQS threshold discussed previously in this section) and a 1.0 ppb threshold. Therefore, before proceeding in responding to these comments, we note that this issue is only relevant to a small number of states whose contributions to any receptor are above 1 percent of the NAAQS but lower than 1 ppb. Under the 2016v3 modeling of 2023 being used in this final rule, the states in this rule with contributions that fall between 0.70 ppb and 1 ppb are Alabama, Kentucky, and Minnesota. Similarly, the EPA applies the 1 percent threshold in its 2026 modeling projections to determine if any states will not be linked to an ozone receptor by that year, and therefore should not be subject to the more stringent requirements that take effect in 2026. The states in this rule in that year with contribution between 0.70 ppb and 1 ppb are

¹⁷⁶ We note that Congress has placed on the EPA a general obligation to ensure the requirements of the CAA are implemented consistently across states and regions. *See* CAA section 301(a)(2). Where the management and regulation of interstate pollution levels spanning many states is at stake, consistency in application of CAA requirements is paramount.

Kentucky, Nevada, and Oklahoma. For all other states covered in this action, at least one linkage exists in 2023 (and, as relevant, in 2026) that is greater than 1 ppb, and therefore the question of whether the EPA must recognize a 1 ppb threshold would not have a dispositive effect on the regulatory determination being made at Step 2.

The 1 percent of the NAAQS threshold is consistent with the Step 2 approach that the EPA applied in CSAPR for the 1997 ozone NAAQS and has subsequently been applied in the CSAPR Update and Revised CSAPR Update when evaluating determining interstate transport obligations for the 2008 ozone NAAQS. The EPA continues to find 1 percent of the ozone NAAQS to be an appropriate threshold. For ozone, as the EPA found in CAIR, CSAPR, and the CSAPR Update, a portion of the nonattainment and maintenance problems in the U.S. results from the combined impact of relatively small contributions from many upwind states, along with contributions from in-state sources and other sources. The EPA's analysis shows that the ozone transport problem being analyzed in this rule is still the result of the collective impacts of emissions from multiple upwind contributors. Therefore, application of a consistent contribution threshold is necessary to identify those upwind states that should have responsibility for addressing their contribution (to the extent found "significant" at Step 3) to the downwind nonattainment and maintenance problems to which they collectively contribute. Where a great number of geographically dispersed emissions sources contribute to a downwind air quality problem, which is the case for ozone, EPA believes that, in the context of CAA section 110(a)(2)(D)(i)(I), a state-level threshold of 1 percent of the NAAQS is a reasonably small enough value to identify only the greater-than-de minimis contributors yet is not so large that it unfairly focuses attention for further action only on the largest single or few upwind contributors. Continuing to use 1 percent of the NAAQS as the screening metric to evaluate collective contribution from many upwind states also allows the EPA (and states) to apply a consistent framework to evaluate interstate emissions transport under the interstate transport provision from one NAAQS to the next. See 86 FR 23054, 23085; 81 FR 74504, 74518; 76 FR 48208, 48237–38.

Further, the EPA notes that the role of the Step 2 threshold is limited and just one step in the larger 4-Step Framework. It serves to screen in states for further

evaluation of emissions control opportunities applying a multifactor analysis at Step 3. Thus, as the Supreme Court has recognized, the contribution threshold essentially functions to exclude states with "*de minimis*" impacts. *EME Homer City*, 572 U.S. 489, 500.

Comments related to the August 2018 memorandum argued that the EPA legally committed itself to approving SIP submissions from states with contributions below 1 ppb and so now the EPA must apply that threshold in this FIP action. (Comments regarding this issue as related to the EPA's action on SIPs is addressed in that rulemaking and is beyond the scope of this action.) This is not what the memorandum said. The memorandum merely provided an analysis regarding "the degree to which certain air quality threshold amounts capture the collective amount of upwind contribution from upwind states."¹⁷⁷ It interpreted "that information to make recommendations about what thresholds *may* be appropriate for use in" SIP submissions (emphasis added).¹⁷⁸ Specifically, the August 2018 memorandum said, "Because the amount of upwind collective contribution capture with the 1 percent and the 1 ppb thresholds is *generally comparable, overall, we believe it may be* reasonable and appropriate for states to use a 1 ppb contribution threshold, as an alternative to a 1 percent threshold, at Step 2 of the 4-step framework in developing their SIP revisions addressing the good neighbor provision for the 2015 ozone NAAQS" (emphasis added).¹⁷⁹ Thus, the text of the August 2018 memorandum in no way committed that the EPA would be using a 1 ppb threshold going forward either in its evaluation of SIPs or in promulgating a FIP. The August 2018 memorandum indicated that "[f]ollowing these recommendations does not ensure that EPA will approve a SIP revision in all instances where the recommendations are followed, as the guidance may not apply to the facts and circumstances underlying a particular SIP. Final decisions by the EPA to approve a particular SIP revision will only be made based on the requirements of the statute and will only be made following an air agency's final submission of the SIP revision to the EPA, and after appropriate notice and opportunity for public review and comment."¹⁸⁰ Further, the August 2018 memorandum

said that "EPA and air agencies should consider whether the recommendations in this guidance are appropriate for each situation."¹⁸¹ The memorandum said nothing regarding what threshold the EPA would apply if promulgating a FIP.

As explained in the SIP disapproval action and again here, the EPA finds it would not be sound policy to apply an alternative contribution threshold or thresholds to one or more states within the 4-step interstate transport framework for the 2015 ozone NAAQS. However, the EPA disagrees with commenters' claims that the agency has reversed course on applying the August 2018 memorandum, because the memorandum never adopted a view that the use of 1 ppb or other alternative thresholds would in fact be acceptable. Although the EPA said at proposal that the EPA may rescind the guidance in the future, we took comment on the subject and also stated, "EPA is not at this time rescinding the August 2018 memorandum."¹⁸² The EPA is not formally rescinding the August 2018 memorandum in this action or at this time. However, it is not required that agencies must "rescind" a memorandum or guidance the moment it becomes outdated or called into question. The August 2018 memorandum was not issued through notice-and-comment rulemaking and is not binding on the Agency or other parties. While the *willingness* of the Agency as expressed in that memorandum to entertain the possibility of an alternative threshold of 1 ppb may be considered a kind of policy position, agencies may change their non-binding policies without going through notice and comment rulemaking. *Catawba County v. EPA*, 571 F.3d 20, 34 (D.C. Cir. 2009). In this case, we went through notice and comment rulemaking on this topic in the SIP-disapproval action (88 FR 9336) and here, even though the August 2018 memorandum was issued without such opportunity for public input. We further address the basis for the consistent use of a 1 percent of NAAQS threshold and summarize our conclusions under the *FCC v. Fox* factors below.

We continue to believe, as set forth in our proposed action, that national ozone transport policy is not well served by

¹⁸¹ *Id.*

¹⁸² 87 FR 9545, 9551 (Feb. 22, 2022) (Alabama, Mississippi, Tennessee); 87 FR 9498, 9510 (Feb. 22, 2022) (Kentucky); 87 FR 9838, 9844 (Feb. 22, 2022) (Illinois, Indiana, Michigan, Minnesota, Ohio, Wisconsin); 87 FR 9798, 9807, 9813, 9820 (Feb. 22, 2022) (Arkansas, Louisiana, Oklahoma, Texas); 87 FR 9533, 9542 (Feb. 22, 2022) (Missouri); 87 FR 31470, 31479 (May 24, 2022) (Utah); 87 FR 31495, 31504 (May 24, 2022) (Wyoming); 87 FR 31485, 31490 (May 24, 2022) (Nevada).

¹⁷⁷ August 2018 memorandum, at 1.

¹⁷⁸ *Id.*

¹⁷⁹ *Id.* at 4.

¹⁸⁰ *Id.* at 1.

allowing for less protective thresholds than 1 percent of the NAAQS at Step 2. Furthermore, the EPA disagrees with commenters who suggest that national consistency is an inappropriate consideration in the context of interstate ozone transport. The Good Neighbor provision, CAA section 110(a)(2)(D)(i)(I), requires to a unique degree of concern for consistency, parity, and equity across state lines.¹⁸³ For a regional air pollutant such as ozone, consistency in requirements and expectations across all states is essential. Based on the EPA's review of good neighbor SIP submissions to-date and after further consideration of the policy implications of attempting to recognize an alternative Step 2 threshold for certain states, the Agency concludes that the attempted use of different thresholds at Step 2 with respect to the 2015 8-hour ozone NAAQS raises substantial policy consistency and practical implementation concerns. The availability of different thresholds at Step 2 has the potential to result in inconsistent application of good neighbor obligations based solely on the strength of a state's SIP submission at Step 2 of the 4-step interstate transport framework. The steps of the analysis that lead up to evaluating emissions reductions opportunities to address states' significant contribution at Step 3 should be applied on a consistent basis. Where alternative thresholds for purposes of Step 2 may be "similar" in terms of capturing the relative amount of upwind contribution (as described in the August 2018 memorandum), nonetheless, use of an alternative threshold would allow certain states to avoid further evaluation of potential emissions controls while other states must proceed to a Step 3 analysis. This can create significant equity and consistency problems among states and could lead to ineffective or inefficient approaches to eliminating significant contribution.

One commenter suggested the EPA could address this potentially inequitable outcome by simply adopting a 1 ppb contribution threshold for all states. However, the August 2018 memorandum did not conclude that 1 ppb would be appropriate for all states and the EPA does not view that conclusion to be supported at present. The EPA recognized in the August 2018

memorandum that there was some similarity in the amount of total upwind contribution captured (on a nationwide basis) between 1 percent and 1 ppb. However, while this may be true in some sense, that is hardly a compelling basis to move to a 1 ppb threshold for every state. Indeed, the 1 ppb threshold has the disadvantage of losing a certain amount of total upwind contribution for further evaluation at Step 3 (e.g., roughly 7 percent of total upwind state contribution was lost according to the modeling underlying the August 2018 memorandum; in the EPA's 2016v2 modeling, the amount lost is 5 percent; in the EPA's 2016v3 modeling used for final, the amount lost is also 5 percent). Further, this logic has no end point. A similar observation could be made with respect to any incremental change. For example, should the EPA next recognize a 1.2 ppb threshold because that would only cause some small additional loss in capture of upwind state contribution as compared to 1 ppb? If the only basis for moving to a 1 ppb threshold is that it captures a "similar" (but actually smaller) amount of upwind contribution, then there is no basis for moving to that threshold at all. Considering the core statutory objective of ensuring elimination of all significant contribution to nonattainment or interference with maintenance of the NAAQS in other states and the broad, regional nature of the collective contribution problem with respect to ozone, we continue to find no compelling policy reason to adopt a new threshold for all states of 1 ppb.

Nor have commenters explained why use of a 1 ppb threshold would be appropriate under the more protective 2015 ozone NAAQS when a 1 percent of the NAAQS contribution threshold has been used for less protective ozone NAAQS. To illustrate, a state contributing greater than 0.75 ppb but less than 1 ppb to a receptor under the 2008 ozone NAAQS was "linked" at Step 2,¹⁸⁴ but if a 1 ppb threshold were used for the 2015 ozone NAAQS then that same state would *not* be "linked" to a receptor at Step 2 under a NAAQS that is set to be *more* protective of human health and the environment. Consistency with past interstate transport actions such as CSAPR, and the CSAPR Update and Revised CSAPR Update rulemakings (which all used the 1 percent of the NAAQS for less protective ozone NAAQS), is an important consideration. We affirm our view in CSAPR that continuing to use a 1 percent of NAAQS approach ensures that if the NAAQS are revised and made

more stringent, an appropriate increase in stringency at Step 2 occurs, so as to ensure an appropriately larger amount of total upwind-state contribution is captured for purposes of fully addressing interstate transport. *See* 76 FR 48208, 48237–38.

We note further that application of a 1 percent of NAAQS threshold has been the EPA's consistent approach in each of our notice-and-comment rulemakings beginning with CSAPR and continuing with the CSAPR Update, the Revised CSAPR Update, and numerous actions on ozone transport SIP submissions. In each case, the 1 percent of the NAAQS threshold was subject to rigorous vetting through public comment and the Agency's response to those comments, including through the use of analytical evaluations of alternative thresholds. *See, e.g.,* 81 FR 74518–19. By contrast, the August 2018 memorandum was not issued through notice-and-comment rulemaking procedures, and the EPA was careful to caveat its utility and ultimate reliability for that reason.

The EPA disagrees with claims that the EPA is applying the August 2018 memorandum inconsistently based on the EPA's actions with regard to Arizona, Iowa, and Oregon. The EPA withdrew a previously proposed approval of Iowa's SIP submission that was premised on a 1 ppb contribution threshold, and re-proposed and finalized approval of that SIP based on a different rationale using a 1 percent of the NAAQS contribution threshold. 87 FR 9477 (Feb. 22, 2022); 87 FR 22463 (April 15, 2022). The EPA also disagrees with any claim that Oregon and Arizona were "allowed" to use a 1 ppb or higher threshold. The EPA approved Oregon's SIP submission for the 2015 ozone NAAQS on May 17, 2019, and both Oregon and the EPA relied on a 1 percent of the NAAQS contribution threshold. 84 FR 7854, 7856 (March 5, 2019) (proposal); 84 FR 22376 (May 17, 2019) (final). In the proposal for this action, the EPA explained it was not proposing to conduct an error correction for Oregon even though updated modeling indicated Oregon contributed above 1 percent of the NAAQS to monitors in California.

The EPA is deferring finalizing a finding at this time for Oregon (*see* section IV.G of this document for additional information). In 2016, the EPA approved Arizona's SIP for the earlier 2008 ozone NAAQS based on a similar rationale with regard to certain monitors in California. 81 FR 15200 (March 22, 2016) (proposal); 81 FR 31513 (May 19, 2016) (final rule). We are deferring finalizing a finding at this time that such a rationale is appropriate

¹⁸³ EPA notes that Congress has placed on EPA a general obligation to ensure the requirements of the CAA are implemented consistently across states and regions. *See* CAA section 301(a)(2). Where the management and regulation of interstate pollution levels spanning many states is at stake, consistency in application of CAA requirements is paramount.

¹⁸⁴ *See* 86 FR 23054, 23058 (April 30, 2021).

with respect to the more protective 2015 ozone NAAQS. While Arizona and Oregon's interstate transport obligations for the 2015 ozone NAAQS remain pending (along with several other states), there is no inconsistency in the treatment of these states or any other state at Step 2.

Some commenters claim the EPA must use a 1 ppb threshold based on the identification of 1 ppb as a significance threshold in one step of the PSD permitting process. The EPA's SIL guidances, however, relate to a different provision of the Clean Air Act regarding implementation of the prevention of significant deterioration (PSD) permitting program. This program applies in areas that have been designated attainment of the NAAQS and is intended to ensure that such areas remain in attainment even if emissions were to increase as a result of new sources or major modifications to existing sources located in those areas. This purpose is different than the purpose of the good neighbor provision, which is to assist downwind areas (in some cases hundreds or thousands of miles away) in resolving ongoing nonattainment of the NAAQS or difficulty maintaining the NAAQS through eliminating the emissions from other states that are significantly contributing to those problems. In addition, as discussed in preceding paragraphs, the purpose of the Step 2 threshold within the EPA's interstate transport framework for ozone is to broadly sweep in all states contributing to identified receptors above a de minimis level in recognition of the collective-contribution problem associated with regional-scale ozone transport. The threshold used in the context of PSD SIL serves a different purpose, and so it does not follow that they should be made equivalent. Further, commenters incorrectly associate the EPA's Step 2 contribution threshold with the identification of "significant" emissions (which does not occur until Step 3), and so it is not the case that the EPA is interpreting the same term differently.

The EPA has previously explained this distinction between the good neighbor framework and PSD SILs. See 70 FR 25162, 25190–25191 (May 12, 2005); 76 FR 48208, 48237 (Aug. 8, 2011). Importantly, the implication of the PSD SIL threshold is not that single-source contribution below this level indicates the absence of a contribution or that no emissions control requirements are warranted. Rather, the PSD SIL threshold addresses whether further, more comprehensive, multi-source review or analysis of air quality

impacts are required of the source to support a demonstration that it meets the criteria for a permit. A source with estimated impacts below the PSD SIL may use this to demonstrate that it will not cause or contribute (as those terms are used within the PSD program) to a violation of an ambient air quality standard, but is still subject to meeting applicable control requirements, including best available control technology, designed to moderate the source's impact on air quality.

Moreover, other aspects of the technical methodology in the SILs guidance compared to the good neighbor framework make a direct comparison between these two values misleading. For instance, in PSD permit modeling using a single year of meteorology the maximum single-day 8-hour contribution is evaluated with respect to the SIL. The purpose of the contribution threshold at Step 2 of the 4-step good neighbor framework is to determine whether the average contribution from a collection of sources in a state is small enough not to warrant any additional control for the purpose of mitigating interstate transport, even if that control were highly cost effective. Using a 1 percent of the NAAQS threshold is more appropriate for evaluating multi-day average contributions from upwind states than a 1 ppb threshold applied for a single day, since that lower value of 1 percent of the NAAQS will capture variations in contribution. If EPA were to use a single day reflecting the maximum amount of contribution from an upwind state to determine whether a linkage exists at Step 2, commenters' arguments for use of the PSD SIL might have more force. This would in effect be a return to the pre-CSAPR contribution calculation methodology of using a single day, see 76 FR 48238. However, that would likely cause more states to become linked, not less. And in any case, consistent with the method in our modeling guidance for projecting future attainment/nonattainment and as the EPA concluded in 2011 in CSAPR, the present good neighbor methodology of using multiple days provides a more robust approach to establishing that a linkage exists at the state level than relying on a single day of data.

A commenter also claimed the 1 percent of NAAQS threshold is inconsistent with the standards of precision for Federal reference monitors for ozone and the rounding requirements found in 40 CFR part 50, appendix U, Interpretation of the Primary and Secondary National Ambient Air Quality Standards for Ozone. Commenter claimed that the 1

percent contribution threshold of 0.7 ppb is lower than the manufacturer's reported precision of these reference monitors and that the requirements found in Appendix U truncates monitor values of 0.7 ppb to 0 ppb. However, the commenter is mistaken in applying criteria related to the precision of monitoring technology to the modeling methodology by which we project contributions when quantifying and evaluating interstate transport at Step 2. Indeed, contributions by source or state cannot be derived from the total ambient concentration of ozone at a monitor at all but must be apportioned through modeling. Under our longstanding methodology for doing so, the contribution values identified from upwind states are based on a robust assessment of the average impact of each upwind state's ozone-precursor emissions over a range of scenarios, as explained in the 2016v3 modeling's Air Quality Modeling Final Rule TSD, in the docket for this rule, Docket ID No. EPA–HQ–OAR–2021–0668. This analysis is in no way connected with or dependent on monitoring instruments' precision of measurement. See *EME Homer City*, 795 F.3d 118, 135–36 (“[A] model is meant to simplify reality in order to make it tractable.”) (quoting *Chemical Manufacturers Association v. EPA*, 28 F.3d 1259, 1264 (D.C. Cir. 1994)).

To the extent that commenters argue that the EPA consider a less stringent threshold as a result of modeling uncertainty, the EPA disagrees with this notion. The EPA has successfully applied a 1 percent of NAAQS threshold to identify linked upwind states using modeling in three prior FIP rulemakings and numerous state-specific actions on good neighbor obligations. This continues to be a reasonable approach, and indeed courts have repeatedly declined to establish bright line criteria for model performance. In upholding the EPA's approach to evaluating interstate transport in CSAPR, the D.C. Circuit held that it would not “invalidate EPA's predictions solely because there might be discrepancies between those predictions and the real world. That possibility is inherent in the enterprise of prediction.” *EME Homer City Generation, L.P. v. EPA*, 795 F.3d 118, 135 (2015). “[T]he fact that a ‘model does not fit every application perfectly is no criticism; a model is meant to simplify reality in order to make it tractable.’” *Id.* at 135–36 (quoting *Chemical Manufacturers Association v. EPA*, 28 F.3d 1259, 1264 (D.C. Cir. 1994)). See also *Sierra Club v. EPA*, 939 F.3d 649, 686–87 (5th Cir. 2019) (upholding EPA's modeling in the

face of complaints regarding an alleged “margin of error,” noting challengers face a “considerable burden” in overcoming a “presumption of regularity” afforded “the EPA’s choice of analytical methodology”) (citing *BCCA Appeal Grp. v. EPA*, 355 F.3d 817, 832 (5th Cir. 2003)).

The Agency will continue to use the CAMx model to evaluate contributions from upwind states to downwind areas. The agency has used CAMx routinely in previous notice and comment transport rulemakings to evaluate contributions relative to the 1 percent threshold for both ozone and PM_{2.5}. In fact, in the original CSAPR, the EPA found that “[t]here was wide support from commenters for the use of CAMx as an appropriate, state-of-the science air quality tool for use in the [Cross-State Air Pollution] Rule. There were no comments that suggested that the EPA should use an alternative model for quantifying interstate transport.” 76 FR 48229 (August 8, 2011). In this action, the EPA has taken a number of steps based on comments and new information to ensure to the greatest extent the accuracy and reliability of its modeling projections at Step 1 and 2, as discussed elsewhere in this section.

The EPA disagrees with commenters that case law reviewing changes in agency positions such as *FCC v. Fox TV Stations, Inc.*, 556 U.S. 502, 515 (2009), is applicable with respect to this issue. As explained above, under the terms of the August 2018 memorandum, the Agency did not conclude that the use of an alternative contribution threshold was justified for any states. But even if it were found that the Agency’s position had changed between this rulemaking action and the August 2018 memorandum, the *FCC v. Fox* factors are met. We have explained above that there are good reasons for continuing to use a 1 percent of NAAQS threshold. We also are aware that we are not using a 1 ppb threshold despite acknowledging the potential for doing so in the August 2018 memorandum. We do not believe that any party has a serious reliance interest that would be sufficient to overcome the countervailing public interest that is served through the EPA’s determination to maintain continuity with its longstanding, more protective 1 percent of NAAQS threshold in this action. *Cf.* 88 FR 9373 (reviewing reliance in the context of the SIP-disapproval action).

The EPA therefore will continue its longstanding practice of applying the 1 percent of NAAQS threshold in this action.

a. States That Contribute Below the Screening Threshold

Based on the EPA’s modeling and considering measured data at violating monitors, the contributions from each of the following states to nonattainment or maintenance-only receptors in the 2023 analytic year are below the 1 percent of the NAAQS threshold: Colorado, Connecticut, the District of Columbia, Delaware, Florida, Georgia, Idaho, Maine, Massachusetts, Montana, Nebraska, New Hampshire, North Carolina, North Dakota, Rhode Island, South Carolina, South Dakota, Vermont, and Washington.¹⁸⁵ The EPA has already approved these states’ 2015 ozone good neighbor SIP submittals. Because the contributions from these states to projected downwind air quality problems are below the screening threshold in the current modeling, these states are not within the scope of this final rule. Additionally, the EPA has made final determinations that two states outside the modeling domain for the air quality modeling analyzed in this final rulemaking—Hawaii¹⁸⁶ and Alaska¹⁸⁷—do not significantly contribute to nonattainment or interfere with maintenance of the NAAQS in any other state.

With respect to Wyoming, our methodology when applied using the 2016v3 modeling suggests that whether the state is linked is uncertain and warrants further analysis. The EPA intends to expeditiously review its assessment with respect to Wyoming and take action addressing Wyoming’s good neighbor obligations for the 2015 ozone NAAQS through a separate action.

b. States That Contribute at or Above the Screening Threshold

Based on the maximum downwind contributions in Table IV.F–1, the Step 2 analysis identifies that the following 21 states contribute at or above the 0.70 ppb threshold to downwind nonattainment receptors in 2023: Alabama, Arkansas, California, Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, Mississippi, Missouri, Nevada, New Jersey, New York, Ohio, Oklahoma, Pennsylvania, Texas, Utah, Virginia, and West Virginia. Based on the maximum downwind contributions in Table IV.F–

1, the following 23 states contribute at or above the 0.70 ppb threshold to downwind modeling-based maintenance-only receptors in 2023: Arizona, Arkansas, California, Illinois, Indiana, Iowa, Kentucky, Louisiana, Maryland, Michigan, Minnesota, Mississippi, Missouri, Nevada, New Jersey, New Mexico, New York, Ohio, Oklahoma, Texas, Virginia, West Virginia, and Wisconsin. Based on the maximum downwind contribution in Table IV.F–3, the following additional states contribute at or above the 0.70 ppb threshold to downwind violating monitor maintenance-only receptors in 2023: Kansas and Tennessee. (However, the EPA is not taking final action based on this analytical result for these two states at this time.) The levels of contribution between each of these linked upwind states and downwind nonattainment receptors and maintenance-only receptors are provided in the Air Quality Modeling Final Rule TSD.

Among the linked states are several western states—California, Nevada, and Utah. While the EPA has not previously included action on linked western states in its prior CSAPR rulemakings, the EPA has consistently applied the 4-step framework in evaluating good neighbor obligations from these states. On a case-by-case basis, the EPA has found in some instances with respect to the 2008 ozone NAAQS that a unique consideration has warranted approval of a western state’s good neighbor SIP submittal that might otherwise be found to contribute above 1 percent of the NAAQS without concluding that additional emissions reductions are required at Step 3 of the framework.¹⁸⁸ The EPA has also explained in prior actions that its air quality modeling is reliable for assessing downwind air quality problems and ozone transport contributions from upwind states throughout the nationwide modeling domain.¹⁸⁹ The EPA is deferring finalizing a finding at this time for Oregon (*see* section IV.G of this document for additional information).

As explained in the following section, the EPA is not, in this action, altering its prior approval of Oregon’s good neighbor SIP submission for the 2015 ozone NAAQS. For the remaining western states included in this rule, the EPA’s modeling supports a conclusion that these states are linked above the

¹⁸⁵ The status of monitoring sites in California to which Oregon may be linked is under review. *See* section IV.G.

¹⁸⁶ The EPA approved Hawaii’s 2015 ozone transport SIP on December 27, 2021. *See* 86 FR 73129.

¹⁸⁷ The EPA approved Alaska’s 2015 ozone transport SIP on December 18, 2019. *See* 84 FR 69331.

¹⁸⁸ *See* interstate transport approval actions under the 2008 ozone NAAQS for Arizona, California, and Wyoming at 81 FR 36179 (June 6, 2016), 83 FR 65093 (December 19, 2018), and 84 FR 14270 (April 10, 2019), respectively.

¹⁸⁹ *See* 81 FR 71991 (October 19, 2016), 82 FR 9155 (February 3, 2017).

contribution threshold to identified ozone transport receptors in downwind states, and therefore, consistent with the treatment of all other states within the modeling domain, the EPA proposes to proceed to evaluate these states for a determination of “significant contribution” at Step 3.

In conclusion, as described above, states with contributions that equal or exceed 1 percent of the NAAQS to either nonattainment or maintenance-only receptors are identified as “linked” at Step 2 of the good neighbor framework and warrant further analysis for significant contribution to nonattainment or interference with maintenance under Step 3. The EPA finds that for purposes of this final rule, the following 23 states are linked at Step 2 in 2023: Alabama, Arkansas, California, Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, Minnesota, Mississippi, Missouri, Nevada, New Jersey, New York, Ohio, Oklahoma, Pennsylvania, Texas, Utah, Virginia, West Virginia, and Wisconsin. In addition, the EPA finds that the following 20 States are linked at Step 2 in 2026: Arkansas, California, Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, Mississippi, Missouri, Nevada, New Jersey, New York, Ohio, Oklahoma, Pennsylvania, Texas, Utah, Virginia, and West Virginia. We note that our updated modeling for this final rule shows that two states, Minnesota and Wisconsin, that we found linked in 2026 at proposal are no longer projected to be linked in that year but are linked in 2023.¹⁹⁰ As at proposal, Alabama is only projected to be linked in 2023, not 2026.

For six states, the EPA’s analysis at this time indicates that a linkage may exist in 2023 for which the EPA had not proposed FIP requirements, or the updated analysis for this final rule suggests that linkages we had previously found in the proposed action are now uncertain and warrant further analysis. The EPA intends to expeditiously address these states in a separate action or actions: Arizona, Iowa, Kansas, New Mexico, Tennessee, and Wyoming.

G. Treatment of Certain Monitoring Sites in California and Implications for Oregon’s Good Neighbor Obligations for the 2015 Ozone NAAQS

The EPA previously approved Oregon’s September 25, 2018 transport SIP submittal for the 2015 ozone

¹⁹⁰ Minnesota and Wisconsin were linked to maintenance-only receptors in Cook County, IL in 2023. Minnesota and Wisconsin are not linked in 2026 because the 2026 average and maximum design values at the monitoring sites are projected to show attainment.

NAAQS on May 17, 2019 (84 FR 22376), because in an earlier round of modeling Oregon was not projected to contribute above 1 percent of the NAAQS to any downwind receptors. In the EPA’s updated modeling used at proposal (2016v2) and again in the final modeling (2016v3), Oregon is modeled to contribute above the 1 percent of NAAQS threshold to several monitoring sites in California that would generally meet the EPA’s definition of nonattainment or maintenance “receptors” at Step 1.¹⁹¹ At proposal, the EPA explained that our analysis of the nature of the air quality problem at these monitoring sites led us to propose a determination that these monitoring sites should not be treated as receptors for purposes of determining interstate transport obligations of upwind states under CAA section 110(a)(2)(D)(i)(I). We explained that we reached this conclusion at Step 1 of our 4-step framework.

The EPA previously made a similar assessment of the nature of certain other monitoring sites in California in approving Arizona’s 2008 ozone NAAQS transport SIP submittal.¹⁹² There, the EPA noted that a “factor [. . .] relevant to determining the nature of a projected receptor’s interstate transport problem is the magnitude of ozone attributable to transport from all upwind states collectively contributing to the air quality problem.”¹⁹³ The EPA observed that only one upwind state (Arizona) was linked above 1 percent of the 2008 ozone NAAQS to the two relevant monitoring sites in California, and the cumulative ozone contribution from all upwind states to those sites was 2.5 percent and 4.4 percent of the total ozone, respectively. The EPA determined the size of those cumulative upwind contributions was “negligible, particularly when compared to the relatively large contributions from upwind states in the East or in certain other areas of the West.”¹⁹⁴ In that action, the EPA concluded the two California sites to which Arizona was linked should not be treated as receptors for the purposes of determining Good Neighbor obligations for the 2008 ozone NAAQS.¹⁹⁵

¹⁹¹ Monitors are included in the docket for this rulemaking. While EPA is providing information about cumulative upwind contribution to the California monitors, the Agency is not making a determination in this action that these monitors are ozone transport receptors.

¹⁹² 81 FR 15200 (March 22, 2016) (proposal); 81 FR 31513 (May 19, 2016) (final rule).

¹⁹³ 81 FR 15203.

¹⁹⁴ *Id.*

¹⁹⁵ *Id.*

Comment: Commenters criticized what they considered to be unfair treatment of Oregon, stating that the EPA is applying a higher contribution threshold than it applies to other states. Commenters argued that EPA has not established a specific threshold for why the level of upwind-state impact at these sites should not be considered meaningful. Commenters argued that our analysis ignored the fact that there are many monitoring sites in California to which Oregon contributes above 1 percent of the NAAQS. Commenters state that EPA has failed to explain why Oregon is not subject to this rulemaking, while other states contribute lower total downwind ozone contributions and fewer receptors. Commenters concluded that since Oregon is linked it should be subject to the same emissions control determinations at Step 3 and 4 as every other state, or otherwise apply the same “nature of the air quality problem” consideration to eliminate other receptors.

Response: The EPA acknowledges that several commenters opposed the proposed treatment of Oregon and the California monitoring sites to which it is linked in the proposed and final modeling. We also recognize that other commenters expressed confusion regarding the role of this proposed determination at Step 1 and how it relates to the longstanding 4-step interstate transport framework that the EPA is otherwise applying in this action. In recognition of these concerns and the need to give further thought to the appropriate treatment of both upwind states and downwind receptors in these circumstances, the EPA is deferring finalizing a finding at this time for Oregon. The current approval of the state’s SIP submission will remain in place for the time being, pending further review. We make no final determination in this action regarding whether the California monitoring sites at issue should or should not be treated as receptors for purposes of addressing interstate transport for the 2015 ozone NAAQS.

V. Quantifying Upwind-State NO_x Emissions Reduction Potential To Reduce Interstate Ozone Transport for the 2015 Ozone NAAQS

A. The Multi-Factor Test for Determining Significant Contribution

This section describes the EPA’s methodology at Step 3 of the 4-step framework for identifying upwind emissions that constitute “significant” contribution for the states subject to this final rule and focuses on the 23 states with FIP requirements identified in the

previous sections. Following the existing framework as applied in the prior CSAPR rulemakings, the EPA's assessment of linked upwind state emissions is based primarily on analysis of several alternative levels of NO_x emissions control stringency applied uniformly across all of the linked states. The analysis includes assessment of non-EGU stationary sources in addition to EGU sources in the linked upwind states.

The EPA applies a multi-factor test—the same multi-factor test that was used in CSAPR, the CSAPR Update, and the Revised CSAPR Update¹⁹⁶—to evaluate increasing levels of uniform NO_x control stringency. The multi-factor test, which is central to EPA's Step 3 quantification of significant contribution, considers cost, available emissions reductions, downwind air quality impacts, and other factors to determine the appropriate level of uniform NO_x control stringency that would eliminate significant contribution to downwind nonattainment or maintenance receptors. The selection of a uniform level of NO_x emissions control stringency across all of the linked states, reflected as a representative cost per ton of emissions reduction (or a weighted average cost per ton in the case of EPA's non-EGU and EGU analysis for 2026 mitigation measures), also serves to apportion the reduction responsibility among collectively contributing upwind states. This approach to quantifying upwind state emission-reduction obligations using uniform cost was reviewed by the Supreme Court in *EME Homer City Generation*, which held that using such an approach to apportion emissions reduction responsibilities among upwind states that are collectively responsible for downwind air quality impacts “is an efficient and equitable solution to the allocation problem the Good Neighbor Provision requires the Agency to address.” 572 U.S. at 519.

There are four stages in developing the multi-factor test: (1) identify levels of uniform NO_x control stringency; (2) evaluate potential NO_x emissions reductions associated with each identified level of uniform control stringency; (3) assess air quality improvements at downwind receptors for each level of uniform control stringency; and (4) select a level of control stringency considering the identified cost, available NO_x emissions reductions, and downwind air quality impacts, while also ensuring that emissions reductions do not

unnecessarily over-control relative to the contribution threshold or downwind air quality.

As mentioned in section III.A.2 of this document, commenters on the proposed rule and previous ozone transport rules have suggested that the EPA should regulate VOCs as an ozone precursor. For this final rule, the EPA examined the results of the contribution modeling performed for this rule to identify the portion of the ozone contribution attributable to anthropogenic NO_x emissions versus VOC emissions from each linked upwind state to each downwind receptor. Of the total upwind-downwind linkages in 2023, the contributions from NO_x emissions comprise 80 percent or more of the total anthropogenic contribution for nearly all of the linkages (121 out of 124 total). Across all receptors, the contribution from NO_x emissions ranges from 84 percent to 97 percent of the total anthropogenic contribution from upwind states. This review of the portion of the ozone contribution attributable to anthropogenic NO_x emissions versus VOC emissions from each linked upwind state leads the Agency to conclude that the vast majority of the downwind air quality areas addressed by the final rule under are primarily NO_x-limited, rather than VOC-limited. Therefore, the EPA continues to find that regulation of VOCs as an ozone precursor in upwind states is not necessary to eliminate significant contribution or interference with maintenance in downwind areas in this final rule. The remainder of this section focuses on EPA's strategy for reducing regional-scale transport of ozone by targeting NO_x emissions from stationary sources to achieve the most effective reductions of ozone transport over the geography of the affected downwind areas.

For both EGUs and non-EGUs, section V.B of this document describes the available NO_x emissions controls that the EPA evaluated for this final rule and their representative cost levels (in 2016\$). Section V.C of this document discusses EPA's application of that information to assess emissions reduction potential of the identified control stringencies. Finally, section V.D of this document describes EPA's assessment of associated air quality impacts and EPA's subsequent identification of appropriate control stringencies considering the key relevant factors (cost, available emissions reductions, and downwind air quality impacts).

This multi-factor approach is consistent with EPA's approach in prior transport actions, such as CSAPR. In

addition, as was evaluated in the CSAPR Update and Revised CSAPR Update, the EPA evaluated whether, based on particularized evidence, its selected control strategy would result in over-control for any upwind state by examining whether an upwind state is linked solely to downwind air quality problems that could have been resolved at a lesser threshold of control stringency and whether an upwind state could reduce its emissions below the 1 percent air quality contribution threshold at a lesser threshold of control stringency. This analysis is described in section V.D of this document.

Finally, while the EPA has evaluated potential emissions reductions from non-EGU sources in prior rules and found certain non-EGU emissions reductions should inform the budgets established in the NO_x SIP Call, this is the first action for which the EPA is finalizing non-EGU emissions reductions within the context of the specific, 4-step interstate transport framework established in CSAPR. The EPA applies its multi-factor test to non-EGUs and independently evaluates non-EGU industries in a consistent but parallel track to its Step 3 assessment for EGUs. This is consistent with the parallel assessment approach taken for EGUs and non-EGUs in the Revised CSAPR Update. Following the conclusions of the EGU and non-EGU multi-factor tests, the identified reductions for EGUs and non-EGUs are combined and collectively analyzed to assess their effects on downwind air quality and whether the rule achieves a full remedy to eliminate “significant contribution” while avoiding over-control.

To ensure that this rule implements a full remedy for the elimination of significant contribution from upwind states, the EPA has reviewed available information on all major industrial source sectors in the upwind states inclusive of commenter-provided data. This analysis leads the EPA to conclude that both EGUs and certain large sources in several specific industrial categories should be evaluated for emissions control opportunities. As discussed in the sections that follow, the EPA determines, for both EGUs and the selected non-EGU source categories, there are impactful emissions reduction opportunities available at reasonable cost-effectiveness thresholds. As in the Revised CSAPR Update, the EPA examines EGUs and non-EGUs in this section on consistent but distinct parallel tracks due to differences stemming from the unique characteristics of the power sector

¹⁹⁶ See CSAPR, Final Rule, 76 FR 48208 (August 8, 2011).

compared to other industrial source categories.

Since the NO_x SIP Call, EGUs have consistently been regulated under ozone transport rules. These units operate in a coordinated manner across a highly interconnected electrical grid. Their configuration and emissions control strategies are relatively homogenous, and their emissions levels and emissions control opportunities are generally very well understood due to longstanding monitoring and data-reporting requirements. Non-EGU sources, by contrast, are relatively heterogeneous, even within a single industrial category, and have far greater variation in existing emissions control requirements, emissions levels, and technologies to reduce emissions. In general, despite these differences, the information available for this rulemaking indicates that both EGUs and certain non-EGU categories have available cost-effective NO_x emissions reduction opportunities at relatively commensurate cost per ton levels, and these emissions reductions will make a meaningful improvement in air quality at the downwind receptors. Section V.B.2 of this document describes EPA's process for selecting specific non-EGU industries and emissions unit types included in this final rulemaking.

The EPA notes that its Step 3 analysis for this FIP does not assess additional emissions reduction opportunities from mobile sources. The EPA continues to believe that title II of the CAA provides the primary authority and process for reducing these emissions at the Federal level. EPA's various Federal mobile source programs, summarized in this section, have delivered and are projected to continue to deliver substantial nationwide reductions in both VOCs and NO_x emissions; these reductions from final rules are factored into the Agency's assessment of air quality and contributions at Steps 1 and 2. Further, states are generally preempted from regulating new vehicles and engines with certain exceptions, and therefore a question exists regarding EPA's authority to address such emissions through such means when regulating in place of the states under CAA section 110(c). See generally CAA section 209. See also 86 FR 23099. As noted earlier, the EPA accounted for mobile source emissions reductions resulting from other federally enforceable regulatory programs in the development of emissions inventories used to support analysis for this final rulemaking, and the EPA does not evaluate any mobile source control measures in its Step 3 evaluation in this

rule.¹⁹⁷ For further discussion of EPA's existing and ongoing mobile source measures, see section V.B.4 of this document.

B. Identifying Control Stringency Levels

1. EGU NO_x Mitigation Strategies

In identifying levels of uniform control stringency for EGUs, the EPA assessed the same NO_x emissions controls that the Agency analyzed in the CSAPR Update and the Revised CSAPR Update, all of which are considered to be widely available in this sector: (1) fully operating existing SCR, including both optimizing NO_x removal by existing operational SCRs and turning on and optimizing existing idled SCRs; (2) installing state-of-the-art NO_x combustion controls; (3) fully operating existing SNCRs, including both optimizing NO_x removal by existing operational SNCRs and turning on and optimizing existing idled SNCRs; (4) installing new SNCRs; and (5) installing new SCRs. Finally, for each of these combustion and post combustion technologies identified, EPA evaluated whether emissions reduction potential from generation shifting at that representative dollar per ton level was appropriate at this Step. Shifting generation to lower NO_x emitting or zero-emitting EGUs may occur in response to economic factors. As the cost of emitting NO_x increases, it becomes increasingly cost-effective for units with lower NO_x rates to increase generation, while units with higher NO_x rates reduce generation. Because the cost of generation is unit-specific, this generation shifting occurs incrementally on a continuum. For the reasons explained in the following sections and supported by technical information provided in the EGU NO_x Mitigation Strategies Final Rule TSD included in the docket for this final rule, the EPA determined that for the regional, multi-state scale of this rulemaking, only EGU NO_x emissions controls 1 and 3 are possible for the 2023 ozone season (fully operating existing SCRs and SNCRs). The EPA finds that it is not possible to

¹⁹⁷ The EPA recognizes that mechanisms exist under title I of the CAA that allow for the regulation of the use and operation of mobile sources to reduce ozone-precursor emissions. These include specific requirements that apply in certain ozone nonattainment areas including motor vehicle inspection and maintenance (I/M) programs, gasoline vapor recovery, clean-fuel vehicle programs, transportation control programs, and vehicle miles traveled programs. See, e.g., CAA sections 182(b)(3), 182(b)(4), 182(c)(3), 182(c)(4), 182(c)(5), 182(d)(1), 182(e)(3), and 182(e)(4). The EPA views these programs as well as others that meet CAA requirements can be effective and appropriate in the context of the planning requirements applicable to designated nonattainment areas.

install state-of-the-art NO_x combustion controls by the 2023 ozone season on a regional scale; those controls are assumed to be available by the beginning of the 2024 ozone season. All cost values discussed in the rest of the section for EGUs are in 2016 dollars.

a. Optimizing Existing SCRs

Optimizing (*i.e.*, turning on idled or improving operation of partially operating) existing SCRs can substantially reduce EGU NO_x emissions quickly, using investments that have already been made in pollution control technologies. With the promulgation of the CSAPR Update and the Revised CSAPR Update, most operators in the covered states improved their SCR performance and have continued to maintain that level of improved operation. However, this optimized SCR performance was not universal and not always sustained. Between 2017 and 2020, as the CSAPR Update ozone-season NO_x allowance price declined, NO_x emissions rates at some SCR-controlled EGUs increased. For example, power sector data from 2019 revealed that, in some cases, operating units had SCR controls that had been idled or were operating partially, and therefore suggested that there remained emissions reduction potential through optimization.¹⁹⁸ The EPA determined in the Revised CSAPR Update that optimizing SCRs was a readily available approach for EGUs to reduce NO_x emissions in the 12 states addressed by a FIP in that rulemaking. Noticeable improvements in emissions rates at units with SCRs during the 2021 and 2022 compliance period further affirm the ability of sources to quickly implement this mitigation strategy and to realize emissions reductions from doing so. This emissions reduction measure is currently available at EGUs across the broader geography affected in this final rulemaking (including in states not previously affected by the Revised CSAPR Update). The EPA thus determines that SCR optimization, of both idled and partially operating controls, is a viable mitigation strategy for the 2023 ozone season.

The EPA estimates a representative marginal cost of optimizing SCR controls to be approximately \$1,600 per ton, consistent with its estimation in the Revised CSAPR Update for this technology. EPA's EGU NO_x Mitigation Strategies Final Rule TSD for this rule describes a range of cost estimates for

¹⁹⁸ See "Ozone Season Data 2018 vs. 2019" and "Coal-fired Characteristics and Controls" at <https://www.epa.gov/airmarkets/power-plant-data-highlights#OzoneSeason>.

this technology noting that the costs are frequently lower than—and for the majority of EGUs, significantly lower than—this representative marginal cost. While the costs of optimizing existing, operational SCR units include only variable costs, the cost of optimizing SCR units that are currently idled considers both variable and fixed costs of returning the control into service. Variable and fixed costs include labor, maintenance and repair, parasitic load, and ammonia or urea for use as a NO_x reduction reagent in SCR systems. Depending on a unit's control operating status, the representative cost at the 90th percentile unit (among the relevant fleet of coal units with SCR covered in this rulemaking) ranges between \$900 and \$1,700 per ton. The EPA performed an in-depth cost assessment for all coal-fired units with SCRs and found that for the subset of SCRs that are already partially operating, the cost of optimizing is often much lower than \$1,600 per ton and is often under \$900 per ton. The EPA anticipates the vast majority of realized cost for compliance with this strategy to be better reflected by the \$900 per ton end of that range (reflecting the 90th percentile of EGUs optimizing SCRs that are already partially operating) because this circumstance is considerably more common than EGUs that have ceased operating their SCR. This cost distinction is reflected in the EPA's RIA cost estimates. When representing the cost of optimization here, the EPA uses the higher value to reflect both optimization of partially operating and idled controls. EPA's analysis of this emissions control is informed by the latest engineering modeling equations used in EPA's IPM platform. These cost and performance equations were recently updated in the summer of 2021 in preparation for this rule, and subsequently evaluated for the final rule in 2022 and determined to still be appropriate. The description and development of the equations are documented in EGU NO_x Mitigation Strategies Final Rule TSD and accompanying documents.¹⁹⁹ They are also implemented in an interactive spreadsheet tool called the Retrofit Cost Analyzer and applied to all units in the fleet. These materials are available in the docket for this action.

The EPA is using the same methodology to identify SCR

¹⁹⁹ The CSAPR Update estimated \$1,400 per ton as a representative cost of turning on idled SCR controls. EPA used the same costing methodology while updating for input cost increases (e.g., urea reagent) to arrive at \$1,600 per ton in the final Revised CSAPR Update (while also updating from 2011 dollars to 2016 dollars).

performance as it did in the Revised CSAPR Update. To estimate EGU NO_x reduction potential from optimizing, the EPA considers the difference between the non-optimized NO_x emissions rates and an achievable operating and optimized SCR NO_x emissions rate. To determine this rate, EPA evaluated nationwide coal-fired EGU NO_x ozone season emissions data from 2009 through 2019 and calculated an average NO_x ozone season emissions rate across the fleet of coal-fired EGUs with SCR for each of these eleven years. The EPA found it prudent to not consider the lowest or second-lowest ozone season NO_x emissions rates, which may reflect SCR systems that have all new components (e.g., new layers of catalyst). Data from these systems are potentially not representative of ongoing achievable NO_x emissions rates considering broken-in components and routine maintenance schedules. Considering the emissions data over the full time period from 2009–2019 results in a third-best rate of 0.079 pounds NO_x per million British thermal units (lb/mmBtu). Therefore, consistent with the Revised CSAPR Update, where EPA identified 0.08 lb/mmBtu as a reasonable level of performance for units with optimized SCR, the EPA finalizes a rate of 0.08 lb/mmBtu as the optimized rate for this rule. The EPA notes that half of the SCR-controlled EGUs achieved a NO_x emissions rate of 0.064 lb/mmBtu or lower over their third-best entire ozone season. Moreover, for the SCR-controlled coal units that the EPA identified as having a 2021 emissions rate greater than 0.08 lb/mmBtu, the EPA verified that in prior years, the majority (more than 90 percent) of these same units had demonstrated and achieved a NO_x emissions rate of 0.08 lb/mmBtu or less on a seasonal or monthly basis. This further supports EPA's determination that 0.08 lb/mmBtu reflects a reasonable emissions rate for representing SCR optimization at coal steam units in identifying uniform control stringency. This emissions rate assumption of 0.08 lb/mmBtu reflects what those units would achieve on average when optimized, recognizing that individual units may achieve lower or higher rates based on unit-specific configuration and dispatch patterns. Units historically performing at, or better, than this rate of 0.08 lb/mmBtu are assumed to continue to operate at that prior performance level.

Given the magnitude and duration of the air quality problems addressed by this rulemaking, the EPA also applied the same methodology to identify a

reasonable level of performance for optimizing existing SCRs at oil- and gas-fired steam units and simple cycle units (for which EPA determined that a 0.03 lb/mmBtu emissions rate reflected SCR optimization) as well as at combined-cycle units (for which the EPA determined that a 0.012 lb/mmBtu emissions rate reflected SCR optimization).

The EPA evaluated the feasibility of optimizing idled SCRs for the 2023 ozone season. Based on industry past practice, the EPA determined that idled controls can be restored to operation quickly (*i.e.*, in less than 2 months). This timeframe is informed by many electric utilities' previous long-standing practice of utilizing SCRs to reduce EGU NO_x emissions during the ozone season while putting the systems into protective lay-up during the non-ozone season months. For example, this was the long-standing practice of many EGUs that used SCR systems for compliance with the NO_x Budget Trading Program. It was quite typical for SCRs to be turned off following the end of the ozone season control period on September 30. These controls would then be put into protective lay-up for several months of non-use before being returned to operation by May 1 of the following ozone season.²⁰⁰ Therefore, the EPA believes that optimization of existing SCRs is possible for the portion of the 2023 ozone season covered under this final rule. The recent successful implementation of this strategy for the Revised CSAPR Update Rule, and corresponding fast improvement in SCR performance rates at units with optimization potential, provides further supporting evidence of the viability of this timeframe.

The vast majority of SCR-controlled units (nationwide and in the 23 linked states for which EPA is issuing a FIP for EGUs) are already partially operating these controls during the ozone season based on reported 2021 and 2022 emissions rates. Notably, the higher ozone season NO_x allowance price observed in 2022 resulted in more units operating their controls closer to their potential and bringing collective emissions from those 12 states closer to the 2023 emissions budgets for those states in this final rule, accordingly.

²⁰⁰ In the 22-state CSAPR Update region, 2005 EGU NO_x emissions data suggest that 125 EGUs operated SCR systems in the summer ozone season while idling these controls for the remaining 7 non-ozone season months of the year. Units with SCR were identified as those with 2005 ozone season average NO_x rates that were less than 0.12 lb/mmBtu and 2005 average non-ozone season NO_x emissions rates that exceeded 0.12 lb/mmBtu and where the average non-ozone season NO_x rate was more than double the ozone season rate.

Existing SCRs operating at partial capacity still provide functioning, maintained systems that may only require an increased chemical reagent feed rate (*i.e.*, ammonia or urea) up to their design potential and catalyst maintenance for mitigating NO_x emissions; such units may require increased frequency or quantity of deliveries, which can be accomplished within a few weeks. In many cases, EGUs with SCR have historically achieved more efficient NO_x removal rates than their current performance and can therefore simply revert to earlier operation and maintenance plans that achieved demonstrably better SCR performance.

In the 12 states subject to this control stringency in the Revised CSAPR Update, the EPA observed significant immediate-term improvements in SCR performance in the first ozone season following finalization of that rule, as evidenced in particular by the sharp drop in emissions rate at Miami Fort unit 7 (*see* EGU NO_x Mitigation Strategies Final Rule TSD). For instance, in June of 2021—within months of the Revised CSAPR Rule being finalized—Miami Fort Unit 7 and Unit 8 (which had substantial SCR optimization potential) were able to reach levels of 0.07 lb/mmBtu of NO_x (a greater than 50 percent reduction from where they had operated the prior year during the same month). Such empirical data further illustrates the viability of this mitigation strategy for the 2023 control period in response to this rule.

Comment: EPA received comments supporting the 0.08 lb/mmBtu emissions rate as achievable and, according to some commenters, underestimate the control's potential. Some of these commenters went on to provide their own analysis demonstrating that the 0.08 lb/mmBtu was achievable not only on average for the non-optimized fleet, but also for these individual units and that the resulting state emissions budgets were likewise achievable. Some commenters suggested that the rate should be lower and premised on EPA using the first- or second-best year instead of the third best year of SCR performance. Some commenters observed that using the same methodology, but omitting SCR units that have since retired, could deliver an even lower SCR performance benchmark rate.

Response: The EPA notes that updating the inventory of coal-fired EGUs to reflect recent retirements and to include data reported since 2019 (*e.g.*, 2009–2021) would provide a lower value of 0.071 lb/mmBtu. However, EPA acknowledges that 2020 operational

data included impacts from COVID–19 pandemic shutdowns (such as atypical electricity demand patterns) which complicate interpretations of typical EGU emissions performance. Additionally, EPA believes that in this context, a unit's retirement in 2020 or 2021 does not obviate the usefulness of its prior SCR operational data for assessing the emissions control performance of other existing SCRs across the fleet. Consequently, EPA is continuing to use the same value of the 0.08 lb/mmBtu emissions rate calculated from the 2009–2019 data set identified at the time of the final Revised CSAPR Update Rule in this rulemaking. EPA's analysis focuses on the third best ozone season average rate because EPA believes that the first- or second-best rate, consistent with its CSAPR Update final rule and in the Revised CSAPR Update, could give undue weight to the emissions control performance of new SCRs in their first year of service and their corresponding newer SCR components. It does not necessarily reflect achievable ongoing NO_x emissions rates at relatively older SCRs. The third-lowest season was selected because it represents a time when the unit was most likely consistently and efficiently operating its SCR in a manner representative of sustained future operation.

Comment: Other commenters suggested that EPA should apply a higher NO_x emissions rate than 0.08 lb/mmBtu to existing SCR at coal EGUs premised on considerations such as: a generally reduced average capacity factor for coal units in recent years, the age of the boiler, coal rank (bituminous or subbituminous), or other unit-specific considerations that commenters claim make the 0.08 lb/mmBtu rate unattainable for a specific unit.

Response: EPA did not find sufficient justification to apply a higher average emissions rate than 0.08 lb/mmBtu. EPA found that some commenters were misunderstanding or misconstruing both EPA's assumption and implementation mechanism as a unit-level requirement for every SCR-controlled unit instead of a reflection of a fleet-wide average based on a third-best rate. The commenters' observation—that 0.08 lb/mmBtu may be difficult for some units to achieve or may not be a preferred compliance strategy for a given unit given its dispatch levels—does not contradict EPA's assumption, but rather supports its methodology and assumptions. As EPA pointed out in the proposed rule, this fleet-level emissions rate assumption of 0.08 lb/mmBtu for non-optimized units reflects, on average,

what those units would achieve when optimized. Some of these units may achieve rates that are lower than 0.08 lb/mmBtu, and some units may operate above that rate based on unit-specific configuration and dispatch patterns. In other words, EPA is using this assumption as the average performance of a unit that optimizes its SCR, recognizing that heterogeneity within the fleet will likely lead some units to overperform and others to underperform this rate. Moreover, a review of unit-specific historical data indicates that this is a reasonable assumption: not only has the group of units with SCR optimization potential demonstrated they can perform at or better than the 0.08 lb/mmBtu rate on average, over 90 percent of the individual units in this group have already met this rate on a seasonal and/or monthly basis based on their reported historical data.

Additionally, EPA's examination of units experiencing SCR performance deterioration included notable instances of poor NO_x control at *increased* capacity factors. As an example, Miami Fort Unit 7 had considerably more hours of operation at a 70 to 79 percent capacity factor in 2019 compared to previous years. However, Miami Fort Unit 7's ozone-season NO_x emissions rate *substantially increased* in 2019 compared to previous years. This SCR performance deterioration runs counter to the notion that an increase in emissions rates is purely driven by reduced capacity factor, as suggested by commenters. This substantial deterioration in the median emissions rate performance is observable even when comparing specific hours in 2019 to specific hours in prior years when the unit operated in the same 70 to 79 percent capacity factor range. In fact, in 2019 the unit experienced notable emissions rate increases from prior years across multiple capacity factor ranges as low as 40 percent to as high as 80 percent. This type of data indicates instances where the increase in emissions rate (and emissions) is not necessitated by load changes but is more likely due to the erosion of the existing incentive to optimize controls (*i.e.*, the ozone-season NO_x allowance price has fallen so low that unit operators find it more economic to surrender additional allowances instead of continuing to operate pollution controls at an optimized level).

EPA observed this pattern in other units identified in this rulemaking as having significant SCR optimization emissions reduction potential. In the accompanying Emissions Data TSD for the supplemental notice that EPA recently released in a proceeding to


address a recommendation submitted to EPA by the Ozone Transport Commission under CAA section 184(c), EPA noted, “In their years with the lowest average ozone season NO_x emissions rates in this analysis, these EGUs had relatively low NO_x emissions rates at mid- and high-operating levels; moreover, there was little variability in NO_x emissions rates at these operating levels. However, during the 2019 ozone season, these EGUs had higher NO_x emissions rates and greater variability in

NO_x emissions rates across operating levels than in the past, particularly at mid-operating levels.”²⁰¹ That hourly data analysis, included in this docket, controls for operating level changes and still finds there to be instances across multiple SCR-controlled units where hourly emissions rates are increasing even when compared to the same load levels in previous years.

Some commenters have alleged that in recent years coal-fired EGUs have declined in capacity factor and that SCR

performance declines at those lower operating levels. However, hourly data indicate that maintaining consistent SCR performance at lower capacity factors is possible. For example, the unit-level performance data in Figure 2 to section VI.B of this document show the emissions rate at a coal-fired EGU with existing SCR staying relatively low (consistent with our optimization assumption of 0.08 lb/mmBtu) and stable across a wide range of capacity factors.²⁰²

Figure 2 to section V.B.1.a: Example of Consistently Low Unit-level Emissions Rate During Periods of Varying Capacity Factor



Furthermore, most recent data from 2022 illustrates that cycling units do have the ability to adjust cycling patterns in a manner that enables them to maintain a lower emissions rate throughout the season while still achieving a load cycling pattern at the unit. For example, the SCR-controlled Conemaugh Unit 2 in Pennsylvania adjusted operating patterns in 2022 to have a slightly higher minimum load in most hours (maintaining a range of 550 MW–900 MW for most hours as opposed to 450 MW–900 MW observed in 2021). This change in minimum load, and corresponding minimum operating temperature, enabled the unit to maintain emissions rates in the 0.05 lb/mmBtu to 0.10 lb/mmBtu range for most of the 2022 season (as opposed to NO_x emissions rates that regularly exceeded

0.25 lb/mmBtu in the 2021 season). This 2022 improvement in SCR operation occurred during a period when allowance prices increased relative to prior years, creating an incentive for potential emissions reductions through SCR optimization.

Comment: EPA also received comment suggesting it should deviate from its approach in the CSAPR Update of using a nationwide data set of all SCR controlled coal units to establish a third best year, and instead limit the dataset to either just the covered states, or—in the case of some commenters—just to the baseline years of those units at which EPA is identifying optimization potential. They claim the current methodology may capture extremely efficient SCR performance years at the best performing units and that level of

performance may not be available at all units with optimization potential. These commenters also disagree with the EPA finding that SCRs can consistently maintain a 0.08 lb/mmBtu rate over time.

Response: EPA reviewed the data and its methodology and evaluated it against its intention to identify a technology-specific representative emissions rate for SCR optimization. In doing so, EPA did not identify any need to make the suggested change. EPA is interested in the performance potential of a technology, and a larger dataset provides a superior indication of that potential as opposed to a smaller, state-limited dataset. Moreover, EPA’s use of the third best year (as opposed to best) from its baseline period results in an average optimization level that is robust

²⁰¹ “Analysis of Ozone Season NO_x Emissions Data for Coal-Fired EGUs in Four Mid-Atlantic States,” EPA Clean Air Markets Division. December

2020. Available at https://www.epa.gov/sites/production/files/2020-12/documents/184c_emission_data_tsd.pdf.

²⁰² EPA, *Air Markets Program Data*. Available at www.epa.gov/ampd.

to the commenters' concern that EPA should not overstate the fleetwide representative optimization level. Prior experience with EPA's methodology and program has borne out empirical evidence of its reasonableness. In both the CSAPR Update and in Revised CSAPR Update rule, EPA appropriately relied on the largest dataset possible (*i.e.*, nationwide) to derive technology performance averages that it then applied respectively to the CSAPR Update 22-state region and the Revised CSAPR Update's 12-state region. EPA repeats that successful approach in this rule. Finally, as noted in the preceding paragraphs, in affirming the reasonableness of this approach, EPA examined the historical reported data (pre-2021) for the units in the states with SCR optimization potential and found the nationwide derived average appropriate and consistent with demonstrated capability and performance of units within those states. That is, the vast majority of units to which this resulting emissions rate assumption was being applied had demonstrated the ability to achieve this rate in some prior year for an extended monthly or seasonal basis. This information is discussed further in the EGU NO_x Mitigation Strategies Final Rule TSD in the docket.

Comment: Some commenters suggested the price of SCR optimization is higher than the \$1,600 per ton figure proposed due to current market conditions for aqueous ammonia or other input prices.

Response: EPA provides a representative cost for this mitigation technology which is anticipated to reflect the cost, on average, throughout the compliance period for the rule. While there may be volatility in the market during that period where the price falls above or below the single representative threshold value, EPA's EGU NO_x Mitigation Strategies Final Rule TSD explains how the representative cost is derived and is inclusive of consultation and vetting by third party air pollution control consulting groups. Commenters did not demonstrate that observed 2021 elevated prices amid market volatility would continue into the future compliance periods discussed in this rule. Moreover, the selection of the mitigation technology is reflective of a variety of factors including reduction potential and air quality impact. A higher cost (commenter suggests up to \$3,800 per ton) would not change EPA's determination that optimizing already existing SCRs is an appropriate mitigation strategy for Step 3 emissions reduction analysis in this rulemaking as

it would remain one of the most widely available, widely practiced, and lowest cost mitigation measures with meaningful downwind air quality benefit. Appendix B of the EGU NO_x Mitigation Strategies Final Rule TSD further addresses commenters' concerns as it provides a variety of sensitivities showing cost per ton levels under a variety of different input assumptions (including higher material and reagent cost). It supports the continued inclusion of this technology in the rule even in the event that higher reagent costs extend into compliance years.

Comment: While many commenters supported the feasibility of 2023 ozone-season implementation by noting the "immediate availability" of SCR optimization, other commenters argued that the engineering, procurement, and other steps required for SCR optimization were not feasible given the anticipated limited window between rule finalization and the start of the 2023 ozone season.

Response: There is ample evidence of units restoring their optimal performance within a two-month timeframe. Not only do units reactivate SCR performance level at the start of an ozone-season when tighter emissions limits begin, but unit-level data also shows instances where sources have demonstrated the ability to quickly alter their emissions rate within an ozone-season and even within the same day in some cases. Moreover, this emissions control is familiar to sources and was analyzed and included in the Revised CSAPR Update emissions budgets finalized in 2021 and the CSAPR Update emissions budgets finalized in 2016. With this experience, and notice through the March 2022 proposed rule, as well as over two months from final rule to effective date, the viability of this emissions control for the 2023 ozone season is consistent with the 2-week to 2-month timeframe that EPA identified as reasonable in the CSAPR Update, Revised CSAPR Update, and in this rulemaking. Similar to prior rules, commenters provide some unit-level examples where it has taken longer. Also similar to those prior rules, EPA does not find those unit-level examples compelling in the context of its fleet average assumptions and in the implementation context of a trading program which provides compliance alternatives in the event a specific unit prefers more time to implement a given control measure. As noted in *Wisconsin*, ". . . all those anecdotes show is that installation can drag on when companies are unconstrained by the ticking clock of the law." 938 F.3d at 330.

b. Installing State-of-the-Art NO_x Combustion Controls

The EPA estimates that the representative cost of installing state-of-the-art combustion controls is comparable to, if not notably less than, the estimated cost of optimizing existing SCR (represented by \$1,600 per ton). State-of-the-art combustion controls such as low-NO_x burners (LNB) and over-fire air (OFA) can be installed or updated quickly and can substantially reduce EGU NO_x emissions. Nationwide, approximately 99 percent of coal-fired EGU capacity greater than 25 MW is equipped with some form of combustion control; however, the control configuration or corresponding emissions rates at a small portion of those units (including units in those states covered in this action) indicate they do not currently have state-of-the-art combustion control technology. For this rulemaking, the Agency re-evaluated its NO_x emissions rate assumptions for upgrading existing combustion controls to state-of-the-art combustion control. The EPA is maintaining its determination that NO_x emissions rates of 0.146 to 0.199 lb/mmBtu can be achieved on average depending on the unit's boiler configuration,²⁰³ and, once installed, reduce NO_x emissions at all times of EGU operation.

These assumptions are consistent with the Revised CSAPR Update. They are further discussed in the EGU NO_x Mitigation Strategies Final Rule TSD. In particular, the EPA is finalizing, as proposed, the application of the 0.199 lb/mmBtu emissions rate assumption for both boiler types (tangentially and wall fired). EPA's analysis calculated average emissions rates of 0.199 lb/mmBtu for combustion controls on dry bottom wall fired units and 0.146 lb/mmBtu for tangentially fired units. However, many of the likely impacted units burn bituminous coal, and the 0.146 lb/mmBtu nationwide average for tangentially-fired (inclusive of subbituminous units) appears to be below the demonstrated emissions rate of state-of-the-art combustion controls for bituminous coal units of this boiler type. Therefore, EPA's assignment of a 0.199 lb/mmBtu emissions rate for combustion controls at all affected unit types is robust to current and future coal choice at a unit.

The EPA has previously examined the feasibility of installing combustion controls and found that industry had demonstrated ability to install state-of-

²⁰³ Details of EPA's assessment of state-of-the-art NO_x combustion controls are provided in the EGU NO_x Mitigation Strategies Final Rule TSD.

the-art LNB controls on a large unit (800 MW) in under six months when including the pre-installation phases (design, order placement, fabrication, and delivery).²⁰⁴ In prior rules, the EPA has documented its own assessment of combustion control timing installation as well as evaluated comments it received regarding installation of combustion controls from the Institute of Clean Air Companies.²⁰⁵ Those comments provided information on the equipment and typical installation time frame for new combustion controls, accounting for all steps. To date, EPA has found it generally takes between 6–8 months on a typical boiler—covering the time through bid evaluation through start-up of the technology. The deployment schedule is repeated here as:

- 4–8 weeks—bid evaluation and negotiation
- 4–6 weeks—engineering and completion of engineering drawings
- 2 weeks—drawing review and approval from user
- 10–12 weeks—fabrication of equipment and shipping to end user site
- 2–3 weeks—installation at end user site
- 1 week—commissioning and start-up of technology

Given the referenced timeframe of approximately 6 to 8 months to complete combustion control installation in the region, the EPA is finalizing that installation of state-of-the-art combustion controls is a readily available approach for EGUs to reduce NO_x emissions by the start of the 2024 ozone season. More details on these analyses can be found in the *EGU NO_x Mitigation Strategies Final Rule TSD*.

The cost of installing state-of-the-art combustion controls per ton of NO_x reduced is dependent on the combustion control type and unit type. The EPA estimates the cost per ton of state-of-the-art combustion controls to be \$400 per ton to \$1,200 per ton of NO_x removed using a representative capacity factor of 85 percent. This cost fits well within EPA's representative cost threshold observed for SCR optimization and combustion controls (of \$1,600 per ton) which would accommodate combustion control upgrade even under scenarios where a

lower capacity factor is assumed. 99 percent of units have some form of combustion controls, indicating the widespread cost-effectiveness of this control. See the *EGU NO_x Mitigation Strategies Final Rule TSD* for additional details.

At proposal EPA assumed that emissions reductions from combustion control upgrades at affected EGUs in states subject to the Revised CSAPR Update program could occur by 2023 given that those EGUs may have already begun pursuing such upgrades in response to that previous rule. However, EPA does not have data to confirm that presumption, and hence EPA is determining in this final rule that combustion control upgrades for all affected EGUs, regardless of whether they were previously subject to the Revised CSAPR Update program, should be considered available by the 2024 ozone season, consistent with the deployment schedule noted in this section.

Comment: Some commenters suggested that EPA, in its modeling for the proposed rule, overestimated the ability of combustion control technologies to achieve very low NO_x emissions rates. The commenters claim EPA's assumptions are derived from projected NO_x emissions rates based on ideal circumstances for NO_x emissions reductions, including combinations of fuel composition and unit design that are not typical and should not be extrapolated to the national inventory.

Response: EPA's emissions performance rate for state-of-the-art combustion controls is derived from historical data and takes both boiler type and coal choice into account. EPA reviewed historical data and identified the average emissions rates for units with this technology already in place. It segmented this analysis by boiler type (dry-bottom wall-fired boiler and tangentially-fired, and further segmented by coal rank to assess the average performance among these varying parameters. As explained in the *EGU NO_x Mitigation Strategies Final Rule TSD*, EPA chose an emissions rate for which it verified accommodated (*i.e.*, was greater than or equal to) the average performance rate identified above for each boiler configuration with state-of-the-art combustion controls and resulted in reductions consistent with the technology's assumed percent reduction potential when applied to this subset of units. It also assessed whether the rate had been demonstrated by both subbituminous and bituminous coal units with state-of-the-art combustion controls. EPA further assessed the percent reduction that achieving this

rate would require from the specific segment of the fleet identified as having this mitigation measure available. Here too, EPA found that the effective percent reduction for the identified fleet (inclusive of their existing coal rank choice) is well within the historical performance range for this technology. Therefore, EPA is finalizing the combustion control upgrade performance assumption of 0.199 lb/mmBtu as appropriate representative average performance rate for this technology and robust to different boiler types and coal ranks.

c. Optimizing Already Operating SNCRs or Turning on Idled Existing SNCRs

Optimizing already operating SNCRs or turning on idled existing SNCRs can also reduce EGU NO_x emissions quickly, using investments in pollution control technologies that have already been made. Compared to no post-combustion controls on a unit, SNCRs can achieve a 25 percent reduction on average in EGU NO_x emissions (with sufficient reagent). They are less capital intensive but less efficient at NO_x removal than SCRs. These controls are in use to some degree across the U.S. power sector. In the 22 linked states with EGU reductions identified in this final rule, approximately 11 percent of coal-fired EGU capacity is equipped with SNCR.²⁰⁶ Recent power sector data suggest that, in some cases, SNCR controls have been operating less in 2021 relative to performance in prior years. For instance, EPA reviewed the last five years of performance data for all the units with SNCR optimization potential in its Engineering Analysis. It found that in 2021—the most recent year reviewed—that the weighted average ozone season emissions rate for these units was higher than the prior three years (indicating some deterioration in average performance). Moreover, a unit level review illustrated that 80 of the 107 units had performed better in a prior year by an average of 13 percent—indicating substantial optimization potential.²⁰⁷

The EPA determined that optimizing already operating SNCRs or turning on idled SNCRs is an available approach for EGUs to reduce NO_x emissions, has similar implementation timing to restarting idled SCR controls (less than 2 months for a given unit), and therefore could be implemented in time for the 2023 ozone season. In this final rule, the EPA is determining that this emissions

²⁰⁴ The EPA finds that, generally, the installation phase of state-of-the-art combustion control upgrades—on a single-unit basis—can be as little as 4 weeks to install with a scheduled outage (not including the pre-installation phases such as permitting, design, order, fabrication, and delivery) and as little as 6 months considering all implementation phases.

²⁰⁵ EPA-HQ-OAR-2015-0500-0093.

²⁰⁶ <https://www.epa.gov/airmarkets/national-electric-energy-data-system-needs-v6>.

²⁰⁷ See “Historical Emission Rates for Units with SNCR Optimization Potential” in the docket for this rulemaking.

control measure is available beginning in the 2023 ozone season.

Using the Retrofit Cost Analyzer described in the *EGU NO_x Mitigation Strategies Final TSD*, the EPA estimates a representative cost of optimizing SNCR ranging from approximately \$1,800 per ton (for partially operating SNCRs) to \$3,900 per ton (for idled SNCRs). For existing SNCRs that have been idled, unit operators may need to restart payment of some fixed and variable operating costs including labor, maintenance and repair, parasitic load, and ammonia or urea. The EPA determined that the majority of units with existing SNCR optimization potential were already partially operating their controls. Therefore, the EPA finalizes a representative cost of \$1,800 per ton for SNCR optimization as this value best reflects the circumstances of the majority of the affected EGUs with SNCR.

d. Installing New SNCRs

The EPA evaluated potential emissions reductions and associated costs from retrofitting EGUs with new SNCR post-combustion controls at steam units lacking such controls, which can achieve a 25 percent NO_x reduction on average. New SNCR technology provides owners with a relatively less capital-intensive option for reducing NO_x emissions compared to new SCR technology, albeit at the expense of higher operating costs on a per-ton basis and less total emissions reduction potential. SNCR is more widely observed on relatively smaller coal units given its low capital/variable cost ratio. The average capacity of a coal unit with SNCR is half the size of the average capacity of coal unit with SCR.²⁰⁸ Given these observations, the EPA identifies this technology as an emissions reduction measure for coal units less than 100 MW lacking post-combustion NO_x control technology. As described in the *EGU NO_x Mitigation Strategies Final Rule TSD*, the EPA estimated that \$6,700 per ton reflects a representative SNCR retrofit cost level for these units.

For this rulemaking, EPA is not considering SNCR installation timing unto itself but is instead considering how long eligible EGUs may need to adopt either SNCR or SCR as a post-combustion control measure. SNCR installations generally have shorter project installation timeframes relative to other post-combustion controls. The time for engineering review, contract award, fabrication, delivery, and

hookup is as little as 16 months including pre-contract award steps for an individual power plant installing controls on more than one boiler. However, SNCR retrofits have less pollution reduction potential than SCR, and as explained further in the next section, the EPA is identifying the retrofit of new SCR rather than SNCR as a strategy for larger steam units due to this lower removal efficiency. This approach respects empirical evidence that larger coal-fired EGUs which installed post-combustion NO_x control technology have overwhelmingly chosen SCR over SNCRs. Even for smaller units less than 100 MW identified as potential candidates for SNCR technology, the EPA does not want to preclude those units from pursuing SCR in lieu of SNCR.

Therefore, in this final rule the EPA defines the availability of emissions reductions from post-combustion control installation to be in 2026, the same period as the start of SCR-based reductions becoming available, to allow enough time for eligible EGUs to choose between SCR or SNCR. SNCR installation shares similar implementation steps with and also need to account for the same regional factors as SCR installations, which are described in the next section. While the EPA is determining that at least 16 months would be needed to complete all necessary steps of SNCR development and installation, an eligible EGU choosing new SCR instead would require installation timing of 36 to 48 months. EPA believes its finalized joint timing considerations for post-combustion control retrofits (SNCR and SCR) are justified given that post-combustion control retrofit decisions are subject to unit-specific economic and engineering factors and are sensitive to operator compliance strategy choices with respect to multiple regulatory requirements.

Comment: Some commenters argued that post-combustion control timing assumptions (SCR and SNCR) should be decoupled, which could result in the EPA using the 16-month time frame specific to SNCR installation to require emissions reductions related to new SNCR installations by the 2025 ozone season.

Response: The EPA does not agree that decoupling SCR and SNCR timing consideration is justified in the context of this final rule's emissions control program for EGUs. Approximately 1,000 tons of emissions reduction potential are estimated for the small coal EGUs deemed eligible for SNCR retrofit. The incentives provided through the implementation of this rule's trading

program will encourage these EGUs to determine and adopt emissions reduction measures (including SNCR or SCR) as soon as possible to reduce their allowance holding compliance burden. By scheduling SNCR-related emissions reductions potential for the 2026 ozone season, the EPA preserves the opportunity for considerably superior emissions reduction potential from these EGUs should they select SCR retrofit instead, while still requiring post-combustion control emissions reduction potential ahead of the next attainment date.

Comment: Some commenters argued that the upper range of SNCR NO_x removal performance (40 percent) referenced by EPA is optimistic for many boilers.

Response: EPA evaluated both actual performance and engineering literature regarding SNCR retrofit technology and found both sources supported the range of reduction estimates cited by EPA. (Refer to the *EGU NO_x Mitigation Strategies Final Rule TSD* in the docket for this rulemaking for additional information.) Moreover, for purposes of calculating state budgets, EPA assumes 25 percent reduction from this technology—not 40 percent—which reflects a value well within the range of documented performance for this technology. Remaining comments on SNCR performance potential are addressed in the *RTC Document* and in the *EGU NO_x Mitigation Strategies Final Rule TSD*.

e. Installing New SCRs

Selective Catalytic Reduction (SCR) controls already exist on over 66 percent of the coal fleet in the linked states that are subject to a FIP in this rulemaking. Nearly every pulverized coal unit larger than 100 MW built in the last 30 years has installed this control, which is generally required for Best Available Control Technology (BACT) purposes. Other than circulating fluidized bed coal units which can achieve a comparably low emissions rate without this technology, the EPA identifies this emissions reduction measure for coal steam units greater than or equal to 100 MW. SCR is widely available for existing coal units of this size and can provide significant emissions reduction potential, with removal efficiencies of up to 90 percent. The EPA limited its consideration of SCR technology to steam units greater than or equal to 100 MW. The costs for retrofitting a plant smaller than 100 MW with SCR increase

²⁰⁸ See *EGU NO_x Mitigation Strategies Final Rule TSD* for additional discussion.

rapidly due to a lack of economies of scale.²⁰⁹

The amount of time needed to retrofit an EGU with new SCR extends beyond the 2023 ozone season. Similar to the SNCR retrofits discussed in this section, the EPA evaluated potential emissions reductions and associated costs from this control technology, as well as the impacts and need for this emissions control strategy, at the earliest point in time when their installation could be achieved. EPA notes that it has previously determined in the context of ozone transport that regional scale implementation of SCRs at numerous EGUs is achievable in 36 months. *See* 63 FR 57356, 57447–50 (October 27, 1998). However, since that time, the EPA has found up to 36–48 months to be a more appropriate installation timeframe for regionwide actions when the EPA is evaluating multiple installations at multiple locations.²¹⁰

In the past, the EPA has found the amount of time to retrofit a single EGU with new SCR, depending on the regulatory program under which such control may be required, may vary between approximately 2 and 4 years depending on site-specific engineering considerations and on the number of installations being considered. This includes steps for engineering review, construction permit, operating permit, and control technology installation (including fabrication, pre hookup, control hookup, and testing). EPA's assessment of installation procedures suggests as little as 21 months may be needed for a single SCR at an individual plant and 36 months at a single plant with multiple boilers. EPA's assessment of units with SCR retrofit potential indicate the majority fall into this first classification, *i.e.*, a single SCR at a power plant.

While EPA finds that 36 months is a possible time frame for SCR installation at individual units or plants, the total of nearly 31 GW of coal capacity with SCR retrofit potential and 19 GW of oil/gas steam capacity with SCR retrofit potential within the geographic footprint of the final rule is a scale of retrofit activity that is not demonstrated to have been achieved within a three-year span based on data from the past two decades. Given that some of the

assumed SCR retrofit potential occurs at plants with multiple units identified with retrofit potential, and given the total volume of SCR retrofit capacity being implemented across the region, EPA is allowing in this final rule between 36 to 48 months, consistent with the regional time frame discussed for SCR retrofit in prior rules, for the full implementation of reductions commensurate with this volume of SCR retrofit capacity, as described further in section VI.A of this document.

The Agency examined the cost for retrofitting a coal unit with new SCR technology, which typically attains controlled NO_x rates of 0.05 lb/mmBtu or less. These updates are further discussed in the EGU NO_x Mitigation Strategies Final Rule TSD.²¹¹ Based on the characteristics of coal units of 100 MW or greater capacity that do not have post-combustion

NO_x control technology, the EPA estimated a weighted-average representative SCR cost of \$11,000 per ton.²¹²

The 0.05 lb/mmBtu emissions rate performance assumption for new SCR retrofits is supported by historical data and third party independent review by pollution control engineering and consulting firms. The EPA first examined unit-level emissions rate data for coal-fired units that had a relatively recent SCR installation (within the last 10 years). The best performing 10 percent of these SCRs were demonstrating seasonal emissions rates of 0.036 lb/mmBtu during this time.

While the EPA identified the 0.05 lb/mmBtu performance assumption consistent with historical data, these performance levels are also informed and consistent with the Agency's IPM modeling assumptions used for more than a decade. These modeling assumptions are based on input from leading engineering and pollution control consulting entities. Most recently, these data assumptions were affirmed and updated in the summer of 2021 and included in the docket for this rulemaking.²¹³ The EPA relies on a

²¹¹ As noted in that TSD, approximately half of the recent SCR retrofits (*i.e.*, installed in the last 10 years) have demonstrated an emission rate across the ozone season below 0.05 lb/mmBtu, even absent a requirement or strong incentive to operate at that level in many cases.

²¹² This cost estimate is representative of coal units lacking any post-combustion control. A subset of units within the universe of coal sources with SCR retrofit potential, but that have an existing SNCR technology in place would have a weighted average cost that falls above this level, but still cost effective. See the EGU NO_x Mitigation Strategies Final Rule TSD for more discussion.

²¹³ See "IPM Model—Updates to Cost and Performance for APC Technologies: SCR Cost Development Methodology for Coal-fired Boilers".

global firm providing engineering, construction management, and consulting services for power and energy with expertise in grid modernization, renewable energy, energy storage, nuclear power, and fossil fuels. Their familiarity with state-of-the-art pollution controls at power plants derives from experience providing comprehensive project services—from consulting, design, and implementation to construction management, commissioning, and operations/maintenance. This review and update supported the 0.05 lb/mmBtu performance assumption as a representative emissions rate for new SCR across coal types.

The EPA performed an assessment for oil/gas steam units in which it evaluated the nationwide performance of those units with SCR technology. For these units, the EPA tabulated EGU NO_x ozone season emissions data from 2009 through 2021 and calculated an average NO_x ozone season emissions rate across the fleet of oil- and gas-fired EGUs with SCR for each of these years. The EPA identified the third lowest year which yielded an SCR performance rate of 0.03 lb/mmBtu as representative of performance for this retrofit technology applied to this type of EGU. Next, the EPA evaluated the emissions and operational characteristics for the existing oil/gas steam fleet lacking SCR technology. EPA's analysis indicated that the majority of reduction potential (approximately 76 percent) from these units occurred at units greater than or equal to 100 MW and that were emitting more than 150 tons per ozone season (*i.e.*, approximately 1 ton per day). Moreover, the cost of reductions for units falling below these criteria increased significantly on a dollar per ton basis. Therefore, the EPA identified the portion of the oil/gas steam fleet meeting these criteria (*i.e.*, greater than or equal to 100 MW and emitting more than 150 tons per ozone season) as representative of the SCR retrofit reduction potential.²¹⁴ For this segment of the oil/gas steam units lacking post-combustion NO_x control technology, the EPA estimated a weighted-average representative SCR cost of \$7,700 per ton.

Comment: Some commenters disagreed with EPA's proposed 36-month timeframe for SCR retrofit. These commenters noted that, while possible at the unit or plant level, the collective volume of SCR installation occurring in

²¹⁴ The EPA used a 3-year average of 2019–2021 reported ozone season emissions to derive a tons per ozone season value representative for each covered oil/gas steam unit.

²⁰⁹ IPM Model-Updates to Cost and Performance for APC Technologies. SCR Cost Development Methodology for Coal-fired Boilers. February 2022.

²¹⁰ *See, e.g.*, CSAPR Close-Out, 83 FR 65878, 65895 (December 21, 2018) and Revised CSAPR Update, 86 FR 23102 (April 30, 2021). *See also* Final Report: Engineering and Economic Factors Affecting the Installation of Control Technologies for Multipollutant Strategies, EPA-600/R-02/073 (Oct. 2002), available at <https://nepis.epa.gov/Adobe/PDF/P1001GOO.pdf>.

a limited region of the country would not be possible given the labor constraints, supply constraints, and simultaneous outages necessary to complete SCR retrofit projects on such a schedule. They noted that achieving such a timeframe against a backdrop of such challenging circumstances is unprecedented and that EPA's assumptions ignore that many of the remaining unretrofitted coal units reflect more site-specific challenges than those that were already retrofitted on a quicker timeframe.

Response: EPA reviewed the comments and is making several changes in this final rule to address some of the concerns identified by the commenters. In particular, EPA found that its own review of historical retrofit patterns as well as technical information submitted by commenters supported commenters' concerns regarding: (1) current and anticipated constraints in labor and supply markets, (2) the potential collective capacity levels of SCR retrofit within 36 months, and (3) possible site-specific complexities at the remaining units without an existing SCR. To address these concerns, EPA is phasing in its SCR installation requirement over a 48-month time frame in this final rule, instead of a 36-month time frame as proposed (see additional detail and discussion in section VI.A.2.a and the EGU NO_x Mitigation Strategies Final Rule TSD). EPA will require half of the reductions associated with SCR installation in 2026 and the other half in 2027. Additionally, EPA is moving the daily backstop rate for these units with identified SCR reduction potential from 2027 to no later than 2030, which defers the increased allowance surrender ratio for emissions above the backstop rate at any outlier units unable to complete the retrofit during that time frame. These adjustments continue to incentivize reductions in NO_x emissions by the attainment date that are consistent with cost-effective SCR controls, but provide more flexibility (both from timing and technology perspective) in how they are procured.

Some commenters requested more than 48 months to install SCR controls based on the collective total volume of SCR retrofit volume identified and past projects that took five or more years. EPA disagrees with these comments and finds that they ignored key aspects of the proposed rule. First, the final rule does not directly require implementation of SCR; rather, it requires reductions commensurate with SCR installations based on a rigorous assessment of SCR retrofit potential. Implementing the reductions through a trading program means that sources in

many cases, as suggested by the *Regulatory Impact Analysis (RIA)*, will find alternative, and more economic means, of reducing emissions—including reduced generation and retirements that are already planned based on the age of the unit, decarbonization goals, or compliance with other Federal/state/local regulation compliance dates. Moreover, the additional new generation incentives provided by the Inflation Reduction Act (enacted after the proposed rule) will further increase the pace of new generation replacing some of the older generating capacity identified as having retrofit potential.²¹⁵ In short, although EPA identified the total SCR retrofit capacity potential for today's existing fleet and does not premise any reduction requirements of incremental retirements, the announced and planned futures for these units indicates that many will likely retire instead of installing SCR. For the capacity identified at Step 3 which lacks SCR, the planned or projected retirement in place of a retrofit moots the SCR timing for these units. Moreover, it also reduces the demand for associated labor and materials which, in turn, frees up resources for any units proceeding with a SCR retrofit. Therefore, comments which cite labor and supply chain challenges for accommodating the entire fleet capacity identified as having SCR retrofit potential significantly overstate the supply-side challenge—as it ignores the fact that much of this capacity has explicit or expected operation plans that will result in compliance without a retrofit.

Even for sources choosing a SCR retrofit compliance pathway, many of these comments ignore the timing flexibilities of the trading program, which (particularly with the changes to the backstop daily emissions rate in this final rule) allow sources to temporarily comply through means other than SCR retrofit if they experience any site-specific retrofit limitations that increase their time frame. Also, historical examples of SCR retrofit projects that exceeded 48 months in duration do not necessarily demonstrate that such projects are impossible in less than 48 months, but rather that they can extend beyond the timeframe if no requirements or incentives are in place for a faster installation. Some also cite site-specific conditions that resulted an

²¹⁵ See "Regulatory Impact Analysis for 2015 Good Neighbor Plan, Appendix 4A: Inflation Reduction Act EGU Sensitivity Run Results." EPA estimated the compliance costs and emissions changes of the final rule in the presence of the IRA, but given time and resource constraints, did not quantify benefits for this sensitivity.

outlier cases of project timing that would not be representative of the conditions expected at future retrofit projects.²¹⁶

Comment: Some stakeholders suggested that EPA's cost estimates of \$11,000 per ton are premised on a 15-year book life of the equipment and are therefore too optimistic for units that plan to retire in well under 15 years.

Response: EPA analysis of SCR retrofit cost reflects a representative value for the technology based on a weighted average cost. The underlying data and the discussion in the EGU NO_x Mitigation Strategies Final TSD illustrates that these costs can vary significantly at the unit level based on factors such as the length of time a pollution control technology would be in operation, the capacity factor of the unit (*i.e.*, how much does it operate), its size or potential to emit, and its baseline emissions rate. The EPA has not in prior transport rulemakings used such factors as justification to excuse any source that is significantly contributing to nonattainment or interfering with maintenance in another state from eliminating that significant contribution as expeditiously as practicable. Unlike under other statutory provisions that may require retrofit of emissions controls on existing sources, such as under CAA section 111(d) or CAA section 169A, there is no remaining useful life factor expressly identified as a justification to relax the requirements of CAA section 110(a)(2)(D)(i)(I). EPA continues to believe that where an emissions control strategy has been identified at Step 3 that is cost-effective on a regional scale and provides meaningful downwind air quality improvement, and is thus appropriately identified as necessary to eliminate significant contribution under the good neighbor provision, it would not be appropriate to allow emissions to continue in excess of those achievable emissions reductions beyond the timeframe for expeditious implementation of reductions as provided under the larger title I structure of the Act for attaining and maintaining the NAAQS. The court in *Wisconsin* recognized that where such emissions have been identified, they should be eliminated as expeditiously as practicable, and in line with the

²¹⁶ Commenters, for example, cited the timing of SCR installation at Sammis 6 and 7. Here, the SCR design and material delivery schedule were tailored to meet unique site conditions that were unlike many other SCR systems where large modules can be used to maximize shop and ground assembly techniques. Additional information is available at <https://www.babcock.com/home/about/resources/success-stories/sammis-plant>.


attainment schedule for downwind areas, which, for the 2015 ozone NAAQS, is provided in CAA section 181. 938 F.3d at 313–20.

Further, EPA observes that more than one-third of the identified SCR retrofit potential (in terms of generating capacity) has no planned retirement date within 15 years, and therefore the cost of pollution control technology on

such units would likely be lower, holding all other parameters equal, on a dollar per ton basis by virtue of the length of time the pollution control equipment may be in operation. Nor does EPA agree that units that would retire in less than 15 years should automatically be considered to face an unreasonably higher cost burden. Based on data analyzed in the EGU NO_x

Mitigation Strategies Final Rule TSD, we find that the cost per ton associated with SCR retrofit technology does not begin to increase significantly above the \$11,000/ton benchmark unless units have dramatically lower operating capacity or retire in less than 5 years' time—as illustrated in Figure 1 to section V.B.1.e of this document.

Figure 1 to section V.B.1.e: SCR Retrofit Cost Weighted Average \$/ton vs Debt Life²¹⁷



Finally, EPA's identification of this mitigation strategy is not meant to be limited only to units that experience a retrofit cost that is less than the representative cost threshold. First, that threshold represents an average, meaning that EPA's analysis already recognizes that some units on a facility-specific basis may face costs higher than that threshold. Further, EPA identifies this technology as widely available, implemented in practice already at many existing EGUs, and now standard for any coal-fired unit coming online in the past 25 years. More than 66 percent of the current large coal fleet already has such controls in place. Even if the cost were higher for some units for the reasons provided by commenters—and

there were no less costly means provided to them to achieve the same level of emissions reduction (which the trading program allows for)—that would not necessarily obviate EPA's basis for finding that an emissions-reduction requirement commensurate with this standard pollution control practice for this unit type is warranted. The implementation of emissions reductions through a trading program, and its corresponding compliance flexibilities, make the use of a single representative cost all the more appropriate in this assessment. Therefore, upon reviewing all of the data including the information supplied by commenters, and even accounting for certain units' announced plans to retire earlier than an assumed 15-year book life for SCR retrofit technology, EPA finds its representative

cost for this technology to be appropriate and reasonable for purposes of analysis under CAA section 110(a)(2)(D)(i)(I) and maintains this cost estimate in the final rule.

However, in recognition of the unique circumstances related to the transition of the power sector away from coal-fired and other high-NO_x emitting fuels and generating technologies, which is anticipated to accelerate in the late 2020s and into the 2030s, EPA has adjusted the final rule to avoid imposing a capital-intensive control technology retrofit obligation which could have overall net-negative environmental consequences (*e.g.*, by extending the life of a higher-emitting EGU or necessitating the allocation of material and personnel that could be used for more advanced clean-technology

²¹⁷ "Debt Life" refers to the term length, or duration, for a loan used to finance the retrofit.

innovations). For units that plan to retire by 2030, the final rule—by extending the daily backstop rate to 2030—allows these units to continue to operate, so long as they comply with the mass-based emissions trading program requirements.²¹⁸ Therefore, a unit experiencing a higher dollar per ton retrofit cost due to retirement plans has the flexibility to install less capital intensive controls such as SNCR, procure less costly allowances through either banking or purchase, or they may also reduce their allowance holding requirement through reduced utilization consistent with their phasing out towards a planned retirement date. This flexibility that EPA has included in the final rule is discussed in further detail in section VI.B of this document.

Comment: Some commenters suggested that the 0.05 lb/mmBtu emissions rate assumed for new SCR units at large coal units is not achievable at all coal units with retrofit potential and that EPA should raise this performance assumption to a value of 0.08 lb/mmBtu consistent with that assumption for existing SCRs.

Response: First, EPA believes the commenter misunderstands its intention with the 0.05 lb/mmBtu SCR rate assumption. This is meant to reflect a representative assumption for emissions rate performance for new SCR installed on the currently unretrofitted coal fleet—in this respect, it represents an average, not a maximum. EPA recognizes that some units will likely perform better (*i.e.*, lower) than this rate and some will potentially perform worse (*i.e.*, higher) than this rate—but that 0.05 lb/mmBtu is a reasonable representation of new SCR retrofit potential on a fleet-wide basis and for identifying expected state and regional emissions reduction potential from this technology. It would be inappropriate for EPA to use the worst performing tier of new SCR retrofit for this representative value. Moreover, EPA's review of historical environmental performance for recently installed SCRs does not support any indication that 0.05 is not representative of the retrofit potential for the fleet. EPA found that three quarters of the SCR retrofit projects completed in the last 15 years have achieved a rate of 0.05 lb/mmBtu or better on a monthly or seasonal basis. Moreover, its review of the engineering literature and consultation with third party pollution control engineering consultancies suggests that vendors are

often willing to guarantee 0.05 lb/mmBtu seasonal performance for new SCR retrofit projects. Current SCR catalyst suppliers provide NO_x emissions warranties based at the catalyst's end-of-life period, often after 16,000 to 24,000 hours of operations, with newer catalyst achieving similar or better NO_x removal rates. Standard commercial terms, made by the purchaser to the SCR Retrofit supplier, can specify a system capable of meeting the proposed NO_x emissions rate and define the catalyst operational life before replacement. Thus, achieving the proposed reduction rates is accomplished through the buyer specifying the SCR retrofit requirements and the supplier providing an optimized system design and installing sufficient catalyst for the targeted end-of-life NO_x emissions rate. The agency is confident that SCR retrofit suppliers will be able to warrant their offerings for the emissions rates proposed in the regulation and to provide sufficient operating life for the affected sector.

Comment: Some commenters suggest that the evaluation of pollution control installation cost at Step 3 should be segmented depending on unit characteristics, and by failing to do so understate the cost of retrofitting SCR controls. In particular, these commenters note that units with lower capacity factors, different coal ranks, with pre-existing controls—such as SNCR—face substantially higher dollar per ton reduced costs than those that do not have such controls in place and should not be identified as a cost-effective mitigation strategy.

Response: Consistent with prior CSAPR rulemakings, at Step 3 EPA evaluates a mitigation technology and its representative cost and performance for the fleet on average. This representative cost is inclusive and robust to the portion of the fleet that may face higher dollar per ton cost. Both the “Technical Support Document (TSD) for the Proposed Federal Implementation Plan Addressing Regional Ozone Transport for the 2015 Ozone National Ambient Air Quality Standard, Docket ID No. EPA–HQ–OAR–2021–0668, EGU NO_x Mitigation Strategies Proposed Rule TSD” (Feb. 2022), hereinafter referred to as the EGU NO_x Mitigation Strategies Proposed Rule TSD, and the EGU NO_x Mitigation Strategies Final TSD discuss the SCR retrofit cost specific to the segment of the fleet that has a SNCR in place and notes that those unit-level higher retrofit cost estimates are factored into its determination of the fleet-wide representative number. Although EPA believes its representative cost are

appropriate and underpinned by operating assumptions reflective of the fleet averages, it nevertheless examined how cost would vary based on some of the variables highlighted by commenter. The EPA derived its capacity factor assumption based on expected future operations of this fleet segment that are inclusive of units operating at a range of capacity factors. It also examined how cost would change assuming different coal rank, assuming different book life, and different reagent cost. These analyses are discussed and shown in Appendix B of the EGU NO_x Mitigation Strategies Final Rule TSD and demonstrate that even under different operating assumptions, the variation in cost does not reach a point that would reverse EPA's finding regarding the appropriateness of this technology as part of this final rule's control stringency. Moreover, as discussed in section V.D of this document, EPA identifies appropriate mitigation strategies based on multiple factors—not solely on cost, and there is no indication that an individual unit's higher retrofit cost would obviate the appropriateness of retrofitting this standard and best practice technology at the unit. Finally, in prior rules and in the proposal, EPA recognized that some units will have higher cost and some will have lower cost relative the fleetwide representative value provided. Implementing the region and state reduction requirements through a mass-based trading program provides a means of alternative lower cost compliance for those sources particularly concerned about the higher retrofit cost at their unit.

Comment: Some commenters suggested that EPA's proposed representative cost for SCR pollution control is likely too high and overstates the true cost of such control. They also noted it aligns with agency precedent. These commenters claim that EPA's cost recovery factor is higher than necessary (thus inflating the cost) as it reflects a weighting of utility-owned to merchant-owned plants that is representative of the fleet, but not the unretrofitted fleet with this retrofit potential identified in this rule. They also noted that EPA's assumed interest rate informing the cost estimate was higher than the prime rate in June of 2022.

Response: EPA agrees that its approach for identifying representative cost thresholds is aligned with prior rules and agrees that its approach is reasonable. As the commenter points out, prime rates and cost recovery factors may indeed be lower in recent data than those assumed by EPA for future years. However, given the

²¹⁸ In the RIA, EPA has modeled the mass-based budgets that are premised on retrofit of SCR technology with the option of complying through other strategies, and finds that they are readily achievable through those other strategies.

volatility among these metrics, EPA believes its choices are appropriate to build cost estimates that are robust to future uncertainty, and if these cost input factors do materialize to be the lower values highlighted by commenter, then it will result in a lower cost assumed in this final rule, but would not otherwise alter any of the stringency identification or regulatory findings put forward in this final rule. EPA performed a cost sensitivity analysis in Appendix B of the EGU NO_x Mitigation Strategies Final Rule TSD which shows how cost for this technology would vary based on different assumed levels for this variable. This analysis shows that under lower interest rates such as those put forward by commenter, that technology cost would drop by approximately 15 percent relative to the representative values put forward in this rule.

f. Generation Shifting

At proposal, EPA considered intrastate emissions reduction potential from generation shifting across the representative dollar per ton levels estimated for the emissions controls considered in previous sections. As the cost of emitting NO_x increases, it becomes increasingly cost-effective for units with lower NO_x rates to increase generation, while units with higher NO_x rates reduce generation. Because the cost of generation is unit-specific, this generation shifting occurs incrementally on a continuum. Consequently, there is more generation shifting at higher cost NO_x-control levels.

The EPA recognizes that imposing a NO_x-control requirement on affected EGUs, like any environmental regulation, internalizes the cost of their pollution, which could result in generation shifting away from those sources toward other generators offering electricity at a lower pollution cost. If, in the context of a market-based allowance trading program form of implementation, the EPA imposes a preset emissions budget that is premised only on assumed installation, optimization, and continued operation of unit-specific pollution control technologies, with no accounting for the likely generation shift in the marketplace away from these higher-polluting sources, that preset emissions budget will contain more tons than would be emitted if the affected EGUs achieved the emissions performance level (on a rate basis) selected at step 3. Hence, EPA has previously quantified and required expected emissions reductions from generation shifting in prior transport rules to avoid undermining the program's incentive to

install, optimize, and operate controls identified in the Agency's determinations regarding the requisite level of emissions control at Step 3. *See, e.g.,* 81 FR 74544–45; 76 FR 48280.

As in these prior rules, at proposal, the EPA did not identify generation shifting as a primary mitigation strategy and stringency measure on its own, but included emissions reductions from this strategy as it would be projected to occur in response to the selected emissions control stringency levels (and corresponding allowance price signals in step 4 implementation). For this rule's proposal, the EPA only specified emissions reductions from generation shifting in its preset budget calculations for 2023 and 2024. Because this rule's dynamic budget methodology applies the selected control stringency's emissions rates to the most recently reported heat input at each affected EGU, dynamic budgeting effectively serves a similar purpose to our ex ante quantification of emissions reduction potential from generation shifting for preset budgets in prior transport rules, *i.e.*, to adequately and continuously incentivize the implementation of the emissions control strategies selected at Step 3. Therefore, dynamic budgets under this rule's program moot the need to specify discrete emissions reduction potential from generation shifting for those control periods, as they automatically reflect whatever generation balance affected EGUs would determine in the marketplace inclusive of their response to the emissions performance levels imposed by this rule.

Comment: Commenters offered both support for and opposition against the inclusion of generation shifting at Step 3 analysis for EGUs. Those in support noted that inclusion of emissions reductions from generation-shifting is integral to the successful implementation of the pollution control measures identified in the selected control stringency at Step 3. Those opposed generally argued the EPA was overestimating reduction potential from generation shifting in light of recent volatility and high prices in the markets for lower emitting fuels such as natural gas. Commenters also noted the electrical grid in certain regions has constraints that would make generation shifting more difficult than the EPA assumed. Commenters also asserted that the EPA did not have the legal authority to require generation shifting.

Response: The EPA disagrees with these comments regarding our legal authority but notes this issue is not relevant for purposes of this final action. The EPA continues to believe it has

authority under CAA section 110(a)(2)(D)(i)(I) to consider and require emissions reductions from generation shifting if the EPA were to find that strategy was necessary to eliminate significant contribution. However, based on circumstances currently facing affected EGUs, as well as the inherent strength of the dynamic budget methodology to automatically reflect the market-determined balance of generation across sources responding to this rule, the EPA is not specifying emissions reduction potential from generation shifting as a part of the Step 3 analysis, nor to require any emissions reductions from generation shifting in preset budgets formulated under Step 4 for any control period, for this final rule.

Currently observable market conditions (*e.g.*, fuel prices) present unusual uncertainty with respect to key economic drivers of generation shifting. The availability of emissions reductions through generation shifting, and the magnitude of those emissions, is dependent on the availability and cost of substitute generation. The primary driver of near-term generation shifting-based emissions reductions has been shifting to lower-emitting natural gas generation. Recent volatility and high prices in the natural gas market have increased the uncertainty and reduced the potential of this emissions control strategy at any given cost threshold in the near term. For example, Henry Hub natural gas prices went from under \$3.00/mmBtu during most of the last decade to an average of nearly \$8.00/mmBtu for the most recent (2022) ozone season before declining sharply at the start of 2023. The current volatility in natural gas prices reduces the availability of emissions reductions from generation shifting and make its identification and quantification too uncertain for incorporation into Step 3 emissions reduction estimates for this rulemaking.

The Step 4 dynamic budget-setting process of this rule obviates the need to specify and require discrete emissions reductions from generation shifting under Step 3. As discussed in section VI of this document, the EPA in this final rule will implement a budget-setting approach that relies on two components: first, we have calculated "preset" budgets that reflect the best information currently available about fleet change over the period 2023 through 2029. Second, beginning in 2026, dynamic state emissions budgets will be calculated that will reflect the balance of generation across sources reported to EPA by EGU operators. Between 2026 and 2029, the actual budget that will be implemented will

reflect the greater of either the preset budget or the dynamic budget calculation; from 2030 onwards, the budgets will be set only through the dynamic budget calculation. This overall approach is well suited for a period of significant power sector transition driven by a variety of economic, policy, and regulatory forces and allows for the balance of generation in this period to adjust in response to these forces while nonetheless ensuring that the budgets will continuously incentivize the emissions control stringency identified at Step 3. See section VI.B.4 of this document for further discussion on the interaction of preset and dynamic budgets during the 2026–2029 time period. With these approaches, and on the present record before the Agency, we conclude that the estimation and incorporation of specified emissions reductions from generation shifting at Step 3 is not necessary to eliminate significant contribution from EGUs for the 2015 ozone NAAQS through this rule's program implementation.

In previous CSAPR rulemakings, the EPA included generation shifting in the budget setting process to capture those reductions that would occur through shifting generation as an economic response to the control stringency determined based on the selected NO_x control strategies. See, e.g., 81 FR 74544–45. “Because we have identified discrete cost thresholds resulting from the full implementation of particular types of emissions controls, it is reasonable to simultaneously quantify the reduction potential from generation shifting strategy at each cost level. Including these reductions is important, ensuring that other cost-effective reductions (e.g., fully operating controls) can be expected to occur.” EGU NO_x Mitigation Strategies Final Rule TSD (EPA–HQ–OAR–2015–0500–0554), at 11–12.

Commenters on this rule and prior transport rules have observed that using preset budgets to factor in generation shifting is flawed in that it results in EPA incorporating specific quantities of emissions reductions from discrete levels of generation shifting that are projected to occur but may in fact ultimately transpire differently in the marketplace. Commenters on this rule claim that other variables, such as constraints in transmission capacity or changes in fuel prices, can drive such differences in projected versus realized generation shifting, and these concerns are particularly exacerbated in a time of significant uncertainty around energy supplies and markets together with new laws passed by Congress (e.g., the

Infrastructure Investment and Jobs Act and the Inflation Reduction Act) driving the current transformation of the power sector. By refraining in this rule from specifying discrete emissions reductions from generation shifting in preset budgets and instead relying on a dynamic budgeting approach to reflect market-driven generation patterns, EPA ensures that its budgets remain sufficiently stringent over the long term to continually incentivize the emissions control stringency it determined to be cost-effective and therefore appropriate to eliminate significant contribution at Step 3. Thus, dynamic budgeting addresses the same concern that animated our use of generation shifting in the CSAPR rulemakings, but in doing so uses a market-following approach that will accommodate, over the long term, unforeseen drops or increases in heat input levels.

g. Other EGU Mitigation Measures

The EPA requested comment on whether other EGU ozone-season NO_x Mitigation technologies should be required to eliminate significant contribution. For instance, the EGU NO_x Mitigation Strategies Proposed and Final Rule TSDs discussed certain mitigation technologies that have been applied to “peaking” units (small, low-capacity factor gas combustion turbines often only operating during periods of peak demand).

Comment: Some commenters emphasized that simple cycle combustion turbines play a significant role in downwind contribution, and they highlight that states such as New York have imposed emissions limits on these sources acknowledging their impact on downwind nonattainment. These commenters suggest that EPA pursue and expedite the implementation of these or similar mitigation measures.

Response: As explained in greater detail in the EGU NO_x Mitigation Strategies Final TSD, both the configuration and operation of this segment of the EGU fleet reflects significant variability among units and across time. In other words, one unit may have a capacity factor in a given year that is one hundred times greater than a similar unit in that same year, or even than its own capacity factor from a preceding year. This type of variability and heterogeneity make it unlikely that there is a single cost-effective control strategy across this fleet segment, and commenters did not provide evidence to the contrary. EPA's analysis discussed in the EGU NO_x Mitigation Strategies Final Rule TSD highlights that there are 32 units emitting more than 10 tons per

year on average for the 2019–2021 ozone seasons and lacking combustion controls or more advanced controls (totaling approximately 1,000 tons of ozone season NO_x emissions in 2021). EPA analysis estimates a representative cost of \$22,000 per ton for dry low NO_x burners or ultra-low NO_x burners at these simple cycle combustion turbines, and over \$100,000 per ton for SCR retrofit at some combustion turbines. Therefore, EPA does not identify any such uniform mitigation measure at Step 3 when estimating reduction potential.

Nonetheless, the EPA recognizes that these simple cycle combustion turbines may have cost-effective emissions-reduction opportunities. These units are included in the emissions trading program and therefore, as in prior transport rules, the program continues to subject them to an allowance holding requirement under this rule which will likely incentivize any available cost-effective NO_x reductions from these EGUs. For instance, emissions rates from these units in New York were considerably lower in 2022, when they faced a high allowance price, versus 2021, when the allowance price was much lower. Therefore, we find that the appropriate treatment of these units in this final rule is to continue to include them in the emissions trading program to incentivize cost-effective emissions reductions, but EPA does not find the magnitude or consistency of cost-effective mitigation potential to establish a specific increment of emissions reduction through a specific Step 3 emissions control determination. Moreover, while EPA's program will incentivize any available cost-effective reductions within this cadre of units (and such behavior is captured in its final program evaluation and modeling the RIA), it does not obviate the need for the other EGU cost-effective reductions elsewhere as suggested by some commenters.

2. Non-EGU or Stationary Industrial Source NO_x Mitigation Strategies

In the early stages of preparing the proposed FIP, the EPA evaluated air quality modeling information, annual emissions, and information about potential controls to determine which industries, beyond the power sector, could have the greatest impact on downwind receptors' air quality and therefore the greatest impact in providing ozone air quality improvements in affected downwind states through reducing those emissions. Specifically, the EPA conducted a screening assessment focused on individual emissions units with >100

typy of actual NO_x emissions in 23 upwind states. Once the industries were identified, the EPA used its Control Strategy Tool to identify potential emissions units and control measures and to estimate emissions reductions and compliance costs associated with application of non-EGU emissions control measures. The technical memorandum “Screening Assessment of Potential Emissions Reductions, Air Quality Impacts, and Costs from Non-EGU Emissions Units for 2026” (“Non-EGU Screening Assessment” or “screening assessment”) lays out the analytical framework and data used to prepare proxy estimates for 2026 of potentially affected non-EGU facilities and emissions units, emissions reductions, and costs.²¹⁹

This screening assessment was not intended to identify the specific emissions units subject to the proposed emissions limits for non-EGU sources but was intended to inform the development of the proposed rule by identifying proxies for (1) non-EGU emissions units that potentially had the most impact in terms of the magnitude of emissions and potential for emissions reductions, (2) potential controls for and emissions reductions from these emissions units, and (3) control costs from the potential controls on these emissions units. This information helped shape the proposed rule.

To further evaluate the industries and emissions unit types identified by the screening assessment and to establish the applicability criteria and proposed emissions limits, the EPA reviewed RACT rules, NSPS rules, NESHAP rules, existing technical studies, rules in approved SIP submittals, consent decrees, and permit limits. That evaluation is detailed in the Proposed Non-EGU Sectors TSD prepared for the proposed FIP.²²⁰

In this final rule, for purposes of this part of the Step 3 analysis, the EPA is retaining emissions control requirements for these industries and many of the emissions unit types included in the proposal. However, based on comments that credibly indicated in certain cases that emissions reduction opportunities are either not available for certain unit types or are at costs that are far greater than the EPA estimated at proposal, the EPA has changed the final rule to either remove or adjust the applicability criteria for such units. For a detailed discussion of

²¹⁹ The memorandum is available in the docket here: <https://www.regulations.gov/document/EPA-HQ-OAR-2021-0668-0150>.

²²⁰ The TSD for the proposed FIP is available in the docket here: <https://www.regulations.gov/document/EPA-HQ-OAR-2021-0668-0145>.

the changes between the proposed FIP and this final rule, in emissions unit types included and in emissions limits, see section VI.C of this document. Tables I.B–2 through I.B–7 in section I.B of this document identify the emissions units and applicable emissions limitations, and Table II.A–1 in section II.A of this document identifies the industries included in the final rule.

For the final rule, to determine NO_x emissions reduction potential for the non-EGU industries and emissions unit types, with the exception of Solid Waste Combustors and Incinerators, we used a 2019 inventory prepared from the emissions inventory system (EIS) to estimate a list of emissions units captured by the applicability criteria for the final rule. For Solid Waste Combustors and Incinerators, the EPA estimated the list of covered units using the 2019 inventory, as well as the NEEDS-v6-summer-2021-reference-case workbook.²²¹ Based on the review of RACT, NSPS, NESHAP rules, as well as SIPs, consent decrees, and permits, we also assumed certain control technologies could meet the final emissions limits.²²² We did not run the Control Strategy Tool to estimate emissions reductions and costs and instead programmed the assessment using R.²²³ Using the list of emissions units estimated to be captured by the final rule applicability criteria, the assumed control technologies that would meet the emissions limits, and information on control efficiencies and default cost/ton values from the control measures database (CMDB),²²⁴ the EPA estimated NO_x emissions reductions and costs for the year 2026. We estimated emissions reductions using the actual emissions from the 2019 emissions inventory. In the assessment, we matched emissions units by Source Classification Code (SCC) from the inventory to the applicable control technologies in the CMDB. We modified SCC codes as necessary to match control technologies to inventory records.

The EPA recognized both at proposal and in the final rule that the cost per ton of emissions controls could vary by industry and by facility. The \$7,500

²²¹ The workbook is available here: <https://www.epa.gov/power-sector-modeling/national-electric-energy-data-system-needs-v6>.

²²² The Final Non-EGU Sectors TSD is available in the docket.

²²³ R is a free software environment for statistical computing and graphics. Additional information is available here: <https://www.r-project.org/>.

²²⁴ More information about the Control Strategy Tool (CoST) and the control measures database (CMDB) can be found at the following link: <https://www.epa.gov/economic-and-cost-analysis-air-pollution-regulations/cost-analysis-modeltools-air-pollution>.

marginal cost/ton threshold reflected in the Non-EGU Screening Assessment functioned as a relative, representative cost/ton level. Similar to the role of cost-effectiveness thresholds the EPA uses at Step 3 to evaluate EGU emissions control opportunities, this threshold is not intended to represent the maximum cost any facility may need to expend but is rather intended to be a representative figure for evaluating technologies to allow for a relative comparison between different levels of control stringency. The value was used to identify potentially cost-effective controls for further evaluation.

In the final rule, partly in recognition of the many comments indicating widely varying cost-per-ton values across industries and facilities, the EPA has updated its analysis of costs for the covered non-EGU industries. This data is summarized in the Technical Memorandum “Summary of Final Rule Applicability Criteria and Emissions Limits for Non-EGU Emissions Units, Assumed Control Technologies for Meeting the Final Emissions Limits, and Estimated Emissions Units, Emissions Reductions, and Costs,” available in the docket. We further respond to comments on the screening assessment in section 2.2 of the response to comments document.

3. Other Stationary Sources NO_x Mitigation Strategies

As part of its analysis for this final rule, the EPA also reviewed whether NO_x mitigation strategies for any other stationary sources may be appropriate. In this section, the EPA discusses three classes of units that have historically been excluded from our interstate air transport programs: (1) solid waste incineration units, (2) electric generating units less than or equal to 25 MW, and (3) cogeneration units. EPA’s initial assessment did not lead it to propose inclusion of the units in these categories. However, EPA requested comment on whether any particular units within this category may offer cost-effective reduction potential.

Based on our request for comment, comments received, and our further evaluation, the EPA is including emissions limits and associated control requirements for the ozone season for solid waste incinerator units in this final rule, in line with the requirements we laid out for comment at proposal. Our analysis in this final rule confirms that these units have emissions reductions of a magnitude, degree of beneficial impact, and cost-effectiveness that is on par with the units in other industrial sectors included in this final rule.

For electric generating units less than 25 MW and cogeneration units previously exempted from EGU emissions budgets established through ozone interstate transport rules, the EPA has determined that these units should not be treated as EGUs in this final rule.

The EPA provides a summary of these three segments, their emissions control opportunities, and potential air quality benefits in the following sections. Additional considerations are further discussed in the EGU NO_x Mitigation Strategies Final TSD and in the *RTC* Document.

a. Municipal Solid Waste Units

At proposal, the EPA solicited comments on whether NO_x emissions reductions should be sought from municipal waste combustors (MWCs) to address interstate ozone transport, specifically on potential emissions limits, control technologies, and control costs. The EPA requested comment on emissions limits of 105 ppmvd on a 30-day rolling average and a 110 ppmvd on a 24-hour block average based on determinations made in the June 2021 Ozone Transport Commission (OTC) *Municipal Waste Combustor Workgroup Report* (OTC MWC Report). See 87 FR 20085–20086. The OTC MWC Report found that MWCs in the Ozone Transport Region (OTR) are a significant source of NO_x emissions and that significant annual NO_x reductions could be achieved from MWCs in the OTR using several different technologies, or combination of technologies at a reasonable cost. The OTC MWC report is included in the docket for this action.

Comment: The EPA received multiple comments supporting the inclusion of emissions limits for MWCs in the final rule. Commenters noted that MWCs are significant sources of NO_x that contribute to ozone problems in the states covered by the proposal. Multiple commenters referenced the OTC MWC report to contend that NO_x emissions from MWCs could be significantly reduced at a reasonable cost. Some commenters reasoned that sources closer to downwind monitors, including MWCs, should be regulated as a more targeted approach and a means to prevent overcontrol of upwind sources. Commenters also noted that the OTC recently signed a memorandum of understanding (MOU) requesting that OTC member states develop cost effective solutions and select the strategy or combination of strategies, as necessary and appropriate, that provides both the maximum certainty and flexibility for that state and its MWCs. Additionally, multiple commenters

noted that MWCs are often located in economically marginalized communities or communities of color. Lastly, one commenter stated that MWCs were arbitrarily excluded from the non-EGU screening assessment prepared for the proposal.

Response: As described in section VI.B.2 of the notice of proposed rulemaking, the EPA assessed emissions reduction potential from non-EGUs by preparing a screening assessment to identify those industries that could have the greatest air quality impact at downwind receptors. While the EPA did not prepare an updated non-EGU screening assessment in preparation for this final rule, the Agency did evaluate MWCs using the criteria developed in the screening assessment for proposal and determined that MWCs should be included in this rulemaking. A discussion of this analysis for MWCs is available in the *Municipal Waste Combustor Supplement to February 28, 2022 Screening Assessment of Potential Emissions Reductions, Air Quality Impacts, and Costs from Non-EGU Emissions Units for 2026*, which is available in the docket for this rule.

Considering EPA's conclusion that MWCs should be included in this final rule if EPA applied the same criteria developed in the screening assessment for proposal, the findings from the OTC MWC report and recent MOU, the fact that many state RACT NO_x rules apply to MWCs, and information received during public comment, the EPA finds that MWCs should be included in this final rule. Thus, the EPA is finalizing NO_x emissions limits and compliance assurance requirements for large MWCs as defined in the regulatory text at § 52.46 and as described in this section.

Comment: Some commenters did not support the inclusion of emissions limits for MWCs in the final rule. Some commenters suggested that the inclusion of NO_x limits in a FIP is not necessary to continue to reduce NO_x emissions from MWCs or to address interstate transport problems. Some commenters noted that many of the MWCs in the states covered by the proposal are already subject to RACT-based NO_x emissions limits that are below the current Federal NSPS NO_x emissions limits for MWCs under 40 CFR part 60, subparts Cb and Eb. One commenter noted that MWCs do not always account for a large percentage of statewide NO_x emissions. Others suggested that voluntary industry actions are also driving downward trends of NO_x emissions for some MWCs. Some commenters also asserted that regulation could interfere with state

waste reduction policies and associated environmental considerations.

Response: Regarding the comments that some MWCs are already subject to RACT NO_x emissions limits, the EPA acknowledges that some states included in this rulemaking have promulgated RACT NO_x emissions limits that apply to certain MWCs, including some that are lower than current MWC NSPS NO_x emissions limits. The EPA does not consider a source to be exempt from this rulemaking just because the source may be subject to other regulatory requirements. As noted, the Agency did evaluate MWCs using the criteria developed in the screening assessment for proposal and has concluded that MWCs should be included in this rulemaking. In considering the emissions limits that are being finalized in this rulemaking, the EPA reviewed existing state RACT rules as described in section VI.C.6 of this document and the "Technical Support Document (TSD) for the Final Rule, Docket ID No. EPA-HQ-OAR-2021-0668, Non-EGU Sectors TSD" (Mar. 2023), hereinafter referred to as Final Non-EGU Sectors TSD. We note that sources already subject to RACT NO_x emissions limits that are equal to or more stringent than the limits finalized in this rulemaking will have the option to streamline regulatory requirements through the Title V permitting process.

Regarding the statement that regulation could interfere with state waste reduction policies and associated environmental considerations, the EPA acknowledges that MWCs serve an important role in municipal solid waste management programs, and that many function as cogeneration facilities that produce electrical power for the power grid. The EPA also analyzed control costs and determined that the required NO_x emissions limits for MWCs can be achieved at a reasonable cost, as described in section VI.C.6 of this document, the Final Non-EGU Sectors TSD, and the OTC MWC Report. Although the EPA does not expect these regulations to disrupt the ability of the industry to provide municipal solid waste and electric services, to the extent a facility is unable to comply with the standards due to technical impossibility or extreme economic hardship, the final rule includes provisions for facility operators to apply for a case-by-case alternative emissions limit. See section VI.C of this document and 40 CFR 52.40(d). In addition, for MWC facilities that are unable to comply with the standard by the 2026 ozone season, the final rule includes provisions for requesting limited extensions of time to

comply. See section VI.C and 40 CFR 52.40(c).

b. Electric Generating Units Less Than or Equal to 25 MW

The EPA has historically not included control requirements for emissions for electric generating units less than or equal to 25 MW of generation for three primary reasons: low potential reductions, relatively high cost per ton of reduction, and high monitoring and other compliance burdens. In the January 11, 1993, Acid Rain permitting rule, the EPA provided for a conditional exemption from the emissions reduction, emitting, and emissions monitoring requirements of the Acid Rain Program for new units having a nameplate capacity of 25 MWe or less that burn fuels with a sulfur content no greater than 0.05 percent by weight, because of the *de minimis* nature of their potential SO₂, CO₂ and NO_x emissions. See 63 FR 57484. The NO_x SIP Call identified these as *Small Point Sources*. For the purposes of that rulemaking, the EPA considered electricity generating boilers and turbines serving a generator 25 MWe or less, to be small point sources. The EPA noted that the collective emissions from small sources were relatively small and the administrative burden to the states and regulated entities of controlling such sources was likely to be considerable. As a result, the rule did not assume reductions from those sources in state emissions budgets requirements (63 FR 57402). Similar size thresholds have been incorporated in subsequent transport programs such as CAIR and CSAPR. As these sources were not identified as having cost-effective reductions and so were not included in those programs, they were also exempted from certain reporting requirements and the data for these sources is, therefore, not of the same caliber as that of covered larger sources.

EPA's preliminary survey of current data, compared to this initial justification, does not appear to offer a compelling reason to depart from this past practice by requiring emissions reductions from these small EGU sources as part of this rule. For instance, as explained in the EGU NO_x Mitigation Strategies Final Rule TSD, EPA has evaluated the costs of SCR retrofits at small EGUs using its Retrofit Cost Analyzer and found that such controls become markedly less cost-effective at lower levels of generating capacity. This analysis concluded that, after controlling for all other unit characteristics, the dollar per ton cost for a SCR retrofit increases by about a factor of 2.5 when moving from a 500

MW to a 10 MW unit, and a factor of 8 when moving to a 1 MW unit.²²⁵ Moreover, the EPA estimates that under 6 percent of nationwide EGU emissions come from units that are less than 25 MW and not covered by current applicability criteria due to this size exemption threshold. Therefore, the EPA is not finalizing any emissions reductions for these units.

Comment: EPA received comment supporting the continued application of the 25 MW threshold.

Response: Consistent with prior rules, the proposal, and stakeholder comment, EPA is continuing to apply its 25 MW applicability threshold for EGUs in this rulemaking. EPA did not find compelling comment to reverse its determination that (1) these sources offer low potential reductions, (2) have relatively high cost per ton, and (3) have high monitoring and other compliance burdens.

c. Cogeneration Units

Consistent with prior transport rules, fossil fuel-fired boilers and combustion turbines that produce both electricity and useful thermal energy (generally referred to as "cogeneration units") and that meet the applicability criteria to be included in the CSAPR NO_x Ozone Season Group 3 Trading Program would be subject to the emissions reduction requirements established in this rulemaking for EGUs. However, those applicability criteria—which the EPA is not altering in this rulemaking (see section VI.B.3 of this document)—exempt some cogeneration units from coverage as EGUs under the trading program. The EPA is finalizing that fossil fuel-fired boilers and combustion turbines that produce both electricity and useful thermal energy and that do not meet the applicability criteria to be included in the CSAPR NO_x Ozone Season Group 3 Trading Program as EGUs would not be subject to the Group 3 emissions trading program. However, to the extent a cogeneration unit meets the applicability criteria for industrial non-EGU boilers covered by this rule, that unit will be subject to the relevant requirements and is not exempted by virtue of being a cogeneration unit.

According to information contained in the EPA's Combined Heat and Power Partnership's document "Catalog of CHP Technologies",²²⁶ there are 4,226 CHP installations in the U.S. providing

²²⁵ Preliminary estimate based on representative coal units with starting NO_x rate of 0.2 lb/mmBtu, 10,000 BTU/kwh, and assuming 80 percent reduction.

²²⁶ This document is available at: https://www.epa.gov/sites/default/files/2015-07/documents/catalog_of_chp_technologies.pdf.

83,317 MWe of electrical capacity. Over 99 percent of the installations are powered by 5 equipment types, those being reciprocating engines (52 percent), boilers/steam turbines (17 percent), gas turbines (16 percent), microturbines (8 percent), and fuel cells (4 percent). The majority of the electrical capacity is provided by gas turbine CHP systems (64 percent) and boiler/steam turbine CHP systems (32 percent). The various CHP technologies described herewith are available in a large range of sizes, from as small as 1 kilowatt reciprocating engine systems to as large as 300 megawatt gas turbine powered systems.

NO_x emissions from rich burn reciprocating engine, gas turbine, and microturbine systems are low, ranging from 0.013 to 0.05 lb/mmBtu. NO_x emissions from lean burn reciprocating engine systems and gas-powered steam turbines systems range from 0.1 to 0.2 lb/mmBtu. The highest NO_x emitting CHP units are solid fuel-fired boiler/steam turbine systems which emit NO_x at rates ranging from 0.2 to 1.2 lb/mmBtu.

Under the final rule (consistent with prior CSAPR rulemakings), certain cogeneration units would be exempt from coverage under the CSAPR NO_x Ozone Season Group 3 Trading Program as EGUs. Specifically, the trading program regulations include an exemption for a unit that qualifies as a cogeneration unit throughout the later of 2005 or the first 12 months during which the unit first produces electricity and continues to qualify through each calendar year ending after the later of 2005 or that 12-month period and that meets the limitation on electricity sales to the grid. To meet the trading program's definition of "cogeneration unit" under the regulations, a unit (*i.e.*, a fossil-fuel-fired boiler or combustion turbine) must be a topping-cycle or bottoming-cycle type that operates as part of a "cogeneration system." A cogeneration system is defined as an integrated group of equipment at a source (including a boiler, or combustion turbine, and a generator) designed to produce useful thermal energy for industrial, commercial, heating, or cooling purposes and electricity through the sequential use of energy. A topping-cycle unit is a unit where the sequential use of energy results in production of useful power first and then, through use of reject heat from such production, in production of useful thermal energy. A bottoming-cycle unit is a unit where the sequential use of energy results in production of useful thermal energy first, and then, through use of reject heat from such production, in production of useful

power. To qualify as a cogeneration unit, a unit also must meet certain efficiency and operating standards in 2005 and each year thereafter. The electricity sales limitation under the exemption is applied in the same way whether a unit serves only one generator or serves more than one generator. In both cases, the total amount of electricity produced annually by a unit and sold to the grid cannot exceed the greater of one-third of the unit's potential electric output capacity or 219,000 MWh. This is consistent with the approach taken in the Acid Rain Program (40 CFR 72.7(b)(4)), where the cogeneration-unit exemption originated.

The EPA requested comment on requiring fossil fuel-fired boilers in the non-EGU industries identified in section VI.C of this document that serve electricity generators and that qualify for an exemption from inclusion in the CSAPR NO_x Ozone Season Group 3 Trading Program as EGUs to instead meet the same emissions standards, if any, that would apply under this rulemaking to fossil fuel-fired boilers at facilities in the same non-EGU industries that do not serve electricity generators.

Comment: Some stakeholders support the continued exclusion of qualifying cogenerators from the EGU program, but suggested they be regulated as non-EGUs if they don't fit the EGU applicability criteria.

Response: The EPA agrees that there is no basis within the four-step framework to exempt cogeneration units that fall under the applicability criteria of the final rule for non-EGU boilers simply because they are cogeneration units. While cogeneration units do have environmental benefits as noted at proposal, some cogeneration unit-types, particularly boilers, are estimated to have NO_x emissions that would otherwise meet this rule's criteria at Step 3 for constituting "significant contribution." These units can meet the emissions limits that are otherwise finalized for these unit types, and the EPA does not find a basis to exclude them simply because they may have other environmentally-beneficial attributes.

These emissions limits are set forth in section VI.C.5 of this document. Therefore, the final requirements for non-EGUs do not exempt cogeneration units and any cogeneration emissions units meeting the applicability criteria for non-EGUs will be subject to the final emissions limits for the appropriate non-EGU emissions unit. Based on EPA's review of available data, across all of the non-EGU industries covered by this rule, there are four cogeneration

boilers (two in Pulp and Papermill and two in Basic Chemical Manufacturing) that would meet the final rule's applicability criteria for non-EGU units and are included in the analysis of non-EGU emissions reduction potential in section V.C.2 of this document.

4. Mobile Source NO_x Mitigation Strategies

Under a variety of CAA programs, the EPA has established Federal emissions and fuel quality standards that reduce emissions from cars, trucks, buses, nonroad engines and equipment, locomotives, marine vessels, and aircraft (*i.e.*, "mobile sources"). Because states are generally preempted from regulating new vehicles and engines with certain exceptions (*see generally* CAA section 209), mobile source emissions are primarily controlled through EPA's Federal programs. The EPA has been regulating mobile source emissions since it was established as a Federal agency in 1970, and all mobile source sectors are currently subject to NO_x emissions standards. The EPA factors these standards and associated emissions reductions into its baseline air quality assessment in good neighbor rulemaking, including in this final rule. These data are factored into EPA's analysis at Steps 1 and 2 of the 4-step framework. As a result of this long history, NO_x emissions from onroad and nonroad mobile sources have substantially decreased (73 percent and 57 percent since 2002, for onroad and nonroad, respectively)²²⁷ and are predicted to continue to decrease into the future as newer vehicles and engines that are subject to the most recent, stringent standards replace older vehicles and engines.²²⁸

For example, in 2014, the EPA promulgated new, more stringent emissions and fuel standards for light-duty passenger cars and trucks.²²⁹ The fuel standards took effect in 2017, and the vehicle standards phase in between 2017 and 2025. Other EPA actions that are continuing to reduce NO_x emissions include the Heavy-Duty Engine and Vehicle Standards and Highway Diesel Fuel Sulfur Control Requirements (66 FR 5002; January 18, 2001); the Clean Air Nonroad Diesel Rule (69 FR 38957; June 29, 2004); the Locomotive and

Marine Rule (73 FR 25098; May 6, 2008); the Marine Spark-Ignition and Small Spark-Ignition Engine Rule (73 FR 59034; October 8, 2008); the New Marine Compression-Ignition Engines at or Above 30 Liters per Cylinder Rule (75 FR 22895; April 30, 2010); and the Aircraft and Aircraft Engine Emissions Standards (77 FR 36342; June 18, 2012).

Most recently, EPA finalized more stringent emissions standards for NO_x and other pollution from heavy-duty trucks (Control of Air Pollution from New Motor Vehicles: Heavy-Duty Engine and Vehicle Standards, 88 FR 4296, January 24, 2023). These standards will take effect beginning with model year 2027. Heavy-duty vehicles are the largest contributor to mobile source emissions of NO_x and will be one of the largest mobile source contributors to ozone in 2025.²³⁰ Reducing heavy-duty vehicle emissions nationally will improve air quality where the trucks are operating as well as downwind. The EPA's existing regulatory program for mobile sources will continue to reduce NO_x emissions into the future.

Comment: The EPA received comments on ozone-precursor emissions from mobile sources, including cars, trucks, trains, ships, and planes. Commenters broadly encouraged the EPA to require emissions reductions from mobile sources in this rule. Commenters stated that the transportation sector plays a significant role in NO_x pollution and ozone formation and urged the EPA to finalize emissions reductions for the transportation sector that will enable attainment of the 2015 ozone NAAQS. Some commenters noted that high proportions of NO_x emissions in various upwind states are attributable to the transportation sector, and stated that EPA should have targeted emissions reductions from mobile sources first before requiring more stringent emissions controls from stationary sources in the same upwind states.

Response: The EPA agrees with commenters that a variety of sources, including mobile sources in the transportation sector, produce NO_x emissions that contribute to ozone air quality problems across the U.S. This rule, as with prior interstate transport actions, does not ignore those emissions, and it credits those on-the-books measures of states and the Federal Government within the four-step framework by including emissions and

²²⁷ US EPA. Our Nation's Air: Status and Trends Through 2019. <https://gispub.epa.gov/air/trendsreport/2020/#home>.

²²⁸ National Emissions Inventory Collaborative (2019). 2016v1 Emissions Modeling Platform. Retrieved from <http://views.cira.colostate.edu/wiki/10202>.

²²⁹ Control of Air Pollution from Motor Vehicles: Tier 3 Motor Vehicle Emissions and Fuel Standards, 79 FR 23414 (April 28, 2014).

²³⁰ Zawacki et al, 2018. Mobile source contributions to ambient ozone and particulate matter in 2025. *Atmospheric Environment*. Vol 188, pg 129–141. Available online: <https://doi.org/10.1016/j.atmosenv.2018.04.057>.

emissions reductions from these sources in the emissions inventory for air quality modeling, which informs Steps 1 and 2 of this analysis. Thus, this rule accurately represents emissions from mobile sources that are used to evaluate the contribution of states to ozone air quality problems in other states. See section IV.C of this document.

The EPA notes that its Step 3 analysis for this FIP does not assess additional emissions reductions opportunities from mobile sources. The EPA continues to believe that title II of the CAA provides the primary authority and process for reducing these emissions at the Federal level. EPA’s various Federal mobile source programs, summarized above in this section, have delivered and are projected to continue to deliver substantial nationwide reductions in both VOCs and NO_x emissions; these reductions from final rules are factored into the Agency’s assessment of air quality and contributions at Steps 1 and 2. Further, states are generally preempted from regulating new vehicles and engines with certain exceptions, and therefore a question exists regarding the EPA’s authority to address such emissions through such means when regulating in place of the states under CAA section 110(c). See generally CAA section 209. See also 86 FR 23099.²³¹ In

any case, the existence of mobile source emissions noted by commenters does not lead to the conclusion that the EPA must require mobile source reductions in this rule or that the EPA has not properly identified “source[s] or other type[s] of emissions activity” in upwind states that “significantly contribute” for purposes of the Good Neighbor Provision. The EPA is committed to continuing the effective implementation and enforcement of current mobile source standards and continuing its efforts on new standards. The EPA will continue to work with state and local air agencies to incorporate emissions reductions from the transportation sector into required ozone attainment planning elements.

C. Control Stringencies Represented by Cost Threshold (\$ per ton) and Corresponding Emissions Reductions

1. EGU Emissions Reduction Potential by Cost Threshold

For EGUs, as discussed in section V.A of this document, the multi-factor test considers increasing levels of uniform control stringency in combination with considering total NO_x reduction potential and corresponding air quality improvements. The EPA evaluated EGU NO_x emissions controls that are widely available (described previously in

section V.B.1 of this document), that were assessed in previous rules to address ozone transport, and that have been incorporated into state planning requirements to address ozone nonattainment.

The EPA evaluated the EGU sources within the State of California and found there were no covered coal steam sources greater than 100 MW that would have emissions reduction potential according to EPA’s assumed EGU SCR retrofit mitigation technologies.²³² The EGUs in the state are sufficiently well-controlled resulting in the lowest fossil-fuel emissions rate and highest share of renewable generation among the 23 states examined at Step 3. EPA’s Step 3 analysis, including analysis of the emissions reduction factors from EGU sources in the state, therefore resulted in no additional emissions reductions required to eliminate significant contribution from any EGU sources in California.

The following tables summarize the emissions reduction potentials (in ozone season tons) from these emissions controls across the affected jurisdictions. Table V.C.1–1 focuses on near-term emissions controls while Table V.C.1–2 includes emissions controls with extended implementation timeframes.

TABLE V.C.1–1—EGU OZONE-SEASON EMISSIONS AND REDUCTION POTENTIAL (TONS)—2023

State	Baseline 2023 OS NO _x	Reduction potential (tons) for varying levels of technology inclusion		
		SCR optimization	SCR optimization + combustion control upgrades	SCR/SNCR optimization + combustion control upgrades
Alabama	6,412	32	32	32
Arkansas	8,955	28	28	28
Illinois	7,721	70	70	247
Indiana	13,298	856	856	858
Kentucky	13,900	299	901	901
Louisiana	9,974	515	515	611
Maryland	1,214	0	0	8
Michigan	10,746	4	4	19
Minnesota	5,643	98	98	139
Mississippi	6,283	73	984	984
Missouri	20,094	7,339	7,339	7,497
Nevada	2,372	4	4	4
New Jersey	915	143	143	143
New York	3,977	64	64	64
Ohio	10,264	1,154	1,154	1,154
Oklahoma	10,470	199	890	890
Pennsylvania	8,573	336	336	436
Texas	41,276	909	909	1,142
Utah	15,762	7	7	7
Virginia	3,329	164	242	263
West Virginia	14,686	554	1,099	1,380

²³¹ This is not to say that states lack other options to reduce emissions from mobile sources. For example, a general list of types of transportation control measures can be found in CAA section 108(f). In addition, in accordance with section 177,

states may (but are not required to) adopt California vehicle emissions standards for which a waiver has been granted from the preemption provisions in section 209(a). States that decide to adopt California vehicle emissions standards may also choose to

submit those standards to be included as a part of their SIP.

²³² The only coal-fired power plant in California is the 63 MW Argus Cogeneration facility in Trona, California.

TABLE V.C.1-1—EGU OZONE-SEASON EMISSIONS AND REDUCTION POTENTIAL (TONS)—2023—Continued

State	Baseline 2023 OS NO _x	Reduction potential (tons) for varying levels of technology inclusion		
		SCR optimization	SCR optimization + combustion control upgrades	SCR/SNCR optimization + combustion control upgrades
Wisconsin	6,321	7	7	26
Total	222,184	12,854	15,681	16,832

* The EPA shows reduction potential from state-of-the-art LNB upgrade as near-term emissions controls, but explains in section V.B and VI.A of this document that this reduction potential would not be implemented until 2024.

TABLE V.C.1-2—EGU OZONE-SEASON EMISSIONS AND REDUCTION POTENTIAL (TONS)—2026 *

State	Baseline 2026 OS NO _x	Reduction potential (tons) for varying levels of technology inclusion			
		SCR optimization	SCR optimization + combustion control upgrades	SCR/SNCR optimization + combustion control upgrades	SCR/SNCR optimization + combustion control upgrades + SCR/SNCR retrofits
Alabama	6,371	32	32	32	604
Arkansas	8,728	28	28	28	4,697
Illinois	6,644	70	70	230	1,281
Indiana	9,468	768	768	770	1,333
Kentucky	13,211	299	739	739	5,303
Louisiana	9,704	515	515	611	5,894
Maryland	901	51	51	59	59
Michigan	7,790	4	4	19	1,959
Minnesota	4,197	98	98	139	1,613
Mississippi	6,022	73	984	984	3,938
Missouri	18,612	7,339	7,339	7,497	11,231
Nevada	1,146	4	4	4	4
New Jersey	915	143	143	143	143
New York	3,977	64	64	64	589
Ohio	9,083	1,154	1,154	1,154	1,154
Oklahoma	10,259	199	890	890	5,968
Pennsylvania	8,362	352	352	452	1,204
Texas	39,684	909	909	1,142	15,980
Utah	9,930	7	7	7	7,338
Virginia	3,019	164	242	263	646
West Virginia	13,185	401	947	1,227	3,507
Wisconsin	5,016	7	7	26	623
Total	196,225	12,680	15,346	16,480	75,067

* The EPA shows all emissions reduction potential identified for assumed SCR retrofits in the Step 3 analytic year 2026, but explains in sections V.B and VI.A of this document that for Step 4 implementation this emissions reduction potential will be phased in during the 2026 and 2027 ozone season control periods.

2. Non-EGU or Industrial Source Emissions Reduction Potential

As described in the memorandum titled “Summary of Final Rule Applicability Criteria and Emissions Limits for Non-EGU Emissions Units, Assumed Control Technologies for Meeting the Final Emissions Limits, and Estimated Emissions Units, Emissions Reductions, and Costs,” the EPA uses the 2019 emissions inventory, the list of emissions units estimated to be captured by the applicability criteria, the assumed control technologies that would meet the emissions limits, and

information on control efficiencies and default cost/ton values from the CMDB, to estimate NO_x emissions reductions and costs for the year 2026. The estimates using the 2019 inventory and information from the CMDB identify proxies for emissions units, as well as emissions reductions, and costs associated with the assumed control technologies that would meet the final emissions limits. Emissions units subject to the final rule emissions limits may differ from those estimated in this assessment, and the estimated emissions reductions from and costs to meet the

final rule emissions limits may also differ from those estimated in this assessment. The costs do not include monitoring, recordkeeping, reporting, or testing costs.

Table V.C.2-1 summarizes the industries, estimated emissions unit types, assumed control technologies, estimated annual costs (2016\$), and estimated ozone season emissions reductions in 2026, and Table V.C.2-2 summarizes the estimated reductions by state.

TABLE V.C.2-1—BY INDUSTRY IN 2026, ESTIMATED EMISSIONS UNIT TYPES, ASSUMED CONTROL TECHNOLOGIES, ANNUAL COSTS (2016\$), AND ESTIMATED EMISSIONS REDUCTIONS (OZONE SEASON TONS)

Industry/industries	Emissions unit type	Assumed control technologies that meet final emissions limits	Annual costs (2016\$)	Ozone season emissions reductions
Pipeline Transportation of Natural Gas	Reciprocating Internal Combustion Engine	NSCR or Layered Combustion, Layered Combustion, SCR, NSCR.	385,463,197	32,247
Cement and Concrete Product Manufacturing.	Kiln	SNCR	10,078,205	2,573
Iron and Steel Mills and Ferroalloy Manufacturing.	Reheat Furnaces	LNB	3,579,294	408
Glass and Glass Product Manufacturing ..	Furnaces	LNB	7,052,088	3,129
Iron and Steel Mills and Ferroalloy Manufacturing.	Boilers	SCR, LNB + FGR	8,838,171	440
Metal Ore Mining	621,496	18
Basic Chemical Manufacturing	49,697,848	1,748
Petroleum and Coal Products Manufacturing.	5,128,439	147
Pulp, Paper, and Paperboard Mills	62,268,540	1,836
Solid Waste Combustors and Incinerators	Combustors or Incinerators	ANSCR or LNT TM and SNCR	38,949,560	2,071
Totals	571,676,839	44,616

TABLE V.C.2-2—ESTIMATED EMISSIONS REDUCTIONS (OZONE SEASON TONS) BY UPWIND STATE IN 2026

State	2019 OS emissions *	OS NO _x reductions
AR	8,790	1,546
CA	16,562	1,600
IL	15,821	2,311
IN	16,673	1,976
KY	10,134	2,665
LA	40,954	7,142
MD	2,818	157
MI	20,576	2,985
MO	11,237	2,065
MS	9,763	2,499
NJ	2,078	242
NV ²³³	2,544	0
NY	5,363	958
OH	18,000	3,105
OK	26,786	4,388
PA	14,919	2,184
TX	61,099	4,691
UT	4,232	252
VA	7,757	2,200
WV	6,318	1,649
Totals	302,425	44,616

* The 2019 OS season emissions are calculated as 5/12 of the annual emissions from the following two emissions inventory files: nonegu_SmokeFlatFile_2019NEI_POINT_20210721_controlupdate_13sep2021_v0 and oilgas_SmokeFlatFile_2019NEI_POINT_20210721_controlupdate_13sep2021_v0.

In Table V.C.2-3 by industry and emissions unit type, the EPA provides a summary of the control technologies applied and their average costs across

all of the non-EGU emissions units. The average cost per ton values range from \$939 to \$14,595 per ton. Note that the average cost per ton values are in 2016

dollars and reflect simple averages and not a percentile or other representative cost values from a distribution of cost estimates.

TABLE V.C.2-3—BY INDUSTRY, EMISSIONS UNIT TYPE, ASSUMED CONTROL TECHNOLOGIES, AND ESTIMATED AVERAGE COST PER TON BY CONTROL TECHNOLOGY ACROSS ALL NON-EGU EMISSIONS UNITS

Industry/industries	Emissions unit type	Assumed control technologies that meet final emissions limits	Average cost/ton values (2016\$)
Pipeline Transportation of Natural Gas	Reciprocating Internal Combustion Engine	NSCR or Layered Combustion, Layered Combustion, SCR, NSCR.	4,981
Cement and Concrete Product Manufacturing	Kiln	SNCR	1,632

²³³ We are not aware of existing non-EGU emissions units in Nevada that meet the applicability criteria for non-EGUs in the final rule.

If any such units in fact exist, they would be subject to the requirements of the rule just as in any other state. In addition, any new emissions unit in

Nevada that meets the applicability criteria in the final rule will be subject to the final rule's requirements. See section III.B.1.d.

TABLE V.C.2-3—BY INDUSTRY, EMISSIONS UNIT TYPE, ASSUMED CONTROL TECHNOLOGIES, AND ESTIMATED AVERAGE COST PER TON BY CONTROL TECHNOLOGY ACROSS ALL NON-EGU EMISSIONS UNITS—Continued

Industry/industries	Emissions unit type	Assumed control technologies that meet final emissions limits	Average cost/ton values (2016\$)
Iron and Steel Mills and Ferroalloy Manufacturing	Reheat Furnaces	LNB	3,656
Glass and Glass Product Manufacturing	Furnaces	LNB	939
Iron and Steel Mills and Ferroalloy Manufacturing	Boilers	SCR or LNB + FGR	8,369
Metal Ore Mining	14,595
Basic Chemical Manufacturing	11,845
Petroleum and Coal Products Manufacturing	14,582
Pulp, Paper, and Paperboard Mills	14,134
Solid Waste Combustors and Incinerators	Combustors or Incinerators	ANSCR or LNT TM and SNCR	7,836
Overall Average Cost/Ton	5,339

Refer to the memorandum titled “Summary of Final Rule Applicability Criteria and Emissions Limits for Non-EGU Emissions Units, Assumed Control Technologies for Meeting the Final Emissions Limits, and Estimated Emissions Units, Emissions Reductions, and Costs” for additional estimates—including by industry and by state. These estimates are proxy estimates, and the EPA also did not prepare detailed engineering analyses for the industries, facilities, and individual emissions units identified for the final rule. Emissions units subject to the final rule emissions limits may differ from those estimated in this assessment, and the estimated emissions reductions from and costs to meet the final rule emissions limits may also differ from those estimated in this assessment.

Comment: Regarding the marginal cost threshold of \$7,500/ton used to assess potential emissions reductions in the non-EGU screening assessment prepared for proposal, commenters raised a range of questions, including (1) why the EPA used a marginal cost threshold that is much higher than the \$2,000/ton threshold used in the 2021 Revised CSAPR Update Rule, (2) why the EPA used a “one size fits all” approach for addressing the estimated cost and actual emissions reductions achievable, particularly for existing sources of NO_x emissions, (3) why the EPA set a \$7,500/ton marginal cost threshold for all non-EGUs, despite acknowledging the heterogeneity of industry, emissions unit types and control options and failing to consider the actual costs associated with achieving the proposed reductions at different types of emissions units in order to artificially inflate the marginal cost threshold and to justify otherwise cost-prohibitive NO_x control technologies. Commenters also stated that controls for their industry are not cost-effective using the EPA’s presumptive value of \$7,500/ton and

that the value may not be technically feasible to apply to existing sources that would have to retrofit controls.

Response: The EPA notes that the primary purpose of the *Screening Assessment of Potential Emissions Reductions, Air Quality Impacts, and Costs from Non-EGU Emissions Units for 2026* (non-EGU screening assessment) was to identify potentially impactful industries and emissions unit types for further evaluation.²³⁴ In the non-EGU screening assessment memorandum we presented an analytical framework to further analyze potential emissions reductions and costs and included proxy estimates for 2026.

As noted in section V.D. of this document, at proposal the EPA found that based on data available at that time and for the purposes of the non-EGU screening assessment, it appeared that a \$7,500 marginal cost-per-ton threshold could be used as a proxy to identify cost-effective emissions control opportunities. Also, the \$7,500 marginal cost-per-ton threshold is higher than the cost-per-ton value used in the Revised Cross-State Air Pollution Rule Update because that rulemaking assessed significant contribution for the less protective 2008 ozone NAAQS, and it is reasonable when assessing significant contribution associated with the more protective 2015 ozone NAAQS, that a potentially more costly universe of emissions controls and related potential reductions should be included in the analysis.²³⁵ Similar to the role of cost-

²³⁴ The non-EGU screening assessment memorandum is available in the docket here: <https://www.regulations.gov/document/EPA-HQ-OAR-2021-0668-0150>.

²³⁵ As the amount of air pollution that is allowed in the ambient air is reduced (i.e., when a NAAQS is revised), it is reasonable to expect that further emissions reductions may be necessary to bring areas into attainment with that more protective standard. At the same time, the available remaining emissions reduction opportunities will likely have become more costly compared to a prior period, because other CAA requirements, including such as earlier transport rules, will have consumed those

effectiveness thresholds the EPA uses at Step 3 to evaluate EGU emissions control opportunities, this threshold is not intended to represent the maximum cost any facility may need to expend but is rather intended to be a representative figure for evaluating technologies to allow for a relative comparison between different levels of control stringency. The EPA’s potential cost threshold for non-EGU controls at proposal was intended to serve a similar representative purpose. Based on the EPA’s updated analysis for this final rule, the EPA recognizes that the \$7,500/ton threshold does not reflect the full range of cost-effectiveness values that are likely present across the many different types of non-EGU industries and emissions units assessed.

While the potentially impactful industries (identified in Step 1 of the analytical framework presented in the non-EGU screening assessment) were directly used, the proxy estimates for emissions unit types, emissions reductions, and costs from the non-EGU screening assessment were not directly used to establish applicability thresholds and emissions limits in the proposal. To further evaluate the impactful industries and emissions unit types and establish the proposed emissions limits, the EPA reviewed RACT rules, NSPS rules, NESHAP rules, existing technical studies (e.g., Ozone Transport Commission, Technical Information Oil and Gas Sector Significant Stationary Sources of NO_x Emissions, October 17, 2012), rules in approved SIP submittals, consent decrees, and permit limits.²³⁶

emissions reduction opportunities that were the least costly. The EPA noted this same possibility in the original CSAPR rulemaking, see 76 FR 48210.

²³⁶ This review is detailed in the Final Non-EGU Sectors TSD available in the docket here: <https://www.regulations.gov/document/EPA-HQ-OAR-2021-0668-0145>.

D. Assessing Cost, EGU and Non-EGU NO_x Reductions, and Air Quality

To determine the emissions that are significantly contributing to nonattainment or interfering with maintenance, the EPA applied the multi-factor test to EGUs and non-EGUs separately, considering for each the relationship of cost, available emissions reductions, and downwind air quality impacts. Specifically, for each sector, the EPA finalizes a determination regarding the appropriate level of uniform NO_x control stringency that would collectively eliminate significant contribution to downwind nonattainment and maintenance receptors. Based on the air quality results presented in this section, we find that the emissions control strategies that were identified and evaluated in sections V.B and V.C of this document and found to be both cost-effective and feasible, deliver meaningful air quality benefits through projected reductions in ozone levels across the linked downwind nonattainment and maintenance receptors in the relevant analytic years 2023 and 2026. Further, EPA finds the emissions control strategies in upwind states that would deliver these benefits to be widely available and in use at many other similar EGU and non-EGU facilities throughout the country, particularly in those areas that have historically or now continue to struggle to attain and maintain the 2015 ozone NAAQS. Applying these emissions control strategies on a uniform basis across all linked upwind states continues to constitute an efficient and equitable solution to the problem of allocating upwind-state responsibility for the elimination of significant contribution. This approach continues to effectively address the “thorny” causation problem of interstate pollution transport for regional-scale pollutants like ozone that transport over large distances and are affected by the vagaries of meteorology. *EME Homer City*, 572 U.S. at 514–16. It requires the most impactful sources in each state that has been found to contribute to ozone problems in other states to come up to minimum standards of environmental performance based on demonstrated NO_x pollution-control technology. *Id.* at 519. When the effects of these emissions reductions are assessed collectively across the hundreds of EGU and non-EGU industrial sources that are subject to this rule, the cumulative improvements in ozone levels at downwind receptors, while they may vary to some extent, are both measurable and meaningful and will assist downwind areas in attaining

and maintaining the 2015 ozone NAAQS.

In addition to the findings of cost-effectiveness, feasibility and widespread availability that support EPA’s identification of the appropriate level of emissions-control stringency at Step 3 discussed in sections V.B and V.C, the findings regarding air quality improvement in this section—as in prior transport rules—are a central component of our Step 3 analytic findings as to the definition of “significant contribution.” EPA’s assessment of air quality improvement for all of the emissions control strategies included shows continued air quality improvement with each additional control strategy measure. Within the group of selected control strategies for EGUs and non-EGUs no clear “knee-in-the-curve” is evident; *i.e.*, there is no point at which there is a noticeable decline in the rate of air quality improvement up through the control stringency level selected. However, if EPA were to go beyond the selected control stringency through inclusion of additional EGU or non-EGU NO_x mitigation technologies for the covered sources and unit-types that are, at least on the record of this action, not widely available, uncertain or untested, and/or far more costly, a “knee-in-the-curve” does materialize, where the incremental air quality benefit per dollar spent per ton on mitigation measures plateaus even as costs increase dramatically. In the Revised CSAPR Update, EPA explained that a knee in the curve “is not on its own a justification for not requiring reductions beyond that point,” 86 FR 23107, but does indicate that it is a useful indicator for informing potential stopping points. The observation that no “knee-in-the-curve” materializes at the stringency levels up through that selected by EPA supports EPA’s identified control stringency.

Further, as the Supreme Court has explained, “while EPA has a statutory duty to avoid over-control, the Agency also has a statutory obligation to avoid ‘under-control,’ *i.e.*, to maximize achievement of attainment downwind.” 572 U.S. at 523. While the ultimate purpose of the good neighbor provision is to eliminate significant contribution and not necessarily to resolve downwind areas’ nonattainment and maintenance problems, we have evaluated the expected attainment status at each identified receptor as we examine the air quality effects of the different emissions control strategies identified. As discussed further in this section, the EPA notes that multiple receptors shift into projected attainment status or shift from projected

nonattainment to maintenance status up through the stringency level ultimately selected by EPA. (And all receptors show improvement in air quality even if their status does not change.) These analytic findings at Step 3 cement EPA’s identification of the selected EGU and non-EGU mitigation measures as the appropriate control stringency to fulfill its statutory obligation to eliminate significant contribution for the 2015 ozone NAAQS for the covered states. The EPA also evaluated whether the final rule resulted in possible over-control scenarios by evaluating if an upwind state is linked solely to downwind air quality problems that could have been resolved at a lower cost threshold, or if an upwind state could have reduced its emissions below the 1 percent of NAAQS air quality contribution threshold at a lower cost threshold. The Agency finds no overcontrol from this rule. See section V.D.4 of this document.

1. EGU Assessment

For EGUs, the EPA examined the emissions reduction potential associated with each EGU emissions control technology (presented in section V.C.1 of this document) and its impact on the air quality at downwind receptors. Specifically, EPA identified and assessed the projected average air quality improvements relative to the base case and whether these improvements are sufficient to shift the status of receptors from projected nonattainment to maintenance or from maintenance to attainment. Combining these air quality factors, costs, and emissions reductions, the EPA identified a control stringency for EGUs that results in substantial air quality improvement from emissions controls that are available in the timeframe for which air quality problems at downwind receptors persist. For all affected jurisdictions, this control stringency reflects, at a minimum, the optimization of existing post-combustion controls and installation of state-of-the-art NO_x combustion controls, which are widely available at a representative cost of \$1,800 per ton. EPA’s evaluation also shows that the effective emissions rate performance across affected EGUs consistent with realization of these mitigation measures does not over-control upwind states’ emissions relative to either the downwind air quality problems to which they are linked at Step 1 or the 1 percent contribution threshold that triggers further evaluation at Step 3 of the 4-step framework for the 2015 ozone NAAQS.

Similarly, the EPA also identified installation of new SCR post-combustion controls at coal steam sources greater than or equal to 100 MW and for a more limited portion of the oil/gas steam fleet that had higher levels of emissions as components of the required control stringency. These SCR retrofits are widely available starting in the 2026 ozone season at \$11,000 and \$7,700 per ton respectively. For all but 3 of the affected states (Alabama, Minnesota, and Wisconsin, which are no longer linked in 2026 at Steps 1 and 2 in EPA's base case air quality modeling for this final rule), EPA's evaluation shows that the effective emissions rate performance across EGUs consistent with the full realization of these mitigation measures does not over-control upwind states' emissions in 2026 relative to either the downwind air quality problems to which they are linked at Step 1 or the 1 percent contribution threshold that triggers further evaluation at Step 3 of the 4-step framework for the 2015 ozone NAAQS (see the Ozone Transport Policy Analysis Final Rule TSD for details).

To assess downwind air quality impacts for the nonattainment and maintenance receptors identified in section IV.D of this document, the EPA evaluated the air quality change at that receptor expected from the progressively more stringent upwind EGU control stringencies that were available for that time period in upwind states linked to that receptor. This assessment provides the downwind ozone improvements for consideration and provides air quality data that is used to evaluate potential over-control situations.

To assess the air quality impacts of the various control stringencies at downwind receptors for the purposes of Step 3, the EPA evaluated changes resulting from the emissions reductions associated with the identified emissions controls in each of the upwind states, as well as assumed corresponding reductions of similar stringency in the downwind state containing the receptor to which they are linked. By applying these emissions reductions to the state containing the receptor, the EPA assumes that the downwind state will

implement (if it has not already) an emissions control stringency for its sources that is comparable to the upwind control stringency identified here. Consequently, the EPA is accounting for the downwind state's "fair share" of the responsibility for resolving a nonattainment or maintenance problem as a part of the over-control evaluation.²³⁷

For this assessment, the EPA used an ozone air quality assessment tool (ozone AQAT) to estimate downwind changes in ozone concentrations related to upwind changes in emissions levels. The EPA focused its assessment on the years 2023 and 2026 as they pertain to the last years for which ozone season emissions data can be used for purposes of determining attainment for the Moderate (2024) and Serious (2027) attainment dates. For each EGU emissions control technology, the EPA first evaluated the magnitude of the change in ozone concentrations at the nonattainment and maintenance receptors for each relevant year (*i.e.*, 2023 and 2026). Next, the EPA evaluated whether the estimated change in concentration would resolve the receptor's nonattainment or maintenance concern by lowering the average or maximum design values, respectively, below 71 ppb. For a complete set of estimates, see the Ozone Transport Policy Analysis Final Rule TSD or the ozone AQAT Excel file.

For 2023, the EPA evaluated potential air quality improvements at the downwind receptors outside of California associated with available EGU emissions control technologies in that timeframe. The EPA determined for the purposes of Step 3 that the average air quality improvement at the receptors relative to the engineering analytics base case was 0.06 ppb for emissions reductions commensurate with optimization of existing SCR/SNCRs and combustion control upgrades. The EPA determined for the purposes of

²³⁷ For EGUs, this analysis for the Connecticut receptors shows no EGU reduction potential in Connecticut from the emissions reduction measures identified given that state's already low-emitting fleet; however, EGU reductions were identified in Colorado and these reductions were included in the over-control analysis.

Step 3 that no receptors switch from maintenance to attainment or from nonattainment to maintenance with these mitigation strategies in place. Table V.D.1–1 summarizes the results of EPA's Step 3 evaluation of air quality improvements at these receptors using AQAT.

For 2026, the EPA determined that the average air quality improvement at these receptors relative to the engineering analytics base case was 0.47 ppb for emissions reductions commensurate with optimization of existing SCR/SNCRs, combustion control upgrades, and new post-combustion control (SCR and SNCR) retrofits at eligible units are assumed to be implemented. The EPA determined for the purposes of Step 3 that in 2026, all but one of the receptors are expected to remain nonattainment or maintenance across these control stringencies, with one receptor in Larimer County, Colorado (Monitor 080690011), switching from maintenance to attainment and two receptors (one in Fairfield County, Connecticut (Monitor 90013007), and one in Galveston, Texas (Monitor ID 481671034)) switching from nonattainment to maintenance with these mitigation strategies in place.²³⁸ Table V.D.1–2 summarizes the results of EPA's Step 3 evaluation of air quality improvements at the receptors included in the AQAT analysis. For more information about how this assessment was performed and the results of the analysis for each receptor, refer to the Ozone Transport Policy Analysis Final Rule TSD and to the Ozone AQAT included in the docket for this rule.

²³⁸ As in prior rules, for the purpose of defining significant contribution at Step 3, the EPA evaluated air quality changes resulting from the application of the emissions reductions in only those states that are linked to each receptor as well as the state containing the receptor. By applying reductions to the state containing the receptor, the EPA ensures that it is accounting for the downwind state's fair share. This method holds each upwind state responsible for its fair share of the downwind problems to which it is linked. Reductions made by other states to address air quality problems at other receptors do not increase or decrease this share. The air quality impacts on design values that reflect the emissions reductions in all linked states action are further discussed in sections V.D.3 and V.D.4 of this document.

TABLE V.D.1-1—AIR QUALITY AT THE RECEPTORS IN 2023 FROM EGU EMISSIONS CONTROL TECHNOLOGIES ^a

Monitor ID No.	State	County	Average DV (ppb)		Max DV (ppb)	
			Baseline (engineering analysis)	SCR/SNCR optimization + LNB upgrade	Baseline (engineering analysis)	SCR/SNCR optimization + LNB upgrade
40278011	Arizona	Yuma	70.36	70.34	72.05	72.04
80350004	Colorado	Douglas	71.12	71.10	71.71	71.70
80590006	Colorado	Jefferson	72.63	72.61	73.32	73.31
80590011	Colorado	Jefferson	73.29	73.27	73.89	73.87
80690011	Colorado	Larimer	70.79	70.78	71.99	71.98
90010017	Connecticut	Fairfield	71.62	71.56	72.22	72.16
90013007	Connecticut	Fairfield	72.99	72.90	73.89	73.80
90019003	Connecticut	Fairfield	73.32	73.25	73.62	73.55
90099002	Connecticut	New Haven	70.61	70.51	72.71	72.61
170310001	Illinois	Cook	68.13	68.11	71.82	71.80
170314201	Illinois	Cook	67.92	67.88	71.41	71.37
170317002	Illinois	Cook	68.47	68.37	71.27	71.17
350130021	New Mexico	Dona Ana	70.83	70.82	72.13	72.12
350130022	New Mexico	Dona Ana	69.73	69.72	72.43	72.42
350151005	New Mexico ^b	Eddy				
350250008	New Mexico	Lea				
480391004	Texas	Brazoria	70.59	70.52	72.69	72.62
481210034	Texas	Denton	69.93	69.88	71.73	71.68
481410037	Texas	El Paso	69.82	69.81	71.43	71.41
481671034	Texas	Galveston	71.82	71.70	73.13	73.01
482010024	Texas	Harris	75.33	75.25	76.93	76.85
482010055	Texas	Harris	71.19	71.10	72.20	72.10
482011034	Texas	Harris	70.32	70.25	71.52	71.45
482011035	Texas	Harris	68.01	67.94	71.52	71.45
490110004	Utah	Davis	71.88	71.87	74.08	74.07
490353006	Utah	Salt Lake	72.48	72.47	74.07	74.06
490353013	Utah	Salt Lake	73.21	73.20	73.71	73.70
550590019	Wisconsin	Kenosha	70.75	70.65	71.65	71.55
551010020	Wisconsin	Racine	69.59	69.46	71.39	71.25
551170006	Wisconsin	Sheboygan	72.64	72.46	73.54	73.36
Average AQ Change Relative to Base (ppb)						0.06
Total PPB Change Across All Receptors Relative to Base ^c						1.58

Table Notes:

^a The EPA notes that the design values reflected in tables V.D.1-1 and -2 correspond to the engineering analysis EGU emissions inventory that was used in AQAT to determine state-level baseline emissions and reductions at Step 3. These tools are discussed in greater detail in the Ozone Transport Policy Analysis Final Rule TSD.

^b New Mexico Eddy and Lea monitors have no values in tables V.D.1-1 and 1-2 as EPA does not have calibration factors for these monitors as no contributions were calculated for them from the proposal AQ modeling

^c The cumulative ppb change only shows the aggregate change across all problematic receptors (some of which are located within close proximity to one another) in this part of the Step 3 analysis. Section VIII of this document provides a more complete picture of the air quality impacts of the final rule.

TABLE V.D.1-2—AIR QUALITY AT RECEPTORS IN 2026 FROM EGU EMISSIONS CONTROL TECHNOLOGIES

Monitor ID No.	State	County	Average DV (ppb)		Max DV (ppb)	
			Baseline (engineering analysis)	SCR/SNCR optimization + LNB upgrade + SCR/SNCR retrofit	Baseline (engineering analysis)	SCR/SNCR optimization + LNB upgrade + SCR/SNCR retrofit
40278011	Arizona	Yuma	69.87	69.84	71.47	71.44
80590006	Colorado	Jefferson	71.70	71.36	72.30	71.95
80590011	Colorado	Jefferson	72.06	71.59	72.66	72.19
80690011	Colorado	Larimer	69.84	69.54	71.04	70.73
90013007	Connecticut	Fairfield	71.25	70.98	72.06	71.78
90019003	Connecticut	Fairfield	71.58	71.34	71.78	71.54
350130021	New Mexico	Dona Ana	70.06	69.89	71.36	71.19
350130022	New Mexico	Dona Ana	69.17	69.00	71.77	71.60
350151005	New Mexico	Eddy				
350250008	New Mexico	Lea				
480391004	Texas	Brazoria	69.89	68.96	72.02	71.06
481671034	Texas	Galveston	71.29	70.02	72.51	71.22
482010024	Texas	Harris	74.83	73.86	76.45	75.46
490110004	Utah	Davis	69.90	69.34	72.10	71.52
490353006	Utah	Salt Lake	70.50	69.96	72.10	71.55
490353013	Utah	Salt Lake	71.91	71.45	72.31	71.84
551170006	Wisconsin	Sheboygan	70.83	70.51	71.73	71.41
Average AQ Change Relative to Base (ppb)						0.47
Total PPB Change Across All Receptors Relative to Base (ppb)						7.04

Figures 1 and 2 to section V.D.1 of this document, included in Appendix I of the Ozone Transport Policy Analysis Final Rule TSD available in the docket for this rulemaking, illustrate the air quality improvement relative to the estimated representative cost associated with the previously identified emissions control technologies. The graphs show improving air quality at the downwind receptors as emissions reductions commensurate with the identified control technologies are assumed to be implemented. Figure 1 to section V.D.1 of this document reflects emissions reductions commensurate with optimization of existing SNCRs and SCR. Figure 2 to section V.D.1 of this document reflects emissions reductions commensurate with installation of new post combustion controls (mainly SCR) layered on top of the emissions reduction potential from the technologies represented in Figure 1 to section V.D.1 of this document. The graphic, and underlying AQAT receptor-by-receptor analysis demonstrates that air quality continues to improve at downwind receptors as EPA examines increasingly stringent EGU NO_x control technologies. While all major technology breakpoints identified in sections V.B and V.C of this document show continued air quality improvements at problematic receptors and at cost and technology levels that are commensurate with mitigation strategies that are proven to be widely available and implemented, EPA's quantification and application of those breakpoints reflect certain exclusions to: (1) preserve this consistency with widely observed mitigation measures in states, and (2) remove any retrofit assumptions at marginal units that would have much higher dollar per ton representative cost and little or no air quality benefit. For instance, the EPA does not define the SCR retrofit breakpoint (\$11,000 per ton) to include retrofit application at steam units less than 100 MW or at oil/gas steam units emitting at less than 150 tons per ozone season. The emissions reductions from these potential categories of measures are small and do not constitute additional "breakpoints" in EPA's estimation. They would entail much higher dollar per ton costs, going beyond what is widely observed in the fleet. This careful calibration of technology breakpoints through exclusion of measures that are clearly not cost-effective in terms of air quality benefit allows for the identification of an EGU uniform control stringency that is an appropriate reflection of those readily available and widely

implemented emissions reduction strategies that will have meaningful downwind air quality impact.

Moreover, these technologies (and representative cost) are demonstrated ozone pollution mitigation strategies that are widely practiced across the EGU fleet and are of comparable stringency to emissions reduction measures that many downwind states have already instituted. The coal SCR retrofit measures driving the majority of the emissions reductions in this action not only reflect industry best practice, but they also reflect prevailing practice among EGUs. More than 66 percent of the existing coal capacity already has this technology in place. For nearly 25 years, all new coal-fired EGUs that commenced construction have had SCR (or equivalent emissions rates). The 1997 proposed amendments to subpart Da revised the NO_x standard based on the use of SCR. The NO_x SIP Call (promulgated in 1998) established emissions reduction requirements premised on extensive SCR installation (142 units) and incentivized well over 40 GWs of SCR retrofit in the ensuing years.²³⁹ Similarly, the Clean Air Interstate Rule established emissions reductions requirements in 2006 that assumed SCR would be installed on another 58 units (15 GW) in the ensuing years among just 10 states, and an even greater volume of capacity chose SCR retrofit measures in the wake of finalizing that action.²⁴⁰

Basing emissions reduction requirements for EGUs on SCR retrofits is also consistent with regulatory approaches adopted by states, which—particularly in downwind areas more impacted by ozone transport contribution from upwind state emissions—have already adopted SCR-based standards as part of stringent NO_x control programs. Regulatory programs that impose stringent RACT requirements on all major power plants and Lowest Achievable Emission Rate (LAER) standards on all new major sources of NO_x have resulted in remaining coal-fired generating resources in states along the Northeast Corridor such as Connecticut, Delaware, New Jersey, New York, and Massachusetts all being retrofitted with SCR.²⁴¹ The Maryland Code of Regulations requires coal-fired sources to operate existing SCR controls or install SCR controls by specified

dates.²⁴² Programs like North Carolina's Clean Smokestacks Act and Colorado's Clean Air, Clean Jobs Act have also required or prompted SCR retrofits on units.²⁴³ Unit-level BART requirements for the first Regional Haze planning period also determined SCR retrofits (and corresponding emissions rates) were cost-effective controls for a variety of sources in the U.S.²⁴⁴

As shown in Figure 1 to section V.D.1 of this document,²⁴⁵ the majority of EGU emissions reduction potential and associated air quality improvements estimated for 2023 occurs from optimization of existing SCRs, with some additional reductions from installation of state-of-the-art combustion controls at the same representative cost threshold. At the slightly higher representative cost threshold of \$1,800 per ton, there is some additional air quality improvement from optimization of existing SNCRs. These measures taken together represent the control stringency at which near-term incremental EGU NO_x reduction potential and corresponding downwind ozone air quality improvements are maximized. This evaluation shows that EGU NO_x reductions for each of the near-term emissions control technologies are available at reasonable cost and that these reductions provide meaningful improvements in downwind ozone concentrations at the identified nonattainment and maintenance receptors. Figure 1 to section V.D.1 of this document²⁴⁶ highlights (1) the continuous connection between identified emissions reduction potential and downwind air quality improvement across the range of near-term mitigation measures assessed, and (2) the cost-effective availability of these reductions and corresponding air quality improvements.

Additional considerations that are unique to EGUs provide additional support for EPA's determination to include SCR and SNCR optimization as part of the identified near-term control stringency, including:

²⁴² 26.11.38 (control of NO_x Emissions from Coal-Fired Electric Generating Units).

²⁴³ <https://www.epa.gov/system/files/documents/2021-09/table-3-30-state-power-sector-regulations-included-in-epa-platform-v6-summer-2021-refe.pdf>.

²⁴⁴ See table 3–35 BART regulations in EPA IPM documentation available at <https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6-summer-2021-reference-case>.

²⁴⁵ Included in Appendix I of the Ozone Transport Policy Analysis Final Rule TSD, which is available in the docket for this rulemaking.

²⁴⁶ Included in Appendix I of the Ozone Transport Policy Analysis Final Rule TSD, which is available in the docket for this rulemaking.

²³⁹ 63 FR 57448.

²⁴⁰ 71 FR 25345.

²⁴¹ EPA-HQ-OAR–2020–0272. Comment letter from Attorneys General of NY, NJ, CT, DE, MA.

- these controls are already installed and available for operation on these units;

- they are on average already partially operating, but not necessarily optimized;

- the reductions are available in the near-term (during ozone seasons when the problematic receptors are projected to persist), including by the 2023 ozone season aligned with the Moderate area attainment date; and

- these sources are already covered under the existing CSAPR NO_x Ozone Season Group 2 or Group 3 Trading Programs or the Acid Rain Program and thus have the monitoring, reporting, recordkeeping, and all other necessary elements of compliance with the trading program already in place.

The majority of EGU emissions reduction potential and associated air quality improvements estimated to start in 2026 occur from retrofitting uncontrolled steam sources with post-combustion controls. At the representative cost threshold of \$11,000 per ton, there are significant additional air quality improvements from emissions reductions commensurate with installation of new SCRs and SNCRs. These measures taken together with the near-term emissions reduction measures described previously represent the level of control stringency in 2026 at which incremental EGU NO_x reduction potential and corresponding downwind ozone air quality improvements are maximized. This evaluation shows that EGU NO_x reductions for each of the emissions control technologies are available at reasonable cost and that these reductions can provide improvements in downwind ozone concentrations at the identified nonattainment and maintenance receptors.

The EPA finds that the control stringency that reflects optimization of existing SCRs and SNCRs, installation of state-of-the-art combustion controls, and the retrofitting of new post combustion controls at the coal and oil/gas steam capacity described previously is projected to result in nearly 73,000 tons of NO_x reduction (approximately 40 percent of the 2026 baseline level) for the 19 linked states in 2026 subject to a FIP for EGUs, which will deliver notable air quality improvements across all transport-impacted receptors and assist in fully resolving one downwind air quality receptor for the 2015 ozone NAAQS. Figure 2 to section V.D.1 of this document²⁴⁷ demonstrates the

continuous connection between identified emissions reduction potential and downwind air quality improvement across the range of mitigation measures assessed in 2026. At no point do the additional emissions mitigation measures examined here fail to produce corresponding downwind air quality improvements.

The EPA is determining that the appropriate EGU control stringency is commensurate with the full operation of all existing post-combustion controls (both SCRs and SNCRs) and state-of-the-art combustion control upgrades for those states linked to downwind nonattainment or maintenance receptors in 2023. For those states also linked in 2026, the EPA is determining that the appropriate EGU control stringency also includes emissions reductions commensurate with the retrofit of SCR at coal steam units of 100 MW or greater capacity (excepting circulating fluidized bed units), new SNCR on coal steam units of less than 100 MW capacity and circulating fluidized bed units, and SCR on oil/gas steam units greater than 100 MW that have historically emitted at least 150 tons of NO_x per ozone season.

As noted previously in section V.B of this document and in the EGU NO_x Mitigation Strategies Final Rule TSD, the EPA considered other methods of identifying mitigation measures (e.g., SCRs on smaller units, combustion control upgrades on combustion turbines, SCRs on combined cycle and simple cycle combustion turbines). The emissions reductions from these potential categories of measures do not constitute additional “technology breakpoints” in EPA’s estimation, but rather reflect a different tier of assessment where further mitigation measures are based on inclusion of smaller and/or different generator-type units (rather than different pollution control technologies). Emissions reductions from these measures are relatively small and would entail much higher dollar per ton costs, going beyond what is widely observed in the fleet. Although these additional measures are not included in EPA’s technology breakpoint analysis discussed in this section, the EPA did analyze the cost, potential reductions, and air quality impact of these additional measures to affirm that they do not merit inclusion in the final stringency for this action. That analysis shows the potential emissions reductions and air quality improvements from these additional measures occur beyond a notable “knee-in-the-curve” breakpoint. In other words, there are very little additional emissions reductions and air quality

improvement at problematic receptors, and the cost associated with these measures increases substantially on a dollar per ton basis. The graphic capturing this effect (located in Appendix I of the Ozone Transport Policy Analysis Final Rule TSD) illustrates the significant decline in cost-effectiveness of reductions if these measures had been included in EPA’s final stringency.²⁴⁸

2. Non-EGU Assessment

Using a 2019 emissions inventory, the list of emissions units estimated to be captured by the applicability criteria, the assumed control technologies that would meet the emissions limits, and information on control efficiencies and default cost/ton values from the control measures database, the EPA estimated NO_x emissions reductions and costs for the year 2026. Given the EPA’s conclusion that the 2026 ozone season is the earliest date by which the required controls can be installed across the identified non-EGU industries, the EPA assessed the effects of these controls in 2026 under its multi-factor test. In the assessment, we matched emissions units by Source Classification Code (SCC) from the inventory to the applicable control technologies in the CMDB. We modified SCC codes as necessary to match control technologies to inventory records. For additional details about the steps taken to estimate emissions units, emissions reductions, and costs, see the memorandum titled “Summary of Final Rule Applicability Criteria and Emissions Limits for Non-EGU Emissions Units, Assumed Control Technologies for Meeting the Final Emissions Limits, and Estimated Emissions Units, Emissions Reductions, and Costs” available in the docket. The estimates using the 2019 inventory and information from the CMDB identify proxies for emissions units, as well as emissions reductions, and costs associated with the assumed control

²⁴⁸ This is not to discount the potential effectiveness of these or other NO_x mitigation strategies outside the context of this rulemaking, which addresses regional ozone transport on a nationwide basis based on the present record. States and local jurisdictions may find such measures particularly impactful or necessary in the context of local attainment planning or other unique circumstances. Further, while the EPA finds on the present record that this rule is a complete remedy to the problem of interstate transport for the 2015 ozone NAAQS for the covered states, the EPA has in the past recognized that circumstances may arise after the promulgation of remedies under CAA section 110(a)(2)(D)(i)(I) in which the exercise of further remedial authority against specific stationary sources or groups of sources under CAA section 126 may be warranted. See Response to Clean Air Act Section 126(b) Petition From Delaware and Maryland, 83 FR 50444, 50453–54 (Oct. 5, 2018).

²⁴⁷ Included in Appendix I of the Ozone Transport Policy Analysis Final Rule TSD, which is available in the docket for this rulemaking.

technologies that would meet the final emissions limits. Emissions units subject to the final rule emissions limits may differ from those estimated in this assessment, and the estimated emissions reductions from, and costs to meet, the final rule emissions limits may also differ from those estimated in this assessment. The costs do not include monitoring, recordkeeping, reporting, or testing costs.

After reviewing public comments and updating some of the data used to provide an accurate assessment of the likely potential emissions reductions that could be achieved from the identified emissions units in the industries analyzed for proposal, the EPA finds that in general, these emissions reductions (with some modifications from proposal) are necessary to eliminate significant contribution at Step 3. The EPA's use of the analytical framework presented in the non-EGU screening assessment to identify potentially impactful industries and emissions unit types in the proposal remains valid. The EPA's criteria were intended to identify industries and emissions unit types that on a broad scale impact multiple receptors to varying degrees. The EPA focused its non-EGU screening assessment on (1) emissions and potential emissions reductions from these industries and emissions units and (2) the potential impact that emissions reductions from those industries and emissions units could deliver to the receptors.

While commenters criticized the analytical framework in the non-EGU screening assessment for assuming potentially unachievable emissions reductions at Step 3, or for not corresponding to a precise list of emissions units that would be covered at Step 4, these comments did not offer an alternative methodology for the Step 3 analysis to identify those industries and emissions units that potentially have the greatest impact and therefore should be scrutinized more closely for emissions reduction opportunities.²⁴⁹ Further, contrary to some commenters' assertions, the EPA's assessment did not result in an unbounded scope of regulation of industrial sources. Of the approximately 40 industries defined by North American Industry Classification System codes the EPA analyzed, only

seven industries were identified as having emissions and potential emissions reduction opportunities that met the EPA's air quality criteria for further assessment.

At proposal, the EPA found that based on data available at that time and for the purposes of the screening assessment, it appeared that a \$7,500 marginal cost-per-ton threshold could be used as a proxy to identify cost-effective emissions control opportunities. Similar to the role of cost-effectiveness thresholds the EPA uses at Step 3 to evaluate EGU emissions control opportunities, this threshold is not intended to represent the maximum cost any facility may need to expend but is rather intended to be a representative figure for evaluating technologies to allow for a relative comparison between different levels of control stringency. For example, in the EGU analysis, the \$11,000/ton average cost threshold for an SCR retrofit represents a range of SCR retrofit costs for units for which the 90th percentile cost-per-ton is roughly \$21,000. See section V.B.a of this document. The EPA's potential cost threshold for non-EGU controls at proposal was intended to serve a similar representative purpose. We respond briefly to comments regarding the use of the \$7,500/ton threshold in section V.C of this document. Comments regarding the screening assessment are further addressed in section 2.2 of the response to comments document in the docket.

Based on the EPA's updated analysis for this final rule, the EPA recognizes that the \$7,500/ton threshold does not reflect the full range of cost-effectiveness values that are likely present across the many different types of non-EGU industries and emissions units assessed. However, the EPA nonetheless finds that, with some adjustments from proposal, the overall mix of emissions controls it identified at proposal is appropriate to eliminate significant contribution to nonattainment or interference with maintenance in downwind areas. In the final analysis, we find that the average cost-per-ton of emissions reductions across all non-EGU industries in this rule generally ranges from approximately \$939/ton to \$14,595/ton, with an overall average of approximately \$5,339/ton. See memorandum titled "Summary of Final Rule Applicability Criteria and Emissions Limits for Non-EGU Emissions Units, Assumed Control Technologies for Meeting the Final Emissions Limits, and Estimated Emissions Units, Emissions Reductions, and Costs," available in the docket.

Nonetheless, overall the EPA finds that the range of cost-effectiveness values for non-EGU industries and emissions units compares favorably with the values used to evaluate EGUs. As discussed in the preceding paragraphs, the representative cost for EGUs to retrofit SCR is \$11,000/ton. This reflects a range of cost estimates, with \$20,900/ton reflecting the 90th percentile of units (see section V.B.a of this document). The higher end of the estimated average cost range for certain non-EGU industrial emissions units is also in that range. While specific emissions units may have higher costs associated with installing pollution control technologies than other similar unit types, this does not in itself undermine the Agency's conclusion that a level of emissions control associated with a specific emissions limit or control technology is appropriate to require across the linked upwind state region, in light of the overall emissions reductions and air quality benefits at downwind receptors that those controls are projected to deliver.

We note that the non-EGU control cost estimates in this final rule were based on historical actual emissions. This can affect the presentation of cost-per-ton values at the unit level, and it would not be appropriate to abandon uniform control stringency among like units in the covered industries across or within upwind states based on such cost differentials.

The EPA finds it appropriate to require a uniform level of emissions control across similar emissions unit types to, among other things, prevent two potential outcomes related to shifting production, either between units within the same facility or between units at different facilities. First, if some units were exempted from control requirements because of historically low actual emissions, there is a risk that source owners or operators may shift production to these specific units, increasing their utilization and resulting in emissions increases from these units. Second, if some owners or operators were able to avoid the control requirements of the final rule on this basis, they could gain a competitive advantage vis-à-vis other facilities within their respective industries. Production could shift from units at another facility subject to the control requirements to the units that avoided control requirements (and thus avoid costs the regulated facility should bear), potentially resulting in emissions increases. The effect of such an approach in such circumstances would be mere emissions shifting rather than the elimination of significant

²⁴⁹ For example, while the EPA has found it appropriate to limit the scope of emissions units that would be subject to emissions limits and controls in the iron and steel industry in light of comments regarding certain sources' inability to meet the EPA's proposed emission limits, this does not alter the EPA's determination that this industry is an impactful industry and that certain emissions controls should still be required.

contribution. Finally, as we have explained in prior transport actions, the cost-effectiveness figure is not the only factor that the agency considers at Step 3, *see* 86 FR 23073, and if used in isolation to make a policy decision without considering other information, could produce a result that is inconsistent with the objective of ensuring significant contribution is eliminated.²⁵⁰

In addition to our evaluation of cost-effectiveness on a cost per ton basis, the EPA's determination at Step 3 for non-EGUs is also informed by the overall level of emissions reductions that will be achieved across the region and the effect those reductions are projected to have on air quality at the downwind receptors (discussed more later in this section). We are also influenced by the fact that these emissions control strategies for non-EGUs are generally well demonstrated to be feasible on many existing units, as established

through our review of consent decrees, permits, RACT determinations, and other data sources. These levels of emissions control have in many cases already been required by states with downwind nonattainment areas for the 2015 ozone NAAQS.

The EPA determined that, for 2026, the incremental average air quality improvement at receptors relative to the EGU case when SCR post-combustion controls were installed was 0.19 ppb when non-EGU controls were applied, based on the Step 3 analysis. The total average air quality improvement was 0.66 ppb when the non-EGU improvement was added to the EGU improvement, meaning that the non-EGU increment accounts for about 29 percent of this average air quality improvement. In general, the air quality results from non-EGU emissions reductions yield additional important downwind benefits to the air quality benefits of the EGU strategy. For

example, the total ppb improvement summed over all of the receptors from EGUs was 7.04 ppb and the non-EGU increment adds another 2.82 ppb of improvement bringing the total to 9.87 (when accounting for rounding). Non-EGUs account for 29 percent of this total air quality improvement as well. Further, these figures should not be considered in isolation; EPA is not comparing EGU strategy effects and non-EGU effects to make a selection between two different approaches. Rather, both the selected EGU and non-EGU emissions reduction strategies at the cost-effectiveness values identified in section V.B and V.C of this document present a comprehensive solution to eliminating significant contribution for the covered states. The combined effect of the EGU and non-EGU strategies is further presented in the following section.

TABLE V.D.2-2—AIR QUALITY AT RECEPTORS IN 2026 FROM NON-EGU INDUSTRIES

Monitor ID No.	State	County	Average DV (ppb)		Max DV (ppb)	
			Baseline (engineering analysis)	EGU SCR/SNCR optimization + LNB upgrade + SCR/SNCR retrofit + non-EGU	Baseline (engineering analysis)	EGU SCR/SNCR optimization + LNB upgrade + SCR/SNCR retrofit + non-EGU
40278011	Arizona	Yuma	69.87	69.80	71.47	71.40
80590006	Colorado	Jefferson	71.70	71.34	72.30	71.93
80590011	Colorado	Jefferson	72.06	71.57	72.66	72.16
80690011	Colorado	Larimer	69.84	69.53	71.04	70.72
90013007	Connecticut	Fairfield	71.25	70.66	72.06	71.46
90019003	Connecticut	Fairfield	71.58	71.06	71.78	71.26
350130021	New Mexico	Dona Ana	70.06	69.86	71.36	71.16
350130022	New Mexico	Dona Ana	69.17	68.96	71.77	71.56
350151005	New Mexico	Eddy				
350250008	New Mexico	Lea				
480391004	Texas	Brazoria	69.89	68.50	72.02	70.58
481671034	Texas	Galveston	71.29	69.28	72.51	70.47
482010024	Texas	Harris	74.83	73.39	76.45	74.98
490110004	Utah	Davis	69.90	69.28	72.10	71.46
490353006	Utah	Salt Lake	70.50	69.91	72.10	71.50
490353013	Utah	Salt Lake	71.91	71.40	72.31	71.80
551170006	Wisconsin	Sheboygan	70.83	70.27	71.73	71.17
Average AQ Change Relative to Base (ppb)						0.66
Total PPB Change Across All Receptors Relative to Base (ppb)						9.87

Table Notes:

^a The EPA notes that the design values reflected in Table V.D.-2 correspond to the engineering analysis EGU emissions inventory that was used in AQAT to determine state-level baseline emissions and reductions at Step 3. These tools are discussed in greater detail in the Ozone Transport Policy Analysis Final Rule TSD.

^b New Mexico Eddy and Lea monitors have no values in Table V.D.2-2 as EPA does not have calibration factors for these monitors as no contributions were calculated for them from the proposal AQ modeling.

^c The cumulative ppb change only shows the aggregate change across all problematic receptors (some of which are located within close proximity to one another) in this part of the Step 3 analysis. Section VIII of this document provides a more complete picture of the air quality impacts of the final rule.

²⁵⁰ Nonetheless, recognizing the diverse non-EGU industries and emissions units covered in this action and the potential that certain individual facilities and emissions units may face extreme

hardship in meeting the general requirements being finalized in this action, the EPA has provided mechanisms in the regulatory requirements for industrial sources that provide for some flexibility

in the emissions limits based on a demonstration of technical impossibility or extreme economic hardship. *See* section VI.C of this document.

For more information about how this assessment was performed and the results of the analysis for each receptor, refer to the Ozone Transport Policy Analysis Final Rule TSD and to the Ozone AQAT included in the docket for this rule.

3. Combined EGU and Non-EGU Assessment

The EPA used the Ozone AQAT to evaluate the combined impact of these selected stringency levels for both EGUs and non-EGUs on all receptors remaining in the 2026 air quality

modeling base case to inform the air quality effects of the rule and to conduct our over-control analysis. EPA’s evaluation demonstrated air quality improvement at the remaining nonattainment or maintenance receptors outside of California (see section IV.D of this document for receptor details). The EPA estimated that the average air quality improvement at these receptors relative to the engineering analytics base case was 0.66 ppb for emissions reductions commensurate with optimization of existing SCR/SNCRs,

combustion control upgrades, application of new post-combustion control (SCR and SNCR) retrofits at eligible units, and all estimated emissions reductions from the non-EGU industries. Table V.D.3–1 summarizes the results of EPA’s Step 3 evaluation of air quality improvements at these receptors using AQAT. In summary, the collective application of these mitigation measures and emissions reductions are projected to deliver meaningful downwind air quality improvements.

TABLE V.D.3–1—CHANGE IN AIR QUALITY AT RECEPTORS IN 2026 FROM FINAL RULE EGU AND NON-EGU EMISSIONS REDUCTIONS^{a b c}

Sector/technology	Ozone season emissions reductions	Total PPB change across all downwind receptors ^d	Average PPB change across all downwind receptors
EGU (SCR/SNCR optimization + LNB upgrade)	16,282	0.71	0.05
EGU SCR/SNCR Retrofit	55,672	6.34	0.42
Non-EGU Industries	44,616	2.82	0.19
Total		9.87	0.66

Table Notes:

^aAs in prior rules, for the purpose of defining significant contribution at Step 3, the EPA evaluated air quality changes resulting from the application of the emissions reductions in only those states that are linked to each receptor as well as the state containing the receptor. By applying reductions to the state containing the receptor, the EPA ensures that it is accounting for the downwind state’s fair share. In addition, this method holds each upwind state responsible for its fair share of the downwind problems to which it is linked. Reductions made by other states to address air quality problems at other receptors do not increase or decrease this share. The air quality impacts on design values that reflect the emissions reductions in all linked states and associated health and climate benefits are discussed in section VII of this document.

^bThe EPA notes that the design values reflected in Tables V.D.1–1 and –2 correspond to the engineering analysis EGU emissions inventory used in AQAT to determine state-level baseline emissions and reductions at Step 3. These tools are discussed in greater detail in the Ozone Transport Policy Analysis Final Rule TSD. Additionally, these emissions reduction values vary slightly from the technology reduction estimates described in section V.C of this document, as the values here reflect the sum of the final identified stringency for each state (e.g., SCR retrofit potential is not assumed in Alabama, Minnesota, and Wisconsin).

^cThe total and average ppb results from non-EGUs emissions reductions shown here were generated using the Step 3 AQAT methodology consistent with that for EGUs (i.e., including reductions from the state containing the receptor and excluding states that are not explicitly linked to particular receptors). The values shown in Table V.C.2–1 were prepared for the non-EGU screening assessment using a methodology where states within the program make emissions reductions for all receptors. States that contain receptors (i.e., Connecticut and Colorado) that are not linked to other receptors are not assumed to make reductions under that methodology.

^dThe cumulative ppb change only shows the aggregate change across all problematic receptors (some of which are located within close proximity to one another) in this part of the Step 3 analysis. Section VIII of this document provides a picture of the projected air quality impacts of the final rule using modeling techniques that differ from the methodologies employed here.

4. Over-Control Analysis

The EPA applied its over-control test to this same set of aggregated EGU and non-EGU data described in the previous section. The EPA performed air quality analysis using the Ozone AQAT to determine whether the emissions reductions for both EGUs and non-EGUs potentially create an “over-control” scenario. As in prior transport rules following the holdings in *EME Homer City*, overcontrol would be established if the record indicated that, for any given state, there is an identified, less stringent emissions control approach for that state, by which (1) the expected ozone improvements would be sufficient to resolve all of the downwind receptor(s) to which that state is linked; or (2) the expected ozone improvements would reduce the upwind state’s ozone contributions below the screening

threshold (i.e., 1 percent of the NAAQS or 0.70 ppb) to all receptors. In *EME Homer City*, the Supreme Court held that the EPA cannot “require[] an upwind State to reduce emissions by more than the amount necessary to achieve attainment in every downwind State to which it is linked.” 572 U.S. at 521. On remand from the Supreme Court, the D.C. Circuit held that this means that the EPA might overstep its authority “when those downwind locations would achieve attainment even if less stringent emissions limits were imposed on the upwind States linked to those locations.” *EME Homer City II*, 795 F.3d at 127. The D.C. Circuit qualified this statement by noting that this “does not mean that every such upwind state would then be entitled to less stringent emissions limits. Some of those upwind States may still be subject

to the more stringent emissions limits so as not to cause other downwind locations to which those States are linked to fall into nonattainment.” *Id.* at 14–15. Further, as the Supreme Court explained, “while EPA has a statutory duty to avoid over-control, the Agency also has a statutory obligation to avoid ‘under-control,’ i.e., to maximize achievement of attainment downwind.” 572 U.S. at 523. The Court noted that “a degree of imprecision is inevitable in tackling the problem of interstate air pollution” and that incidental over-control may be unavoidable. *Id.* “Required to balance the possibilities of under-control and over-control, EPA must have leeway in fulfilling its statutory mandate.” *Id.*²⁵¹

²⁵¹ Although the Court described over-control as going beyond what is needed to address “nonattainment” problems, the EPA interprets this

Consistent with these instructions from the Supreme Court and the D.C. Circuit, using the Ozone AQAT, the EPA first evaluated whether reductions resulting from the selected control stringencies for EGUs in 2023 and 2026 combined with the emissions reductions selected for non-EGUs in 2026 can be anticipated to resolve any downwind nonattainment or maintenance problems (see the Ozone Transport Policy Analysis Final Rule TSD for details on the construction and application of AQAT).

Similar to our approach in the CSAPR Update and the Revised CSAPR Update, our primary overcontrol assessment examines the receptor changes from the emissions reductions of the upwind states found linked to a receptor. Consistent with prior Rules, EPA also assumed that downwind states that are not upwind states in this rule implement reductions commensurate with the rule's requirements (this treatment applies specifically to Colorado and Connecticut). This configuration effectively presents an equitable representation of the effects of the rule in that linked upwind states do not shift their responsibility to other upwind states linked to different receptors. It also effectively resolves any interdependence and "which state goes first?" questions. Furthermore, the downwind states in which a receptor is located are held to a "fair share" of emissions reductions—*i.e.*, the same level of emissions control stringency that the upwind states must implement.

The EPA also repeated this analysis using an alternative configuration, as described in the Ozone Transport Policy Analysis Final Rule TSD. In this configuration, we looked at the combined effect of the entire program across all linked upwind states on each receptor and did not assume that a downwind state that is not also an upwind state makes any additional emissions reductions beyond the baseline in the relevant year. This configuration effectively isolates how the rule as a whole, and just the rule, will affect air quality and linkages. While the first configuration described is, in the Agency's view, the more appropriate way to evaluate overcontrol, taken together the configurations provide a more robust basis on which to rest our conclusions regarding overcontrol. In any case, as further

holding as not impacting its approach to defining and addressing both nonattainment and maintenance receptors. In particular, the EPA continues to interpret the Good Neighbor provision as requiring it to give independent effect to the "interfere with maintenance" prong. *Accord Wisconsin*, 938 F.3d at 325–27.

illustrated in the Ozone Transport Policy Analysis Final Rule TSD, our analysis under both configurations establishes that there is no overcontrol and so there is no need to reconcile any difference in results between them.

We also looked at the ordering of increments of emissions reduction and have found that it does not matter whether we assume EGU emissions controls would be applied first, followed by non-EGU controls, or vice-versa. For 2023, the question is moot as there are only EGU reductions to examine. For 2026, the analysis showed there would be no overcontrol either way. In 2026, the EPA's overcontrol analysis (as presented here) examined all EGU reductions first and layered in non-EGU reductions in the last step of the overcontrol check. However, the EPA also examined an alternative ordering scenario where the non-EGU reductions were assessed prior to the EGU reductions associated with installation of new SCR post-combustion controls (see the Ozone Transport Policy Analysis Final Rule TSD for details). This ordering did not impact the results of the overcontrol test. The specific results of these analyses are presented in the TSD.

The control stringency selected for 2023 (a representative cost threshold of \$1,800 per ton for EGUs) includes emissions reductions commensurate with optimization of existing SCRs and SNCRs and installation of state-of-the-art combustion controls, is not estimated to change the status of any receptors.²⁵² Thus, the nonattainment or maintenance receptors that the states are linked to remain unresolved. Nor do any states' contribution levels drop below the 1 percent of NAAQS threshold. Thus, the EPA determined that none of the 23 linked states have all of their linkages resolved at the final EGU level of control stringency in 2023, and hence, the EPA finds no over-control in the final level of stringency.

Based on the air quality baseline modeling for 2026, all receptors to which Alabama, Minnesota, and Wisconsin are linked in 2023 are projected to be in attainment in 2026. Therefore, no additional stringency is finalized for EGUs or non-EGUs in those states beyond the 2023 level of stringency. For the remaining 20 states,

²⁵² For purposes of this rule, the violating monitor receptors inform our determinations at Step 1 and 2 by strengthening the analytical basis on which we conclude upwind states are linked in 2023. Because no linkages identified using our air quality modeling methodology resolve in 2023 under the selected control stringency, it is not necessary to evaluate overcontrol with respect to the additional set of violating-monitor receptors.

the selected control stringency beginning in 2026 includes additional EGU controls and the non-EGU emissions reductions.

The EPA assesses air quality impacts and overcontrol in the year 2026 in this final rule, even though the rule accommodates the potential need for individual facilities (both EGU and non-EGU) to have some additional time to come into compliance. The EPA views this additional time to be a reflection of need (based on demonstrated impossibility) that is justified at Step 4 of the interstate transport framework rather than at Step 3. As explained in section VI.A of this document, with respect to EGUs, the EPA extends the full implementation of the SCR retrofit-based reductions across 2026 and 2027 to accommodate any *unit-level* scheduling challenges. However, we find that many sources can meet a three-year installation time and the trading program features and the allowance price will incentivize these reductions to occur as soon as possible. Similarly, with respect to non-EGU industrial sources, the final rule provides limited circumstances for individual facilities to seek and to be granted extensions of time to install required pollution controls and achieve the emissions rates established in this rule based on a showing of necessity. Those circumstances where an extension may be warranted for any specific facility are unknown at this time and will be evaluated through a source-specific application process, where the need for extension can be established with source-specific evidence. See section VI.C of this document. Further, 2026 is the critical analytic year associated with the last full ozone season before the 2027 Serious area attainment date and is the year by which significant contribution must be eliminated if at all possible. Therefore, for purposes of this analysis, the collective *state and regional* representation of these reductions are fully assumed in 2026. The potential ability of both EGU and non-EGU sources to have some amount of additional time beyond 2026 to comply with requirements that we have determined at Step 3 are necessary to eliminate significant contribution does not necessitate evaluating a later year than 2026 for overcontrol. The stringency of the control program does not alter in any year beyond 2026.²⁵³ By

²⁵³ Thus, we note, this circumstance is different than the record on which overcontrol was found in *EME Homer City*. There, CSAPR would have implemented an increase in the emissions control stringency of the rule (as reflected in a change in emissions control stringency expressed as dollars

Continued

fully reflecting all Step 3 emissions reductions in its overcontrol test for 2026, EPA ensures that it is not understating the emissions impact and benefit when performing the test.

The EPA used the Ozone AQAT to evaluate the impact of this selected stringency level (as well as other potential stringency levels) on all receptors remaining in the 2026 air quality modeling base case. This assessment shows that the selected control stringency level is estimated to change the status of three receptors to attainment or maintenance in 2026. Brazoria County, Texas (Monitor ID 480391004); and Galveston County, Texas (Monitor ID 481671034), are estimated to come into attainment. We observe that one of the Fairfield, Connecticut, receptors (Monitor ID 090013007) is estimated to go from nonattainment to maintenance (when EGU emissions reductions with SCR are applied, prior to the application of the non-EGU emissions reductions). This receptor is expected to remain in maintenance even after the application of the non-EGU emissions reductions. Based on these data, EPA finds that all linked states except Arkansas, Mississippi, and Oklahoma are projected to continue to be linked to nonattainment or maintenance receptors after implementation of all identified Step 3 reductions, and hence, the EPA finds no over-control in its determination of that level of stringency for those states. Arkansas, Mississippi, and Oklahoma are linked to at least one of the two Texas receptors that are projected to come into attainment with the full implementation of the control strategy at Step 3. However, these two Texas receptors are expected to remain as maintenance-only receptors prior to the final increment of reductions assessed (the addition of the non-EGU reductions), so EPA concludes that imposition of the incremental non-EGU

per ton from \$100/ton to \$500/ton). That change in stringency marked a determination that EPA had made at Step 3 regarding the degree of emissions reduction that sources needed to achieve beginning in 2014. But in that year, the court found EPA's record to reveal that certain states would not need to go up to that higher level of stringency because air quality problems and/or linkages were already projected to be resolved at the lower level of stringency. See 795 F.3d at 128–30. The analogous year to 2014 here is 2026. The stringency level of this control program does not change post-2026. Nor do we think individual sources should gain the benefit of delaying emissions reductions simply in the hopes that they could show those reductions would be overcontrol; each source must be held to the elimination of its portion of significant contribution. Necessity may demand some additional amount of time for compliance, but equity demands that individual sources not gain an untoward advantage from delay and reliance on other sources' timelier compliance.

level is appropriate to avoid under-control as to these states and does not constitute overcontrol.²⁵⁴

Next, the EPA evaluated the potential for over-control with respect to the 1 percent of the NAAQS threshold applied in this final rulemaking at Step 3 of the good neighbor framework, assessed for the selected control stringencies for each state for each period that downwind nonattainment and maintenance problems persist (*i.e.*, 2023 and 2026). Specifically, the EPA evaluated whether the selected control stringencies would reduce upwind emissions to a level where the contribution from any of the 23 linked states in 2023 or 20 linked states in 2026 would be below the 1 percent threshold. The EPA finds that for the mitigation measures assumed in 2023 and in 2026, all states that contributed greater than or equal to the 1 percent threshold in the base case are projected to continue to contribute greater than or equal to 1 percent of the NAAQS to at least one remaining downwind nonattainment or maintenance receptor for as long as that receptor remained in nonattainment or maintenance. EPA notes that in 2026, for Oklahoma, when the incremental level of stringency associated with the non-EGU control strategy is applied, Oklahoma's contribution to Galveston County Texas is expected to drop below the 1 percent threshold (at the same time that the receptor has its maintenance problems resolved). EPA concludes that this does not constitute overcontrol because both the receptor and the contribution are estimated to remain above the maintenance level and linkage threshold at the prior level of stringency and, thus, since otherwise justified at Step 3, the full stringency for 2026 is appropriate to avoid under-control. For more information about this assessment, refer to the Ozone Transport Policy Analysis Final Rule TSD and the Ozone AQAT.

Therefore, EPA finds that all of the selected EGU and non-EGU NO_x reduction strategies selected in EPA's Step 3 analysis can be applied to all states linked in 2026 to eliminate significant contribution to nonattainment and interference with maintenance of the 2015 ozone NAAQS without introducing an overcontrol

²⁵⁴ Even with full implementation of the rule, these two receptors are only projected to come into attainment by a relatively small degree, and no policy option is ascertained in the record by which attainment could be achieved to an even lesser degree. Nonetheless, the EPA further evaluated whether there were any overcontrol concerns through sensitivity analyses. Under all scenarios, the EPA finds there is no overcontrol. See the Ozone Transport Policy Analysis Final Rule TSD for more discussion and analysis.

problem based on the present record. The Supreme Court has directed the EPA to avoid both over-control and under-control in addressing good neighbor obligations. In addition, the D.C. Circuit has reinforced that over-control must be established based on particularized, record evidence on an as-applied basis.

The determination that the stringency of this action does not constitute overcontrol for any linked state is further reinforced by EPA's observation in section III.A of this document regarding the nature of the ozone problem. Ozone levels are known to vary, at times dramatically, from year to year. Future ozone concentrations and the formation of ground level ozone may also be impacted by factors in future years that the EPA cannot fully account for at present. For example, changes to meteorological conditions could affect future ozone levels. Climate change could also contribute to higher than anticipated ozone levels in future years through wildfires and heat waves, which can contribute directly and indirectly to higher levels of ozone. Any modeling projection can be characterized as having some uncertainty, and that is not a sufficient reason to ignore modeling results. However, in the context of the overcontrol test, the question is whether it is clear according to particularized evidence that there is no need for the emissions reductions in question. See *EME Homer City*, 572 U.S. at 523 (“[A] degree of imprecision is inevitable in tackling the problem of interstate air pollution. Slight changes in wind patterns or energy consumption, for example, may vary downwind air quality in ways EPA might not have anticipated.”). Under this standard, the degree of attainment that is projected to occur under the rule in relation to the Texas receptors discussed above is not so large or certain to occur that it would be appropriate to attempt to devise a less stringent emissions control strategy for the relevant linked states as a result, particularly in light of the fact that at the penultimate stringency level the receptors are not resolved.

It is also possible that ozone-precursor emissions from certain sources may decline beyond what we currently project in this rule. For example, the IRA may result in reductions in fossil-fuel fired generation, which should in turn result in lower NO_x emissions during the ozone season.²⁵⁵ We have

²⁵⁵ As discussed in section IV.C.2.b, there are also potential ways in which the IRA may not necessarily result in reductions in NO_x emissions from EGUs.

assessed this scenario to ensure our overcontrol conclusions are robust even if the IRA has those effects. As discussed in the Regulatory Impact Analysis, the EPA conducted additional modeling of the final policy scenario (inclusive of economically efficient methods of compliance available within the Step 4 implementation programs) using its IPM tool. The EPA observes that the differences in estimated costs and emissions reductions in the IRA sensitivity (presented in Appendix 4A of the RIA) suggests that there would also be differences in estimated health and climate benefits under that scenario, although the Agency did not have time under this rulemaking schedule to quantify those differences. The EPA also used AQAT to conduct an additional EGU modeling sensitivity reflecting the IRA. Both the IPM sensitivity and the corresponding AQAT assessment of the IRA scenarios demonstrated no overcontrol as every state linkage to a downwind problematic receptor persisted in the penultimate level of stringency when EPA performed its Step 3 evaluation—even when the impacts of the IRA are incorporated. This further affirmed EPA's conclusion of no overcontrol concerns at the stringency level of the final rule. This overcontrol sensitivity is further discussed in the Ozone Transport Policy Analysis Final Rule TSD, Appendix K.

In light of the mandate of the CAA to protect the public health and environment through the elimination of significant contribution under the Good Neighbor Provision for the 2015 ozone NAAQS, nothing in the present record establishes on an as-applied, particularized basis that this rule will result in an unnecessary degree of control of upwind-state emissions.

Comment: Many commenters alleged that the rule overcontrols emissions by more than necessary to eliminate significant contribution for the 2015 ozone NAAQS, on the basis that the emissions reductions are unnecessary or are unnecessarily stringent.

Response: As discussed earlier in this section, EPA has analyzed whether this rule “overcontrols” emissions and has found based on a robust, multi-faceted analysis, that it does not. In particular, EPA has not identified a lesser-stringency emissions control strategy for any state that would either fully resolve the air quality problems at a downwind receptor location or resolve that upwind state's linkage to a level below the 1 percent of NAAQS contribution threshold. No commenter has provided a particularized, as-applied analysis demonstrating that EPA's emissions

control strategy will actually result in any overcontrol of emissions in the manner the EPA or courts have understood that term, and overcontrol allegations must be proven through particularized, as-applied challenges. *See EME Homer City*, 795 F.3d at 127; *see also Wisconsin*, 938 F.3d at 325 (“[T]he way to contest instances of overcontrol is not through generalized claims that EPA's methodology would lead to over-control, but rather through a ‘particularized, as-applied challenge.’” Accordingly, as we did when presented with similar arguments in *EME Homer III*, we reject Industry Petitioners' arguments because they do no more than speculate that aspects of ‘EPA's methodology *could* lead to over-control of upwind States.’”) (cleaned up) (citing *EME Homer City*, 795 F.3d at 136–137).

Comment: For 2 of the 20 states linked in 2026, Arkansas and Mississippi, the last downwind receptor to which these two states are linked (*i.e.*, Brazoria County, Texas) was estimated to achieve attainment and maintenance after full application of EGU reductions and Tier 1 non-EGU reductions at proposal. Commenters noted that this suggested application of the estimated non-EGU, and/or some EGU, emissions reductions constituted over-control for these states.

Response: EPA notes that at proposal, this downwind receptor only resolved by a small margin after the application of all EGU and Tier 1 non-EGU emissions reductions. As explained earlier in this section, the final rule air quality modeling shows that the receptors to which these states are linked do not resolve upon full implementation of the identified EGU reductions by themselves, and only reach attainment by a small degree following the additional reductions from the non-EGU control strategy.²⁵⁶ If the EPA were to select the control stringency of this penultimate step, both upwind-state contribution and downwind-state air quality receptors would persist while the cost-effective emissions reductions that were identified to eliminate significant

²⁵⁶ Because in the final record we do not identify cost, air quality, and emission reduction factors that sufficiently differentiate either source-type or emissions control strategy among the Tier 1 and Tier 2 industries identified at proposal, we combined the non-EGU industries and emissions reductions into one group, and we are finalizing requirements for all non-EGU industries and most emissions unit types identified at proposal. In light of the small degree to which the relevant receptors reach attainment and the multi-faceted assessment of overcontrol we have undertaken, the overcontrol assessment with respect to non-EGUs in the final rule is sufficient to establish that there is no overcontrol.

contribution remain available but unimplemented. This would constitute under-control. Consequently, as described, the EPA views the control stringency required of these states in this final rule as not constituting over-control and appropriate to eliminate significant contribution to nonattainment and interference with maintenance of this NAAQS in line with our Step 3 determinations for all other states. See the Ozone Transport Policy Analysis Final Rule TSD section C.3 for discussion and analysis regarding overcontrol for states solely linked to one or both of these receptors.

Comment: Commenters raised a variety of arguments that the enhancements to the EGU trading program in this action will result in overcontrol of power plant emissions. They alleged that dynamic budgeting would cause the budget to continually decrease even after significant contribution is eliminated. They similarly argue that annual emissions bank recalibration and the emissions backstop emissions rate have not been shown to be justified to eliminate significant contribution.

Response: This final rule's determination regarding the appropriate level of control stringency for EGUs finds that the amounts of NO_x emissions reduction achieved through these strategies at EGUs are appropriate and cost-justified under the Step 3 multifactor analysis. These determinations are associated with particular emissions control technologies and strategies as detailed in sections V.B.1 and V.C.1 above. It is the implementation of those strategies at the covered EGU sources and the air quality effects of those strategies (coupled with non-EGUs) in the relevant analytic year of 2026 on which we base our determination of significant contribution at Step 3. This includes the evaluation of whether there is overcontrol, which is also conducted for the 2026 analytic year as explained above. As explained below, we disagree that the enhancements to the trading program at Step 4 implicate the need for further overcontrol analysis. These enhancements operate together to ensure the trading program continues to maintain the Step 3 emissions control stringency over time. These enhancements reflect lessons learned through EPA's experience with prior trading programs implemented under the good neighbor provision. None of commenters' arguments that these enhancements result in overcontrol are persuasive.

Commenters contend that these enhancements to the trading program go

beyond a mass-based budget approach as applied in CSAPR. Because these improvements in the program result in a continuing incentive for each covered EGU source to maintain the pollution control performance the EPA found appropriate to eliminate significant contribution at Step 3, commenters believe these enhancements must necessarily result in prohibited overcontrol. These arguments appear to be premised on the assumption that overall emissions may later decline to such a point that there is no longer a linkage between a particular state and any downwind receptors for reasons other than the requirements of this rule.

As an initial matter, no commenter has provided an empirical analysis demonstrating that the control stringency identified at Step 3 to eliminate significant contribution would actually result in any overcontrol. The case law is clear that over-control allegations must be proven through particularized, as-applied challenges. See prior response to comments. More importantly here, the Group 3 trading program enhancements do not impose increased stringency in years after 2030 and do not force emissions to continually be reduced to ever lower levels. They are only designed to incentivize the implementation of the Step 3 emissions control stringency that eliminates significant contribution. The circumstances that could potentially cause a receptor or linkage to resolve at some point in the future after 2026 are not circumstances that are within the power of this rule to control. Nor would those circumstances present a justification as to why upwind sources should no longer be obligated to eliminate their own significant contribution. *Wisconsin*, 938 F.3d at 324–25 (rejecting overcontrol arguments premised on attributing air quality problems to other emissions).

Further, the EPA is not constrained by the statute to only implement good neighbor obligations through fixed, unchanging, mass-based emissions budgets. See section III.B.1 of this document. The EPA has defined the “amount” of emissions that must be prohibited to eliminate significant contribution in this action based on a series of determinations of which emissions control strategies, for certain identified EGU and non-EGU sources, are appropriate applying the Step 3 multifactor analysis. Notably, the non-EGU industrial source emissions reductions in this action are *not* being achieved at Step 4 through mass-based emissions trading, nor are they required to be by any provision of the CAA. See section III.B.1.

As explained in sections III.B.1.d and VI.B.1 of this document, the EPA finds good reason based on its experience with trading programs that using fixed, mass-based, ozone-season wide budgets does not necessarily ensure the elimination of significant contribution over the entire region of linked states or throughout each ozone season. Even in the original CSAPR rulemaking, which promulgated only fixed, mass-based budgets, such outcomes were never the EPA’s intention to allow. See, e.g., 76 FR 48256–57 (“[I]t would be inappropriate for a state linked to downwind nonattainment or maintenance areas to stop operating existing pollution control equipment (which would increase their emissions and contribution).”). Despite the EPA’s expectations in CSAPR, the experience of the Agency since that time establishes a real risk of “under-control” if the existing trading framework is not enhanced. See *EME Homer City*, 572 U.S. at 523 (“[T]he Agency also has a statutory obligation to avoid ‘under-control,’ i.e., to maximize achievement of attainment downwind.”).

Further, the EPA has already once adjusted its historical approach to better account for known, upcoming changes in the EGU fleet to ensure mass-based emissions budgets adequately incentivize the control strategy determined at Step 3. This adjustment was introduced in the Revised CSAPR Update. See 82 FR 23121–22. The EPA now believes it is appropriate to ensure in a more comprehensive manner, and in perpetuity, that a mass-based emissions-trading framework incentivizes continuing implementation of the Step 3 control strategies to ensure significant contribution is eliminated in all upwind states and remains so. This is fully analogous in material respect to an approach to implementation at Step 4 that relies on application of unit-specific emissions limitations, which under the Act would typically apply in perpetuity and may only be modified through a future SIP- or FIP-revision rulemaking process. See CAA section 110(i) prohibiting modifications to implementation plan requirements except by enumerated processes. The availability of unit-specific emissions rates as a means to eliminate significant contribution is discussed in further detail in section III.B.1 of this document. The EPA also explained this in the proposal. See 87 FR 20095–96.

Further, these enhancements are directly related to assisting downwind areas specifically with the goal of attaining and maintaining the 2015 8-hour ozone NAAQS. In this respect, they are not “unnecessary” or

“unrelated” to carrying out the mandates of CAA section 110(a)(2)(D)(i)(I). Taking measures to ensure that each upwind source covered by an emissions trading program is adequately incentivized to eliminate excessive emissions (as found at Step 3) throughout the entirety of each ozone season is entirely appropriate in light of the nature of the ozone problem. Ozone exceedances recur on varying days throughout the summertime ozone season, and it is not possible to predict in advance which specific days will have high ozone. Further, impacts to public health and the environment from ozone can occur through short-term exposure (e.g., over a course of hours, i.e., on a daily basis). The 2015 ozone NAAQS is expressed as an 8-hour average, and only a small number of days in excess of the ozone NAAQS can cause a downwind area to be in nonattainment. Thus, even a small number of exceedances can result in continuing and/or increased regulatory burdens on the downwind jurisdiction. Taking these considerations into account, it is evident that a fixed, mass-based emissions program that does not adequately incentivize emissions reductions commensurate with our Step 3 determinations on each day of every ozone season going forward does not provide a sufficient guarantee that the emissions that significantly contribute on those particular days and at particular receptor locations when ozone levels are at risk of exceeding the NAAQS have been eliminated. See section V.B.1.a and VI.B of this document for more discussion of data observations regarding SCR optimization.

These enhancements are also consistent with the general policies and principles EPA has long applied in implementing the NAAQS through the SIP/FIP framework of section 110. Emissions control measures relied on to meet CAA requirements must be permanent and enforceable and included in the implementation plan itself. See, e.g., *Montana Sulfur & Chem. Co. v. EPA*, 666 F.3d 1174, 1196 (9th Cir. 2012); 40 CFR 51.112(a). In the General Preamble laying out EPA’s plans for implementing the 1990 CAA Amendments, the EPA identified a core “principle” that control strategies should be “accountable.” “This means, for example, that source-specific limits should be permanent and must reflect the assumptions used in the SIP demonstrations.” 57 FR 13498, 13568 (April 16, 1992). EPA went on, “The principles of quantification, enforceability, replicability, and

accountability apply to all SIPs and control strategies, including those involving emissions trading, marketable permits and allowances.” *Id.* EPA also explained that its “emissions trading policy provides that only trades producing reductions that are surplus, enforceable, permanent, and quantifiable can get credit and be banked or used in an emissions trade.” *Id.* These principles follow from the language of the Act, including CAA section 110(a)(2), 107(d)(3)(E)(iii), 110(i), and 110(l). These provisions and principles further underscore the importance of ensuring that the emissions reductions the EPA has found necessary to eliminate significant contribution are in fact implemented on a consistent and permanent basis even within the context of an emissions trading program.

The EPA disagrees that the budget adjustments that would occur over time under this final rule (for example, the annual dynamic-budget adjustment) must be reassessed each time they occur through notice and comment rulemaking under CAA section 307(d). This would serve no purpose. The formulas that the EPA will apply to adjust the budgets and allowance bank are set in this final rule and are intended to maintain, not increase (or decrease), program stringency. While the EPA intends to provide an opportunity for stakeholders to review and propose corrections to its data as it implements the established budget formulas, no larger reassessment of the emissions control program is needed on an ongoing basis, because, again, that program is simply calibrated to ensure that emissions reductions commensurate with the determination of “significance” in Step 3 continue to be obtained over the long term. As described earlier, these trading program provisions are analogous to, or mimic, the effect of unit-specific emissions limitations that apply in perpetuity.²⁵⁷

Commenters also confuse the “amount” of emissions that must be eliminated under CAA section 110(a)(2)(D)(i)(I) as being synonymous with a fixed, mass-based budget that reflects the residual emissions allowed following the elimination of significant contribution. However, EPA views the “amount” to be eliminated as those emissions that are in excess of the cost-

effective emissions control strategies identified in Step 3. This is further explained in section III.B.1 of this document.

Thus, this rule is in compliance with the overcontrol principles that the D.C. Circuit applied on remand in *EME Homer City* to find certain instances of overcontrol in CSAPR’s emissions control strategies. The D.C. Circuit found that EPA had imposed more stringent emissions-control strategies for certain states than were necessary to resolve all of those states’ linkages. 795 F.3d at 128–30. Specifically, for sulfur dioxide, the court found certain receptors would reach attainment if all linked upwind states had implemented “cost controls” at \$100/ton or \$400/ton, rather than EPA’s selected stringency level of \$500/ton. Similarly, for ozone season NO_x, the court found that receptors were projected to attain the NAAQS at stringencies below \$500/ton. The court’s focus was on the stringency of the emissions control obligations as determined through the application of cost thresholds at Step 3 of the analysis. The court did not hold that EPA may only use fixed, mass-based budgets to implement those reductions. The court did not hold that EPA must permit individual polluting sources to be allowed to increase their emissions at some point in the future. The court did not hold that EPA’s good neighbor FIPs must, effectively, contain termination clauses, such that they cease to ensure the implementation of the control stringency determined as necessary at Step 3, the moment a downwind receptor reaches attainment. Indeed, such a rule would contravene the statute’s clear, forward-looking directive that EPA must also eliminate upwind emissions that interfere with maintenance of the NAAQS; see *North Carolina*, 531 F.3d at 908–911; *Wisconsin*, 938 F.3d at 325–26.

The *EME Homer City* court on remand in fact rejected various arguments that other aspects of EPA’s emissions control strategy in CSAPR resulted in overcontrol, holding that EPA had properly given effect to the interfere with maintenance prong, and noting that petitioners failed to make out proven, as-applied demonstrations of overcontrol:

At bottom, each of those claims is an argument that EPA’s methodology could lead to over-control of upwind States that are found to interfere with maintenance at a downwind location. That could prove to be correct in certain locations. But the Supreme Court made clear in *EME Homer* that the way to contest instances of over-control is not through generalized claims that EPA’s methodology would lead to over-control, but

rather through a “particularized, as-applied challenge.” *EME Homer*, 134 S. Ct. at 1609, slip op. at 31. And petitioners do not point to any actual such instances of over-control at downwind locations.

795 F.3d at 137. The court went on to observe, “EPA may only limit emissions ‘by just enough to permit an already-attaining State to maintain satisfactory air quality.’ If States have been forced to reduce emissions beyond that point, affected parties will have meritorious as-applied challenges.” *Id.* (quoting 572 U.S. at 521–22). But this too was not a holding that EPA may not ensure effective and permanent implementation of an emissions control stringency that EPA has found warranted under CAA section 110(a)(2)(D)(i)(I). Such an approach is available through the more conventional CAA practice of setting unit-specific emissions limitations that would apply on a permanent and enforceable basis. See CAA sections 110(a)(2) and 302(y) (providing for SIPs and FIPs to include “enforceable emissions limitations” in addition to economic incentive measures like trading programs).²⁵⁸ This is in fact how EPA intends to ensure significant contribution is eliminated from non-EGU industrial sources for which a mass-based trading regime is, at least at the present time, unworkable (see section VI.C of this document). And EPA has provided for the elimination of significant contribution through source-specific emissions limitations in prior transport actions as well, so this position is not novel. See section III.B of this document.

Nonetheless, EPA recognizes that under the Act, both FIPs and SIPs may be revised, and states may replace FIPs with SIPs if EPA approves them. Any such revision must be evaluated to ensure no applicable CAA requirements are interfered with. See, e.g., *Indiana v. EPA*, 796 F.3d 803 (7th Cir. 2015). For example, states may be able to demonstrate in the future that through some other permanent and enforceable methods of emissions reduction that they have adopted into their SIP, they will be able to achieve a similar emissions control stringency with different emissions reduction requirements imposed on different sources as compared to the FIPs finalized in this action. See section VI.D of this document.

Therefore, commenters’ contentions that EPA’s trading program enhancements result in prohibited

²⁵⁷ We note further that because all of the trading program provisions, including the dynamic budget-setting provisions and process, are established by this final FIP rulemaking, the ministerial future-year budget adjustment process complies with the CAA section 110(i) prohibition on modification of implementation plan requirements except by enumerated process.

²⁵⁸ “Emissions limitation” is in turn defined at CAA section 302(k) as a “requirement . . . which limits the quantity, rate, or concentration of emissions of air pollutants on a continuous basis. . . .”

overcontrol are not proven through as-applied, particularized challenges, and they are premised on an incorrect understanding of the CAA and the relevant case law. The Agency rejects the contention that it must somehow provide in the present FIP action for a relaxation in the stringency of the Step 4 implementation program and thus allow for the recurrence of pollution that we have found here, in this action, significantly contributes to downwind ozone nonattainment and maintenance problems.

VI. Implementation of Emissions Reductions

A. NO_x Reduction Implementation Schedule

This action will ensure that emissions reductions necessary to eliminate significant contribution will be achieved “as expeditiously as practicable” and no later than the downwind attainment dates except where compliance by those dates is not possible. See CAA section 181(a); *Wisconsin*, 938 F.3d at 318–20. The timing of this action will provide for all possible emissions reductions to go into effect beginning in the 2023 ozone season for the covered states, which is aligned with the next upcoming attainment date of August 3, 2024, for areas classified as Moderate nonattainment under the 2015 ozone standard. Additional emissions reductions that the EPA finds not possible to implement by that attainment date will take effect as expeditiously as practicable. Emissions reductions commensurate with SCR mitigation measures for EGUs will start in 2026 and be fully implemented by 2027. Emissions reductions through the mitigation measures for industrial sources will generally go into effect in 2026; however, as explained in section VI.C of this document, we have provided for case-by-case extensions of up to one year based on a demonstration of necessity (with the potential for up to an additional two years based on a further demonstration). The full suite of emissions reductions is generally anticipated to take effect by the 2027 ozone season, which is aligned with the August 3, 2027, attainment date for areas classified as Serious nonattainment under the 2015 ozone NAAQS. This rule constitutes a full remedy for interstate transport for the 2015 ozone NAAQS for the states covered; the EPA does not anticipate further rulemaking to address good neighbor obligations under this NAAQS will be required for these states with the finalization of this rule.

EPA’s determinations regarding the timing of this rule are informed by and in compliance with several recent court decisions. The D.C. Circuit has reiterated several times that, under the terms of the Good Neighbor Provision, upwind states must eliminate their significant contributions to downwind areas “consistent with the provisions of [title I of the Act],” including those provisions setting attainment deadlines for downwind areas.²⁵⁹ In *North Carolina*, the D.C. Circuit found the 2015 compliance deadline that the EPA had established in CAIR unlawful in light of the downwind nonattainment areas’ 2010 deadline for attaining the 1997 NAAQS for ozone and PM_{2.5}.²⁶⁰ Similarly, in *Wisconsin*, the Court found the CSAPR Update unlawful to the extent it allowed upwind states to continue their significant contributions to downwind air quality problems beyond the downwind states’ statutory deadlines for attaining the 2008 ozone NAAQS.²⁶¹ In *Maryland*, the Court found the EPA’s selection of a 2023 analysis year in evaluating state petitions submitted under CAA section 126 unlawful in light of the downwind Marginal nonattainment areas’ 2021 deadline for attaining the 2015 ozone NAAQS.²⁶² The Court noted in *Wisconsin* that the statutory command—that compliance with the Good Neighbor Provision must be achieved in a manner “consistent with” title I of the CAA—may be read to allow for some deviation from the mandate to eliminate prohibited transport by downwind attainment deadlines, “under particular circumstances and upon a sufficient showing of necessity,” but concluded that “[a]ny such deviation would need to be rooted in Title I’s framework” and would need to “provide a sufficient level of protection to downwind States.”²⁶³

1. 2023–2025: EGU NO_x Reductions Beginning in 2023

The near-term EGU control stringencies and corresponding

²⁵⁹ *North Carolina v. EPA*, 531 F.3d 896 (D.C. Cir. 2008), *Wisconsin v. EPA*, 938 F.3d 303 (D.C. Cir. 2019), and *Maryland v. EPA*, 958 F.3d 1185 (D.C. Cir. 2020).

²⁶⁰ *North Carolina*, 531 F.3d at 911–913.

²⁶¹ *Wisconsin*, 938 F.3d at 303, 3018–20.

²⁶² *Maryland*, 958 F.3d at 1203–1204. Similarly, in *New York v. EPA*, 964 F.3d 1214 (D.C. Cir. 2020), the Court found the EPA’s selection of a 2023 analysis year in evaluating New York’s section 126 petition unlawful in light of the New York Metropolitan Area’s 2021 Serious area deadline for attaining the 2008 ozone NAAQS. 964 F.3d at 1226 (citing *Wisconsin* and *Maryland*).

²⁶³ *Wisconsin*, 938 F.3d at 320 (citing CAA section 181(a) (allowing one-year extension of attainment deadlines in particular circumstances) and *North Carolina*, 531 F.3d at 912).

reductions in this rulemaking cover the 2023, 2024, and 2025 ozone seasons. This is the period in which some reductions will be available, but the portion of full remedy reductions related to post combustion control installation identified in sections V.B through V.D of this document are not yet available. The EGU NO_x mitigation strategies available during these initial 3 years are the optimization of existing post-combustion controls (SCRs and SNCRs) and combustion control upgrades. As described in sections V.B through V.D of this document and in accompanying TSDs, these mitigation measures can be implemented in under two months in the case of existing control optimization and in 6 months in the case of combustion control upgrades. These timing assumptions account for planning, procurement, and any physical or structural modification necessary. The EPA provides significant historical data, including the implementation of the most recent Revised CSAPR Update, as well as engineering studies and input factor analysis documenting the feasibility of these timing assumptions. However, these timing assumptions are representative of fleet averages, and the EPA has noted that some units will likely overperform their installation timing assumptions, while others may have unit configuration or operational considerations that result in their underperforming these timing assumptions. As in prior interstate transport rules, the EPA is implementing these EGU reductions through a trading program approach. The trading program’s option to buy additional allowances provides flexibility in the program for outlier sources that may need more time than what is representative of the fleet average to implement these mitigation strategies while providing an economic incentive to outperform rate and timing assumptions for those sources that can do so. In effect, this trading program implementation operationalizes the mitigation measures as state-wide assumptions for the EGU fleet rather than unit-specific assumptions.

However, starting in 2024, as described in section VI.B.7 of this document, unit-specific backstop daily emissions rates are applied to coal units with existing SCR at a level consistent with operating that control. The EPA believes that implementing these emissions reductions through state emissions budgets starting in 2023 while imposing the unit-specific backstop emissions rates in 2024 achieves the necessary environmental

performance as soon as possible while accommodating any heterogeneity in unit-level implementation schedules regarding daily operation of optimized SCRs.

Additionally, as in prior rules, the EPA assumes combustion control upgrade implementation may take up to 6 months. In the Revised CSAPR Update, covering 12 of the 22 states for which emissions reduction requirements for EGUs are established under this action, the EPA finalized the rule in March of 2021 and thus did not require these combustion control-based emissions reductions in ozone-season state emissions budgets until 2022 (year two of that program).²⁶⁴ The EPA is applying the same timing assumption regarding combustion control upgrades for this rulemaking. Given the same relationship here between the date of final action and the year one ozone season, the EPA is not assuming the implementation of any additional combustion control upgrades in state emissions budgets until year two (*i.e.*, the 2024 ozone season). Any identified combustion control upgrade emissions reductions are reflected beginning in the 2024 ozone-season budgets for all covered states. For the 12 states covered under the Revised CSAPR Update, any identified emissions reduction potential from combustion control upgrade is included and reflected in those state budgets beginning in 2024—which means EGUs in those states have even more time than the 14 months between finalization of this rule and the 2024 ozone season if they started any planning or installation earlier in response to the Revised CSAPR Update.

2. 2026 and Later Years: EGU and Stationary Industrial Source NO_x Reductions Beginning in 2026

The EPA finds that it is not possible to implement all necessary emissions controls across all of the affected EGU and non-EGU sources by the August 3, 2024, Moderate area attainment date. In accordance with the good neighbor provision and the downwind attainment schedule under CAA section 181 for the 2015 ozone NAAQS, the EPA is aligning its analysis and implementation of the emissions reductions addressing significant contribution from EGU and non-EGU sources that require relatively longer lead time at a sectoral scale with the 2026 ozone season. The 2026 ozone season is the last full ozone season that precedes the August 3, 2027, Serious area attainment date for the 2015 ozone

NAAQS.²⁶⁵ The EPA proposed to require compliance with all of the remaining EGU and non-EGU control requirements beginning in the 2026 ozone season. The EPA continues to find 2026 to be the relevant analytic year for purposes of its Step 3 analysis, including its analysis of overcontrol, as discussed in section V.D.4 of this document. However, many commenters argued that full implementation of the EGU and industrial source control strategies is not feasible for every source by the 2026 ozone season. The EPA addresses these technical comments specifically in sections V.B and VI.C of this document. The EPA also commissioned a study to develop a better understanding of the time needed for installation of emissions controls for the industrial sector units covered in this rule, which is included in the docket and discussed in section VI.A.2.b of this document. While the EPA does not agree with all of the commenters' assertions regarding the time they claim is needed for control installation, in other respects the concerns raised were sufficient to justify some adjustments to the compliance schedule for the final rule. We have provided for the emissions reductions commensurate with assumed EGU post-combustion emissions control retrofits to be phased in over the 2026 and 2027 ozone season emissions budgets, and we have provided a process in the final regulations for individual non-EGU industrial sources to seek limited compliance extensions extending no later than 2029 based on a case-by-case demonstration of necessity. This compliance schedule delivers substantial emissions reductions in the 2026 and 2027 ozone seasons and before the 2027 Serious area attainment date, and it only allows compliance extensions beyond that attainment date based on a rigorous, source-specific demonstration of need for the additional time.²⁶⁶

²⁶⁵ For each nonattainment area classified under CAA section 181(a) for the 2015 ozone NAAQS, the attainment date is "as expeditiously as practicable" but not later than the date provided in table 1 to 40 CFR 51.1303(a). Thus, for areas initially designated nonattainment effective August 3, 2018 (83 FR 25776), the latest permissible attainment dates are: August 3, 2021 (for Marginal areas), August 3, 2024 (for Moderate areas), August 3, 2027 (for Serious areas), and August 3, 2033 (for Severe areas).

²⁶⁶ While we generally use the term "necessity" to describe the showing that non-EGU facilities must meet in seeking compliance extensions, the elements for this showing are designed to allow the EPA to make a judgment that comports with the standard of "impossibility" established in case law such as *Wisconsin*. In other words, the "necessity" for additional time is effectively a showing by the source that it would be "impossible" for it to meet the compliance deadline.

The timing of this final rule provides three to four years for EGU and non-EGU sources to install whatever controls they deem suitable to comply with required emissions reductions by the start of the 2026 and 2027 ozone seasons. In addition, the publication of the proposal provided roughly an additional year of notice to these source owners and operators that they should begin engineering and financial planning (steps that can be taken prior to any capital investment) to be prepared to meet this implementation timetable.

The EPA views this timeframe for retrofitting post-combustion NO_x emissions controls and other non-EGU controls to be reasonable and achievable. A 3-year period for installation of control technologies is consistent with the statutory timeframe for implementation of the controls required to address interstate pollution under section 110(a)(2)(D) and 126 of the Act, the statutory timeframes for implementation of RACT in ozone nonattainment areas classified as Moderate or above, and other statutory provisions that establish control requirements for existing stationary sources of pollution.

For example, section 126 of the CAA authorizes a downwind state or tribe to petition the EPA for a finding that emissions from "any major source or group of stationary sources" in an upwind state contribute significantly to nonattainment in, or interfere with maintenance by, the downwind state. If the EPA makes a finding that a major source or a group of stationary sources emits or would emit pollutants in violation of the relevant prohibition in CAA section 110(a)(2)(D), the source(s) must shut down within three months from the finding unless the EPA directly regulates the source(s) by establishing emissions limitations and a compliance schedule extending no later than three years from the date of the finding, to eliminate the prohibited interstate transport of pollutants as expeditiously as practicable.²⁶⁷ Thus, in the provision that allows for direct Federal regulation of sources violating the good neighbor provision, Congress established three years as the maximum amount of time available from a final rule to when emissions reductions need to be achieved at the relevant source or group of sources. Because this action is not taken under CAA section 126(c), the mandatory timeframe for implementation of emissions controls

²⁶⁷ CAA 110(a)(2)(D)(i) and 126(c).

²⁶⁴ 86 FR 23093.

under that provision is not directly applicable, but it is informative.

In response to arguments from sources that more time than has been provided in the final rule is necessary, this provision strongly indicates that allowing time beyond a three-year period must be based on a substantial showing of impossibility. Our analysis based on comments and considering additional information is that the additional time we have provided in the final rule is both justified and sufficient in light of the statutory objective of expeditious compliance.

Additionally, for ozone nonattainment areas classified as Moderate or higher, the CAA requires states to implement RACT requirements less than three years after the statutory deadline for submitting these measures to the EPA.²⁶⁸ Specifically, for these areas, CAA sections 182(b)(2) and 182(f) require that states implement RACT for existing VOC and NO_x sources as expeditiously as practicable but no later than May 31, 1995, approximately 30 months after the November 15, 1992, deadline for submitting RACT SIP revisions. For purposes of the 2015 ozone NAAQS, the EPA has interpreted these provisions to require implementation of RACT SIP revisions as expeditiously as practicable but no later than January 1 of the fifth year after the effective date of designation, which is less than three years after the deadline for submitting RACT SIP revisions.²⁶⁹ For areas initially designated nonattainment with a Moderate or higher classification effective August 3, 2018 (83 FR 25776), that implementation deadline falls on January 1, 2023, approximately 29 months after the August 3, 2020

²⁶⁸ See, e.g., 40 CFR 51.1112(a)(3) and 51.1312(a)(3)(i) (requiring implementation of RACT required pursuant to initial nonattainment area designations no later than January 1 of the fifth year after the effective date of designation, which is less than 3 years after the SIP submission deadline under 40 CFR 51.1112(a)(2) and 51.1312(a)(2)(i), respectively).

²⁶⁹ 40 CFR 51.1312(a)(2)(i) (requiring submission of RACT SIP revisions no later than 24 months after the effective date of designation) and 40 CFR 51.1312(a)(3)(i) (requiring implementation of RACT SIP revisions as expeditiously as practicable, but no later than January 1 of the fifth year after the effective date of designation). For reclassified areas, states must implement RACT SIP revisions as expeditiously as practicable, but no later than the start of the attainment year ozone season associated with the area's new attainment deadline, or January 1 of the third year after the associated SIP revision submittal deadline, whichever is earlier; or the deadline established by the Administrator in the final action issuing the area reclassification. 40 CFR 51.1312(a)(3)(ii); see also 83 FR 62989, 63012–63014.

submission deadline.²⁷⁰ Moderate ozone nonattainment areas must also implement all reasonably available control measures (including RACT) needed for expeditious attainment within three years after the statutory deadline for states to submit these measures to the EPA as part of a Moderate area attainment demonstration.²⁷¹ Nonattainment areas for the 2015 ozone NAAQS that were reclassified to Moderate nonattainment in October 2022 face this same regulatory schedule, meaning that their sources are required to implement RACT controls in 2023. With the exception of the Uinta Basin, which is not an identified receptor in this action, no Marginal nonattainment area met the conditions of CAA section 181(a)(5) to obtain a one-year extension of the Moderate area attainment date. 87 FR 60899 (Oct. 7, 2022). Thus, all Marginal areas (other than Uinta) that failed to attain have been reclassified to Moderate. *Id.* In the October 2022 final rulemaking EPA made determinations that certain Marginal areas failed to attain by the attainment date, reclassified those areas to Moderate, and established SIP submission deadlines and RACM and RACT implementation deadlines. EPA set the attainment SIP submission deadlines for the bumped up Moderate areas to be January 1, 2023. See 87 FR 60897, 60900. The implementation deadline for RACM and RACT is also January 1, 2023. *Id.*

The EPA notes that the types and sizes of the EGU and non-EGU sources that the EPA includes in this rule, as well as the types of emissions control

²⁷⁰ 40 CFR 51.1312(a)(2)(i) (requiring submission of RACT SIP revisions no later than 24 months after the effective date of designation).

²⁷¹ See, e.g., 40 CFR 51.1108(d) (requiring implementation of all control measures (including RACT) needed for expeditious attainment no later than the beginning of the attainment year ozone season, which, for a Moderate nonattainment area, occurs less than 3 years after the deadline for submission of reasonably available control measures under 40 CFR 51.1112(c) and 51.1108(a) and 40 CFR 51.1308(d) (requiring implementation of all control measures (including RACT) needed for expeditious attainment no later than the beginning of the attainment year ozone season, which, for a Moderate nonattainment area, occurs less than three years after the deadline for submission of reasonably available control measures under 40 CFR 51.1312(c) and 51.1308(a)). Because the attainment demonstration for a Moderate nonattainment area (including RACT needed for expeditious attainment) is due three years after the effective date of the area's designation (40 CFR 51.1308(a) and 51.1312(c)), and all Moderate nonattainment areas must attain the NAAQS as expeditiously as practicable but no later than 6 years after the effective date of the area's designation (40 CFR 51.1303(a)), the beginning of the "attainment year ozone season" (as defined in 40 CFR 51.1300(g)) for such an area is less than three years after the due date for the attainment demonstration.

technologies on which the EPA bases the emissions limitations that would take effect for the 2026 and 2027 ozone seasons, generally are consistent with the scope and stringency of RACT requirements for existing major sources of NO_x in downwind Moderate nonattainment areas and some upwind areas, which many states have already implemented in their SIPs.²⁷² Thus, the timing Congress allotted for sources in downwind states to come into compliance with RACT requirements bears directly on the amount of time that should be allotted here and indicates, as does CAA section 126, that three years is an outer limit on the time that should be given sources to come into compliance where possible. In light of the January 1, 2023, deadline for implementation of RACT in Moderate nonattainment areas, the EPA finds that a May 1, 2026 deadline for full implementation of the emissions control requirements in this final rule would generally provide adequate time for any individual source to install the necessary controls, barring the circumstances of necessity discussed further in this section.

Finally, with respect to emissions standards for hazardous air pollutants, section 112(i)(3) of the CAA requires the EPA to establish compliance dates for each category or subcategory of existing sources subject to an emissions standard that "provide for compliance as expeditiously as practicable, but in no event later than 3 years after the effective date of such standard," with limited exceptions. CAA section 112(i)(3)(B) authorizes the EPA to grant an extension of up to 1 additional year for an existing source to comply with emissions standards "if such additional period is necessary for the installation of controls," and sections 112(i)(4) through (7) provide for limited compliance extensions where other conditions are met.²⁷³ Here again, where Congress was concerned with addressing emissions of pollutants that impact public health, a 3-year time period was allotted as the time needed for existing sources to come into compliance where possible. As discussed further in section VI.A.2.b of this document, the process for obtaining a compliance extension for industrial sources in this rule is generally modeled on 40 CFR 63.6(i)(3), which implements

²⁷² See the Final Non-EGU Sectors TSD for a discussion of SIP-approved RACT rules in effect in downwind states.

²⁷³ See, e.g., CAA section 112(i)(4), which provides for limited compliance extensions granted by the President based on national security interests.

the extension provision for existing sources under CAA section 112(i)(3)(B).

All of these statutory timeframes for implementation of new control requirements on existing stationary sources indicate that Congress considered 3 years to be not only a sufficient amount of time but an upper bound of time allowable (barring instances of impossibility) for existing stationary sources to install or begin the installation of pollution controls as necessary for expeditious attainment, to eliminate prohibited interstate transport of pollutants, and to protect public health.

Further, the EPA notes that, given the number of years that have passed since EPA's promulgation of the 2015 ozone NAAQS and related nonattainment area designations in 2018, and in light of the *Maryland* court's holding that good neighbor obligations for the 2015 ozone NAAQS should have been implemented by the Marginal area attainment date in 2021,²⁷⁴ the implementation of good neighbor obligations for these NAAQS is already delayed, and the sources subject to NO_x emissions control in this rule have continued to operate for several years without the controls necessary to eliminate their significant contribution to ongoing and persistent ozone nonattainment and maintenance problems in other states. Under these circumstances, we find it reasonable to require compliance with the control requirements for all non-EGUs and the EGU reductions related to post-combustion control retrofit identified in section V.B.1.b of this document beginning in the 2026 ozone season (with full implementation by the 2027 ozone season for EGUs, and the availability of source-specific extensions based on a demonstration of necessity for non-EGUs).

As the D.C. Circuit noted in *Wisconsin*, the good neighbor provision requires upwind states to "eliminate their substantial contributions to downwind nonattainment in concert with the attainment deadlines" in the downwind states, even where those attainment deadlines occur before EPA's statutory deadline under CAA section 110(c) to promulgate a FIP.²⁷⁵

²⁷⁴ 958 F.3d at 1203–1204 (remanding the EPA denial of section 126 petition based on the EPA analysis of downwind air quality in 2023 rather than 2021, the year containing the Marginal area attainment date).

²⁷⁵ 938 F.3d at 317–318. For example, the court observed that the EPA may shorten the deadline for SIP submissions under CAA section 110(a)(1) and may issue FIPs soon thereafter under CAA section 110(c)(1), to align the upwind states' deadline for satisfying good neighbor obligations with the downwind states' deadline for attaining the NAAQS. *Id.* at 318.

Referencing the Supreme Court's description of the attainment deadlines as "the heart" of the CAA, the *Wisconsin* court noted that some deviation from the mandate to eliminate prohibited transport by downwind attainment deadlines may be allowed only "under particular circumstances and upon a sufficient showing of necessity."²⁷⁶

For the reasons provided in the following sub-sections, the EPA finds that installation of certain EGU controls and all non-EGU controls is not possible by the Moderate area attainment date for the 2015 ozone NAAQS (*i.e.*, August 3, 2024),²⁷⁷ and, for certain sources, may not be possible by the 2026 ozone season or even the August 3, 2027, Serious area attainment date. While the EPA's technical analysis demonstrates that for any individual source, control installation could be accomplished by the start of the 2026 ozone season, in light of the scope of this rule coupled with current information on the present economic capacity of sources, control-installation vendors, and associated markets for labor and material, it is the EPA's judgment that a three-year timeframe is not possible for all sources subject to this rule collectively to come into compliance. Therefore, additional time beyond 2026 will be allowed for certain facilities in recognition of these constraints on the processes needed for installation of controls across all of the covered sources.

a. EGU Schedule for 2026 and Later Years

As discussed in sections V.B through V.D of this document, significant emissions reduction potential exists and is included in EPA's quantification of significant contribution based on the potential to install post-combustion controls (SCR and SNCRs) at EGUs. However, as discussed in detail in those sections, the assumption for installation of this technology on a region-wide scale is 36–48 months in this final rule. This amount of time allows for all necessary procurement, permitting, and installation milestones across multiple units in the covered region. Therefore, the EPA finds that these emissions reductions are not available any earlier than the 2026 compliance period. Starting in 2026, state emissions budgets will reflect full implementation of assumed SNCR mitigation measures and

²⁷⁶ *Id.* at 316 and 319–320 (noting that any such deviation must be "rooted in Title I's framework" and "provide a sufficient level of protection to downwind States").

²⁷⁷ Compliance by the August 3, 2021, Marginal area attainment date is also impossible as that date has passed.

implementation of half the emissions reduction potential identified for assumed SCR mitigation measures. For each year in 2027 and beyond, state emissions budgets include all of the emissions reductions commensurate with these post-combustion control technologies identified for covered units in Step 3. The EPA notes that similar compliance schedules and post-combustion control retrofit installations have been realized successfully in prior programs allowing similar timeframes. Subsequent to the NO_x SIP Call and the parallel Finding of Significant Contribution and Rulemaking on Section 126 Petitions (which became effective December 28, 1998, and February 17, 2000, respectively²⁷⁸), nearly 19 GW of SCR retrofit came online in 2002 and another 42 GW of SCR retrofit came online for steam boilers in 2003, illustrating that a considerable volume of SCR retrofit capacity is possible within a 36-month period.

Comment: Some commenters disagreed with EPA's proposed 36-month timeframe for SCR retrofit. These commenters noted that, while possible at the unit or plant level, the collective volume of assumed SCR installation would not be possible given the labor constraints, supply constraints, and simultaneous outages necessary to complete SCR retrofit projects on such a schedule. They noted that many of the remaining coal units lacking SCR pose more site-specific installation challenges than those that were already retrofitted on a quicker timeframe.

Response: EPA is making several changes in this final rule to address these concerns. First, EPA is phasing in emissions reductions commensurate with assumed SCR installations consistent with a 36-to-48-month time frame in this final rule, instead of a 36-month time frame as proposed. EPA is implementing half of this emissions reduction potential in 2026 ozone-season NO_x budgets for states containing these EGUs and the other half of this emissions reduction potential in 2027 ozone-season NO_x budgets for those states. This phase-in approach to implementing SCR retrofit reduction potential over a three to four year period is in response to comments, including those from third-party full-service engineering firms. These commenters highlighted that while the

²⁷⁸ See 63 FR 57356 (October 27, 1998); 65 FR 2674 (January 18, 2000). The D.C. Circuit stayed the NO_x SIP Call by an order issued May 25, 1999. After upholding the rule in most respects in *Michigan v. EPA*, 213 F.3d 663 (D.C. Cir. 2000), the court lifted the stay by an order issued June 22, 2000.

proposed 36-month time frame is viable at the plant level, it would be “very unlikely” that the collective volume of SCR capacity could be installed in a three-year time frame based on a variety of factors. First, the commenters identified constraints on labor needed to retrofit 32 GW of capacity, highlighting that the Bureau of Labor and Statistics projects that there will be a decline in boilermaker employment over the decade and that the Associated Builders and Contractors (ABC) identifies the need for 650,000 additional skilled craft professionals on top of the normal hiring pace to meet the economy-wide demand created by infrastructure investment and other clean energy projects (e.g., carbon capture and storage). They highlighted the decline in companies serving this type of large-scale retrofit project as the lack of new coal units and the retirement of coal units has curtailed activity in this area over the past five years. They also identified supply bottlenecks for key SCR components that would slow the ability to implement a large volume of SCR within 3 years, affecting electrical conduits, transformers, piping, structural and plate steel, and wire (with temporary price increases ranging from 30 percent to 200 percent). Finally, commenters note that site-specific conditions can make retrofits for individual units a lengthier process than historical averages (e.g., under prior rules more accommodating sites retrofitted first) and that four years may be necessary for some projects, accordingly. EPA found the technical justification submitted in comment consistent with its prior assessments that a range of 39–48 months is appropriate for SCR-retrofit timing within regional-scale programs.²⁷⁹ Therefore, EPA is adjusting the timeframe to still incentivize these reductions by the attainment date while accommodating the potential for some SCR retrofits to require between 36–48 months for installation.

Some commenters requested more than 48 months for SCR installation based on past projects that took five or more years. EPA disagrees with these commenters for two reasons. First, while EPA is identifying SCR retrofit potential to define significant contribution at Step 3, the rule only requires emissions reductions commensurate with that technology, implemented through a trading program, meaning that operators of EGUs eligible for SCR retrofit may pursue a variety of strategies for reducing emissions. Such compliance

flexibility will accommodate extreme or unique circumstances in which a desired SCR retrofit is not achieved by the 2027 ozone season, although EPA finds such a circumstance exceedingly unlikely. Second, the historical examples that exceeded 48 months do not necessarily demonstrate that such projects are impossible to execute in less than 48 months, but rather that they can extend beyond that timeframe if no requirements or incentives are in place for a faster installation. As the D.C. Circuit has recognized, historical data on the amount of time sources have taken to install pollution controls do not in themselves establish the minimum amount of time in which those controls could be installed if sources are subject to a legal mandate to do so. See *Wisconsin*, 938 F.3d at 330 (“[A]ll those anecdotes show is that installation can drag on when companies are unconstrained by the ticking clock of the law.”).

b. Non-EGU or Industrial Source Schedule for 2026 and Later Years

The EPA proposed to require that all emissions reductions associated with the requirements for non-EGU industrial sources go into effect by the start of the 2026 ozone season, but also requested comment on its control-installation timing estimates for non-EGUs and requested comment on the possibility of providing for limited compliance extensions based on a showing of necessity. See 87 FR 20104–05.

Comment: The EPA received numerous comments regarding the inability of various non-EGU industries to install controls to comply with the emissions limits by 2026. Specifically, commenters raised concerns regarding the ability to meet these deadlines due to the ongoing geopolitical instability triggered by the war in Ukraine, COVID–19 pandemic-driven disruptions, and supply chain delays and shortages. Commenters also claimed that the EPA’s three-year installation timeframe for non-EGUs does not account for the time needed to obtain necessary permits. Commenters stated that even where controls are feasible for a source, some sources would need to shut down due to their inability to install controls by 2026 and requested that the EPA provide additional time for sources to come into compliance. Commenters from multiple non-EGU industries stated that the proposed applicability criteria will require controls to be installed on thousands of non-EGU emissions units. Because of the number of emissions units, commenters raised concerns with permitting delays and the unavailability of skilled labor and

necessary components. Commenters suggested various timelines for control installation timing ranging from one additional year to seven years. Other commenters asserted that the data supported the conclusion that all non-EGU sources, or at least some non-EGU sources, could install controls by 2026 or earlier, and that EPA has a legal obligation to impose good neighbor requirements as expeditiously as practicable by such sources, including earlier than 2026 if possible.

Response: After reviewing the information received during the public comment period and the additional information presented in the Non-EGU Control Installation Timing Report, the EPA has concluded that the majority of non-EGUs can install and operate the required controls by the 2026 ozone season. For the non-EGU control requirements on which the EPA has based its Step 3 findings as described in section V of this document, the emissions limits will generally go into effect starting with the 2026 ozone season (except where an individual source qualifies for a limited extension of time to comply based on a specific demonstration of necessity, as described in this section). The EPA finds that meeting the emissions limitations of this final rule through installation of necessary controls by an ozone season before 2026 is not expected to be possible for the industrial sources covered by this final rule.

The EPA recognizes that labor shortages, supply shortages, or other circumstances beyond the control of source owner/operators may, in some cases, render compliance by 2026 impossible for a particular industrial source. Therefore, the final rule contains provisions allowing source owner/operators to request limited compliance extensions based on a case-by-case demonstration of necessity. Under these provisions, the owner or operator of a source may initially apply for an extension of up to one year to comply with the applicable emissions control requirements, which if approved by the EPA, would require compliance no later than the 2027 ozone season. The EPA may grant an additional case-based extension of up to two additional years for full compliance, where specific criteria are met.

The EPA initiated a study to examine the time necessary to install the potential controls identified in the final rule’s cost analysis for all of the non-EGU industries subject to the final rule, including SNCR, low NO_x burners, layered combustion, NSCR, SCR, fluid gas recirculation, and SNCR/advanced selective noncatalytic reduction

²⁷⁹ 86 FR 23102.

(ASNCR). The resulting report, which we refer to as the “Non-EGU Control Installation Timing Report,” identified a range of estimated installation times with minimum estimated installation times ranging from 6–27 months without any supply chain delays and 6–40 months with potential supply chain delays depending on the industry.²⁸⁰ The Non-EGU Control Installation Timing Report also identified maximum estimated installation times ranging from 12–28 months without any supply chain delays and 12–72 months with potential supply chain delays depending on the industry. As indicated in the Non-EGU Control Installation Timing Report, the installation of layered combustion and NSCR control technology, in particular, could take between 9 and 72 months depending on supply chain delays.²⁸¹ The report also indicated that permitting processes may take 6 to 12 months but noted that these processes typically can proceed concurrent with other steps of the installation process.²⁸²

We find that the potential time needed for permitting processes is generally unlikely to significantly affect installation timeframes of at least three years given that a source that has three or more years to comply is expected, in most cases, to have adequate time to apply for and secure the necessary permits during that time. Permitting processes may, however, impact shorter installation times ranging from 12–28 months. Given the 12–28 month estimate for minimum and maximum installation times without supply chain delays and permitting timeframes typically ranging from 6–12 months, the EPA finds that the controls for non-EGU sources needed to comply with this final rule are generally not expected to be installed significantly before the 2026 ozone season.

Generally, the Non-EGU Control Installation Timing Report indicated that all non-EGU unit types subject to the final rule could install controls within 28 months if there are no supply chain delays. Thus, the Non-EGU Control Installation Timing Report confirms that for any individual facility, meeting the emissions limitations of this final rule through installation of controls can be completed by the start of the 2026 ozone season. It is only when the number of units in the U.S. potentially affected by the rule is taken

into account, coupled with broader considerations of economic capacity including current information on supply-chain delays, that the potential need for additional time beyond 2026 becomes a possibility. Under ideal economic conditions (*i.e.*, no supply-chain delays or other constraints), affected units are estimated to be capable to install both combustion and post-combustion controls before the 2026 ozone season. Many commenters, however, provided information on installation timing estimates based on current supply chain delays and labor constraints. These commenters generally stated that installation of the necessary controls for some units would take longer than three years if supply chain delays similar to those that have occurred over the past few years continue. The Non-EGU Control Installation Timing Report reflected this information, together with additional information gathered from pollution control vendors, to develop ranges of estimates of possible installation times given current (*i.e.*, 2022) labor market conditions and material supplies. The Non-EGU Control Installation Timing Report also discussed how the installation and optimization of post-combustion controls over a similar timeframe at both EGUs and non-EGUs subject to this final rule would, considered cumulatively, potentially affect the installation timing needs of the covered non-EGU sources.

Based on information provided by commenters and vendors, the Non-EGU Control Installation Timing Report indicated that if current supply chain delays continue, control installations could take as long as 61 months for most non-EGU industries and possibly as long as 64–112 months in difficult cases. Notably, however, the conclusions in the Non-EGU Control Installation Timing Report reflect three key assumptions that could result in the relatively lengthy timing estimates at the outer end of this range: (1) the current state of supply chain delays and disruptions would continue without any increase in labor supply, materials, or reduction in fabrication timing; (2) the labor and materials markets would not adjust in response to this rule in the timeframe needed to meet the increased demand for control installations; and (3) the Report was unable to account for some of the flexibilities built into the final rule that will allow owners and operators to install controls on the most cost-effective units with shorter installation times.

As presented in the Non-EGU Control Installation Timing Report, supply chain delays and disruptions have

generally been lessening since they peaked in 2020 during the COVID–19 pandemic, and many economic indicators have shown some improvement towards pre-pandemic levels, including freight transportation, inventory to sales ratios, interstate miles traveled, U.S. goods imports, and supply chain indices.²⁸³ If these economic indicators continue to improve and the availability of fabricators and materials continues to trend upward, the control timing estimates identified in the Non-EGU Control Installation Timing Report could prove to be overstated for some industries and control technologies. In addition, the Non-EGU Control Installation Timing Report did not account for the labor and supply market adjustments that would be anticipated to occur to meet increased demand for control technologies and related materials and labor over the next several years in response to the rule. *Cf. Wisconsin*, 938 F.3d at 330 (“[A]ll those anecdotes [of elongated control installation times] show is that installation can drag on when companies are unconstrained by the ticking clock of the law.”). For example, some of the longer installation timeframes identified in the Non-EGU Control Installation Timing Report are based on assumed limits on the current availability of skilled labor needed to install combustion controls and post combustion controls. If the market adjusts in response to increasing demand for this type of skilled labor in the timeframe needed for compliance (*e.g.*, there is an increase in boilermaker and engine controls labor), the installation timing estimates in the Non-EGU Control Installation Timing Report again could be overstated.

The Non-EGU Control Installation Timing Report also did not account for flexibilities provided in this final rule that will enable owners and operators of certain affected units to identify the most cost-effective and efficient means for installing any necessary controls. For example, one concern highlighted by commenters was the amount of time necessary to install controls on engines that have been in operation for 50 or more years. The requirements that we are finalizing for engines in the Pipeline Transportation of Natural Gas industry include an exemption for emergency engines and provisions allowing source owner/operators to request the EPA approval of facility-wide emissions averaging plans, both of which enable owners and operators of affected units to take costs, installation timing needs,

²⁸⁰ See generally SC&A, *NO_x Emission Control Technology Installation Timing for Non-EGU Sources* (March 14, 2023) (“Non-EGU Control Installation Timing Report”).

²⁸¹ See Non-EGU Control Installation Timing Report, Executive Summary (March 14, 2023).

²⁸² *Id.* at Section 5.6.

²⁸³ *Id.* at Section 6.1.

and other considerations into account in deciding which engines to control.

In response to industry concern about the number and size of units captured by the proposed applicability criteria, the EPA has made several changes to the applicability criteria in the final rule to focus the control requirements on impactful non-EGU units. As explained further in section VI.C of this document, the EPA is establishing exemptions for low-use boilers and engines where it would not be cost-effective to require controls at this time. Finally, as discussed in section VI.C.3 of this document, the EPA is not finalizing the proposed requirements for most emissions unit types in the Iron and Steel Mills and Ferroalloy Manufacturing industry given the EPA does not currently have a sufficient technical basis for finalizing those proposed requirements. These changes reduce the number of non-EGU units that will actually need to install controls and should reduce the strain on the labor and supply chain and permitting processes. For example, for engines, the EPA estimates that the facility-wide emissions averaging provision would, in many cases, allow facilities to install controls on only one-third of their engines, on average (see section VI.C.1 of this document for further discussion).

Taking all of these considerations into account, the EPA finds that the outer range of timing estimates presented in the Non-EGU Control Installation Timing Report generally reflects a conservative set of installation timing estimates and that the factors described previously could result in installation timeframes that fall toward the shorter end of the ranges of time that factor in supply-chain delays or could obviate those supply-chain delay issues entirely.

Based on all of these considerations, the EPA has concluded that three years is generally an adequate amount of time for the non-EGU sources covered by this final rule to install the controls in the 20 states that remain linked in 2026. The EPA also recognizes, however, that some sources may not be able to install controls by the 2026 ozone season despite making good faith efforts to do so, due to the aforementioned supply chain delays or other circumstances entirely beyond the owner or operator's control. Therefore, the final FIPs require compliance with the emissions control requirements for non-EGUs by the beginning of the 2026 ozone season, with limited exceptions based on a showing of necessity for individual sources that meet specific criteria. Where an individual owner or operator submits a satisfactory demonstration

that an extension of time to comply is necessary, due to circumstances entirely beyond the owner or operator's control and despite all good faith efforts to install the necessary controls by May 1, 2026, the EPA may determine that installation by 2026 is not possible and thereby grant an extension of up to one year for that source to fully implement the required controls. If, after the EPA has granted a request for an initial compliance extension, the source remains unable to comply by the extended compliance date due to circumstances entirely beyond the owner or operator's control and despite all good faith efforts to install the necessary controls by the extended compliance date, the owner or operator may request and the EPA may grant a second extension of up to two additional years for full compliance, where specific criteria are met. This application process is generally in accordance with the concept on which the Agency requested comment in the proposal, *see* 87 FR 20104–05, and is modeled on a similar process provided for industrial sources subject to CAA section 112 NESHAPs, found at 40 CFR 63.6(i)(3).

The EPA intends to grant a request for an initial compliance extension only where a source demonstrates that it has taken all steps possible to install the necessary controls by the applicable compliance date and still cannot comply by the 2026 ozone season, due to circumstances entirely beyond its control. Any request for a compliance extension must be received by the EPA at least 180 days before the May 1, 2026, compliance date. The request must include all information obtained from control technology vendors demonstrating that the necessary controls cannot be installed by the applicable compliance date, any permit(s) secured for the installation of controls or information from the permitting authority on the timeline for issuance of such permit(s) if the source has not yet obtained the required permit(s); and any contracts entered into by the source for the installation of the control technology or an explanation as to why no contract is necessary. The EPA may also consider documentation of a source owner's/operator's plans to shut down a source by the 2027 ozone season in determining whether a source is eligible for a compliance extension. The owner or operator of an affected unit remains subject to the May 1, 2026 compliance date unless and until the Administrator grants a compliance extension.

The EPA intends to grant a request for a second compliance extension beyond

2027 only where a source owner/operator submits updated documentation showing that it is not possible to install and operate controls by the 2027 ozone season, despite all good faith efforts to comply and due to circumstances entirely beyond its control. The request must be received by the EPA at least 180 days before the extended compliance date and must include, at minimum, the same types of information as that required for the initial extension request. The owner or operator of an affected unit remains subject to the initial extended compliance date unless and until the Administrator grants a second compliance extension. A denial will be effective on the date of denial.

As discussed earlier in section VI.A, in *Wisconsin* the court held that some deviation from the CAA's mandate to eliminate prohibited transport by downwind attainment deadlines may be allowed only "under particular circumstances and upon a sufficient showing of necessity."²⁸⁴ This standard is met when, in the EPA's judgment, compliance by the attainment date amounts to an impossibility. The EPA cannot allow a covered industrial source to avoid timely compliance with the emissions control requirements established in this final rule unless the source owner/operator can demonstrate that compliance by the 2026 ozone season is not possible due to circumstances entirely beyond their control. The criteria that must be met to qualify for limited extensions of time to comply are designed to meet this statutory mandate. The EPA anticipates that the majority of the industrial sources covered by this final rule will not qualify for a compliance extension.

B. Regulatory Requirements for EGUs

To implement the required emissions reductions from EGUs, the EPA is revising the existing CSAPR NO_x Ozone Season Group 3 Trading Program (the "Group 3 trading program") established in the Revised CSAPR Update both to expand the program's geographic scope and to enhance the program's ability to ensure favorable environmental outcomes. The EPA is using a trading program for EGUs because of the inherently greater flexibility that a trading program can provide relative to more prescriptive, "command-and-control" forms of regulation of sufficient stringency to achieve the necessary emissions reductions. In the electric

²⁸⁴ *Wisconsin*, 938 F.3d at 316 and 319–320 (noting that any such deviation must be "rooted in Title I's framework" and "provide a sufficient level of protection to downwind States").

power sector, EGUs' extensive interconnectedness and coordination create the ability to shift both electricity production and emissions among units, providing a closely related ability to achieve emissions reductions in part by shifting electricity production from higher-emitting units to lower-emitting or non-emitting units. Thus, while the Step 3 control-stringency determination for EGUs to eliminate significant contribution is based on strategies that do not require generation shifting or reduced utilization of EGUs, the sector's unusual flexibility with respect to how emissions reductions can be achieved makes the flexibility of a trading program particularly useful as a means of lowering the overall costs of obtaining such reductions. In addition, it is essential for the electric power sector to retain short-term operational flexibility sufficient to allow electricity to be produced at all times in the quantities needed to meet demand simultaneously, and the flexibility of a trading program can be helpful in supporting this aspect of the industry as well.

To ensure emissions reductions necessary to eliminate significant contribution are maintained, in this rulemaking, the EPA is making certain enhancements to the current provisions of the Group 3 trading program addressing emissions-control performance by some kinds of individual units that will necessarily reduce the flexibility of the program to some extent for those units. In analyzing significant contribution at Step 3, once a linkage has been established between an upwind state and a downwind receptor, we identify an appropriate set of emissions control strategies, considering cost and other factors, that would eliminate significant contribution from the upwind state without leading to undercontrol or overcontrol at the downwind linked receptors. At Step 4, for EGUs, we develop emissions budgets based on consistent application of the identified strategies to the sources. This level of emission control at each source identified in Step 3 is what the EPA deems to eliminate significant contribution, while the design of emission budgets that successfully implement that level of emission control is determined at Step 4. See section III.B and V.

The trading program enhancements discussed in this section are designed to ensure that sources actually achieve that level of emission control and thereby eliminate significant contribution on a permanent basis at Step 4. The enhancements ensure that the emissions budgets for EGUs continue to secure the

level of emission control identified at Step 3 at the sources active in the trading program on a more consistent basis throughout each ozone season than prior transport trading programs (including those that did not provide complete remedies for interstate pollution transport) have required. An alternative form of implementation at Step 4 would be to implement source-specific emissions limitations (*e.g.*, rate-based standards expressed as mass per unit of heat input) reflecting the control strategies identified at Step 3. This is a very common form of implementation for many other CAA requirements and is indeed the manner of implementation selected in this very rulemaking for other affected industrial sources. See sections III.B, V.D.4, and VI.C. But doing so would require loss of the flexibilities inherent in a trading program, inclusive of these enhancements, that facilitate orderly and timely achievement of the required emission reductions in the power sector.

Prior to this rule, the Group 3 trading program has applied to EGUs meeting the program's applicability criteria within the borders of twelve states: Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, New Jersey, New York, Ohio, Pennsylvania, Virginia, and West Virginia. Affected EGUs in these twelve states will continue to participate in the Group 3 trading program as revised in this rulemaking, with some revised provisions taking effect in the 2023 control period and other revised provisions taking effect later as discussed elsewhere in this document. The EPA is expanding the Group 3 trading program's geographic scope to include all of the additional states for which EGU emissions reduction requirements are being established in this rulemaking. Affected EGUs within the borders of seven states currently covered by the CSAPR NO_x Ozone Season Group 2 Trading Program (the "Group 2 trading program")—Alabama, Arkansas, Mississippi, Missouri, Oklahoma, Texas, and Wisconsin—will transition from the Group 2 trading program to the revised Group 3 trading program at the beginning of the 2023 control period,²⁸⁵ and affected EGUs within the borders of the three states not currently covered by any CSAPR trading program for seasonal NO_x emissions—Minnesota, Nevada, and Utah—will enter the Group 3 trading program in the 2023 control period on the effective date of this rule.

²⁸⁵ Affected EGUs in the three other states currently covered by the Group 2 trading program—Iowa, Kansas, and Tennessee—will continue to participate in that program.

As discussed in section VI.B.12.a of this document, because the effective date of the rule will likely be sometime during the 2023 ozone season, special transitional provisions have been developed to allow for efficient administration of the rule's EGU requirements through the Group 3 trading program while not imposing any new substantive obligations on parties prior to the rule's effective date, similar to the transitional provisions implemented under the Revised CSAPR Update.

As is the case for the states already in the Group 3 trading program, for each state added to the program, the set of affected EGUs will include new units as well as existing units and will also include units located in Indian country within the state's borders. Sections VI.B.2 and VI.B.3 of this rule provide additional discussion of the geographic expansion of the Group 3 trading program and the units in the expanded geography that will become subject to the program under the program's existing applicability provisions.

In addition to expanding the Group 3 trading program's geographic scope, the EPA is modifying the program's regulations prospectively to include certain enhancements to improve environmental outcomes. Two of the proposed enhancements will adjust the overall quantities of allowances available for compliance in the trading program in each control period so as to maintain the rule's selected control stringency and related EGU effective emissions rate performance level as the EGU fleet evolves. First, instead of establishing emissions budgets for all future years under the program at the time of the rulemaking, which cannot reflect future changes in the EGU fleet unknown at the time of the rulemaking, the EPA is revising the trading program regulations to include a dynamic budgeting procedure. Under this procedure, the EPA will calculate emissions budgets for control periods in 2026 and later years based on more current information about the composition and utilization of the EGU fleet, specifically data available from the 2024 ozone season and following (*e.g.*, for 2026, data from periods through 2024; for 2027, data from periods through 2025; etc.). Through the 2029 control period, the dynamically determined budgets will apply only if they are higher than preset budgets established in the rule. (Associated revisions to the program's variability limits and unit-level allowance allocation procedures will coordinate these provisions with the revised budget-setting procedures.) Second,

starting with the 2024 control period, the EPA will annually recalibrate the quantity of accumulated banked allowances under the program to prevent the quantity of allowances carried over from each control period to the next from exceeding the target bank level, which would be revised to represent a preset percentage of the sum of the state emissions budgets for each control period. The preset percentage will be 21 percent for control periods through 2029 and 10.5 percent for control periods in 2030 and later years. Together, these enhancements will protect the intended stringency of the trading program against potential erosion caused by EGU fleet turnover and will better sustain over time the incentives created by the trading program to achieve the degree of emissions control for EGUs that the EPA has determined is necessary to address states' good neighbor obligations.

Two further enhancements to the Group 3 trading program establish provisions designed to promote more consistent emissions control by individual EGUs within the context of the trading program. First, starting with the 2024 control period for coal-fired EGUs with existing SCR controls and the earlier of the 2030 control period or the control period after which an SCR is installed for other large coal-fired EGUs, a daily NO_x emissions rate of 0.14 lb/mmBtu will apply as a backstop to the seasonal emissions budgets (which are based on an assumed seasonal average emissions rate of 0.08 lb/mmBtu for EGUs with existing SCR controls). Each ton of emissions exceeding a unit's backstop daily emissions rate, after the first 50 such tons, in a given control period will incur a 3-for-1 allowance surrender ratio instead of the usual 1-for-1 allowance surrender ratio. Second, also starting with the 2024 control period, the trading program's existing assurance provisions, which require extra allowance surrenders from sources that are found responsible for contributing to an exceedance of the relevant state's "assurance level" (*i.e.*, typically 121 percent of the state's emissions budget), will be strengthened by the addition of another backstop requirement. Specifically, for any unit equipped with post-combustion controls that is found responsible for contributing to an exceedance of the state's assurance level, the revised regulations will prohibit the unit's seasonal emissions from exceeding by more than 50 tons the emissions that would have resulted if the unit had achieved a seasonal average emissions rate equal to the

higher of 0.10 lb/mmBtu or 125 percent of the unit's lowest previous seasonal average emissions rate under any CSAPR seasonal NO_x trading program.²⁸⁶

These two enhancements are designed to ensure that all individual units with SCR controls have strong incentives to continuously operate and optimize their controls, and also to ensure that all units with post-combustion controls have strong incentives to optimize their emissions performance when a state's assurance level might otherwise be exceeded. These enhancements are generally designed to ensure consistency with the EPA's determination regarding the emissions control stringency needed from EGUs to eliminate significant contribution under the Step 3 multifactor analysis as discussed in section V of this document. Further, these enhancements are designed to provide greater assurance that emissions controls will be operated on all days of the ozone season and therefore necessarily on the days that turn out to be most critical for downwind ozone levels. The EPA expects that promoting more consistently good emissions performance by individual EGUs will better ensure that each state's significant contribution is fully eliminated by this action, *see North Carolina*, 531 F.3d at 919–21. In addition to addressing the statutory requirements of eliminating significant contribution, the EPA anticipates that these enhancements will also deliver public health and environmental benefits to underserved and overburdened communities.

The revisions to the Group 3 trading program being finalized in this rule are very similar to the proposed revisions. The changes from proposal to the set of states covered are driven largely by updates to the air quality modeling performed for the final rule, as described in section IV of this document. The changes from proposal to the trading program enhancements are generally being made in response to comments on the proposal, as discussed in more detail in the remainder of section VI.B of this document.

²⁸⁶ The requirement would not apply for control periods during which the unit operated for less than 10 percent of the hours, and emissions rates achieved in such previous control periods would be excluded from the comparison.

1. Trading Program Background and Overview of Revisions

a. Current CSAPR Trading Program Design Elements and Identified Concerns

The use of allowance trading programs to achieve required emissions reductions from the electric power sector has a long history, rooted in the Clean Air Act Amendments of 1990. In Title IV of those amendments, Congress specified the design elements for a 48-state allowance trading program to reduce SO₂ emissions and the resulting acid precipitation. Building on the success of that first allowance trading program as a tool for addressing multi-state air pollution issues, since 1998 EPA has promulgated and implemented multiple allowance trading programs for SO₂ or NO_x emissions to address the requirements of the CAA's good neighbor provision with respect to successively more protective NAAQS for fine particulate matter and ozone. Most of these trading programs have applied either exclusively or primarily to EGUs.

The EPA currently administers six CSAPR trading programs for EGUs (promulgated in CSAPR, the CSAPR Update, and the Revised CSAPR Update) that differ in the pollutants, geographic regions, and time periods covered and in the levels of stringency, but that otherwise have been nearly identical in their core design elements and their regulatory text.²⁸⁷ The principal common design elements currently reflected in all of the programs are as follows:

- An "emissions budget" is established for each state for each control period, representing the EPA's quantification of the emissions that would remain under certain projected conditions after elimination of the emissions prohibited by the good neighbor provision under those projected conditions. For each control period of program operation, a quantity of newly issued "allowances" equal to the amount of each state's emissions budget is allocated among the state's sources. (States have options to replace the EPA's default allocations or to institute an auction process.) Total emissions in a given control period from all sources in the program are effectively

²⁸⁷ The six current CSAPR trading programs are the CSAPR NO_x Annual Trading Program, CSAPR NO_x Ozone Season Group 1 Trading Program, CSAPR SO₂ Group 1 Trading Program, CSAPR SO₂ Group 2 Trading Program, CSAPR NO_x Ozone Season Group 2 Trading Program, and CSAPR NO_x Ozone Season Group 3 Trading Program. The regulations for the six programs are set forth at subparts AAAAA, BBBB, CCCC, DDDD, EEEE, and GGGG, respectively, of 40 CFR part 97.

capped at a level no higher than the total quantity of allowances available for use in the control period, consisting of the sum of all states' emissions budgets for the control period plus any unused allowances carried over from previous control periods as "banked" allowances.

- "Assurance provisions" in each program establish an "assurance level" for each state for each control period, defined as the sum of the state's emissions budget plus a specified "variability limit." The purpose of the assurance provisions is to limit the total emissions from each state's sources in each control period to an amount close to the state's emissions budget for the control period, consistent with the good neighbor provision's mandate that required emissions reductions must be achieved within the state, while allowing some flexibility beyond the emissions budget to accommodate year-to-year operational variability. In the event a state's assurance level is exceeded, responsibility for the exceedance is apportioned among the state's sources through a procedure that accounts for the sources' shares of the state's total emissions for the control period as well as the sources' shares of the state's assurance level for the control period.

- At the program's compliance deadlines after each control period, sources are required to hold for surrender specified quantities of allowances. The minimum quantities of allowances that must be surrendered are based on the sources' reported emissions for the control period at a 1-for-1 ratio of allowances to tons of emissions (or 2-for-1 in instances of late compliance). In addition, two more allowances must be surrendered for each ton of emissions exceeding a state's assurance level for a control period, yielding an overall 3-for-1 surrender ratio for those emissions (or 4-for-1 in instances of late compliance). Failure to timely surrender all required allowances is potentially subject to penalties under the CAA's enforcement provisions.

- To continuously incentivize sources to reduce their emissions even when they already hold sufficient allowances to cover their expected emissions for a control period, and to promote compliance cost minimization, operational flexibility, and allowance market liquidity, the programs allow trading of allowances—both among sources in the program and with non-source entities—and also let allowances that are unused in one control period be carried over for use in future control periods as banked allowances. Although the CSAPR programs do not limit trading of allowances, and prior to this

rule have not limited banking of allowances within a given trading program, the 3-for-1 surrender ratio imposed by the assurance provisions on any emissions exceeding a state's assurance level disincentivizes sources from relying on either in-state banked allowances or net out-of-state purchased allowances to emit over the assurance level.²⁸⁸

- Finally, other common design elements ensure program integrity, source accountability, and administrative transparency. Most notably, each unit must monitor and report emissions and operational data in accordance with the provisions of 40 CFR part 75; all allowance allocations or auction results, transfers, and deductions must be properly recorded in the EPA's Allowance Management System; each source must have a designated representative who is authorized to represent all of the source's owners and operators and is responsible for certifying the accuracy of the source's reports to the EPA and overseeing the source's Allowance Management System account; and comprehensive data on emissions and allowances are made publicly available.

The EPA continues to believe that the historical CSAPR trading program structure established by the common design elements just described has important positive attributes, particularly with respect to the exceptional degree of compliance flexibility it can provide to a sector such as the electric power sector where such flexibility is especially useful and valuable. However, the EPA also shares many stakeholders' concerns about whether the historical structure, without enhancements, is capable of adequately addressing states' good neighbor obligations with respect to the 2015 ozone NAAQS in light of the rapidly evolving EGU fleet and the protectiveness and short-term form of the ozone standard. One set of concerns relates to the historically observed tendency under the trading programs for the supply of allowances to grow over time while the demand for allowances falls, reducing allowance prices and eroding the consequent incentives for sources to effectively control their emissions. A second, overlapping set of concerns relates to the general absence of source- or unit-specific emissions reduction requirements, allowing some

²⁸⁸ As discussed in section VI.B.6 of this document, while allowance banking has not previously been limited under any of the CSAPR trading programs, limits on the use of banked allowances were included in the earlier NO_x Budget Trading Program in the form of "flow control" provisions.

individual sources to idle or run less optimally existing emissions controls even when a linkage between the sources' state and a receptor persists. For example, certain units in Ohio and Pennsylvania have been found to have operated their controls below target emissions performance levels used for budget setting under the CSAPR Update in the 2019–2021 period, even though the Revised CSAPR Update found that these states remained linked through at least 2021 to receptors for the 2008 ozone NAAQS, and the CSAPR Update itself was only a partial remedy. See 86 FR 23071, 23083. While this unit-level behavior may have been permissible under the prior program, emissions from these individual sources can contribute to increased pollution concentrations downwind on the particular days that matter for downwind exceedances of the relevant air quality standard. This indicates that the prior program design was not effectively ensuring the elimination of significant contribution.²⁸⁹

The EPA has analyzed hourly emissions data reported in prior cap-and-trade programs and identified instances of sources that did not operate SCR controls for substantial portions of recent ozone seasons. In an effort to ensure emissions control on critically important highest ozone days, guard against non-operation of emissions controls under a more protective NAAQS, and provide assurance of elimination of significant contribution to downwind areas, while also maintaining appropriate compliance and operational flexibility for EGUs, the EPA in this rule is implementing a suite of enhancements to the trading program. These will help to ensure reductions occur on the highest ozone days commensurate with our Step 3 determinations, in addition to maintaining a mass-based seasonal requirement. To meet the statutory mandate to eliminate significant contribution and interference with

²⁸⁹ We also observe that these sources' emissions have the potential to impact downwind overburdened communities. See Ozone Transport Policy Analysis Final Rule TSD, Section E. The EPA conducted a screening-level analysis to determine whether there may be impacts on overburdened communities resulting from those EGUs receiving backstop emissions rates under this rule. This analysis identified a greater potential for these sources to affect areas of potential concern than the national coal-fired EGU fleet on average. However, this analysis is distinct from the more comprehensive exposure analysis conducted as discussed in section VII of this document and the RIA. In addition, we note that our conclusions regarding the EGU trading program enhancements in this final rule are wholly supportable and justified under the good neighbor provision, even in the absence of any potential benefits to overburdened communities.

maintenance on the critically important days, this combination of provisions will strongly incentivize sources to plan to run controls all season, including on the highest ozone days, while giving reasonable flexibility for occasional operational needs.²⁹⁰

In this rulemaking, the EPA is revising the Group 3 trading program to include enhancements designed to address both sets of concerns described previously. The principles guiding the various revisions and the relationships of the revisions to one another are discussed in sections VI.B.1.b and VI.B.1.c of this document. The individual revisions are discussed in more detail in sections VI.B.4 through VI.B.9 of this document.

b. Enhancements To Maintain Selected Control Stringency Over Time

The first set of concerns noted about the current CSAPR trading program structure relates to the programs' ability to maintain the rule's selected control stringency and related EGU effective emissions performance level as the EGU fleet evolves over time. Under the historical structure of the CSAPR trading programs, the effectiveness of the programs at maintaining the rule's selected control stringency depends entirely on how allowance prices over time compare to the costs of sources' various emissions reduction opportunities, which in turn depends on the relationship between the supply for allowances and the demand for allowances. In considering possible ways to address concerns about the ability to enhance the historical trading program structure to better sustain incentives to control emissions over time, the EPA has focused on the trading program design elements that determine the supply of allowances, specifically the approach for setting state emissions budgets and the rules concerning the carryover of unused allowances for use in future control periods as banked allowances.

i. Revised Emissions Budget-Setting Process

In each of the previous rulemakings establishing CSAPR trading programs, the EPA has evaluated the emissions that could be eliminated through implementation of certain types of emissions control strategies available at various cost thresholds to achieve

²⁹⁰ Deferral of the backstop daily emissions rate for certain EGUs, for reasons discussed in section VI.B.7 of this document, does not alter this finding that this trading program enhancement is an important part of the solution to eliminating significant contribution from EGUs under CAA section 110(a)(2)(D)(i)(I).

certain rates of emissions per unit of heat input (*i.e.*, the amount of fuel consumed) and the effects of the resulting emissions reductions on downwind air quality. After determining the emissions control strategies and associated emissions reductions that should be required under the good neighbor provision by considering these factors in a multifactor test at Step 3, the EPA has then for purposes of Step 4 implementation program design projected the amounts of emissions that would remain after the assumed implementation of the selected emissions control strategies at various points in the future and has established the projected remaining amounts of emissions as the state emissions budgets in trading programs.

Projecting the amounts of emissions remaining after implementation of selected emissions controls necessarily requires projections not only for sources' future emissions rates but also for other factors that influence total emissions, notably the composition of the future EGU fleet (*i.e.*, the capacity amounts of different types of sources with different emissions rates) and their future utilization levels (*i.e.*, their heat input). To the extent conditions unfold in practice that differ from the projections made at the time of a rulemaking for these other factors, over time the emissions budgets may not reflect the intended stringency of the emissions control strategies identified in the rulemaking as consistent with addressing states' good neighbor obligations. Further, projecting EGU fleet composition and utilization beyond the relatively near-term analytic years of 2023 and 2026 given particular attention in this rulemaking has become increasingly challenging in light of the anticipated continued evolution of the electric power sector toward more efficient and cleaner sources of generation, including as driven by incentives provided by the Infrastructure Investment and Jobs Act as well as the Inflation Reduction Act.

A consequence of using a trading program approach with preset emissions budgets that do not keep pace with the trends in EGU fleet composition and heat input is that the preset emissions budgets maintain the supply of allowances at levels that increasingly exceed the emissions that would occur even without implementation of the emissions control strategies used as the basis for determining the emissions budgets, causing decreases in allowance prices and hence the incentives to implement the control strategies. As an example, although the emissions

budgets in the CSAPR Update established in 2016 reflected implementation of the emissions control strategy of operating and optimizing existing SCR controls, within four years the EPA found that EGU retirements and changes in utilization not anticipated in EPA's previous budget-setting computations had made it economically attractive for at least some sources to idle or reduce the effectiveness of their existing controls (relying on purchased allowances instead).²⁹¹ While the EPA has provided analysis indicating that, on average, sources operate their controls more effectively on high electric demand days, it has also identified cases where units fail to optimize their controls on these days. Downwind states have suggested this type of reduced pollution control performance has occurred on the day and preceding day of an ozone exceedance.^{292 293} While the EPA had previously provided analysis focusing on the year of initial program implementation, when allowance prices were high (*i.e.*, 2017 for the CSAPR Update), to demonstrate that on average, sources operate their controls more effectively on high electric demand days, even in that case it had identified situations where particular units failed to optimize their controls on these days. In later years, when allowance prices had fallen, more sources, including some identified by commenters, had idled or reduced the effectiveness of their controls. Such an outcome undermined the ongoing achievement of emissions rate performance consistent with the control strategies identified in the CSAPR Update to eliminate significant contribution to nonattainment and interference with maintenance, despite the fact that the mass-based budgets were being met.

In the Revised CSAPR Update, the EPA took steps to better address the rapid evolution of the EGU fleet, specifically by setting updated emissions budgets for individual future

²⁹¹ The price of allowances in CSAPR Update states started at levels near \$800 per ton in 2017 but declined to less than \$100 per ton by 2019 and were less than \$70 per ton in July 2020 (data from S&P Global Market Intelligence).

²⁹² 86 FR 23117.

²⁹³ See EPA-HQ-OAR-2020-0272-0094 ("[This] is demonstrated through examination of Maryland's ozone design value days for June 26th–28th, 2019. On those days, Maryland recorded 8-hour ozone levels of 75, 85 and 83 ppb at the Edgewood monitor. Maryland Department of the Environment evaluated the daily NO_x emission rate for units in Pennsylvania that were found to influence the design values on the 3 exceedance days (and 1 day prior to the exceedance) against the past-best ozone season 30-day rolling average optimized NO_x rate (which tends to be higher than the absolute lowest seasonal average rate).")

years though 2024 that reflect future EGU fleet changes known with reasonable certainty at the time of the rulemaking. Some commenters in that rulemaking requested that the EPA also update the year-by-year emissions budgets to reflect future fleet changes that might become known after the time of the rulemaking, but the EPA declined to do so, in part because no methodology for making future emissions budget adjustments in response to post-rulemaking data had been included in the proposal for the rulemaking.

Based on information available as of December 2022, it appears that the emissions budgets set for the first two control periods covered by the Revised CSAPR Update generally succeeded at creating incentives to operate emissions controls under the Group 3 trading program for those control periods. However, the EPA recognizes that the lack of emissions budget adjustments after 2024 in conjunction with industry trends toward more efficient and cleaner resources will likely lead to a surplus of allowances after the adjustments end. This prospect for the existing Group 3 trading program should be avoided by the changes being made in this rulemaking. In this rulemaking, besides establishing new preset emissions budgets for the 2023 through 2029 control periods, the EPA is also extending the Group 3 trading program budget-setting methodology used in the Revised CSAPR Update to routinely calculate dynamic emissions budgets for each future control period from 2026 on, to be published in the year before that control period, with each dynamic emissions budget generally reflecting the latest available information on the composition and utilization of the EGU fleet at the time that dynamic emissions budget is determined. For the control periods in 2026 through 2029, each state's final emissions budget will be the preset budget determined for the state in this rulemaking except in instances when the dynamic budget determined for the state (and published approximately one year before the control period using the dynamic budget-setting methodology) is higher. For control periods in 2030 and thereafter, the emissions budgets will be the amounts determined for each state in the year before the control period using the dynamic budget-setting methodology.

The current budget-setting methodology established in the Revised CSAPR Update and the revisions being made to that methodology are discussed in detail in section VI.B.4 of this document and the Ozone Transport

Policy Analysis Final Rule TSD. To summarize here, the methodology used to determine the preset budgets largely follows the Revised CSAPR Update's emissions budget-setting methodology, which included three primary steps: (1) establishment of a baseline inventory of EGUs adjusted for known retirements and new units, with heat input and emissions rate data for each EGU in the inventory based on recent historical data; (2) adjustment of the baseline data to reflect assumed emissions rate changes resulting from known new controls, known gas conversions, and implementation of the emissions control strategies used to determine states' good neighbor obligations; and (3) application of an increment or decrement to reflect the effect on emissions from projected generation shifting among the units in a state at the emissions reduction cost associated with the selected emissions control strategies. In this rulemaking, the EPA has determined the preset state emissions budgets for the control periods from 2023 through 2029 by using the Revised CSAPR Update's budget-setting methodology, except that the step of that methodology intended to reflect the effects of generation shifting has been eliminated.

The dynamic budget-setting methodology used to determine dynamic state emissions budgets in the year before each control period starting with the 2026 control period is set forth in the revised Group 3 trading program regulations at 40 CFR 97.1010(a). This methodology modifies the Revised CSAPR Update's budget-setting methodology in two ways. First, the baseline EGU inventory and heat input data, but not the emissions rate data, will be updated for each control period using the most recent available reported data in combination with reported data from the four immediately preceding years. For example, in early 2025, using the final data reported for 2020 through 2024, the EPA will update the baseline inventory and heat input data used to determine dynamic state emissions budgets for the 2026 control period.²⁹⁴ Second, the EPA will not apply an increment or decrement to any state emissions budget for projected

²⁹⁴ As discussed in section VI.B.4 of this document, the state-level data used to determine the overall state-level heat input for computing a state's dynamic budget will be a three-year average (e.g., 2022–2024 state-level data will be used in 2025 to set the 2026 dynamic budgets). The unit-level data used to determine individual units' shares of the state-level heat input in the computations will be the average of the three highest non-zero heat input amounts for the respective units over the most recent five years (e.g., 2020–2024 unit-level data will be used in 2025 to set the 2026 dynamic budgets).

generation shifting associated with implementation of the selected control strategies, because any such shifting should already be reflected in the reported heat input data used to update the baseline.

The EPA believes that the revisions to the emissions budget-setting process will substantially improve the ability of the emissions budgets to keep pace with changes in the composition and utilization of the EGU fleet. The dynamic budget-setting methodology will account for the electric power sector's overall trends toward more efficient and cleaner resources, both of which tend to decrease total heat input at affected EGUs, and through 2029 the preset budgets established in the rule will also account for these factors to the extent known. The dynamic budget-setting methodology will also account for other factors that could lead to increased heat input in some states, such as generation shifting from other states or increases in electricity demand caused by rising electrification. The dynamic budget-setting procedure is specified in this final rule's trading program regulations and the computations, which are straightforward, can be performed in a spreadsheet to deliver reliable results. The EPA will provide public notice of the preliminary calculations and the data used by March 1 of the year preceding the control period and will provide an opportunity for submission of any objections to the data and preliminary calculations before finalizing the dynamic budgets for each control period by May 1 of the year before the control period to which those dynamic budgets apply. Thus, for example, sources and other stakeholders will have certainty by May 1, 2025, of the dynamic emissions budgets that will be calculated for the 2026 control period that starts May 1, 2026. Moreover, as of the issuance of this final rule, stakeholders will know the state-level preset emissions budgets for the 2026–2029 control periods, which serve as floors that will only be supplanted by dynamic budgets calculated for those control periods if such a dynamic budget yields a higher amount of tons than the corresponding preset budget established in this action.

It bears emphasis that the annually updated information used in the dynamic budget-setting computations will concern only the composition and utilization of the EGU fleet and not the emissions rate data also used in those computations. The dynamically determined emissions budget computations for all years will reflect only the specific emissions control

strategies used to determine states' good neighbor obligations as determined in this rulemaking, along with fixed historical emissions rates for units that are not assumed to implement additional control strategies, thereby ensuring that the annual updates will eliminate emissions as determined to be required under the good neighbor provision. The stringency of the emissions budgets will simply reflect the stringency of the emissions control strategies determined in the Step 3 multifactor analysis and will do so more consistently over time than the EPA's previous approach of computing emissions budgets for all future control periods at the time of the rulemaking.

The rule's revisions relating to state emissions budgets and the budget-setting process generally follow the proposal except for two changes we are making in response to comments, specifically: we will use historical data from multiple years rather than a single year in the dynamic budget-setting process, and we are establishing preset emissions budgets for the 2026–2029 control periods such that the dynamic budgets for those control periods will only be imposed where they exceed the corresponding preset budgets finalized in this rule. The rationale for these changes is discussed later in this section as part of the responses to the relevant comments. Details of the final budget-setting methodology and responses to additional comments are discussed further in section VI.B.4 of this document.

The final rule's provisions relating to the determination of state-level variability limits and assurance levels and unit-level allowance allocations are coordinated with the budget-setting methodology. These provisions generally follow the proposal except that the change to the methodology for determining variability limits is implemented starting with the 2023 control period instead of the 2025 control period and the final methodology for determining unit-level allocations of allowances to coal-fired units considers the controlled emissions rate assumptions applicable to the same units in the budget-setting process. Details of these provisions, including the rationales for the changes from proposal, are discussed in sections VI.B.5 and VI.B.9, respectively.

ii. Allowance Bank Recalibration

Besides the levels of the emissions budgets, the second design element of the trading program structure that affects the supply of allowances in each control period, and that consequently also affects the ability of a trading

program to maintain the rule's selected control stringency as the EGU fleet evolves over time, is the set of rules concerning the carryover of unused allowances for use in future control periods as banked allowances. As noted previously, trading and banking of allowances in the CSAPR trading programs can serve a variety of purposes: continuously incentivizing sources to reduce their emissions even when they already hold sufficient allowances to cover their expected emissions for a control period, facilitating compliance cost minimization, accommodating necessary operational flexibility, and promoting allowance market liquidity. All of these purposes are advanced by rules that allow sources to trade allowances freely (both with other sources and with non-source entities such as brokers). All of these purposes are also advanced by rules that allow unused allowances to be carried over for possible use in future control periods, thereby preserving a value for the unused allowances. However, while the EPA considers it generally advantageous to place as few restrictions on the trading of allowances as possible,²⁹⁵ unrestricted banking of allowances has a potentially significant disadvantage offsetting its advantages, namely that it allows what might otherwise be temporary surpluses of allowances in some individual control periods to accumulate into a long-term allowance surplus that reduces allowance prices and weakens the trading program's incentives to control emissions. With weakened incentives, some operators would be more likely to choose not to continuously operate and optimize their emissions controls, imperiling the ongoing achievement of emissions rate performance consistent with the control

²⁹⁵ The advantages of trading programs discussed earlier in this section—providing continuous emissions reduction incentives, facilitating compliance cost minimization, and supporting operational flexibility—depend on the existence of a marketplace for purchasing and selling allowances. Broader marketplaces generally provide greater market liquidity and therefore make trading programs better at providing these advantages. The EPA recognizes that unrestricted use of *net* purchased allowances—meaning quantities of purchased allowances that exceed the quantities of allowances sold—by a source or group of sources as an alternative to making emissions reductions can interfere with the achievement of the desired environmental outcome. Therefore, section VI.B.1.c of this document discusses the enhancements to the Group 3 trading program that the EPA is making in this rulemaking to reduce reliance on net purchased allowances by incentivizing or requiring better environmental performance at individual EGUs. However, the concern arises from the *use of an excessive quantity* of net purchased allowances for a particular purpose, not from the existence of a *marketplace* where allowances may be freely bought and sold.

strategies defined as eliminating significant contribution to nonattainment and interference with maintenance.

As discussed in detail in section VI.B.6 of this rule, the EPA is revising the Group 3 trading program by adding provisions that establish a routine recalibration process for banked allowances that will be carried out in August 2024 and each subsequent August, after the compliance deadline for the control period in the previous year. In each recalibration, the EPA will reset the total quantity of banked allowances for the Group 3 trading program (“Group 3 allowances”) held in all Allowance Management System accounts to a level computed as a target percentage of the sum of the state emissions budgets for the current control period. The target percentage will be 21 percent for the 2024–2029 control periods and 10.5 percent for control periods in 2030 and later years. The recalibration procedure entails identifying the ratio of the target bank amount to the total quantity of banked allowances held in all accounts before the recalibration and then, if the ratio is less than 1.0, multiplying the quantity of banked allowances held in each account by the ratio to identify the appropriate recalibrated amount for the account (rounded to the nearest allowance), and deducting any allowances in the account exceeding the recalibrated amount.

As noted previously, recalibration of the bank for each control period will be carried out in August of that control period. This timing will accommodate the process of deducting allowances for compliance for the previous control period, which cannot be completed before sources' June 1 compliance deadline for the previous control period, and will then provide approximately two additional months for sources to engage in any desired allowance transactions before recalibration occurs. However, data that can be used to estimate the bank recalibration ratio for each control period will be available shortly after the end of the previous control period, and the EPA will use these data to make information on the estimated bank recalibration ratio for each control period publicly available no later than March 1 of the year of that control period, thereby facilitating the ability of affected EGUs to anticipate their ultimate holdings of recalibrated banked allowances to inform their compliance planning for that control season. Affected EGUs will also have several months following the completed bank recalibration in August to transact allowances with other parties as needed

before the allowance transfer deadline of June 1 of the following year.

The EPA believes this revision to the Group 3 trading program's banking provisions establishing an annual bank recalibration process will complement the revisions to the budget-setting process by preventing any surplus of allowances created in one control period from diminishing the intended stringency and resulting emissions reductions of the emissions budgets for subsequent control periods.

The calibration procedure will not erase the value of unused allowances for the holder, because the larger the quantity of banked allowances that is held in a given account before each recalibration, the larger the quantity of banked allowances that will be left in the account after the recalibration for possible sale or use in meeting future compliance requirements. Because the banked allowances will always have value, the opportunity to bank allowances will continue to advance the purposes served by otherwise unrestricted banking as described previously. Opportunities to bank unused allowances can serve all these same purposes whether a banked allowance is of partial value (if the bank needs recalibrating to its target level) or is of full value compared to a newly issued allowance for the next control period.

The final rule's provisions relating to bank recalibration generally follow the proposal except that, in response to comments, the target percentage used to determine the recalibrated bank levels for the 2024–2029 control periods is being set at 21 percent instead of 10.5 percent. The rationale for this change is discussed later in this section as part of the responses to the relevant comments. Details of the bank recalibration provisions are discussed further in section VI.B.6 of this rule.

c. Enhancements To Improve Emissions Performance at Individual Units

The second set of concerns about the structure of the current CSAPR trading programs relates to the general absence of source- or unit-specific emissions reduction requirements. Without such requirements, the programs affect individual sources' emissions performance only to the extent that the incentives created by allowance prices are high enough relative to the costs of the sources' various emissions control opportunities. In circumstances where the incentives to control emissions are insufficient, some individual sources even idle existing emissions controls. Emissions from these individual sources can contribute to increased pollution

concentrations downwind on the particular days that matter for downwind exceedances of the relevant air quality standard.

This EPA intends that the trading program enhancements described in section VI.B.1.b of this rule will improve the Group 3 trading program's ability to sustain emissions control incentives over time such that needed emissions performance will be achieved by all participating units without the need for additional requirements to be imposed at the level of individual units. However, because obtaining needed emissions performance at individual units is also important to the elimination of significant contribution in keeping with the EPA's Step 3 determinations, the EPA is supplementing the previously discussed enhancements with two other new sets of provisions that will apply to certain individual units within the larger context of the Group 3 trading program. The allowance price will continue to be the most important driver of good environmental performance for most units, but the proposed unit-level requirements will be important supplemental drivers of performance and will offer additional assurance that significant contribution is eliminated on a daily basis during the ozone season by more continuous operation of existing pollution controls.

i. Unit-Specific Backstop Daily Emissions Rates

The first of the trading program enhancements intended to improve emissions performance at the level of individual units is the addition of backstop daily NO_x emissions rate provisions that will apply to large coal-fired EGUs, defined for this purpose as units serving electricity generators with nameplate capacities equal to or greater than 100 MW and combusting any coal during the control period in question. Starting with the 2024 control period, a 3-for-1 allowance surrender ratio (instead of the usual 1-for-1 surrender ratio) will apply to emissions during the ozone season from any large coal-fired EGU with existing SCR controls exceeding by more than 50 tons a daily average NO_x emissions rate of 0.14 lb/mmBtu. The additional allowance surrender requirement will be integrated into the trading program as a new component in the calculation of each unit's primary emissions limitation, such that the additional allowances will have to be surrendered by the same compliance deadline of June 1 after each control period. The amount of additional allowances to be surrendered will be determined by computing, for

each day of the control period, any excess of the unit's reported emissions (in pounds) over the emissions that would have resulted from combusting that day's actual heat input at an average daily emissions rate of 0.14 lb/mmBtu, summing the daily amounts, converting from pounds to tons, computing the amount of any excess over 50 tons, and multiplying by two. Starting with the second control period in which newly installed SCR controls are operational, but not later than the 2030 control period, the 3-for-1 surrender ratio will apply in the same way to all large coal-fired EGUs except circulating fluidized bed units, consistent with EPA's determination that a control stringency reflecting installation and operation of SCR controls on all such large coal-fired EGUs is appropriate to address states' good neighbor obligations with respect to the 2015 ozone NAAQS.

In prior rules addressing interstate transport of air pollution, stakeholders have noted that while seasonal cap-and-trade programs are effective at lowering ozone and ozone-forming precursors across the ozone season, attainment of the standard is measured on key days and therefore it is necessary to ensure that the rule requires emissions reductions not just seasonally, but also on those key days.²⁹⁶ They have noted that while the trading programs established under the NO_x SIP Call, CAIR, and CSAPR have all been successful in ensuring seasonal reductions, states must remain below daily peak levels, not just seasonal levels, to reach attainment. These downwind stakeholder communities have suggested that operating pollution controls on the highest ozone days (and immediately preceding days) during the ozone season is of critical importance. The EPA has analyzed hourly emissions data reported in prior cap-and-trade programs and has identified instances of sources that did not operate SCR controls for substantial portions of recent ozone seasons. These instances are discussed in section V.B.1.a of this document and in the EGU NO_x Mitigation Strategies Final Rule TSD in the docket. While the EPA has in prior ozone transport actions not found sufficient evidence of emissions control idling or non-optimization to take the step of building in enhancements to the trading program to ensure unit-level control operation, our review of subsequent-year data for prior programs suggests that the non-optimization

²⁹⁶ E.g., comments of Maryland Department of the Environment on the proposed Revised CSAPR Update at 3, EPA-HQ-OAR-2020-0272-0094.

behavior increases in the latter years of a program. Applied to this context (e.g., a rule providing a full remedy to interstate transport for the more protective 2015 ozone NAAQS and an extended period of expected persistence of receptors), this data suggests this deterioration in performance could become prevalent and problematic in future years if not addressed. Rather than allow for the potential of continued deterioration in the environmental performance of our trading programs, the EPA finds the evidence of declining SCR performance in later years of trading programs sufficient to justify prophylactic measures in this rule to ensure the emissions control strategy selected at Step 3 is indeed implemented at Step 4. Thus, particularly in the context of the more protective 2015 ozone NAAQS combined with the full remedy nature of this action and the extended timeframe for which upwind contribution to downwind nonattainment is projected to persist, the EPA agrees with these stakeholders that the set of measures promulgated in this rulemaking to implement the control stringency levels found necessary to address states' good neighbor obligations should include measures designed to more effectively ensure that individual units operate their emissions controls routinely throughout the ozone season, thereby also ensuring that the controls are planned to be in operation on the particular days that turn out to be most critical for ozone formation and for attainment of the NAAQS. Routine operation of emissions controls will also provide relief to overburdened communities downwind of any units that might otherwise have chosen not to operate their controls. In the Ozone Transport Policy Analysis Final Rule TSD, the EPA conducted a screening analysis that found nearly all of the EGUs included in this analysis are located within a 24-hour transport distance of many areas with potential EJ concerns. Thus, the EPA is adopting backstop daily rate limits at the individual unit level because it is appropriate and justified in the context of eliminating significant contribution under CAA section 110(a)(2)(D)(i)(I). While the former justification is sufficient to finalize this enhancement to the trading program, we also anticipate that this measure will deliver public health and environmental benefits to overburdened communities (as well as the rest of the population).²⁹⁷

²⁹⁷ Nonetheless, the environmental justice exposure analysis indicates that preexisting disparities among demographic groups are likely to

We considered whether, as some commenters suggested, it would be appropriate to simply implement unit-specific daily emissions limitation at all of the large, coal-fired EGUs, and forego an emissions trading approach altogether. While this is within the EPA's statutory authority, *see* CAA section 110(a)(2)(A) and 302(y), and merits careful consideration, we are declining to do so in this action but intend to closely monitor EGU emissions performance in response to the trading program finalized here. The purpose of establishing a backstop daily NO_x emissions rate and implementing it through additional allowance surrender requirements instead of as an enforceable emissions limitation is to incentivize improved emissions performance at the individual unit level while continuing to preserve, to the extent possible, the advantages that the flexibility of a trading program brings to the electric power sector. As discussed in section VI.B.7 of this document, under the EPA's historical trading programs without the enhancements made in this rulemaking, some individual coal-fired units with SCR controls have chosen to operate the controls at lower removal efficiencies than in past ozone seasons or even to idle the controls for entire ozone seasons. In addition, some SCR-equipped units have chosen to routinely cycle their emissions controls off at lower load levels, such as while operating overnight, instead of operating the controls, upgrading the units to enable the controls to be operated under those conditions, or not operating the units under those conditions. Collectively, this non-optimization of existing controls has a detrimental impact on problematic receptors. Table V.D.1-1 shows the expected air quality benefit from control optimization (totaling nearly 1.6 ppb change across all receptors).²⁹⁸

The EPA has identified sources of interstate ozone pollution such as the New Madrid and Conemaugh plants (in Missouri and Pennsylvania, respectively) whose SCR controls were not operating for substantial portions of recent ozone seasons. The data included in Appendix G of the Ozone Transport Policy Analysis Final Rule TSD, available in the docket for this rulemaking, demonstrate that these units have operated their SCRs better and more consistently during years with

persist even under this final rule. *See* section VII of this document.

²⁹⁸ As illustrated in the table and underlying data, a small portion of this ppb impact is attributable to combustion control upgrade potential.

higher NO_x allowance prices. Downwind stakeholders have noted that some of the higher emissions rates (specifically in the case of Conemaugh Unit 2 in 2019) have occurred on the day of and the preceding day of an ozone exceedance in bordering states.²⁹⁹

The EPA believes that the design of the daily emissions rate provisions will be effective in addressing these types of high-emitting behavior by significantly raising the cost of planned operator decisions that substantially compromise environmental performance. At the same time, the provision will not unduly penalize an occasional unplanned exceedance, because the amount of additional allowances that would have to be surrendered to address a single day's exceedance would be much smaller than the amount that would have to be surrendered to address planned poor performance sustained over longer time periods. Moreover, the EPA believes that the inclusion of a 50-ton threshold before the increased surrender requirements would apply is sufficient to address virtually all instances where a unit's emissions would exceed the 0.14 lb/mmBtu daily rate because of unavoidable startup or shutdown conditions during which SCR equipment cannot be operated, thereby ensuring that the provision will not penalize units for emissions that are beyond their reasonable control.

The EPA is applying the daily emissions rate provisions to large coal-fired EGUs, and not to other types of units, for reasons that are consistent with EPA's determinations regarding the appropriate control stringency for EGUs to address states' good neighbor obligations with respect to the 2015 ozone NAAQS. Installation and operation of SCR controls is well-established as a common practice for the best control of NO_x emissions from coal-fired EGUs, as evidenced by the fact that the technology is already installed on more than 60 percent of the sector's total coal-fired capacity and installed on nearly 100 percent of the coal fired boilers in the top quartile of emissions rate performance. In the context of addressing good neighbor obligations with respect to the 2015 ozone NAAQS, the EPA is determining that a control stringency reflecting universal installation and operation of SCR technology at large coal-fired EGUs (other than circulating fluidized bed units) is appropriate at Step 3. Finally, where SCR controls are installed on such units, optimized operation of those controls is an extremely cost-effective method of achieving NO_x emissions

²⁹⁹ EPA-HQ-OAR-2020-0272-0094.

reductions. The EPA believes these considerations support establishment of the daily emissions rate provisions on a universal basis for large coal-fired EGUs, with near-term application of the provisions for units that already have the controls installed and deferred application for other units, as discussed later.

With regard to gas-fired steam EGUs, SCR controls are nowhere near as prevalent, and while the EPA is including some SCR controls at gas-fired steam units in the selected control stringency at Step 3, the EPA is not including universal SCR controls at gas-fired steam units. Because the EPA is not determining that universal installation and operation of SCR controls at gas-fired steam EGUs is part of the selected control stringency, in order not to constrain the power sector's flexibility to choose which particular gas-fired steam EGUs are the preferred candidates for achieving the required emissions reductions, the EPA is not applying the daily emissions rate provisions to large gas-fired steam EGUs. Focusing the backstop daily emissions rates on coal-fired units is also consistent with stakeholder input which has emphasized the need for short-term rate limits at coal units given their relatively higher emissions rates.

The EPA developed the level of the daily average NO_x emissions rate—0.14 lb/mmBtu—through analysis of historical data, as described in section VI.B.7 of this document. A rate of 0.14 lb/mmBtu represents the daily average NO_x emissions rate that has been demonstrated to be achievable on approximately 95 percent of days covering more than 99 percent of total ozone-season NO_x emissions by coal-fired units with SCR controls that are achieving a seasonal NO_x average emissions rate of 0.08 lb/mmBtu (or less), which is the seasonal NO_x emissions rate that the EPA has determined is indicative of optimized SCR performance by units with existing SCR controls.

As noted previously, the daily average emissions rate provisions will apply beginning in the 2024 control period for large coal-fired units with installed SCR controls, one control period later than optimization of those controls will be reflected in the state emissions budgets under this rule. For these units, not applying the daily average rate provisions until 2024 serves three purposes. First, it provides all the units with a preparatory interval to focus attention on improving not only the average performance of their SCR controls but also the day-to-day consistency of performance before they

will be held to increased allowance-surrender consequences for exceeding the daily rate. Second, it provides the subset of units that exhaust to common stacks with other units that currently lack SCR controls an opportunity to exercise the option to install and certify any additional monitoring systems needed to monitor the individual units' NO_x emissions rates separately; otherwise, the daily emissions rate provisions will apply to the SCR-equipped units based on the combined NO_x emissions rates measured in the common stacks. Third, it provides all units sufficient time to update the data handling software in their existing monitoring systems as needed to compute and report the additional hourly and daily data values needed for implementation of the provisions.³⁰⁰

With respect to the units without existing SCR controls, the daily average emissions rate provisions will apply starting with the second control period in which newly installed SCR controls are operational at the unit, but not later than the 2030 control period. This implementation timing represents a change from the proposal, under which the daily average emissions rate provisions would have applied to units without existing SCR starting in the 2027 control period. Commenters noted that for many units without SCR, replacement of the unit within a few years, and shifting of some generation to cleaner units in the interim, would be a more economic compliance strategy than installation of new SCR controls. The commenters further noted that implementation of the daily average emissions rate for these units starting in 2027 would strongly disadvantage such an alternative strategy if the capacity replacement and any associated transmission improvements could not be implemented by 2027. In light of these comments, the EPA has determined that as long as the emissions budgets determined in this rule to eliminate significant contribution are still being implemented as expeditiously as practicable—which in this instance the EPA has determined requires phasing in the required emissions reductions by 2027—it is reasonable to defer implementation of the daily average emissions rate provisions to 2030 for units without SCR to allow temporarily greater flexibility to pursue compliance strategies other than installation of new

³⁰⁰ For further discussion of emissions monitoring and reporting requirements under the rule, including the options available to plants where SCR-equipped and non-SCR-equipped coal-fired units exhaust to common stacks, see section VI.B.10 of this document.

controls. This lag is permissible consistent with the obligation to eliminate significant contribution for reasons that are further discussed in response to comments in section VI.B.1.d of this document. However, for any units that choose a compliance strategy of installing new SCR controls before 2030, the daily average emissions rate provisions would apply in the second control period of operation. Specification of the second control period rather than the first control period provides the unit operators with an opportunity to gain operational experience with the new equipment before the units will be held to increased allowance-surrender consequences for exceeding the daily rate.

The unit-specific daily emissions rate provisions are being finalized as proposed except for two changes noted in the previous summary: the exclusion from extra allowance surrender requirements of a unit's first 50 tons of emissions in a control period exceeding the backstop daily rate, and the revision of the starting date for implementation of the requirement for units without existing SCR controls to 2030 or the second control period of SCR operation, if earlier. The rationale for these changes is further discussed in the responses to comments later in this section. Additional details of the unit-specific daily emissions rate provisions are discussed in section VI.B.7 of this document.

ii. Unit-Specific Emissions Limitations Contingent on Assurance Level Exceedances

The second of the trading program enhancements intended to improve emissions performance at the level of individual units is the addition of unit-specific secondary emissions limitations for units with post-combustion controls starting with the 2024 control period. The secondary emissions limitations will be determined on a unit-specific basis according to each unit's individual performance but will apply to a given unit only under the circumstance where a state's assurance level for a control period has been exceeded, the unit is included in a group of units to which responsibility for the exceedance has been apportioned under the program's assurance provisions, and the unit operated during at least 10 percent of the hours in the control period. Where these conditions for application of a secondary emissions limitation to a given unit for a given control period are met, the unit's secondary emissions limitation consists of a prohibition on NO_x emissions during the control

period that exceed by more than 50 tons the NO_x emissions that would have resulted if the unit had achieved an average emissions rate for the control period equal to the higher of 0.10 lb/mmBtu or 125 percent of the unit's lowest average emissions rate for any previous control period under any CSAPR seasonal NO_x trading program during which the unit operated for at least 10 percent of the hours.

The secondary emissions limitation is in addition to, not in lieu of, the primary emissions limitation applicable to each source, which continues to take the form of a requirement to surrender a quantity of allowances based on the source's emissions, and also in addition to the existing assurance provisions, which similarly continue to take the form of a requirement for the owners and operators of some sources to surrender additional allowances when a state's assurance level is exceeded. In contrast to these other requirements, the unit-specific secondary emissions limitation takes the form of a prohibition on emissions over a specified level, such that any emissions by a unit exceeding its secondary emissions limitation would be subject to potential administrative or judicial action and subject to penalties and other forms of relief under the CAA's enforcement authorities. The reason for establishing this form of limitation is that experience under the existing CSAPR trading programs has shown that, in some circumstances, the existing assurance provisions have been insufficient to prevent exceedances of a state's assurance level for a control period even when the likelihood of an exceedance has been foreseeable and the exceedance could have been readily avoided if certain units had operated with emissions rates closer to the lower emissions rates achieved in past control periods. The assurance levels exist to ensure that emissions from each state that contribute significantly to nonattainment or interfere with maintenance of a NAAQS in another state are prohibited. *North Carolina v. EPA*, 531 F.3d 896, 906–08 (D.C. Cir. 2008). The EPA's programs to eliminate significant contribution must therefore achieve this prohibition, and the evidence of foreseeable and avoidable exceedances of the assurance levels demonstrates that EPA's existing approach has not been sufficient to accomplish this.

The purpose of including assurance levels higher than the state emissions budgets in the CSAPR trading programs is to provide flexibility to accommodate operational variability attributable to factors that are largely outside of an

individual owner's or operator's control, not to allow owners and operators to plan to emit at emissions rates that could be anticipated to cause a state's total emissions to exceed the state's emissions budget or assurance level. Conduct leading to a foreseeable, readily avoidable exceedance of a state's assurance level cannot be reconciled with the statutory mandate of the CAA's good neighbor provision that emissions "within the state" significantly contributing to nonattainment or interfering with maintenance of a NAAQS in another state must be prohibited. Because the current CSAPR regulations do not expressly prohibit such conduct and have proven insufficient to deter it in some circumstances, the EPA is correcting the regulatory deficiency in the Group 3 trading program by adding secondary emissions limitations that cannot be complied with through the use of allowances.

The EPA notes that although the purpose of the secondary emissions limitations is to strengthen the assurance provisions, which apply on a statewide, seasonal basis, the unit-specific structure of the new limitations will strengthen the incentives for individual units with post-combustion controls to maintain their emissions performance at levels consistent with their previously demonstrated capabilities. The new limitations will strengthen the incentives to operate and optimize the controls continuously, which can be expected to reduce some individual units' emissions rates throughout the ozone season, including on the days that turn out to be most critical for downwind ozone levels. Better emissions performance on average across the ozone season by individual units likely will also help address impacts of pollution on overburdened communities downwind from some such units. *See Ozone Transport Policy Analysis Final Rule TSD, Section E.*

The unit-specific secondary emissions limitations are being finalized as proposed except that the limitations will apply only to units with post-combustion controls. The rationale for this change, and additional details regarding the provisions, are discussed in section VI.B.8 of this document.

d. Responses to General Comments on the Revisions to the Group 3 Trading Program

This section summarizes and provides the EPA's responses to overarching comments received on the EPA's proposal to implement the emissions reductions required from EGUs under

this rule through expansion and enhancement of the Group 3 trading program originally established in the Revised CSAPR Update, particularly comments on electric system reliability. Responses to comments about individual aspects of the enhanced trading program are addressed in the respective subsections of this section in which those aspects are discussed. Responses to comments concerning alleged overcontrol and the EPA's legal authority are in sections V.D. and III. Comments not addressed in this document are addressed in the separate *RTC* document available in the docket for this action.

Comment: Some commenters, including EGU owners, states, and several RTOs, expressed concern that the requirements for EGUs as formulated in the proposal could lead to a degradation in the reliability of the electric system. As background, some of these commenters noted that the power sector is currently undergoing rapid change, with older and less economic fossil-fuel-fired steam generating units retiring while the majority of the new capacity being added consists of wind and solar capacity. They noted that fossil-fuel-fired generating capacity provides reliability benefits not necessarily provided by other types of generating capacity, including not only the ability to generate electricity in the absence of wind or sunlight, but also inertia, ramping capability, voltage support, and frequency response. Commenters stated that past EGU retirements and the pace of change in the generating capacity mix have already been stressing the electric system in some regions, and that the forecasted risk of events where the electric system would be unable to fully meet load is rising.

For purposes of their comments, these commenters generally assumed that the rule would lead to additional retirements of fossil-fuel-fired generating capacity beyond the retirements that EGU owners have already planned and announced. Some of the commenters also suggested that remaining fossil-fuel-fired generators would be unwilling to operate when needed because allowances might be unavailable for purchase or too costly. In the context of an already-stressed electric system, the commenters predicted that these assumed consequences of the rule would threaten resource adequacy and result in degraded electric reliability. To support their assumptions concerning additional retirements, some of the commenters pointed to projections of incremental generating capacity retirements

included in the results of modeling performed by the EPA to analyze the costs and benefits of the proposed rule. Some commenters indicated that they expected EGU owners to be interested in retiring and replacing uncontrolled units as of the date of implementation of the backstop daily rate requirement on uncontrolled units, and expressed concern that the proposal to implement that requirement as of the 2027 control period did not allow sufficient time for planning and implementation of all the necessary generation and transmission investments to make this a viable compliance strategy; for these commenters, 2027 and the immediately following years were the period of greatest concern. Some commenters appear simply to have assumed that owners of units not already equipped with SCR controls would choose to retire the units as of the ozone season in which the units would otherwise become subject to the backstop daily emissions rate provisions, regardless of whether replacement investments had been completed.

Some of the commenters raising concerns about electric system reliability suggested potential modifications to the proposed rule that the commenters believed could help address their concerns. The suggestions included various mechanisms for suspending some or all of the trading program's requirements for certain EGUs at times when an RTO or other entity responsible for overseeing a region of the interconnected electrical grid determines that generation from those EGUs is needed and the EGUs might not otherwise agree to operate. Other suggestions focused on ways of providing EGUs with greater confidence that allowances would be available to cover their incremental emissions during particular events. A number of commenters used the term "reliability safety valve," in some cases with reference to the types of suggestions just mentioned and in other cases without details. Some commenters pointed to the "safety valve" provision included in the Group 2 trading program regulations under the Revised CSAPR Update. Another commenter pointed to provisions for a "reliability safety valve" included in the Clean Power Plan (80 FR 64662, Oct. 23, 2015).

In addition to offering critiques and recommendations concerning the proposed rule's contents, some commenters claimed that the EPA had failed to conduct sufficient analysis of the potential implications of the proposed rule on electrical system reliability. These commenters called on the EPA to consult with RTOs and other

entities with responsibilities relating to electric system reliability and to perform additional analysis. Some commenters advocated for renewed consultations and analysis before each planned adjustment to emissions budgets under the dynamic budget-setting process. Commenters cited the consultation processes followed during implementation of other EPA rules, such as the Mercury and Air Toxics Standards (MATS) (77 FR 9304, Feb. 16, 2012).

Response: The EPA disagrees with the comments asserting that this rule would threaten resource adequacy or otherwise degrade electric system reliability. The emissions reduction requirements for EGUs under this rule are being implemented through the mechanism of an allowance trading program. Under the trading program, no EGU is required to cease operation. The core trading program requirements for a participating EGU are to monitor and report the unit's NO_x emissions for each ozone season period and to surrender a quantity of allowances after the end of the ozone season based on the reported emissions. To address states' obligations under the good neighbor provision, some units of course will have to take some type of action to reduce emissions, the actions taken to reduce emissions will generally have costs, and some EGU owners will conclude that, all else being equal, retiring a particular EGU and replacing it with cleaner generating capacity is likely to be a more economic option from the perspective of the unit's customers and/or owners than making substantial investments in new emissions controls at the unit. However, the EPA also understands that before implementing such a retirement decision, the unit's owner will follow the processes put in place by the relevant RTO, balancing authority, or state regulator to protect electric system reliability. These processes typically include analysis of the potential impacts of the proposed EGU retirement on electrical system reliability, identification of options for mitigating any identified adverse impacts, and, in some cases, temporary provision of additional revenues to support the EGU's continued operation until longer-term mitigation measures can be put in place. No commenter stated that this rule would somehow authorize any EGU owner to unilaterally retire a unit without following these processes, yet some comments nevertheless assume that is how multiple EGU owners would proceed, in violation of their obligations to RTOs, balancing authorities, or state regulators relating to the provision of

reliable electric service. Assumptions of this nature are simply not reasonable. Like many commenters, the EPA does expect that retirement will be viewed as a more economic compliance strategy for some EGUs than installing new controls, but the Agency also expects that any resulting unit retirements will be carried out through an orderly process in which RTOs, balancing authorities, and state regulators use their powers to ensure that electric system reliability is protected. The trading program inherently provides ample flexibility to allow such an orderly transition to take place. In addition, as discussed later in this section, the EPA has adopted several changes in the final rule to increase flexibility specifically for the early years of the trading program for which commenters have indicated the greatest concerns about electric system reliability.

As an initial matter, the EPA notes two fundamental aspects of this rulemaking which together provide a strong foundation for the Agency's conclusion that the emissions reductions required from EGUs can be achieved with no adverse impacts on electric system reliability. First, there is ample evidence indicating that the required emissions reductions are feasible. As discussed in section V of this document, the magnitude and timing of the EGU emissions reductions required by this action reflect application of technologies that are already in widespread use, on schedules that are supported by industry experience. Second, the required emissions reductions are being implemented through the mechanism of a trading program. The enhanced trading program under this rule, like the trading programs established by the EPA under prior rules, provides EGU owners with opportunities to substitute emissions reductions from sources where achieving reductions is cheaper and easier for emissions reductions from other sources where achieving reductions is more costly or difficult. In general, an EGU owner has options to operate the emissions controls identified by the EPA for that type of unit (including installation or upgrade of controls where necessary), operate other types of emissions controls, or adapt the unit's levels of operation to produce less generation if the unit is a higher-emitting EGU or more generation if the unit is a lower-emitting EGU. The backstop daily emissions rate provisions in this rule reduce the degree of available flexibility relative to the degree of flexibility in the Agency's

previous trading programs under CAIR and CSAPR but by no means eliminate it. Moreover, even the backstop rate provisions are structured as requirements to surrender additional allowances rather than as hard limits, providing a further element of flexibility. No EGU is required to retire or is prohibited from operating at any time under this rule. EGUs only need to surrender of the appropriate quantities of allowances after the end of the control period.³⁰¹

Further, in the large number of comments submitted in this rulemaking that assert concerns over electric system reliability, no commenter has cited a single instance where implementation of an EPA trading program has actually caused an adverse reliability impact. Indeed, similar claims made in the context of the EPA's prior trading program rulemakings have shown a considerable gap between rhetoric and reality. For example, in the litigation over the industry's multiple motions to stay implementation of CSAPR, claims were made that allowing the rule to go into effect would compromise reliability. Yet in the 2012 ozone season starting just over 4 months after the rule was stayed, EGUs covered by CSAPR collectively emitted below the overall program budgets that the rule would have imposed in that year if the rule had been allowed to take effect, with most individual states emitting below their respective state budgets despite CSAPR not being in effect.³⁰² Similarly, in the litigation over the 2015 Clean Power Plan, assertions that the rule would threaten electric system reliability were made by some utilities or their representatives, yet even though the Supreme Court stayed the rule in 2016, the industry achieved the rule's emissions reduction targets without the rule ever going into effect. See *West Virginia v. EPA*, 142 S. Ct. 2587, 2638 (2022) (Kagan, J., dissenting) (“[T]he industry didn’t fall short of the [Clean Power] Plan’s goal; rather, the industry exceeded that target, all on its own. . . . At the time of the repeal . . . there [was] likely to be no difference between a world where the [Clean Power Plan] was implemented and one where it [was] not.”) (quoting 84 FR 32561). The claims that these rules

would have had adverse reliability impacts were proved to be groundless.

Notwithstanding the long experience confirming the ability of the EPA's trading programs to obtain emissions reductions from EGUs without impairing the sector's ability to provide reliable electric service, the Agency of course does not rely here solely on its experience, but has carefully reviewed the comments on this topic for any information that might indicate the appropriateness of modifications to the enhanced trading program as proposed. In recognition of the important role that RTOs play in ensuring electric system reliability, and consistent with the requests of some commenters, the EPA has engaged in outreach to the RTOs that commented on the proposal to better understand their comments specifically and the reliability-related comments of other commenters more generally.³⁰³ Through these meetings, the central reliability-related concern was identified as one of timing. In order for retirement to be a viable compliance strategy for a unit that cannot be entirely spared until replacement investments in generation or transmission are completed, it must be possible for the unit to operate at critical times for a transition period. Like other stakeholders, the RTOs perceived implementation of the backstop daily emissions rate provisions on uncontrolled units as materially strengthening incentives for such units to either install controls or retire. The RTOs were concerned that the option for a coal-fired unit without SCR controls to maintain limited operation while surrendering allowances at a 3-for-1 ratio for all emissions exceeding the backstop daily rate was one that EGU owners would be reluctant to pursue. Accordingly, the RTOs expected considerable interest from EGU owners in retiring and replacing uncontrolled units as of the date of implementation of the backstop daily rate requirement on uncontrolled units, and they were concerned that the proposal to implement that requirement as of the 2027 control period did not allow sufficient time for planning and implementation of all the necessary generation and transmission investments to make this a viable compliance strategy. The RTOs described their concerns as greatest

through approximately the 2029 control period.

The RTOs also described a concern about potentially illiquid allowance markets. They believed it was possible that some EGUs might claim an inability to operate at particular times when needed unless they had confidence that they would be able to obtain additional allowances. The RTOs were particularly concerned that introduction of dynamic budgeting as proposed would create uncertainty for some EGUs regarding the quantities of allowances they would have available for use, particularly given the potentially large year-to-year swings if budgets were based on historical data from a single year. Some of the RTOs suggested potential solutions for these issues, principally in the form of auctions or RTO-administered allocations of allowances from pools of supplemental allowances, with access to the supplemental allowances triggered by certain indications of temporary stress on the electric system.

In the final rule, the EPA is adopting several changes from the proposal to help address the reliability-related concerns that were identified in comments and brought into greater focus by the consultations with the RTOs. The first change adopted in response to these comments is that application of the backstop daily NO_x emissions rate to units without existing SCR controls is being deferred until the 2030 control period, or the second control period in which a unit operates new SCR controls, if earlier. The purpose of this change is to address the concerns that application of the backstop daily NO_x emissions rate to EGUs without existing SCR starting in 2027 would provide insufficient time for planning and investments needed to facilitate unit retirement as a compliance pathway, which some commenters noted they prefer or have already planned. In particular, where an EGU owner would prefer to retire and replace an uncontrolled EGU rather than to install new controls, and in recognition that reliability-related needs may require some degree of operation from such units in the period before the investments needed to replace the unit can be completed, deferral of the backstop daily emissions rate provisions ensures that the necessary generation can be provided without being made subject to a 3-for-1 allowance surrender ratio that might render that compliance strategy uneconomic compared to the faster but less environmentally beneficial compliance strategy of installing new controls. The EPA has considered the statutory mandate that states' good neighbor obligations—

³⁰¹ The EPA has prepared a resource adequacy assessment of the projected impacts of the final rule showing that the projected impacts of the final rule on power system operations, under conditions preserving resource adequacy, are modest and manageable. See *Resource Adequacy and Reliability Analysis Final Rule TSD*, available in the docket.

³⁰² For a state-by-state comparison, see Appendix C of the Ozone Transport Policy Analysis Final Rule TSD.

³⁰³ The EPA also met with non-RTO balancing authorities that submitted comments. Memoranda identifying the dates, attendees, and topics of discussion of these meetings with RTOs and non-RTO balancing authorities are available in the docket.

including this action's requirement for large coal-fired EGUs to make emissions reductions commensurate with good SCR operation—be addressed as expeditiously as practicable. The EPA has also considered the fact that in this rule, the backstop daily emissions rate serves as a supplement to the broader requirement for emissions reductions commensurate with application of several control technologies at several types of EGUs, encompassing the extent of emissions reductions that would be incentivized by the backstop emissions rate requirement. The EPA views the backstop daily emissions rate as part of the solution to eliminating significant contribution in that it strongly incentivizes emissions-control operation throughout each day of the ozone season. See sections III.B.1.d, VI.B.1.b, VI.B.1.c.i. For that reason, in general we are finalizing the daily backstop emissions rate for units that have SCR installed or that install it in the future. It is only as an exception to that general rule that we defer the backstop daily emissions rate given the transition period and reliability concerns identified by commenters. The EPA finds that in this circumstance, as long as state emissions budgets continue to reflect the required degree of emissions reductions, deferral of the backstop rate requirement for uncontrolled units for a transition period can be justified on the basis of the greater long-term environmental benefits obtained through facilitating the replacement of these affected EGUs with cleaner sources of generation. Beginning in the 2030 ozone season, all coal-fired EGUs identified for SCR retrofit potential in this action will be subject to the backstop daily emissions rate. Any such units that remain in operation in that year can and should meet the backstop daily emissions rate or be subject to the heightened allowance surrender ratio.

The second change from the proposal adopted in response to the reliability-related comments is that the target percentage of the states' emissions budgets used to recalibrate the target bank level will be set at the proposed 10.5 percent starting in the 2030 control period, and for the control periods from 2024 through 2029, a target percentage of 21 percent will be used instead. The adoption of the higher target percentage for use through the 2029 control period is intended to promote greater allowance market liquidity during a period of relatively rapid fleet transition about which commenters expressed more focused reliability-related needs. As discussed later in this section, the EPA expects the introduction of the

bank recalibration process in 2024 generally to boost market liquidity (by discouraging allowance hoarding) and also considers the target percentage of 10.5 percent set forth in the proposal well supported. Nevertheless, the Agency agrees with suggestions by commenters that, at least in the early years of the enhanced trading program, a larger bank would provide further liquidity and would give program participants greater confidence that allowances would be available for purchase when needed. Greater confidence by sources would help address RTOs' concern about the possibility that some sources could be reluctant to operate if they were unsure of their ability to procure allowances to cover their emissions. In finding that this modification from proposal is appropriate, the EPA has considered the fact that use of a higher target percentage will not result in the creation of any additional allowances in any control period, because under the recalibration provisions, when the total quantity of allowances banked from the previous control period is less than the bank target level, the consequence is not that additional allowances are created to raise the bank to the target level, but simply that no bank adjustment is carried out. We also note that while including an annual bank recalibration of any percentage is an enhancement in the trading program from prior trading programs under the good neighbor provision established in the CAIR, CSAPR, CSAPR Update, and Revised CSAPR Update rulemakings, it is not unprecedented; the trading program established under the NO_x SIP Call included "progressive flow control" provisions that were designed differently from the bank recalibration provisions in this rule but had the same purpose and general effect.

The third change from the proposal adopted in response to the reliability-related comments is that the EPA is determining preset state emissions budgets not only for the control periods in 2023 and 2024 as proposed, but also for the control periods in 2025 through 2029. Finalizing preset state emissions budgets through 2029 will establish predictable amounts for the minimum quantities of allowances available during the period when commenters have expressed concern that the reliability-related need for such predictability is greatest. Moreover, the EPA will also determine state emissions budgets using the final dynamic budget-setting methodology for the control periods in 2026 through 2029, and for each state and control period, the

dynamic budget to be published in the future will only supplant the preset budget finalized in this rule for a control period in which that dynamic budget is higher than the corresponding preset budget. The reason for using dynamic budgets when they are higher than the corresponding preset budgets is that the EPA recognizes that evolution of the EGU fleet will not follow the exact path projected at the time of the rulemaking, and that by not accounting for certain events, the preset methodology could result in issuance of smaller quantities of allowances than the EPA would find consistent with the quantities of emissions from a well-controlled EGU fleet using the dynamic budget-setting methodology. Events that could cause preset budgets to underpredict a state's well-controlled emissions, which are more likely in years farther in the future from the time of the rulemaking, include deferral of a large EGU's previously planned retirement date or increases in electricity demand that outpace the general trend of lower-emitting or non-emitting generation replacing higher-emitting generation. After considering the commenters' interest in greater predictability during the early years of the amended trading program as well as the need to protect against instances where the preset budgets could underpredict a state's well-controlled emissions in years farther from the year of the rulemaking, the EPA finds that the combination of these factors justifies the approach of using the higher of the two budgets for the control periods from 2026 through 2029.

In addition to the changes made in response to reliability-related comments, several other changes to the proposal being adopted primarily for other reasons will also help address the factors identified as reliability-related concerns. Most notably, the EPA is adopting changes to the dynamic budget computation procedure to incorporate multiple years of heat input data, which will reduce year-to-year variability in the budgets determined under that procedure and should to some extent reduce uncertainty about the quantities of allowances available for use in instances where a dynamic budget is being used instead of preset budget. In addition, the adoption of a 50-ton threshold before application of the 3-for-1 surrender ratio to emissions exceeding the backstop daily NO_x emissions rate should ensure that no unit incurs the higher surrender ratio solely because of unavoidable emissions during startup and should help address concerns that some units might be reluctant to operate because of the associated emissions-

related costs. Also, the 2026–2027 phase-in of emissions reductions commensurate with installation of new SCR controls will increase the quantities of allowances available in the 2026 state emissions budgets for most states in the trading program.

To summarize: in light of the strong record supporting the feasibility of the emissions reductions required from EGUs; the use of a trading program as the mechanism for achieving those emissions reductions, with multiple options for achieving compliance and no requirements to cease operation of any individual EGU at any time; the established processes of RTOs, other balancing authorities, and state regulators for managing any EGU retirement requests that do occur in an orderly manner with evaluation of potential reliability impacts and implementation of mitigation measures where needed; the unbroken, decades-long historical success of the EPA's trading programs at achieving emissions reductions without any adverse reliability impacts; the views expressed by commenters that facilitating EGU retirement and replacement as a possible compliance strategy through 2029 would be particularly helpful; the changes made in the final rule for control periods through 2029 specifically to increase flexibility during this transitional period, including deferring application of the backstop daily emissions rate provisions for EGUs without existing SCR controls, increasing the target percentage used to determine the target allowance bank level for purposes of the bank recalibration provisions, and establishing preset state emissions budgets which serve as floors against potential dynamic budget imposition in those control periods; and the changes made in the final rule incorporating multiple years of heat input data into the dynamic budget-setting procedure, adding a 50-ton threshold before application of the 3-for-1 surrender ratio to emissions exceeding the backstop daily NO_x emissions rate, and phasing in emissions reductions requirements commensurate with new SCR installations through 2027; the EPA concludes that this action does not pose any material risk of adverse impact to electric system reliability.

The EPA has also considered the other suggestions offered by commenters for addressing reliability-related issues. With respect to suggestions that the rule should include provisions allowing some or all of the trading program's requirements to be suspended at times when an RTO or other entity with grid management

responsibilities determines there is a reliability-related need, the EPA again observes that the rule's emissions reduction requirements are being implemented through a trading program mechanism which makes exceptions of this nature unnecessary. Trading programs inherently offer the flexibility to accommodate variability in the utilization of individual units. The "reliability safety valve" provisions in the Clean Power Plan, which one commenter cited as a precedent to support some form of temporary exemption under this rule, in fact was available only in situations where a state plan did not allow emissions trading and instead imposed unit-specific emissions constraints. *See* 80 FR 64877–879. Even the 3-for-1 allowance surrender ratio under the backstop daily NO_x emissions rate provisions can be met through the surrender of additional allowances. The rule does not bar any EGU from operating at any time as long as all allowance surrender requirements are met.

With respect to suggestions that the EPA must undertake recurring modeling of the evolving electrical system and consult with RTOs before each planned adjustment to emissions budgets, which start from the premise that the rule poses risk to electric system reliability that must be continuously monitored, the EPA disagrees with the premise and therefore also disagrees with the suggestions. As discussed in section V of this document, the EPA has taken care to ensure that the emissions reduction requirements applicable to EGUs under this rule are feasible through application of the control technologies selected as the basis of the emissions reductions. The EPA has also performed modeling in this rulemaking to assess the benefits and costs of the rule when all required emissions reductions are achieved. That modeling, which incorporates a representation of electrical grid regions and interregional constraints on energy and capacity exchange, affirms the feasibility of the overall emissions reduction requirements and is illustrative of a control strategy where some units retire and are replaced instead of installing new controls. The EPA has also consulted with the RTOs (as well as other balancing authorities) in the course of this rulemaking to ensure that the EPA understood the concerns expressed in their comments such that we could address those comments in this final rule. The EPA does not agree that further modeling or ongoing consultations with RTOs are needed in

advance of the recurring dynamic budget adjustments, which do not increase the stringency of the rule's emissions reduction requirements established in the final rule. The extensive consultation processes adopted by the Agency in conjunction with the MATS rulemaking are not a relevant precedent; the MATS rule, which was promulgated to address a different statutory mandate, was structured in the form of unit-specific emissions constraints, fundamentally different from the requirements of this rule. The EPA notes that other entities responsible for maintaining reliability and managing entry and exit of resources, including the North American Electric Reliability Corporation (NERC) and RTOs and other balancing authorities, already routinely assess resource adequacy and reliability inclusive of meeting all regulatory requirements, including environmental requirements.

While the EPA does not agree that such consultations are a necessary precondition for successful implementation of this rule, the Agency remains available to engage with any affected EGU or reliability authority requesting to meet and discuss the intersection of its power sector regulatory programs with electric reliability planning and operations. The EPA is also continuing its practice of meeting with the U.S. Department of Energy and the Federal Energy Regulatory Commission to maintain mutual awareness of how Federal actions and programs intersect with the industry's responsibility to maintain electric reliability.³⁰⁴

The EPA is not adopting the suggestion to replicate the so-called "safety valve" mechanism created under the Revised CSAPR Update. That mechanism, cited by some commenters as potential precedent for an unspecified form of "reliability safety valve" in this action, gave owners of covered EGUs a one-time opportunity to voluntarily convert allowances banked under the Group 2 trading program to allowances useable in the Group 3 trading program at an 18-for-1 ratio for use in the trading program's initial control period in 2021. *See* 82 FR 23137–138. EGU owners chose to use the voluntary mechanism to acquire a total of 382 allowances, representing only 0.36 percent of the sum of the state emissions budgets and only 0.26 percent

³⁰⁴ *See, e.g.*, U.S. Department of Energy and U.S. Environmental Protection Agency, Joint Memorandum on Interagency Communication and Consultation on Electric Reliability (March 8, 2023), available at <https://www.epa.gov/power-sector/electric-reliability-mou>.

of the total quantity of allowances available for compliance in that control period.³⁰⁵ For the 2023 control period, the bank of allowances carried over from the 2022 control period plus the incremental starting bank that will be created by conversion of additional allowances banked under the Group 2 trading program (see section VI.B.12.b of this document) will total over 30 percent of the full-season emissions budgets.³⁰⁶ Given the larger starting bank and this rule's bank recalibration provisions (which will be implemented starting with the 2024 control period, but which the EPA expects will increase allowance market liquidity starting with the 2023 control period), the Agency views establishment of a one-time voluntary conversion opportunity for the 2023 control period analogous to the Revised CSAPR Update's "safety valve" provision as unnecessary.

Finally, in the final rule the EPA is not adopting any of the other suggestions concerning additional allowances available through auctions or RTO-administered allowance pools. For the reasons discussed throughout this section, the EPA concludes that the trading program as established in this action provides a flexible compliance mechanism that will allow the required emissions reductions to be achieved without the need for creation of additional allowances. However, the EPA also recognizes the potential for allowance market liquidity to be further increased through some form of auction mechanism. For instance, it may be appropriate to pair the introduction of an auction with a reduction in the bank recalibration percentage that begins earlier than 2030. Through a supplemental rulemaking, the Agency intends to propose and take comment on potential amendments to the Group 3 trading program that would add such an auction mechanism to the regulations and make other appropriate adjustments

³⁰⁵ Additional allowances available for compliance under the Group 3 trading program in the 2021 control period included a starting allowance bank created through mandatory conversion of a portion of the allowances banked under the Group 2 trading program as well as supplemental allowances issued to ensure that no provisions of the Revised CSAPR Update increasing regulatory stringency would take effect before that rule's effective date. See 86 FR 23133–137.

³⁰⁶ The full-season emissions budgets for the 2023 control period under the Group 3 trading program and the incremental starting bank created in this action through conversion of additional Group 2 allowances (but not the bank of allowances carried over from the 2022 control period under the Group 3 trading program) will be prorated to reflect the portion of the 2023 ozone season occurring after the effective date of this rule. See sections VI.B.12.a. and VI.B.12.b.

in the implementation framework at Step 4.³⁰⁷

2. Expansion of Geographic Scope

In light of the findings at Steps 1, 2, and 3 of the 4-step interstate transport framework, the EPA is expanding the geographic scope of the existing CSAPR NO_x Ozone Season Group 3 Trading Program to encompass additional states (and Indian country within the borders of such states) with EGU emissions that significantly contribute for purposes of the 2015 ozone NAAQS. Specifically, the EPA is expanding the Group 3 trading program to include the following states and Indian country within the borders of the states: Alabama, Arkansas, Minnesota, Mississippi, Missouri, Nevada, Oklahoma, Texas, Utah, and Wisconsin. Any unit located in a newly added jurisdiction that meets the applicability criteria for the Group 3 trading program will become an affected unit under the program, as discussed in section VI.B.3 of this document.

CSAPR, the CSAPR Update, and the Revised CSAPR Update also applied to sources in Indian country, although, when those rules were issued, no existing EGUs within the regions covered by the rules were located on lands that the EPA understood at the time to be Indian country.³⁰⁸ In contrast, within the geographic scope of this rulemaking, the EPA is aware of areas of Indian country within the borders of both Utah and Oklahoma with existing EGUs that meet the program's applicability criteria. Issues related to state, tribal, and Federal CAA implementation planning authority with

³⁰⁷ Such a rulemaking would not reopen any determinations which the Agency has made at Steps 1, 2, or 3 of the interstate transport framework in this action. Nor would it reopen any aspects of implementation of the program at Step 4 except for those in relation to establishing an auction and associated adjustments to ensure program stringency is maintained. In this respect, such a rulemaking would constitute a discretionary action that is not necessary to resolution of good neighbor obligations. Rather, these adjustments, if finalized, would reflect a shift from one acceptable form of implementation at Step 4 to a slightly modified but also acceptable form of implementation at Step 4, as related to EGUs. No legal or technical justification for this action as set forth in the record here depends on or would be undermined by the development of an alternative approach that includes an auction, and if the EPA for any reason determines not to propose or finalize such a rulemaking, no aspect of this rule would thereby be rendered infeasible or incomplete.

³⁰⁸ CSAPR and the CSAPR Update both applied to EGUs located in areas within Oklahoma's borders that are now understood to be Indian country, consistent with the U.S. Supreme Court's decision in *McGirt v. Oklahoma*, 140 S. Ct. 2452 (2020) (and subsequent case law), clarifying the extent of certain Indian country within Oklahoma's borders. However, those rules were issued before the *McGirt* decision. See section III.C.2.a.

respect to sources in Indian country in general and in these areas in particular are discussed in section III.C.2 of this document. EPA's approach for determining a portion of each state's budget for each control period that will be set aside for allocation to any units in areas of Indian country within the state not subject to the state's CAA implementation planning authority is discussed in section VI.B.9 of this document.

Units within the borders of each newly added state will join the Group 3 trading program on one of two possible dates during the program's 2023 control period (that is, the period from May 1, 2023, through September 30, 2023). The reason that two entry dates are necessary is that, as discussed in section VI.B.12.a of this document, the effective date is expected to fall after May 1, 2023. In the case of states (and Indian country within the states' borders) whose sources do not currently participate in the CSAPR NO_x Ozone Season Group 2 trading program—Minnesota, Nevada, and Utah—the sources will begin participating in the Group 3 trading program on the rule's effective date. However, in the case of the states (and Indian country within the states' borders) whose sources do currently participate in the Group 2 trading program—Alabama, Arkansas, Mississippi, Missouri, Oklahoma, Texas, and Wisconsin—the sources will begin participating in the Group 3 trading program on May 1, 2023, regardless of the rule's effective date, subject to transitional provisions designed to ensure that the increased stringency of the Group 3 trading program as revised in this rulemaking will not substantively affect the sources' requirements prior to the rule's effective date. This approach provides a simpler transition for the sources historically covered by the Group 2 trading program than the alternative approach of being required to switch from the Group 2 trading program to the Group 3 trading program in the middle of a control period, and it is the same approach that was followed for sources that transitioned from the Group 2 trading program to the Group 3 trading program in 2021 under the Revised CSAPR Update. Section VI.B.12.a of this document contains further discussion of the rationale for this approach and the specific transitional provisions.

The EPA notes that under the rule, the expanded Group 3 trading program will include not only 19 states for which the EPA is determining that the required control stringency includes, among other measures, installation of new post-combustion controls, but also three

states—Alabama, Minnesota, and Wisconsin—for which the EPA is determining that the required control stringency does not include such measures. In previous rulemakings, the EPA has chosen to combine states in a single multi-state trading program only where the selected control stringencies were comparable, to ensure that states did not effectively shift their emissions reduction requirements to other states with less stringent emissions reduction requirements by using net out-of-state purchased allowances. Although the assurance provisions in the CSAPR trading programs were designed to address the same general concern about excessive shifting of emissions reduction activities between states, EPA chose not to rely on the assurance provisions as sufficient to allow for interstate trading in situations where the states were assigned differing emissions control stringencies.

In this rulemaking, the EPA believes the previous concern about the possibility that certain states might not make the required emissions reductions is sufficiently addressed through the various enhancements to the design of the trading program, even where states have been assigned differing emissions control stringencies. First, the existing assurance provisions are being substantially strengthened through the addition of the unit-specific secondary emissions limitations discussed in sections VI.B.1.c.ii and VI.B.8. Second, by ensuring that individual units operate their emissions controls effectively, the unit-specific backstop daily emissions rate provisions discussed in sections VI.B.1.c.i and VI.B.7 will necessarily also ensure that required emissions reductions occur within the state. With these enhancements to the design of the trading program, the EPA does not believe it is necessary for sources in Alabama, Minnesota, and Wisconsin to be excluded from the revised Group 3 trading program simply because their emissions budgets reflect a different selected emissions control stringency than the other states in the program.

The EPA's legal and analytic bases for expansion of the Group 3 trading program to each of the additional covered states, as well as responses to the principal related comments, are discussed in sections III, IV, and V of this document, respectively, and responses to additional comments are contained in the *RTC* document. With respect to the proposed approach of including all states covered by the rule in a single trading program even where the assigned control stringencies differ, the only comments received by the EPA

supported the approach, which is finalized as proposed.

3. Applicability and Tentative Identification of Newly Affected Units

The Group 3 trading program generally applies to any stationary, fossil-fuel-fired boiler or stationary, fossil fuel-fired combustion turbine located in a covered state (or Indian country within the borders of a covered state) and serving at any time on or after January 1, 2005, a generator with nameplate capacity exceeding 25 MW and producing electricity for sale, with exemptions for certain cogeneration units and certain solid waste incineration units. To qualify for an exemption as a cogeneration unit, an otherwise-affected unit generally (1) must be designed to produce electricity and useful thermal energy through the sequential use of energy, (2) must convert energy inputs to energy outputs with efficiency exceeding specified minimum levels, and (3) may not produce electricity for sale in amounts above specified thresholds. To qualify for an exemption as a solid waste incineration unit, an otherwise-affected unit generally (1) must meet the CAA section 129(g)(1) definition of a “solid waste incineration unit” and (2) may not consume fossil fuel in amounts above specified thresholds. The complete text of the Group 3 trading program's applicability provisions and the associated definitions can be found at 40 CFR 97.1004 and 97.1002, respectively. The applicability of this rule to MWCs and cogeneration units outside the Group 3 trading program is discussed in sections V.B.3.a and V.B.3.c of this document, respectively, and MWC applicability criteria are further discussed in section VI.C.6 of this document.

In this rulemaking, the EPA did not propose and is not finalizing any revisions to the existing applicability provisions for the Group 3 trading program. Thus, any unit that is located in a newly added state and that meets the existing applicability criteria for the Group 3 trading program will become an affected unit under the program. The fact that the applicability criteria for all of the CSAPR trading programs are identical therefore is sufficient to establish that any units that are currently required to participate in another CSAPR trading program in any of the additional states where such other programs currently are in effect—Alabama, Arkansas, Minnesota, Mississippi, Missouri, Oklahoma, Texas, and Wisconsin (including Indian country within the borders of such

states)—will also become subject to the Group 3 trading program.

In the additional states where other CSAPR trading programs are not currently in effect—Nevada and Utah (including Indian country within the borders of such states)—units already subject to the Acid Rain Program under that program's applicability criteria (see 40 CFR 72.6) generally also meet the applicability criteria for the Group 3 trading program. Based on a preliminary screening analysis of the units in these states that currently report emissions and operating data to the EPA under the Acid Rain Program, the Agency believes that all such units are likely to meet the applicability criteria for the Group 3 trading program.

Because the applicability criteria for the Acid Rain Program and the Group 3 trading program are not identical, it is possible that some units could meet the applicability criteria for the Group 3 trading program even if they are not subject to the Acid Rain Program. Using data reported to the U.S. Energy Information Administration, in the proposal the EPA identified six sources in Nevada and Utah (and Indian country within the borders of the states) with a total of 15 units that appear to meet the general applicability criteria for the Group 3 trading program and that do not currently report NO_x emissions and operating data to the EPA under the Acid Rain Program. These units were listed in a table in the proposed rule, and the data from that table for these units are reproduced as Table VI.B.3–1 of this document. For each of these units, the table shows the estimated historical heat input and emissions data that the EPA proposed to use for the unit when determining state emissions budgets if the unit was ultimately treated as subject to the Group 3 trading program.³⁰⁹ The EPA requested comment on whether each listed unit would or would not meet all relevant criteria set forth in 40 CFR 97.1004 and the associated definitions in 97.1002 to qualify for an exemption from the trading program and whether the estimated historical heat input and emissions data identified for each unit

³⁰⁹ As discussed in section VI.B.10, any unit that becomes subject to the Group 3 trading program pursuant to this rule and that does not already report emissions data to the EPA in accordance with 40 CFR part 75 will not be required to report emissions data or be subject to allowance holding requirements under the Group 3 trading program until May 1, 2024, in order to provide time for installation and certification of the required monitoring systems. Such a unit will not be taken into account for purposes of determining state emissions budgets and unit-level allocations under the Group 3 trading program until the 2024 control period.

were representative. With respect to the listed units within the borders of Nevada or Utah, the EPA received no comments asserting either that the units qualified for applicability exemptions or that the estimated data identified by the

EPA were unrepresentative.³¹⁰ For purposes of this rule, the EPA is therefore presuming that the units listed in Table VI.B.3–1 do not qualify for applicability exemptions and that the estimated data shown in the table for

each unit are representative. However, the owners and operators of the sources retain the option to seek applicability determinations under the trading program regulations at 40 CFR 97.1004(c).

TABLE VI.B.3–1—ESTIMATED DATA TO BE USED FOR PRESUMPTIVELY AFFECTED UNITS WITHIN THE BORDERS OF NEVADA AND UTAH THAT DO NOT REPORT UNDER THE ACID RAIN PROGRAM

State	Facility ID	Facility name	Unit ID	Unit type	Estimated ozone season heat input (mmBtu)	Estimated ozone season average NO _x emissions rate (lb/mmBtu)	Notes
Nevada	2322	Clark	GT4	CT	190,985	0.0475	
Nevada	2322	Clark	GT5	CT	1,455,741	0.0191	
Nevada	2322	Clark	GT6	CT	1,455,741	0.0187	
Nevada	2322	Clark	GT7	CT	1,455,741	0.0178	
Nevada	2322	Clark	GT8	CT	1,455,741	0.0204	
Nevada	54350	Nev. Cogen. Assoc. 1—Garnet Val	GTA	CT	660,100	0.0377	1
Nevada	54350	Nev. Cogen. Assoc. 1—Garnet Val	GTB	CT	660,100	0.0387	1
Nevada	54350	Nev. Cogen. Assoc. 1—Garnet Val	GTC	CT	660,100	0.0387	1
Nevada	54349	Nev. Cogen. Assoc. 2—Black Mtn ..	GTA	CT	749,778	0.0323	1
Nevada	54349	Nev. Cogen. Assoc. 2—Black Mtn ..	GTB	CT	749,778	0.0370	1
Nevada	54349	Nev. Cogen. Assoc. 2—Black Mtn ..	GTC	CT	749,778	0.0364	1
Nevada	56405	Nevada Solar One	HI	Boiler	479,452	0.1667	
Nevada	54271	Saguaro	CTG1	CT	1,383,149	0.0314	1
Nevada	54271	Saguaro	CTG2	CT	1,383,149	0.0301	1
Utah	50951	Sunnyside	1	Boiler	1,888,174	0.1715	

Table notes:

¹ Unit reports capability of producing both electricity and useful thermal energy.

4. State Emissions Budgets

In this final rule, the EPA is using a combination of a “preset” budget calculation methodology and a “dynamic” budget calculation methodology to establish state emissions budgets for the Group 3 trading program. A “preset” budget is one for which the absolute amount expressed as tons per ozone season control period is established in this final rule. It uses the latest data currently available on EGU fleet composition at the time of this final action. A “dynamic” budget is one for which the formula and emissions-rate information is finalized in this rule, but updated EGU heat input and inventory information is used on a rolling basis to set the total tons per ozone season for each control period. Both methods of budget calculation are designed to set budgets reflective of the emissions control strategies and associated stringency levels (expressed as an emissions rate of pounds of NO_x per mmBtu) identified for relevant EGU types at Step 3—which we will refer to in this section as the “Step 3 emissions

control stringency.” Preset budgets provide greater certainty for planning purposes and can be reliably established in the short-term based on known, upcoming changes in the EGU fleet. Due to build time for new units and planning and approval processes for plant retirements, these major fleet alterations are often known several years in advance. This information facilitates presetting budgets that appropriately calibrate the identified control stringency to the fleet. Dynamic budgets better assure that the budgets remain commensurate with the Step 3 emissions control stringency over the longer term, as currently unknown changes in the EGU fleet occur. In this final rule, in response to comments, we have adjusted the proposal to give a greater role for preset budgets through 2029, while dynamic budgeting will be phased in to provide greater certainty in the short term and allow for a transition period to an exclusively “dynamic” approach beginning in 2030.

For the control periods from 2023 through 2025, the preset budgets established in the rule will serve as the state emissions budgets for the control

periods in those years, with no role for dynamic budgeting. For the control periods from 2026 through 2029, the EPA is determining preset emissions budgets for each control period in the rule and will also calculate and publish dynamic budgets for each state in the year before each control period using the dynamic budget-setting methodology finalized in this rule, applied to data available at the time of the calculations. For these four control periods, each state’s preset budget serves as a floor and may be supplanted by the dynamic emissions budget EPA calculates for the state for that control period only if the dynamic budget is higher than the preset budget. For control periods in 2030 and thereafter, the state emissions budgets will be the dynamic budgets calculated and published in the year before each control period.

In the dynamic budget calculation methodology, it is the fleet composition (reflected by heat input patterns across the fleet in service, inclusive of EGU entry and exit) that is dynamic, while the emissions stringency finalized in this rule is constant, as reflected in

³¹⁰ One commenter expressed the view that eight of the listed units within Nevada’s borders appear to meet the CSAPR applicability criteria but provided no comments on the specific proposed data. See comments of Berkshire Hathaway Energy,

EPA-HQ-OAR-2021-0668-0554, at 58–59. The EPA also received comments concerning sources within Delaware’s borders that were included in the proposal’s request for comment; these comments are moot because Delaware is not being added to

the Group 3 trading program in the final rule. See comments of Calpine, EPA-HQ-OAR-2021-0668-0515; comments of Delaware City Refining, EPA-HQ-OAR-2021-0668-0309.

emissions rates for various types of units. Multiplying the assumed emissions rate for each unit (as finalized in this rule) by the identified recent historical heat input for each unit and summing the results to the state level would provide a given year's state dynamic emissions budgets. Dynamic budgets are a product of the formula promulgated in this action applied to a rolling three-year average of reported heat input data at the state level and a rolling highest-three-of-five-year average of reported heat input data at the unit level. As such, the EPA is confident that dynamic budgets will more accurately reflect power sector composition, particularly in later years, and certainly from 2030 and beyond, than preset budgets could and will therefore better implement the Step 3 emissions control stringency over long time horizons.

Starting in 2025 (for the 2026 control period), the dynamic budgets, along with the underlying data and calculations will be publicly announced, and this will occur approximately one year before the relevant control period begins. These will be published in the **Federal Register** through notices of data availability (NODAs), similar to how other periodic actions that are ministerial in nature to implement the trading programs are currently handled. And as with such other actions, interested parties will have the opportunity to seek corrections or administrative adjudication under 40 CFR part 78 if they believe any data used in making these calculations, or the calculations themselves, are in error.

To illustrate how dynamic budgeting will work after the transition from preset budgets, the dynamic budgets for the 2030 ozone season control period will be identified by May 1, 2029, using the latest available average of three years of reported operational data at that time (*i.e.*, the average of 2026–2028 heat input data at the state level and 2024–2028 years of rolling data at the unit level) applied in a simple mathematical formula finalized in this rule, which multiplies this heat input data by the emissions rates quantified in this rule. Therefore, if a unit retires before the start of the 2028 ozone season but had not announced its upcoming retirement at the time of this rule's finalization, the dynamic budget approach ensures that the dynamic budgets for 2030 and subsequent control periods would represent the identified control stringency applied to a fleet reflecting that retirement.

The two examples discussed next illustrate the implementation of the dynamic budget during the 2026–2029

time period. During this period, the state emissions budget for each state for a given control period will be the preset state emissions budget unless the dynamic budget is higher. This approach accommodates scenarios where baseline fossil heat input may exceed levels anticipated by EPA in the preset budgets (*e.g.*, this could result from greater electric vehicle penetration rates). Table VI.B.4–1 illustrates this scenario. In the preset budget approach for 2028, the 2028 heat input is estimated based on the latest available heat input data at the time of rule proposal (*i.e.*, 2021; see the subsection on preset budget methodology later in this section), which cannot reflect a subsequent change in fleet heat input values (column 2) due to, *e.g.*, increased utilization to meet increased electric load. However, the dynamic budget would use 2022–2026 heat input values at the unit level and 2024–2026 heat input values at the state level—as opposed to 2021 heat input values—as the latest representative values to inform the 2028 state emissions budget. Therefore, the heat input values in column 2 under the dynamic scenario reflect the change in fleet utilization levels, and when multiplied by the emissions rates reflecting the Step 3 emissions control stringency in this final rule, the corresponding emissions (18,700 tons) summed in column 4 constitute a state budget that more accurately reflects the Step 3 emissions control stringency applied to the fleet composition for that year, as opposed to the 17,000 tons identified in the preset budget approach. As illustrated in the example, the dynamic variable is the heat input variable, which changes over time. In this instance, the dynamic budget value of 18,700 tons would be implemented for 2028 instead of the preset value, and thus accommodate the unforeseen utilization changes in response to higher demand.

In the second table, Table VI.B.4–2, the dynamic budget is lower than the preset budget due to retirements that were not foreseen at the time the preset budgets were determined. In the preset budget approach for 2028, the 2028 heat input is still estimated based on the latest available heat input data at the time of rule proposal (*i.e.*, 2021), which cannot reflect a subsequent fleet change in heat input values due to an unanticipated retirement of one of the state's coal-fired units before the start of the 2028 ozone season. However, the dynamic budget again would use 2022–2026 heat input values at the unit level and 2024–2026 heat input values at the state level—as opposed to 2021 heat

input values—as the latest representative values to inform the 2028 state emissions budget, which would reflect the decline in coal heat input and replacement with natural gas heat input (capturing the coal unit's retirement). Therefore, the heat input values under the dynamic budget scenario reflect the change in fleet composition, and when multiplied by the relevant emissions rates reflecting the Step 3 emissions control stringency identified in this final rule, the corresponding emissions (15,000 tons) constitute a state budget that reflects the identified control stringency applied to the fleet composition for that year as opposed to the 17,000 tons in summed in the first table. However, for the 2026–2029 period, in which the EPA implements an approach that utilizes the higher of the dynamic budget or preset budget, the budget implemented for 2028 in this scenario would be the 17,000 ton preset amount.

During the 2026–2029 transition period—during which substantial, publicly announced utility commitments exist for higher emitting units to exit the fleet—it is still possible that yet-to-be known, unit-specific retirements (such as illustrated in this second scenario) may result in dynamic budgets that are lower than the preset budgets finalized in this rule. However, during this transition period EPA believes that having the preset budgets serve as floors for the state emissions budgets is appropriate for two primary reasons identified by commenters. First, commenters repeatedly emphasized the need for certainty and flexibility to successfully carryout plans for significant fleet transition through the end of the decade. The 2026–2029 period is expected to have substantial fleet turnover. Current Form EIA–860 data, in which utilities report their retirement plans, identify 2028 as the year with the most planned coal capacity retirements during the 2023–2029 timeframe. Using preset budgets as state emissions budget floors provides states and utilities with information on minimum quantities of allowances that can be used for planning purposes. In turn, this fosters the operational flexibility needed while putting generation and transmission solutions into place to accommodate such elevated levels of retirements. Second, the latter part of the decade has a significant amount of unit-level firm retirements already planned and announced for purposes of compliance with other power sector regulations or fulfillment of utility commitments. These known retirements are already

captured in the preset state budgets, with the result that the likelihood and magnitude of instances where a state's dynamic budget for a given control period would be lower than its preset budget for the control period is reduced in this 2026–2029 period relative to control periods further in the future for which retirement plans have not yet been announced. After 2029, the dynamic budgets from 2030 forward

will fully capture all prior retirements and new builds when the fleet is entering this period where unit-specific data on such plans is less frequently available. For instance, through the remaining portion of the decade, the amount of coal steam retirements identified and reported through Form EIA–860 is nearly 7 GW each year. However, for the decade beginning in 2030—the amount of capacity currently

reported with a planned retirement is less than 2 GW each year.³¹¹ This yet-to-be available data and relative lack of currently known firm retirement plans for 2030 and beyond make dynamic budget implementation for those years essential for state emissions budgets to maintain the Step 3 control stringency required under this rule.

TABLE VI.B.4–1—EXAMPLE OF PRESET AND DYNAMIC BUDGET CALCULATION IN SCENARIO OF INCREASED FOSSIL HEAT INPUT

	Preset budget approach (2028)			Dynamic budget approach (2028)		
	Preset heat input (tBtu)	Preset emissions rate (lb/mmBtu)	Preset tons (heat input × emissions rate)/2000	Heat input (tBtu)	Emissions rate (lb/mmBtu)	Tons (heat input × emissions rate)/2000
Coal Units	600	0.05	15,000	660	0.05	16,500
Gas Units	400	0.01	2,000	440	0.01	2,200
State Budget (tons)	17,000	18,700

TABLE VI.B.4–2—EXAMPLE OF PRESET AND DYNAMIC BUDGET CALCULATION IN SCENARIO OF UNANTICIPATED RETIREMENT

	Preset budget approach (2028)			Dynamic budget approach (2028)		
	Preset heat input (tBtu)	Preset emissions rate (lb/mmBtu)	Preset tons (heat input × emissions rate)/2000	Heat input (tBtu)	Emissions rate (lb/mmBtu)	Tons (heat input × emissions rate)/2000
Coal Units	600	0.05	15,000	500	0.05	12,500
Gas Units	400	0.01	2,000	500	0.01	2,500
State Budget (tons)	17,000	15,000

In summary, for the control periods in 2023 through 2025, EPA is providing only preset budgets in this final rule because those control periods are in the immediate future and would not substantially benefit from the use of future reported data. For these years, the certainty around new builds and retirements is higher than ensuing years. For the ozone season control periods of 2026 through 2029, EPA is providing both preset budgets in this final rule and dynamic budgets via future ministerial actions. For those control periods from 2026 through 2029, the preset budgets finalized in this rule serve as floors, such that a given state's dynamic budget ultimately calculated and published for that control period will apply to that state's affected EGUs only if it is higher than the corresponding preset budget finalized in this rulemaking. This approach is in response to stakeholder comments requesting more advance

notice regarding the total quantities of allowances available to accommodate compliance planning through the latter half of the decade, during a period of particularly high fleet transition expected with or without this rulemaking.

EPA's emissions budget methodology and formula for establishing Group 3 budgets are described in detail in the Ozone Transport Policy Analysis Final Rule TSD and summarized later in this section.

a. Methodology for Determining Preset State Emissions Budgets for the 2023 Through 2029 Control Periods

To compose preset state emissions budgets, the EPA is using the best available data at the time of developing this final rule regarding retirements and new builds. The EPA relies on a compilation of data from Form EIA–860 (where facilities report their future

retirement plans), the PJM Retirement Tracker, utilities' integrated resource plans, notification of compliance plans with other EPA power sector regulatory requirements, and other information sources that EPA routinely canvasses to populate the data fields included in the Agency's NEEDS database. The EPA has updated this data on retirements and new builds using the latest information available from these sources at the time of final rule development as well as input provided by commenters.

For determining preset state emissions budgets, the EPA generally uses historical ozone season data from the 2021 ozone season, the most recent data available to EPA and to commenters responding to this rulemaking's proposal and providing a reasonable representation of near-term fleet conditions. This is similar to the approach taken in the CSAPR Update and the Revised CSAPR Update, where

³¹¹ See 2021 Form EIA Form 860—Schedule 3, Generator Data. Department of Energy, Energy Information Administration.

the EPA likewise began with data for the most recent ozone season at the time of proposal (2015 and 2019, respectively).

By using historical unit-level NO_x emissions rates, heat input, and emissions data in the first stage of determining preset emissions budgets, the EPA is grounding its budgets in the most recent representative historical operation for the covered units at the time EPA began its final rulemaking. This data set is a reasonable starting point for the budget-setting process as it reflects recent publicly available and quality assured data reported by affected facilities under 40 CFR part 75, largely using CEMS. The reporting requirements include quality control measures, verification measures, and instrumentation to best record and report the data. In addition, the designated representatives of EGU sources are required to attest to the accuracy and completeness of the data.

The first step in deriving the future year state emissions budget is to calibrate historical data to planned future fleet conditions. EPA does this by adjusting this historical baseline information to reflect the known changes (e.g., when deriving the 2023 state emissions budget, EPA starts by

adjusting 2021 unit-level data to reflect changes announced and planned to occur by 2023). The EPA adjusted the 2021 ozone-season data to reflect committed fleet changes expected to occur in the baseline. This includes announced and confirmed retirements, new builds, and retrofits that occur after 2021 but prior to 2023. For example, if a unit emitted in 2021, but retired prior to May 1, 2022, its 2021 emissions would not be included in the 2023 baseline estimate. For units that had no known changes, the EPA uses the actual emissions, heat input, and emissions rates reported for 2021 as the baseline starting point for calculating the 2023 state emissions budgets. Using this method, the EPA arrived at a baseline emission, heat input, and emissions rate estimate for each unit for a future year (e.g., 2023).

The second step in deriving the preset state emissions budgets is for EPA to take the adjusted historical data from Step 1, and adjust the emissions rates and mass emissions to reflect the control stringencies identified as appropriate for EGUs of that type. For instance, if an SCR-equipped unit was not operating its SCR so as to achieve a seasonal average emissions rate of 0.08

lb/mmBtu or less in the historical baseline, the EPA lowered that unit's assumed emissions rate to 0.08 lb/mmBtu and calculated the impact on the unit's mass emissions. Note that the heat input is held constant for the unit in the process, reflecting the same level of unit operation compared to historical 2021 data. The improved emissions rate of 0.08 lb/mmBtu is applied to this constant heat input, reflecting control optimization. In this manner, the unit-level totals from Step 1 are adjusted to reflect the additional application of the assumed control technology at a given control stringency. This is illustrated in Table VI.B.4.a–1. Row 1 reflects the 2021 historical data for this SCR-controlled unit. Row 2 reflects no change (as there are no known changes such as planned retirement or coal-to-gas conversion). Row 3 reflects application of the Step 3 stringency (i.e., a 0.08 lb/mmBtu emissions rate from SCR optimization). The resulting impact on emissions is a reduction from the historical 4,700 tons to an expected future level of 615 tons. A state's preset budget for a given control period is the sum of the amounts computed in this manner for each unit in the state for the control period.

TABLE VI.B.4.a–1—EXAMPLE OF UNIT-LEVEL DATA CALCULATIONS FOR DERIVING STATE EMISSIONS BUDGETS

	Heat input (tBtu)	Emission rate (lb/mmBtu)	Emissions (tons)
Historical Data (2021)	15.384	0.61	4,700
Step 1 (Baseline)—Historical data adjusted for planned changes	15.384	0.61	4,700
Step 2—Baseline further adjusted for Step 3 stringency	15.384	0.08	615

For each control period from 2026 onward, the unit-specific emissions rates assumed for all affected states except Alabama, Minnesota, and Wisconsin will reflect the selected control stringency that incorporates post-combustion control retrofit opportunities for the relevant units identified in the state emissions budgets and calculations appendix to the Ozone Transport Policy Analysis Final Rule TSD. The emissions rates assigned to large coal-fired EGUs for 2026 state emissions budget computations only reflect 50 percent of the SCR retrofit emissions reduction potential at each of those units, to capture the phase-in approach EPA is taking for this control as described in section VI.A of this document. The EPA calculates these unit-level emissions rates in 2026 as the sum of the unit's baseline emissions rate and its controlled emissions rate divided by two (i.e., 50 percent of the emissions reduction potential of that

pollution control measure). The emissions rates assigned to these large coal-fired EGUs for 2027 state emissions budget computations reflect the full assumed SCR retrofit emissions potential at those units, by applying the controlled emissions rate only. For example, a coal steam unit greater than or equal to 100 MW currently lacking a SCR and emitting at 0.20 lb/mmBtu would be assumed to reduce its emissions rate to 0.125 lb/mmBtu rate in 2026 and 0.050 lb/mmBtu rate in 2027 for purposes of deriving its preset state emissions budgets in those years.

Comment: Some commenters suggested that EPA should not reflect planned retirements in its preset budgets. The suggestion stems from commenters' observation that those retirement decisions may yet change.

Response: The effectiveness of EPA's future year preset state emissions budgets depends on how well they are calibrated to the expected future fleet.

Therefore, EPA believes it is important to incorporate expected new builds, retirements, and unit changes already slated to occur. Ignoring these factors would dilute, rather than strengthen, the ability of preset budgets to capture the most representative fleet of EGUs to which they will be applied. Omitting scheduled retirements and new builds from state emissions budgets would reflect units that power sector operators and planning authorities do not expect to exist, while failing to reflect units that are expected to exist.

EPA notes it is using the best available data at the time of the final rule. EPA relies on a compilation of data from Form EIA–860 where facilities report their future retirement plans. In addition, EPA is using data from regional transmission organizations who are cataloging, evaluating, and approving such retirement plans and data; data from notifications submitted directly to EPA by the utility themselves

through comments; and retirement notifications submitted to permitting authorities. This information is highly reliable, real-world information that provides EPA with the high confidence that such retirements will in fact occur.

If a unit's future retirement does not occur on the currently scheduled date, EPA observes that such an unexpected departure from the currently available evidence would still not undermine the ability of affected EGUs to comply with their applicable state budgets. EPA's approach of using historical data and incorporation only of announced fleet changes in estimating its future engineering analytics baseline means that its future year baseline generation and retirement outlook for higher emitting sources is more likely to understate future retirements (rather than overstate as suggested by commenter), as EPA does not assume for the purpose of preset budget quantification any retirements beyond those that are already planned. In other words, in the 2023 through 2029 timeframe for which EPA is establishing preset state emissions budgets in this rulemaking, there are more likely to be additional future EGU retirements beyond those scheduled prior to the finalization of this rule than there are to be reversed or substantially delayed changes to already announced EGU retirement plans. For instance, subsequent to the EPA's finalization of the Revised CSAPR Update Rule budgets for 2023 (rule finalized in March 2021), the owners of Sammis Units 5–7 and Zimmer Unit 1 in Ohio (totaling nearly 3 GW of coal capacity) announced that the units would retire by 2023—nearly 5 years earlier than previously planned.^{312 313} These coal retirements were not captured in Ohio's 2023 or 2024 state emissions budgets established under the Revised CSAPR Update. Meanwhile, there have been no announcements of previously announced retirement plans being rescinded or delayed for other Ohio units. Similarly, the Joppa Power Plant in Illinois accelerated its retirement from 2025 to 2022 shortly after the Revised CSAPR Update Rule was signed.³¹⁴

³¹² Available at <https://www.prnewswire.com/news-releases/energy-harbor-transitions-to-100-carbon-free-energy-infrastructure-company-in-2023-301501879.html>.

³¹³ Available at <https://www.spglobal.com/commodityinsights/en/market-insights/latest-news/coal/071921-vistra-plans-to-retire-13-gw-zimmer-coal-plant-in-ohio-five-years-early>.

³¹⁴ Available at <https://www.prnewswire.com/news-releases/joppa-power-plant-to-close-in-2022-as-company-transitions-to-a-cleaner-future-301263013.html>.

We further observe that the commenters' concern is only materially meaningful for the 2023 through 2025 preset budget periods, where the currently known information is generally the most reliable. For the 2026–2029 control periods, if an anticipated fleet change such as an EGU retirement does not actually occur, the dynamic budget setting methodology would, all else being equal, generate a budget reflective of that unit's continued operation (as the budget would be based on the preceding years of historical data), and that dynamic budget will supplant the preset budget for that state (if it represents a total quantity of emissions higher than the preset budget).

Because the future is inherently uncertain, all analytic tools and information resources used in any estimation of future EGU emissions will yield some differences between the projected future and the realized future. Such potential differences may either increase or decrease future emissions in practice, and the unavoidable existence of such differences does not, on its own, render the EPA's inclusion of currently announced retirements an unreasonable feature of the methodology for determining future year preset emissions budgets. To the contrary, if the EPA failed to include these announced retirements, the rule would knowingly authorize amounts of additional, sustained pollution that are not currently expected to occur. If those retirements largely or entirely occur as currently scheduled, the overestimated state budgets would allow other EGUs to emit additional pollution in place of the emissions from the retired EGUs instead of maintaining or improving their emissions performance to eliminate significant contribution with nonattainment and interference with maintenance of the NAAQS.³¹⁵

Additionally, as noted elsewhere, EPA's use of a market-based program, a starting bank of converted allowances, and variability limits are all features that will readily accommodate whatever relatively limited differences in emissions may occur if a currently scheduled EGU retirement is ultimately postponed during the preset budget years of 2023 through 2025. Therefore, EPA's resulting preset state emissions budgets—inclusive of expected fleet turnover—are robust to the inherent uncertainty in future year baseline

³¹⁵ Some of these announced retirements reflect the operator's reported intention to EPA to retire the affected capacity by that time as part of their compliance with effluent limitation guidelines or with the coal combustion residuals rule.

conditions for the period in which they are applied.

Comment: Some commenters suggested that EPA should use a multi-year baseline for all of its state budget derivations, including preset budgets, to control for outlier years that may not be representative of future years due to major weather events or other fleet disruptions (such as a large nuclear unit outage).

Response: For preset state emissions budget derivation, EPA is finalizing use of the same single-year³¹⁶ historical baseline approach it used in the proposed rule. This approach is similar to the Revised CSAPR Update, where EPA also relied on a single-year historical baseline to inform its Step 3 approach. EPA's interest in a historical data set to inform this part of the analysis is to capture the most representative view of the power sector. For estimating preset state budgets, EPA finds that, particularly at the state level, more recent data is a better representation and basis for future year baselines rather than incorporating older data. Taking as an example preset budget estimation for the 2023 through 2025 ozone seasons, the EPA is able to compare its single-year base line to an alternative multi-year baseline (e.g., a 3-year baseline encompassing 2020–2022) and determine that the single year baseline better reflects future fleet operation expectation than a multi-year baseline that incorporates units which have since retired as well as outlier patterns in load during pandemic-related shutdowns.

EPA recognizes that 2021 is the latest available historical data as of the preparation of this rulemaking, and therefore the most up-to-date picture of the fleet at the time EPA began its analysis. EPA then further evaluates the 2021 historical data at the state level to determine whether it was a representative starting point for estimating future year baseline levels and subsequently deriving the preset state emissions budgets. If the Agency finds any state-level anomalies, it makes necessary adjustments to the data. While unit-level variation may occur from year-to-year, those variations are often offset by substitute generation from other units within the state. Therefore, EPA conducts its first screening at the state level by identifying any states where 2021 heat

³¹⁶ For the purposes of this rulemaking, when describing a "year" or "years" of data utilized in state emission budget computations, the EPA is actually utilizing the relevant data from May 1 through September 30 of the referenced year(s), consistent with the control period duration of this rule's EGU trading program.

input and 2021 emissions were the lowest year for heat input and emissions relative to the past several years (2018–2022, excluding 2020 due to shut downs and corresponding reduced utilization related to the pandemic onset).^{317 318} Then, for that limited number of states (AL, LA, MS, and TX) in which 2021 reflects the minimum fossil fuel heat input and minimum emissions over the baseline evaluation period, EPA—similar to prior rules—evaluated whether any unit-level anomalies in operation were driving this lower heat input at the state level. EPA examined unit-level 2021 outages to determine where an individual unit-level outage might yield a significant difference in state heat input, corresponding emissions baseline and resulting state emissions budgets. When applying this test to all of the units in the previously identified states (and even when applying to EGUs in all states for whom Federal implementation plans are finalized in this rulemaking), the EPA determined that the only unit with a 2021 outage that (1) decreased its output relative to preceding or subsequent years by 75 percent or more (signifying an outage), and (2) could potentially impact the state’s emissions budget substantially as it constituted more than 5 percent of the state’s heat input in a non-outage year was Daniel Unit 2 in Mississippi. EPA therefore adjusted this state’s baseline heat input and NO_x emissions to reflect the operation of this unit based on its 2019 data—which was the second most recent year of data available at the time of proposal (excluding 2020 given atypical impacts from pandemic-related shutdowns) for which this unit operated. The EPA then applied the Step 3 mitigation strategies as appropriate to this unit (*i.e.*, combustion controls upgrade in 2024, SCR retrofit in 2026/2027) to derive this portion of Mississippi’s budget. This test, and subsequent adjustment as necessary, enables EPA to utilize the

latest, most representative data in a manner that is robust to any substantial state-level or region-level outlier events within that dataset and further validates EPA’s comprehensive approach to using the most recent single year of data for preset budgets.

b. Methodology for Determining Dynamic State Emissions Budgets for Control Periods in 2026 onwards

In this final rule, the EPA is finalizing an approach of using multi-year baseline data for purposes of dynamic budget computation. The aforementioned testing of the representative nature of a single year of baseline data for purposes of preset budget setting is not possible in the dynamic budget process as that data will not be available until a later date. Further, the EPA generally agrees with commenters that use of a multi-year period will be more robust to any unrepresentative outlier years in fleet operation and thus better suited for purposes of dynamic budgets. The methodology for determining dynamic state emissions budgets for later control periods (2026 and beyond) relies on a nearly identical methodology for applying unit-level emissions rate assumptions as the preset budget methodology. But it uses more recent heat input data that will become available by that future time, employing a multi-year approach for identifying the heat input data so as to ensure representativeness.

For dynamic budgets, EPA uses more years of baseline data to control for any state-level and unit-level variation that may occur in a future single year that is not possible to identify at present. First, for each unit operating in the most recent ozone season for which data have been reported, EPA identifies the average of the three highest unit-level heat input values from the five ozone seasons ending with that ozone season to get a representative unit-level heat

input. Ozone seasons for which a unit reported zero heat input are excluded from the averaging of the three highest heat input values for that unit. These representative unit-level heat input values established for each unit individually are then summed for all units in each state. Each unit’s representative unit-level heat input is then divided into this state-level sum to get that unit’s representative percent of the aggregated average heat input values for all affected EGUs in that state.

Next, EPA calculates a representative state-level heat input by taking the average state-level total heat input across affected EGUs from the most recent three ozone seasons for which data have been reported, to which the above-derived representative unit-level percentages of heat input are applied. The EPA uses a three-year baseline period for state-level heat input versus the five-year baseline period noted previously for unit-level heat input because there is less variation from year to year at the state level compared to the unit level. Multiplying the representative unit-level percentages of heat input by the representative state-level heat input yields a normalized unit-level heat input value for each affected EGU. This step assures that the total heat input being reflected in a dynamic state budget does not exceed the average total heat input reported by affected EGUs in that state from the three most recent years. Finally, each normalized unit-level heat input value is multiplied by the emissions rate reflecting the assumed unit-specific control stringency for each particular year (determined at Step 3) to get a unit-level emissions estimate. These unit-level emissions estimates are then summed to the state level to identify the dynamic budget for that year. This procedure to derive normalized unit-level heat input is captured in the following table:

TABLE VI.B.4.b–1—DERIVATION OF NORMALIZED UNIT-LEVEL HEAT INPUT
[Illustrative]

	2022 Heat input	2023 Heat input	2024 Heat input	2025 Heat input	2026 Heat input	Representative unit-level heat input (avg of 3 highest of past 5)	Representative unit-level percent	Representative state level heat input (avg 3 most recent state totals)	Normalized unit-level heat input
Unit A	100	200	150	200	300	233	41%	483	199
Unit B	50	100	200	50	100	133	24	483	114
Unit C	250	150	150	200	100	200	35	483	170

³¹⁷ EPA identified states for which 2021 both heat input and emissions were the low year among the examined baseline period as a preliminary screen to identify potential instances where reduced utilization may lead to an understated emissions baseline value.

³¹⁸ EPA also conducted a similar test to identify states in which 2021 heat input and emissions were the high year among the examined baseline period and found that it was for both Utah and Pennsylvania. However, for both states the elevated heat input trend persisted into 2022 (at slightly

lower levels and was correlated with retirements elsewhere in the region—indicating that some of this heat input increase may be representative of the future fleet and that planned retirements factored into preset budget will remove any unrepresentative heat input from 2021.

TABLE VI.B.4.b-1—DERIVATION OF NORMALIZED UNIT-LEVEL HEAT INPUT—Continued
[Illustrative]

	2022 Heat input	2023 Heat input	2024 Heat input	2025 Heat input	2026 Heat input	Representative unit-level heat input (avg of 3 highest of past 5)	Representative unit-level percent	Representative state level heat input (avg 3 most recent state totals)	Normalized unit-level heat input
State Total	400	450	500	450	500	567

The EPA will issue these dynamic budget quantifications approximately 1 year before the relevant control period. We view such actions as ministerial in nature in that no exercise of agency discretion is required. For instance, starting in early 2025, the EPA would take the most recent three years of state-level heat input data and the most recent five years of unit-level heat input data and calculate 2026 state emissions budgets using the methodology described previously. For 2026–2029, EPA is establishing the preset state emissions budgets finalized in this rulemaking and will only supplant those preset emissions budgets with the to-be-published dynamic emissions budgets if, for a given state and a given control period, that dynamic budget yields a higher level of emissions than the corresponding preset budget finalized in this rulemaking. For 2030 and beyond, the EPA solely uses the dynamic budget process.

By March 1 of 2025, and each year thereafter, the EPA will make publicly available through a NODA the preliminary state emissions budgets for the subsequent control period and will provide stakeholders with a 30-day opportunity to submit any objections to the updated data and computations. (This process will be similar to the releases of data and preliminary computations for allocations from new unit set-asides that is already used in existing CSAPR trading programs.) By May 1 of 2025, and each year thereafter, the EPA will publish the dynamic budgets for the ozone-season control period in the following calendar year. Through the 2029 ozone season control period, these budgets will only be imposed if the applicable dynamic state budget is higher than the corresponding preset state budget finalized in this rulemaking. Preliminary and final unit-level allowance allocations for the units in each state in each control period will be published on the same schedule as the dynamic budgets for the control period. For the control periods from 2026 through 2029, the allocations will reflect the higher of the preset or dynamic budget for each state, and after 2030, the allocations will reflect the dynamic budgets. Additional details,

corresponding data and formulas, and examples for the dynamic budget are described in the Ozone Transport Policy Analysis Final Rule TSD.

Comment: Multiple commenters claimed that designing a dynamic budget process that relies on a single year of yet-to-be known heat input data may produce an unrepresentative view of fleet operations for the immediate ensuing years. Commenters pointed to the hypothetical of another pandemic-like year (e.g., 2020) occurring in the future, noting that 2020 would have been a poor choice for estimating 2022 fleet operation and the same would likely hold true if a similar event occurred, for example, in 2025—that would consequently make that year a poor choice as a representative of 2027 baseline. They further pointed out that severe weather events and operating disruptions (a large nuclear plant outage) can similarly render a single year baseline a risky choice to inform future expectations.

Response: Insofar as the commenters are addressing the reference period for dynamic budget computation regarding years of data that have not yet occurred and therefore not currently available for evaluating their representative nature, EPA agrees and is incorporating a rolling 3-year baseline at the state level and a rolling 5-year baseline at the unit level for determining dynamic budgets in this final rule. These multi-year rolling baseline (or reference periods) will minimize any otherwise undue impact from individual years where fleet-level or unit-level heat input was uncharacteristically high or low. EPA determined that such an approach, while not needed for preset budgets, is necessary in the case of dynamic budgets because the baseline in that instance is occurring in a future year and therefore is not knowable and available to test for representativeness at the time of the final rule. To control for this type of uncertainty, the EPA finds it appropriate to use a multi-year baseline in this instance per commenter suggestion. While a multi-year baseline may have a slight drawback of using a slightly more dated past fleet performance (including emissions from higher emitting EGUs that may have

subsequently reduced utilization by the target year for which the dynamic budget is being calculated) to estimate the expected future fleet performance at the emissions performance levels determined by the Step 3 result in this rulemaking, that drawback is worth the advantage of protecting against instances where atypical circumstances in the most recent single year may occur and not be representative of the subsequent year for which the dynamic budget is being estimated. This singular drawback of moving to a multi-year baseline is most pronounced in the early years of dynamic budgeting. Therefore, EPA is able to lessen the impact of this drawback of the multi-year baseline by extending the earliest start date of dynamic budgets from 2025 (as proposed) to 2026 in the final rule.

Comment: Commenters suggested that the dynamic budget procedure would not provide enough advance notice of state budget and unit level allocation for sources to adequately plan future year operation.

Response: EPA disagrees with the notion that the timing of the dynamic budget determination would occur too close to the control period to allow adequate operations planning for compliance. As described previously, the dynamic budget level would be provided approximately 1 year in advance of the start of the control period (i.e., around May 1), and the allowance allocations would occur on July 1, approximately 10 months prior to the start of the compliance period. Not only is this an adequate amount of time as demonstrated by the successful implementation of past rules that have been finalized and implemented within several months of the beginning of the first affected compliance period (e.g., Revised CSAPR Update), but EPA notes it is maintaining similar trading program flexibility and banking flexibilities of past programs which provide further opportunities for sources to procure allowances and plan for any future operating conditions. Finally, as noted previously, the EPA is providing preset budgets for the years 2023–2029, which serve as an effective floor on the state’s ultimate emissions budget level for years 2026–2029, as

states will receive the higher of the preset or dynamic budget for those years. This provision of certain preset state emissions budgets serving as a floor level for 2026–2029 should further assuage commenters' concerns regarding planning certainty about allowance allocations and state emissions budget levels during this period of power sector transition to cleaner energy sources.

Comment: Commenters raised concerns that there is a two-year lag in the dynamic budgets in that, for example, for the dynamic budget in the 2026 control period, the calculations will be based on heat input and inventory information reflective of data through 2024. Commenters contend that, if there is a much greater need for allowances for compliance due to unavoidable or unforeseen need for a higher amount of heat input than reflected in prior years' data, the budget for that control period will not reflect this need, and the allowances will only become available when the dynamic budget is calculated using that information (*i.e.*, 2025 data would be reflected starting in the 2027 dynamic budget). According to commenters, this lag could present a serious compliance challenge. Other commenters raised a concern in the opposite direction about the potential "slack" created by the lag time—meaning that as high-emitting units retire, their emissions and operation will still inform the state emissions budgets for additional years beyond their retirement due to the lag.

Response: The EPA recognizes there will be a data lag inherent in the computation of future year dynamic emissions budgets, because the dynamic budgets will reflect fleet composition and utilization data from recent previous control periods rather than the control periods for which the dynamic budgets are being calculated. This means that the resulting dynamic budgets will reflect a limited lag behind the actual pace of the EGU fleet's trends. However, on the whole, those trends are clearly toward more efficient and cleaner generating resources. Thus, the data lag on the whole will inure to the compliance benefit of EGUs by resulting in dynamic budgets that are generally calculated at levels likely to be somewhat higher than what a dynamic budget calculation reflecting real-time EGU operations would produce. The EPA believes this data lag is worthwhile to provide more compliance planning certainty and advance notice to affected EGUs of the dynamic budget applicable to an upcoming control period. Furthermore, this data lag in dynamic budget computation is comparable to the data lag of quantifying preset state

budgets for 2023 through 2025 based upon 2021 data, and at no point in the long history of EPA's trading programs has such a data lag in state budget computation yielded any compliance problems for affected EGUs. Without dynamic budgeting, the data lag inherent in calculating preset budgets would grow unabated with the passage of time, as a fixed reference year of heat input levels would continually apply regardless of potentially higher heat input levels farther and farther into the future. By eliminating the increase in the length of the data lag, this new dynamic budgeting approach is a substantial improvement in performance of the program relative to previous approaches that were not capable of capturing changes over time in the fleet and its utilization beyond the scheduled changes known to the EPA at the time of establishing preset budgets.

The EPA disagrees that this lag will in fact pose compliance challenges for EGUs even if the unlikely scenario described by commenters were to occur. Several factors influence this. First, the change in methodology to preset budgets serving as a floor on budgets through 2029 means that the dynamic budget methodology can only produce an increase in the budget from this final rule through that year. Second, the adoption of a multi-year approach for identifying the heat input used to calculate the dynamic budgets will smooth the year-to-year budget changes and effectively eliminate the possibility of greatest concern, which was that a single year of unusually low heat input would be used to set the budget for a subsequent year that turned out to have unusually high heat input. While a year of unusually high heat input for a given state may still occur, the state's budgets for those years will never be based on heat input from an anomalously low year, but instead will always be based on an average of several years' heat input. Third, because the Group 3 trading program is an interstate program implemented over a wide geographic region, and it is unlikely that all regions of the country would uniformly experience a marked increase in fossil fuel heat input necessitating an additional supply of allowances, it is likely that allowances will be available for trade from one area of the country where there is less demand to another area where there is greater demand. Fourth, as explained in section VI.B.5 of this document, each state's assurance level will adjust to reflect actual heat input in that year. Specifically, the EPA will determine each state's variability

limit for a given control period so that the percentage value used will be the higher of 21 percent or the percentage (if any) by which the total reported heat input of the state's affected EGUs in the control period exceeds the total reported heat input of the state's affected EGUs as reflected in the state's emissions budget for the control period. Thus, if in year 2030, for example, a state's actual heat input levels increase to a level that is not reflected in the dynamic budget calculation using earlier years of data, the assurance level (which absent the unusually high heat input would be 121 percent of the state's budget) will be calculated by the EPA following the 2030 ozone season, using that higher reported heat input. This will avoid imposing a three-for-one allowance surrender penalty on sources except where emissions exceed the assurance level even factoring in the increase in heat input in that year. Finally, as some commenters observed, the inherent data lag in dynamic budget quantification means that a state budget for the year 2030 will continue to reflect emissions from any EGU that retires before the 2030 control period but is still operating anytime during the 2026–2028 reference years from which the 2030 dynamic budget will be calculated. Given the likely ongoing trend of relatively high-emitting EGU retirements over time, this method for determining dynamic budgets should further assist the ability of remaining EGUs to obtain sufficient allowances to cover future heat input levels.

With respect to the comments expressing concern that dynamic budgets would create too much slack because of the lag in incorporating retirements, the EPA observes that dynamic budgets will yield a closer representation of Step 3 control stringency across the future fleet than preset budgets for years in which retirement plans are currently relatively unknown. Moreover, any risk that the lag would lead to an unacceptably large surplus of allowances is limited by EPA's finalization of the annual bank recalibration to 21 percent and 10.5 percent of the budget beginning in 2024 and 2030 respectively. The corresponding risk that a lag will lead sources to not operate emissions controls, due to a surplus of allowances, is also limited by the backstop daily emissions rates that start in 2024 (for sources with existing SCR controls) and no later than 2030 for other coal-fired sources.

Comment: Commenters allege that the dynamic budget methodology is effectively a "one-way ratchet" because, if EGUs pursue compliance strategies

such as reduced utilization or generation shifting to comply with the rule rather than install or optimize pollution controls pursuant to the identified Step 3 emissions control strategies, the effect will be that the dynamic budget calculated in a future year will reflect that reduced heat input, but the applied emissions rate assumption will be the same. Thus, the approach according to commenters actually “punishes” sources for achievement of emissions reductions commensurate with EPA’s Step 3 determinations through alternative compliance means, by producing a smaller budget in later years (less heat input multiplied by the same emissions rate). If the source again reduces utilization or shifts generation to comply with this budget, then budgets in later years will again ratchet down, and so on.

Response: First, the claims of dynamic budgeting being a one-way ratchet are incorrect. As pointed out at proposal, the dynamic budget process would allow for increased utilization to result in increased budgets. Moreover, this concern is entirely mooted for the period 2026 through 2029 with the shift to preset budgets serving as a floor; dynamic budgeting can only increase the budget used in any given year in this time period. Additionally, the use of a multi-year average heat input in the budget-setting calculations will, on the

whole, modulate the dynamic budgets such that the budgets over time will only gradually change with changes in the operating profile of the EGU fleet.

For the control periods 2030 and later, this rule is premised on the expectation that all large coal-fired EGU sources identified for SCR-retrofit potential will, if they continue operating in 2030 or later, have installed the requisite post-combustion controls. Thus, the backstop daily emissions rate applies for all such sources beginning in the 2030 ozone season. In this latter period (post-2030), the EPA disagrees that the dynamic budget will punish fleet segments seeking to continue to pursue a strategy of reduced utilization. Rather, the dynamic budget will simply continue to reflect the Step 3 emissions control stringency. For instance, if there are two otherwise high-emitting sources in a state that can reduce emissions by operating SCR, this rule’s control stringency finds it cost effective for both sources to operate their controls. If one source retires and is replaced by new lower-emitting generation, it is not a punishment to have the budgets adjust in a way that still incentivize remaining units to operate their controls. This is simply right-sizing the budget to an evolving fleet. It is a feature of the rule, not a flaw, and is designed to address observed instances in prior rules where market-driven reduced utilization resulted in non-binding (*i.e.*, overly

slack) budgets and corresponding conditions where the incentive to operate a control dissipated over time. In the event that sources reduce utilization whether for compliance purposes or market-driven reasons, that also does not obviate the importance of continuing to incentivize the Step 3 emissions control stringency at identified sources.

c. Final Preset State Emissions Budgets

For affected EGUs in each covered state (and Indian country within the state’s borders), this final rule establishes preset budgets for the control periods 2023 through 2029. For control periods 2026 through 2029, any of those preset budgets may be supplanted by the corresponding dynamic budget that will be tabulated at later date, if and only if that dynamic budget yields a higher amount. For 2030 and beyond, the dynamic budget formula promulgated in this rule will be applied to future year data to quantify state emissions budgets for those control periods. The procedures for allocating the allowances from each state budget among the units in each state (and Indian country within the state’s borders) are described in section VI.B.9 of this document. The amounts of the final preset state emissions budgets for the 2023 through 2029 control periods are shown in Table VI.B.4.c–1.

TABLE VI.B.4.c–1—CSAPR NO_x OZONE SEASON GROUP 3 PRESET STATE EMISSIONS BUDGETS FOR THE 2023 THROUGH 2029 CONTROL PERIODS

[Tons]^{a,b}

State	Final emissions budgets for 2023	Final emissions budgets for 2024	Final emissions budgets for 2025	Preset emissions budgets for 2026	Preset emissions budgets for 2027	Preset emissions budgets for 2028	Preset emissions budgets for 2029
Alabama	6,379	6,489	6,489	6,339	6,236	6,236	5,105
Arkansas	8,927	8,927	8,927	6,365	4,031	4,031	3,582
Illinois	7,474	7,325	7,325	5,889	5,363	4,555	4,050
Indiana	12,440	11,413	11,413	8,410	8,135	7,280	5,808
Kentucky	13,601	12,999	12,472	10,190	7,908	7,837	7,392
Louisiana	9,363	9,363	9,107	6,370	3,792	3,792	3,639
Maryland	1,206	1,206	1,206	842	842	842	842
Michigan	10,727	10,275	10,275	6,743	5,691	5,691	4,656
Minnesota	5,504	4,058	4,058	4,058	2,905	2,905	2,578
Mississippi	6,210	5,058	5,037	3,484	2,084	1,752	1,752
Missouri	12,598	11,116	11,116	9,248	7,329	7,329	7,329
Nevada	2,368	2,589	2,545	1,142	1,113	1,113	880
New Jersey	773	773	773	773	773	773	773
New York	3,912	3,912	3,912	3,650	3,388	3,388	3,388
Ohio	9,110	7,929	7,929	7,929	7,929	6,911	6,409
Oklahoma	10,271	9,384	9,376	6,631	3,917	3,917	3,917
Pennsylvania	8,138	8,138	8,138	7,512	7,158	7,158	4,828
Texas	40,134	40,134	38,542	31,123	23,009	21,623	20,635
Utah	15,755	15,917	15,917	6,258	2,593	2,593	2,593
Virginia	3,143	2,756	2,756	2,565	2,373	2,373	1,951
West Virginia	13,791	11,958	11,958	10,818	9,678	9,678	9,678
Wisconsin	6,295	6,295	5,988	4,990	3,416	3,416	3,416

TABLE VI.B.4.c-1—CSAPR NO_x OZONE SEASON GROUP 3 PRESET STATE EMISSIONS BUDGETS FOR THE 2023 THROUGH 2029 CONTROL PERIODS—Continued

[Tons]^{a b}

State	Final emissions budgets for 2023	Final emissions budgets for 2024	Final emissions budgets for 2025	Preset emissions budgets for 2026	Preset emissions budgets for 2027	Preset emissions budgets for 2028	Preset emissions budgets for 2029
Total	208,119	198,014	195,259	151,329	119,663	115,193	105,201

Table Notes:

^a The state emissions budget calculations pertaining to Table VI.B.4.c-1 are described in greater detail in the Ozone Transport Policy Analysis Final Rule TSD. Budget calculations and underlying data are also available in Appendix A of that TSD.

^b In the event this final rule becomes effective after May 1, 2023, the emissions budgets and assurance levels for the 2023 control period will be adjusted under the rule's transitional provisions to ensure that the increased stringency of the new budgets would apply only after the rule's effective date. The 2023 budget amounts shown in Table VI.B.4.c-1 do not reflect these possible adjustments. The transitional provisions are discussed in section VI.B.12 of this document.

5. Variability Limits and Assurance Levels

Like each of the other CSAPR trading programs, the Group 3 trading program includes assurance provisions designed to limit the total emissions from the sources in each state (and Indian country within the state's borders) in each control period to an amount close to the state's emissions budget for the control period, consistent with the principle that each state's sources must be held to the elimination of significant contribution within that state, while allowing some flexibility beyond the emissions budget to accommodate year-to-year operational variability beyond sources' reasonable ability to control. For each state, the assurance provisions establish an assurance level for each control period, defined as the sum of the state's emissions budget for the control period plus a variability limit, which under the Group 3 trading program regulations in effect before this rulemaking was 21 percent of the relevant state emissions budget. The purpose of the variability limit is to account for year-to-year variability in EGU operations, which can occur for a variety of reasons including changes in weather patterns, changes in electricity demand, and disruptions in electricity supply from other units or from the transmission grid. Because of the need to account for such variability in operations of each state's EGUs, the fact that emissions from the state's EGUs may exceed the state's emissions budget for a given control period is not treated as inconsistent with satisfaction of the state's good neighbor obligations as long as the total emissions from the EGUs remain below the state's assurance level. Emissions from a state's EGUs above the state's emissions budget but below the state's assurance level are treated in the same manner as emissions below the state's emissions budget in that such emissions are subject to the same

requirement to surrender allowances at a ratio of one allowance per ton of emissions. In contrast, emissions above the state's assurance level for a given control period are strongly discouraged as inconsistent with the state's good neighbor obligations and are subject to an overall 3-for-1 allowance surrender ratio. The establishment of assurance levels with associated extra allowance surrender requirements was intended to respond to the D.C. Circuit's holding in *North Carolina* requiring the EPA to ensure within the context of an interstate trading program that sources in each state are required to address their good neighbor obligations within the state and may not simply shift those obligations to other states by failing to reduce their own emissions and instead surrendering surplus allowances purchased from sources in other states.³¹⁹

In this rulemaking, the EPA did not propose and is not making changes to the basic structure of the Group 3 trading program's assurance provisions, which will continue to set an assurance level for each control period equal to the state's emissions budget for the control period plus a variability limit and will continue to apply a 3-for-1 surrender ratio to emissions exceeding the state's assurance level.³²⁰ Each assurance level also will continue to apply to the collective emissions of all units within the state and Indian country within the state's borders.³²¹ However, the EPA is making a change to the methodology for determining the variability limits. Specifically, the EPA will determine

³¹⁹ 531 F.3d at 908.

³²⁰ As discussed in section VI.B.8, the EPA is also establishing a new secondary emissions limitation for individual units that will apply in situations where an exceedance of the relevant state's assurance level has occurred.

³²¹ See 40 CFR 97.1002 (definitions of "common designated representative," "common designated representative's assurance level" and "common designated representative's share"), 97.1006(c)(2), and 97.1025.

each state's variability limit for a given control period so that, instead of always multiplying the state's emissions budget for the control period by a value of 21 percent, the percentage value used will be the higher of 21 percent or the percentage (if any) by which the total reported heat input of the state's affected EGUs in the control period exceeds the total historical heat input of the state's affected EGUs as reflected in the state's emissions budget for the control period. For example, if the total reported heat input of the state's covered sources for the 2025 control period is 130 percent of the historical heat input used in computing the state's 2025 budget, then the state's variability limit for the 2025 control period will be 30 percent of the state's emissions budget instead of 21 percent of the state's emissions budget. The EPA expects that the minimum 21 percent will apply in almost all instances, and that the alternative, higher percentage value will apply only in control periods where operational variability causes an unusually large increase relative to the historical data used in setting the state's emissions budget, which would be a situation meriting a temporarily higher variability limit and assurance level. The revised methodology for determining the variability limits will apply both with respect to control periods when a state's emissions budget is a preset budget established in this final rule and with respect to control periods when a state's emissions budget is a dynamically-determined budget computed using the procedures laid out in the regulations, and it will apply starting with the 2023 control period rather than starting with the 2025 control period as proposed.

The purpose of the revision to the variability limits is to better align the variability limits for successive control periods with the heat input data used in setting the state emissions budgets. Under the final rule, each dynamically

determined emissions budget will be computed using the latest available reported heat input, which for each budget set for a control period in 2026 or a later year will be the average state-level heat input for the control periods two, three, and four years before the control period whose budget is being determined (for example, the dynamic state emissions budgets for the 2026 control period will be computed in early 2025 using the reported state-level heat input for the 2022–2024 control periods). The revised variability limits will be well coordinated with the budgets established using this dynamic budgeting process, because the percentage change in the actual heat input for the control period relative to the earlier multi-year average heat input used in computing the state's emissions budget will be an appropriate measure of the degree of operational variability actually experienced by the state's EGUs in the control period relative to the assumed operating conditions reflected in the state's budget. Setting a variability limit in this manner is thus entirely consistent with the overall purpose of including variability limits in the assurance provisions.

As discussed in sections VI.B.1.b.i and VI.B.4, for the 2023–2025 control periods the state emissions budget for a given control period will be the preset budget determined in this rule, and for the 2026–2029 control periods, the state emissions budget for a given control period will be the preset budget determined in this rule rather than the dynamically determined budget computed in the year before the control period unless the dynamic budget is higher than the preset budget. If the state emissions budget is the preset budget, the historical heat input data reflected in that budget will be the heat input data for the 2021 control period, adjusted to reflect projected changes in fleet composition over time that are known at the time of this rulemaking, but not adjusted to reflect changes in fleet composition that are not known at the time of the rulemaking or changes in the utilization of individual units.³²² In this case, the variability limit for the control period would be the higher of 21 percent or the percentage change in the actual heat input for the control period relative to the heat input for the 2021 control period as adjusted to reflect the projected changes in fleet composition. The EPA believes it is reasonable to

apply the same principle in setting the variability limit in control periods where the preset floor budgets are used as in control periods where the dynamically determined budgets are used, because the preset floor budgets are computed using the same principles as the dynamically determined budgets, with the major difference being that the available heat input data used in computing the preset budgets are necessarily less current. Accordingly, because preset budgets established in this manner are used starting with the 2023 control period, the EPA believes it is also reasonable to begin implementing the revised methodology for determining variability limits starting with the 2023 control period.

The reason the EPA is using the higher of a fixed 21 percent or the percentage change in heat input computed as just described is that the EPA believes that, for operational planning purposes, it can be useful for sources to know in advance of the control period a minimum value for what the variability limit could turn out to be. Because a state's actual total heat input for a control period is not known until after the end of the control period, this revision will have the consequence that the state's final variability limit and assurance level for the control period also will not be known until after the control period. However, because the rule provides that the variability limit will always be at least 21 percent, the sources in a state will be able to rely for planning purposes on the knowledge that the assurance level will always be at least 121 percent of the state's emissions budget for the control period. Advance knowledge of the minimum possible amount of the assurance level can be useful to sources, because one way a fleet owner can be confident that it will never incur the 3-for-1 allowance surrender ratio owed for emissions exceeding its state's assurance level is to plan its operations so as to never allow the emissions from its fleet to exceed the fleet's aggregated share of the state's assurance level for the control period. Knowing that the variability limit will always be at least 21 percent will provide sources with minimum values they could use for such planning purposes.

The EPA believes that 21 percent is a reasonable value to use as the minimum variability limit. To determine appropriate variability limits for the trading programs established in CSAPR, the EPA analyzed historical state-level heat input variability over the period from 2000 through 2010 as a proxy for emissions variability, assuming constant emissions rates. See 76 FR 48265. Based

on that analysis, the variability limits for ozone season NO_x in both CSAPR and the CSAPR Update were set at 21 percent of each state's budget, and these variability limits for the NO_x ozone season trading programs were then codified in 40 CFR 97.510 and 97.810, along with the respective state budgets.³²³ For the Revised CSAPR Update, the EPA performed an updated variability analysis for the twelve states being moved into the Group 3 trading program in that rulemaking, evaluating historical state-level heat input variability over the period from 2000 through 2019. The updated analysis again resulted in a variability estimate of 21 percent. The EPA also considered shorter time periods for the updated analysis and found that the resulting variability estimates were not especially sensitive to the particular time period analyzed.³²⁴ A further updated analysis for this rulemaking again results in a variability estimate of 21 percent for most states, and although the historical analysis indicates a higher percentage for the covered state with the smallest total heat input figures in this analysis—New Jersey—the EPA does not consider it appropriate to raise the minimum variability limit percentage beyond 21 percent for all other covered states based on the analytic results for one state, where small absolute heat input figures have resulted in a larger variability percentage.³²⁵ (Moreover, because of the provision allowing a state's variability limit for a given control period to be higher than 21 percent if the state's actual heat input exceeds the heat input used to set the state's emissions budget by more than 21 percent, there is no need to set a minimum variability limit higher than 21 percent specifically for New Jersey.) Based on the consistent conclusions of these multiple analyses, the EPA is continuing to use 21 percent as the

³²³ Briefly, the 21 percent variability limit was determined in the analysis by identifying, for all the states in the region covered by the ozone season NO_x trading program, and at a 95 percent confidence level, the maximum expected deviation in any state's total heat input for any single control period in the data sample from that state's trend-adjusted mean total heat input for all the control periods in the data sample. For details on the original variability analysis for 26 states over the 2000–2010 period, including a description of the methodology, see the Power Sector Variability Final Rule TSD from the CSAPR (EPA–HQ–OAR–2009–0491–4454), available in the docket for this rule.

³²⁴ For the updated variability analysis for twelve states for the 2000–2019 period, see the Excel file “Historical Variability in Heat Input 2000 to 2019.xls”, available in the docket for this rule.

³²⁵ See the Excel document, “OS Heat Input—Variability 2000 to 2021.xls” for updated data, application of the CSAPR variability methodology, and results applied to heat input for 2000 through 2021 for all states and for the region collectively.

³²² The total heat input amount used in computing each state's preset emissions budget for each control period from 2023 through 2029 is included in Appendix A of the Ozone Transport Policy Analysis Final Rule TSD at column I of the “State 2023”–“State 2029” worksheets.

minimum value in the revised approach for establishing variability limits for all control periods under this rule.

The provisions of the final rule relating to assurance levels and variability limits are unchanged from proposal, with the exception that the provision establishing a higher variability limit for a state in a given control period where the state's actual heat input exceeds the heat input used in computing the state emissions budget for that control period by more than 21 percent will be implemented starting with the 2023 control period instead of the 2025 control period.

Comment: Some commenters supported the EPA's proposal to raise a state's variability limit above 21 percent for a given control period if the state's actual heat input for the control period was more than 121 percent of the historical heat input used to set the state's budget for that control period. These commenters agreed with the EPA that making this adjustment is consistent with the assurance provisions' purpose of strongly incentivizing each state to achieve its required emissions reductions within the state while also accounting for year-to-year variability in electric system operations.

One commenter stated that the EPA should not finalize the proposed revision to the variability limit provisions, claiming that by allowing sources in some states to increase utilization and heat input so as to exceed the state's budget by more than 21 percent in a given year, the adjustment would then cause the state's subsequent dynamically determined budgets to be higher, allowing greater emissions over time.

Response: The EPA disagrees with the comment advocating against finalization of the proposed change to the variability limit provisions. The Agency continues to view the proposed change as useful for accommodating instances where, because of electrical system operating needs, a state's actual total heat input in a control period exceeds the historical heat input used to set the state emissions budget for the control period, potentially causing increased emissions even when all EGUs in a state are achieving emissions rates consistent with the Step 3 emissions control stringency. Moreover, the EPA does not believe that the provision would lead to higher overall program-wide budgets. No extra allowances would be created by the increase in a state's variability limit, so with or without the adjustment, any allowances to cover the emissions in excess of the state's budget would still need to be obtained through

acquisition of allowances issued to sources in other states or the use of banked allowances. Thus, to the extent that the change in the variability limit provisions facilitates shifting of generation from some states to other states, increased heat input in the first set of states would generally be offset by decreased heat input in the second set of states, such that any increases in future dynamic budgets for the first set of states would be offset by decreases in future dynamic budgets for the second set of states. In addition, the final rule's use of multiple years of historical heat input data to compute the dynamically-determined state budgets will moderate the effect of any single year's heat input on the dynamically-determined budgets for future control periods.

6. Annual Recalibration of Allowance Bank

As discussed in section VI.B.1.b of this document, the EPA is making two revisions to the Group 3 trading program designed to better maintain the Step 3 emissions control stringency over time. The first proposed revision, discussed in section VI.B.4 of this document, is to adopt a dynamic budget-setting methodology that will allow state emissions budgets in future years to reflect more accurate information about the composition and utilization of the EGU fleet. The second, complementary, revision is to recalibrate the bank of unused allowances each control period to prevent allowance surpluses from accumulating and adversely impacting the ability of the trading program in future control periods to maintain the Step 3 emissions control stringency.

As proposed and now finalized in this rule, the bank recalibration process will start with the 2024 control period, after the compliance process for the 2023 control period for all current and newly added states in the Group 3 trading program has been completed. The recalibration process for each control period will be carried out on or shortly after August 1 of that control period, two months after the compliance deadline for the previous control period, making the date of the first recalibration August 1, 2024. The recalibrations take place on August 1 each year because compliance for the previous control period would not be completed until after June 1. However, because data on the amounts of allowances held are publicly available and the total quantity of allowances needed for compliance for the previous control period will be known shortly after the end of that control period, sources and other market participants will be able to ascertain

with reasonable accuracy shortly after the end of each control period what degree of recalibration to expect for the next control period, even if the recalibration would not actually be carried out until the following August. The EPA will make an estimate of the applicable calibration ratio for each control period publicly available no later than March 1 of the year of the control period for which the bank will be recalibrated.

Before undertaking a recalibration process each control period, the EPA will first determine whether the total amount of all banked Group 3 allowances from previous control periods held in all facility accounts and general accounts in the Allowance Management System exceeds the target bank amount. (For this purpose, no distinction will be made between banked Group 3 allowances issued from the state emissions budgets for previous control periods and banked Group 3 allowances issued through the conversion of previously banked Group 2 allowances.) If the total amount of banked Group 3 allowances does not exceed the target bank amount, the EPA will not carry out any recalibration for that control period. If the total amount of unused allowances does exceed the target bank amount, the EPA will determine for each account with holdings of banked Group 3 allowances the account-specific recalibrated amount of allowances, computed as the account's total holdings of banked Group 3 allowances immediately before the recalibration multiplied by the target bank amount and divided by the total amount of banked Group 3 allowances in all accounts, rounded up to the nearest allowance. Finally, the EPA will deduct from each account any banked Group 3 allowances exceeding the account's recalibrated amount of banked allowances.

As the target bank amount used in the recalibration process for each control period, the EPA will use an amount determined as a percentage of the sum of the state emissions budgets for the control period. For the control periods from 2024 through 2029, the target percentage will be 21 percent, which is the sum of the states' minimum variability limits.³²⁶ For control periods in 2030 and later years, the target percentage will be 10.5 percent, or half of the sum of the states' minimum

³²⁶ As discussed in section VI.B.5, an individual state's variability limit can be higher than 21 percent in a given control period if the state's actual heat input for that control period is more than 121 percent of the historical heat input used in computing the state emissions budget for the control period.

variability limits. In the proposal, the EPA cited two reasons for proposing the 10.5 percentage amount. First, in the transition from CSAPR to the CSAPR Update, where the EPA set a target bank amount 1.5 times the sum of the variability limits, and in the transition from the CSAPR Update to the Revised CSAPR Update, where the EPA set a target bank amount of 1.0 times the sum of the variability limits, in each case the initial bank proved larger than necessary, as total emissions of all sources in the program were less than the budgets. Second, an analysis of year-to-year variability of heat input for the region covered by this rule suggests that the regional heat input for an individual year can be expected to vary by up to 10.5 percent above or below the central trend with 95 percent confidence. This variability analysis is an application to the entire region of the variability analysis EPA has performed for individual states to establish the minimum variability limit of 21 percent for the states in the trading program.³²⁷ When the analysis is performed at the regional level, the data show less year-to-year variation than when the analysis is performed at the individual state level. Within the trading program structure, it is reasonable to use variability analyzed at the level of individual states to set the variability limits, which apply at the level of individual states, while using variability analyzed at the level of the overall region to set a target level for a bank, which will apply at the level of the overall program.

In the final rule, in response to comments, the EPA has determined to maintain the 10.5 target percentage for the reasons discussed in previous paragraphs, but to defer application of this target percentage until the 2030 control period. For the control periods from 2024 through 2029, the EPA will instead use a target percentage of 21 percent. The reason for using a higher target percentage for the 2024–2029 control periods is to provide additional support for allowance market liquidity during these years, which both the EPA and commenters view as an important period of generating fleet transition for the power industry.

The annual bank recalibrations, at either ratio, are an important

enhancement to the trading program that will help maintain the control stringency determined to be necessary to address states' good neighbor obligations for the 2015 ozone NAAQS over time. Moreover, the recalibrations are less complex than alternative approaches would be. For example, the NO_x Budget Trading Program established in the NO_x SIP Call also contained provisions designed to prevent excessive accumulations of banked allowances on program stringency, but those provisions—under the name “progressive flow control”—introduced uncertainty as to whether banked allowances would be usable to offset one ton of emissions or less than one ton of emissions in the current control period. As a consequence of this uncertainty, in some control periods, allowances banked from earlier control periods traded at lower prices than allowances issued for the current control period.³²⁸ The EPA considers the recalibration mechanism established in this rule to be simpler with less associated uncertainty. Following each bank recalibration, all allowances usable for compliance in the control period will have known, equal compliance values for the remainder of the control period and until the deadline for surrendering allowances after the control period.

Finally, the EPA observes that the recalibration mechanism is entirely consistent with the Agency's existing authority under 40 CFR 97.1006(c)(6) to “terminate or limit the use and duration” of any Group 3 allowance “to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.” The Administrator is determining that the recalibrations are both necessary and appropriate to ensure that the control stringency selected in this rulemaking is maintained and states' good neighbor obligations with respect to the 2015 ozone NAAQS are addressed. The recalibration process will complement the revised budget-setting process by preventing any surplus of allowances created in one control period from diminishing the intended stringency and resulting emissions reductions of the emissions budgets for subsequent control periods. For further discussion

of the reasons for bank recalibration, see section VI.B.1.b.ii of this document.

The bank recalibration mechanism finalized in this rule is unchanged from the proposal except for the final rule's adoption of a target percentage of 21 percent rather than 10.5 percent for the control periods from 2024 through 2029. The EPA's responses to comments on the bank recalibration mechanism are discussed in the remainder of this section and in section 5 of the *RTC* document. Further discussion of the reasons for adopting a higher target percentage for the 2024–2029 control periods is included in section VI.B.1.d of this document.

Comment: Some commenters acknowledged the EPA's authority to manage the quantities of allowances carried over from one control period to the next as banked allowances, including some commenters who as a policy matter did not support such an approach. Other commenters claimed that any removal from the program of allowances banked in earlier control periods would constitute an unlawful taking of property or would constitute unlawful overcontrol.

Response: The EPA disagrees with comments contending that the proposed bank recalibration provisions would be unlawful, either as asserted takings of property or as over-control for purposes of the Good Neighbor provision. With respect to the claim that removing allowances would constitute takings of property, the commenters misconstrue the nature of an allowance. The allowances used in the Group 3 trading program are created under the program's regulations, which expressly provide that the allowances are not property rights but are limited authorizations to emit NO_x in accordance with the provisions of the Group 3 trading program.³²⁹ These provisions of the Group 3 trading program regulations have been in existence since the Revised CSAPR Update and were not reopened in this action. This approach of creating limited authorizations to engage in particular forms of conduct within a regulatory program extends back to the Acid Rain Program, where the approach was mandated by Congress, and has been followed by EPA in each subsequent allowance trading program for the electric power sector.³³⁰ Moreover, as noted earlier in this section, the Group 3 trading program regulations provide the EPA

³²⁷ See the Power Sector Variability Final Rule TSD from CSAPR, available at <https://www.epa.gov/csapr/power-sector-variability-final-rule-tds> for a description of the methodology. Also see the Excel document “OS Heat Input—Variability 2000 to 2021.xls” for updated data, application of the CSAPR variability methodology, and results applied to heat input for 2000 through 2021 for all states and for the region collectively.

³²⁸ For more discussion of the progressive flow control mechanism, as well as allowance price data showing a discounted value for banked allowances, see “NO_x Budget Trading Program: 2005 Program Compliance and Environmental Results” (September 2006) at 28–30, <https://www.epa.gov/sites/default/files/2015-08/documents/2005-nbp-compliance-report.pdf>.

³²⁹ 40 CFR 97.1006(c)(6)–(7).

³³⁰ See, e.g., 42 U.S.C. 7651b(f) and 40 CFR 72.9(c)(6)–(7) (Acid Rain Program example); 40 CFR 97.6(c)(6)–(7) (Federal NO_x Budget Trading Program example); 40 CFR 97.106(c)(5)–(6) (CAIR NO_x Annual Trading Program example).

Administrator with the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act, and the Administrator is making such a determination in this rule.

The EPA also disagrees that bank recalibration would constitute overcontrol. The emissions that are permissible in a given control period consistent with the Step 3 control stringency are quantified in the state emissions budgets for the control period. Banked allowances from previous control periods are necessarily surplus to the state emissions budgets for the current control period. As noted in section VI.B.1, in an allowance trading program, banking provisions can serve several useful purposes, including continuously incentivizing sources to reduce their emissions even when they already hold sufficient allowances to cover their expected emissions for a control period, facilitating compliance cost minimization, accommodating necessary operational flexibility, and promoting allowance market liquidity. However, these useful purposes do *not* include allowing sources to plan to emit in excess of the Step 3 control stringency as represented by the state emissions budgets for the control period. Accordingly, in the overcontrol analysis discussed in section V.D.4, the EPA analyzed whether the emissions reductions necessary to meet the state emissions budgets without relying for compliance purposes on any allowances banked in earlier control periods would result in overcontrol and determined there would be no overcontrol. (That is, the modeling of the effects of the Group 3 emissions budgets in 2026 did not include an assumption that there would be any banked allowances.) Thus, even if the Agency had finalized regulatory provisions removing *all* banked allowances from the trading program between control periods—in contrast to the actual bank recalibration provisions, which permit substantial quantities of banked allowances to remain in the trading program—the information available to the Agency suggests such provisions would not constitute overcontrol. With respect to some commenters' assertions that bank recalibration would over-control by "writing off" emission reductions that may have gone beyond the reductions necessary to address the Good Neighbor provision or would make it more difficult to create surplus allowances in one control period to offset excess emissions in later control periods, EPA

notes that the NAAQS apply continuously, and the possibility that the sources in a state may have done more than the minimum necessary to meet the state's Good Neighbor obligations in one control period does not create a right for the state to do less than is necessary to meet the state's Good Neighbor obligations in subsequent control periods.

Comment: Some commenters expressed concern that excessive quantities of banked allowances, like excessive quantities of budgeted allowances, can lead to lower allowance prices. The commenters observed that with lower allowance prices, some units would likely operate their controls less effectively, resulting in a greater likelihood that the emissions stringency found necessary in this rule would not be sustained. Other commenters expressed the view that other provisions of the rule, including more stringent state emissions budgets, the backstop daily NO_x emissions rate provisions, and the assurance provisions would be sufficient to incentivize EGUs to operate their controls effectively, making allowance bank recalibration superfluous for this purpose.

Response: The EPA agrees with the comments explaining that without bank recalibration, the quantities of banked allowances can grow, leading to lower allowance prices, diminished incentives for sources to optimize control operation, and greater risk of failure to sustain the Step 3 control stringency, and disagrees with the comments arguing that other rule provisions would make bank recalibration unnecessary. The suggestion that the assurance provisions can maintain program stringency regardless of allowance quantities ignores the fact that the emission levels consistent with the Group 3 control stringency in a given control period are the state emissions budgets, not the higher assurance levels. If the quantities of banked allowances in the program grow to the point where sources collectively can plan to emit above the collective state emissions budgets, then the trading program would be unable to ensure that the Group 3 control stringency is being achieved, even if emissions do not rise further than the assurance levels. Further, there are now examples from the Group 2 trading program of sources emitting in excess of the state-wide assurance levels, because a glut of banked allowances which was not prevented by the regulations for that trading program rendered even the three-to-one surrender ratio ineffective. Suggestions that the backstop emissions rate provisions can maintain program

stringency regardless of the quantities of banked allowances are similarly mistaken, because rather than reducing overall emissions of all sources in the trading program, the backstop rate provisions are designed to ensure that the largest individual sources of potential emissions operate their controls consistently. If the quantities of banked allowances are allowed to grow to the point where sources collectively can plan to emit above the collective state emissions budgets, the backstop rate provisions would do nothing to constrain emissions from the sources not subject to the backstop rate.

With respect to the suggestion that state emissions budgets reflecting sufficient control stringency can avoid the need for bank recalibration, the EPA observes that the budget-setting and bank recalibration provisions in this rule are complements, not substitutes. If in a given year sources collectively emit against the collective state emissions budgets such that the ending allowance bank—that is, the allowances remaining after deduction of the allowances required for compliance—is less than the bank target amount, then the bank will not be recalibrated for the following control period. However, in the event that sources collectively emit against the collective state emissions budgets such that the ending allowance bank is above the bank target amount, then the recalibration provisions will ensure that the recalibrated allowance bank does not introduce an excessive overall quantity of allowances into the trading program for the following control period when combined with the state emissions budgets calculated for that control period. Without the recalibration provisions, the trading program would lack any mechanism for removing excess allowances that are inconsistent with maintaining the Step 3 emissions control stringency which the Step 4 trading program is designed to implement.

Comment: Some commenters claimed that the recalibration process itself would have undesirable consequences. First, some said that because bank recalibration would be executed partway through the control period, it would introduce uncertainty concerning the quantities of allowances each source would have available, impeding efforts to plan. Second, some commenters claimed that the prospect of bank recalibration would create counterproductive incentives for allowance holders. According to the commenters, allowance holders would be incentivized to "use or lose" their allowances (to reduce the number of allowances that would be removed from

their accounts in the recalibration process), thereby causing increased emissions, or alternatively would be incentivized to refuse to sell allowances (to allow the holders to have more allowances after the next recalibration), thereby reducing allowance market liquidity.

Response: The EPA disagrees with these comments. As discussed previously in this section, the recalibration process has been scheduled for August 1 of each control period because compliance for the previous control period (and the associated allowance trading activities) would not be completed until after June 1. However, the information needed to project the degree of recalibration will be available by early November of the previous year, and the EPA will make an estimate publicly available no later than March 1, two months before the start of the control period. Further, at least 80 percent of the allowances for use in a given control period will be the allowances allocated from the state emissions budgets (with the recalibrated banked allowances from the prior control period comprising the remainder), and the emissions budgets and unit-level allocations amounts will be known approximately a year before the start of the control period.

The comments claiming that the introduction of a bank recalibration process would create incentives to “use or lose” allowances or to hoard allowances are not persuasive. By reducing the supply of allowances carried over from previous control periods, bank recalibration would tend to raise the price of allowances in the current control period, making it more cost-effective and therefore in sources’ interest to further reduce their emissions than to increase their emissions. Higher allowance prices would also increase the cost of hoarding allowances just as higher fuel prices raise the cost of maintaining large fuel inventories. Moreover, the EPA expects that the prospect of having banked allowances recalibrated after the end of the control period is much more likely to *discourage* hoarding than to encourage it. Given the choice between holding an allowance which may be removed as part of an upcoming recalibration process or instead selling the allowance for cash, the sale option will become more attractive. By creating a “sell or lose” incentive for holders of surplus allowances, the recalibration process should increase allowance market liquidity. At the same time, by ensuring a banked allowance will always have some value for use in a future control period, the bank

recalibration mechanism in this program will continue to incentivize early emissions reductions.

Comment: Turning to the level of the bank recalibration target, some commenters objected to the target bank percentage of 10.5 percent, saying that a larger bank would be needed to ensure that sufficient allowances would be available to enable sources to run as needed to provide reliable electricity service, particularly with the large year-to-year swings in budgets that the commenters anticipated could occur with dynamic budgets computed using a single rolling historical year and with anticipated growth in renewable generation. Some commenters recommended a target bank percentage of 21 percent. Some commenters stated that even if the overall quantity of allowances available for use was greater than the total amount of emissions, a larger bank of allowances would facilitate trading and promote greater allowance market liquidity, citing reports of high allowance prices in 2022.

Response: As discussed in sections VI.B.1.d and VI.B.4 and earlier in this section, the EPA does not agree with comments suggesting that annual bank recalibration in itself poses a risk to electric grid reliability. Nevertheless, the Agency has made several changes from proposal in the final rule designed to address concerns expressed about reliability by increasing compliance flexibility through the 2029 control period. These changes through the 2029 control period include the use of a target bank percentage of 21 percent and the promulgation of preset budgets that will serve as the state emissions budgets unless the dynamic budgets for the control periods are higher. In addition, to reduce year-to-year variability under the budget-setting methodology, dynamic budgets will be calculated using multiple years of historical heat input data instead of heat input data from a single year. The EPA views these changes as responsive to the principal reasons that commenters gave for their claims that the target bank percentage should be higher than 10.5 percent. Regarding the claim that a higher target bank percentage is needed because increased renewable generation makes the demand for fossil generation more variable, commenters did not provide evidence demonstrating that the overall quantities of fossil generation throughout the multi-state region covered by this rule—as opposed to the operating patterns of some individual units—are becoming more variable, and the Agency declines to make an

adjustment for such a reason at this time.

With respect to the comments advocating for an even higher bank target percentage to facilitate trading and promote market liquidity, the Agency observes that any such advantage of larger allowance banks must be balanced with the disadvantages of excess allowance supply—specifically, reduced allowance prices, diminished incentives for sources to optimize control operation, and greater risk of failure to sustain the Step 3 control stringency. In the final rule, the EPA finds that a reasonable balance between these opposing considerations is struck by temporarily adopting a higher bank target percentage of 21 percent (consistent with the initial bank targets used in this rule and previous rules) and deferring implementation of the 10.5 percent target bank percentage identified by the Agency’s analysis as a sustainable percentage in the longer term until the 2030 control period.

7. Unit-Specific Backstop Daily Emissions Rates

While the identified EGU emissions reductions in section V of this document (*i.e.*, the Step 3 emissions control stringency) are incentivized and secured primarily through the corresponding seasonal state emissions budgets (expressed as a seasonal tonnage limit for all covered EGUs within a state’s borders) described earlier, the EPA is also incorporating a backstop daily emissions rate of 0.14 lb/mmBtu applied to coal-fired steam units serving generators with nameplate capacity greater than or equal to 100 MW in covered states, except circulating fluidized bed units. This is important for ensuring the elimination of significant contribution on a more consistent basis from the relevant sources and over each day of the ozone season.

Starting with the 2024 control period, a 3-for-1 allowance surrender ratio (instead of the usual 1-for-1 surrender ratio) will apply to emissions during the ozone season from any large coal-fired EGU with existing SCR controls exceeding by more than 50 tons a daily average NO_x emissions rate of 0.14 lb/mmBtu. The daily average emissions rate provisions will apply to large coal-fired EGUs without existing SCR controls (except circulating fluidized bed units) starting with the second control period in which newly installed SCR controls are operational at the unit, but not later than the 2030 control period. See Appendix A of the Ozone Transport Policy Analysis Final Rule

TSD for a list of coal-fired steam units serving generators larger than or equal to 100 MW in covered states for which the identified backstop emissions rate will apply.

For each unit subject to the backstop daily emissions rate provisions for a given control period, the amount of emissions subject to the 3-for-1 surrender ratio will be determined as follows, generally on an automated basis using the unit's data acquisition and handling system (DAHS) required under 40 CFR part 75. For each day of the control period where the unit's average emissions rate for that day was higher than 0.14 lb/mmBtu, the owner or operator will compute what the unit's reported emissions on that day would have been (given the unit's reported heat input for the day) at an emissions rate of 0.14 lb/mmBtu. The difference between the unit's emissions for the day as actually reported and the emissions that would have been reported if the unit's emissions rate was 0.14 lb/mmBtu is the unit's daily exceedance. The amount of emissions subject to the 3-for-1 surrender ratio for the control period is the sum of the unit's daily exceedances for all days of the control period minus 50 tons (but not less than zero).³³¹ All calculations will rely on the data monitored and reported for the unit in accordance with 40 CFR part 75.

The EGU NO_x Mitigation Strategies Final Rule TSD describes the methodology for deriving the 0.14 lb/mmBtu daily rate limit in more detail. The methodology is summarized as follows. First, consistent with stakeholders' focus on providing daily assurance of control operation, which is consistent with the 8-hour form of the 2015 ozone NAAQS and the tendency for ozone levels to spike on a diurnal cycle, the EPA determined that daily (as opposed to hourly or monthly) was an appropriate time metric for backstop emissions rate limits instituted to ensure operation of controls on high ozone days. The EPA derived the 0.14 lb/mmBtu daily rate limit by determining the particular level of a daily rate that would be comparable in stringency to the 0.08 lb/mmBtu seasonal emissions rate that the Agency has identified as reflecting SCR optimization at existing units.³³² The

³³¹ In the regulatory text at 40 CFR 97.1024 defining the total quantity of allowances that must be surrendered for a source's emissions in a control period, these amounts of emissions for all the units at the source are subject to a requirement to surrender two extra allowances per ton in addition to the usual 1-for-1 allowance surrender requirement, yielding a total surrender ratio of 3-for-1 for emissions over the 50-ton threshold.

³³² See page 24 of "Guidance for 1-hour SO₂ Nonattainment Area SIP Submission" at https://www.epa.gov/sites/default/files/2016-06/documents/20140423guidance_nonattainment_sip.pdf.

EPA first conducted an empirical exercise using reported daily emissions rate data from existing, SCR-controlled coal units that were emitting at or below 0.08 lb/mmBtu on a seasonal average basis. This seasonal rate reflects the average across a unit's range of varying daily rates reflecting different operation conditions. When the EPA examined the daily emissions rate pattern for these units considered to be optimizing their SCRs on a seasonal basis, the EPA observed that over 95 percent of the time, their daily rates were below 0.14 lb/mmBtu. In addition, for these units, less than 1 percent of their seasonal emissions would exceed this daily rate limit.

The EPA conducted this analysis to be consistent with the methodology developed in the 2014 1-hr SO₂ attainment area guidance for identifying "comparably stringent" emissions rates over varying time-periods.³³³ Appendix C of that guidance describes a series of steps that involve: (1) compiling emissions data to reflect a distribution of emissions rates with various averaging times, (2) determining the 99th percentile of the average emissions values compiled in the previous step, and then (3) applying "adjustment factors" or ratios of the 99th percentile values to emissions rates to convert them (usually from a short-term rate to a longer-term rate). In this case, the EPA applied the methodology in reverse to convert a longer-term limit (the seasonal rate of 0.08 lb/mmBtu which was assumed to be equivalent to a 30-day rate of 0.08 lb/mmBtu for purposes of this comparison of rates across averaging times) to a comparably stringent short-term limit (a daily rate of 0.14 lb/mmBtu).

The inclusion of a 50-ton threshold for emissions exceeding the backstop daily emissions rate before the 3-for-1 surrender applies is a change from the proposal. As discussed in section VI.B.1.d of this document, the EPA made this change in response to comments concerning the possibility that the 3-for-1 surrender ratio could otherwise have applied to emissions outside an EGU operator's control, with

www.epa.gov/sites/default/files/2016-06/documents/20140423guidance_nonattainment_sip.pdf. "A limit based on the 30-day average of emissions, for example, at a particular level is likely to be a less stringent limit than a 1-hour limit at the same level 1 since the control level needed to meet a 1-hour limit every hour is likely to be greater than the control level needed to achieve the same limit on a 30-day average basis."

³³³ See Guidance for 1-Hour SO₂ Nonattainment Area SIP Submissions available at https://www.epa.gov/sites/default/files/2016-06/documents/20140423guidance_nonattainment_sip.pdf.

the most important example being the emissions during unit startup before SCR equipment can be brought into service, and to a lesser extent the emissions during unit shutdown. The analysis used by the EPA to derive the 50-ton threshold is described in detail in the Ozone Transport Policy Analysis Final Rule TSD. Briefly, for a set of 164 SCR-equipped units with seasonal average NO_x emissions rates at or below 0.08 lb/mmBtu in 2021, the EPA evaluated the total amounts of emissions that would have been determined to exceed a daily average emissions rate of 0.14 lb/mmBtu in the 2021 and 2022 ozone seasons. In the 2021 ozone season, only 572 tons out of these units' total emissions of 60,350 tons, or 0.9 percent, would have been considered exceedances, with an average exceedance per unit of less than 4 tons. The highest amount for any of the 164 individual units in either ozone season was 48 tons. Based on this analysis, the EPA concludes that adding a 50-ton threshold to the backstop daily emissions rate provisions will ensure that substantially all emissions outside the control of an SCR-equipped unit's operator will not be subject to the 3-for-1 surrender ratio. Because there is no reason to expect the range of emissions during conditions when SCR controls cannot be operated to differ between SCR-equipped units and units without SCR, inclusion of the 50-ton threshold effectively prevents application of the 3-for-1 ratio to emissions during startup and shutdown by units without SCR as well.

At the same time, the EPA believes the 50-ton threshold is not large enough to eliminate the intended incentive to achieve emissions rates consistent with good SCR performance under conditions other than startup and shutdown. For a set of 124 SCR-equipped units with seasonal average NO_x emissions rates above 0.08 lb/mmBtu, the total amount of emissions exceeding a daily average emissions rate of 0.14 lb/mmBtu in the 2021 ozone season was 18,629 tons. Of this total amount, 15,374 tons would have been in excess of the 50-ton thresholds for the various units, indicating that even after application of the threshold, the 3-for-1 surrender ratio would have applied to over 80 percent of the daily exceedance amounts.

The backstop daily NO_x emissions rate provisions finalized in this rule are unchanged from the proposal except for the inclusion of a 50-ton threshold for emissions exceeding the backstop emissions rate before the 3-for-1 surrender ratio applies and the deferral of the application of the provisions to units without existing SCR controls

until the 2030 control period or, if earlier, the second control period in which new SCR controls are operated at a unit. The EPA's responses to comments on the backstop daily NO_x emissions rate provisions, including the reasons for these changes, are discussed in the remainder of this section and in section 5 of the *RTC* document.

Comment: Some commenters strongly supported the backstop daily emissions rate provisions, noting their benefit to downwind receptors on potential nonattainment days, their benefit to neighboring communities, and evidence of deterioration in SCR performance in the absence of such provisions. Other commenters stated that the backstop daily emissions rate provisions are unnecessary, either because SCR-equipped EGUs would already be sufficiently incentivized to operate and optimize their controls by the stringency of the state emissions budgets and the resulting allowance prices or because most SCR-equipped EGUs are already required to operate and optimize their SCRs by conditions in their operating permits. Some commenters cited previous EPA analyses showing that it is unusual for SCR-equipped units to turn off their SCRs only on high electricity demand days (HEDD).

Commenters suggested diverse possible changes to the types of EGUs that would be covered by the backstop daily emissions rate provisions. Some commenters stated that the provisions should apply to all EGUs or to all SCR-equipped EGUs, including non-coal-fired units. Other commenters stated that exemptions should be provided for units operating at capacity factors below 10 percent or for emissions during emergencies.

Some commenters stated that implementation of the backstop daily emissions rate provisions would cause unintended and counterproductive consequences. Some of these commenters claimed that by requiring the surrender of extra allowances, the backstop emissions rate provisions would create shortages of allowances for the program overall. Other commenters claimed that the disincentives to operate units subject to the backstop emissions rate provisions would cause load to shift to higher-emitting generators not covered by the trading program (such as sources in states outside the program's geographic region, EGUs smaller than 25 MW, and sources considered demand-side resources, including end-user-sited diesel generator units), potentially resulting in higher overall emissions.

Response: The EPA agrees that backstop daily emissions rate provisions should be implemented and disagrees

with comments suggesting that the need for the backstop daily emissions rate provisions is contradicted by previous EPA analyses or is already adequately addressed by other provisions of this rule or other legal requirements. As discussed in sections V.D.1 and VI.B.1.c of this document, the EPA has determined that a control stringency reflecting universal installation and operation of SCR technology at large coal-fired EGUs is appropriate. There are several important differences between this rule and previous actions addressing interstate ozone transport where the Agency did not include such provisions. First, this rule constitutes a full remedy, unlike some prior actions. Second, this rule is the first rule in which the EPA is addressing good neighbor obligations with respect to the more protective 2015 ozone NAAQS. Third, the EPA has examined the most recent data over a broader geographic and temporal footprint specific to the coverage of this rule, and it illustrates a greater degree of SCR performance erosion than in the prior years in which EPA conducted such analysis. Fourth, nonattainment and maintenance for this NAAQS are projected to persist well into the future in EPA's baseline, making enhancements and safeguards such as the backstop daily emissions rate provisions essential for securing elimination of significant contribution in future periods for which fleet configuration is inherently more uncertain.

With respect to claims that inclusion of the backstop daily emissions rate provisions is contradicted by the EPA's earlier analyses concerning SCR operational changes specific to high electricity demand days, the EPA disagrees. Historical data reported to the EPA show that multiple SCR-equipped units across the states covered by this action have chosen not to operate their SCRs, or to operate them at materially less than their full removal capability, for entire ozone seasons. The apparent infrequency of one type of behavior—*i.e.*, instances of units running their controls on most days but turning the controls off specifically on high electricity demand days—does not contradict the evidence concerning another type of behavior—*i.e.*, non-operation or suboptimal operation of controls for entire ozone seasons. The evidence from previous trading programs demonstrates that reliance solely on the incentives created by allowance prices and corresponding static state emissions budgets has been insufficient to cause all SCR-equipped

units to operate and optimize their controls for entire ozone seasons.

The EPA acknowledges that some SCR-equipped units are likely already subject to other legal requirements calling for their SCR controls to be operated and optimized such that their seasonal average NO_x emissions rates will generally not exceed 0.08 lb/mmBtu (the level of seasonal SCR performance that the EPA used to derive the equivalent 0.14 lb/mmBtu level of daily SCR performance for the backstop daily NO_x emissions rate). However, commenters do not claim, and the EPA does not believe, that *all* SCR-equipped units are subject to other legal requirements calling for an equivalent degree of SCR operation and optimization. In the context of a multi-state trading program, it is more efficient and equitable, and far more transparent, for the EPA to establish rule provisions uniformly incentivizing all large coal-fired EGUs to install and operate SCR controls than to attempt to establish differentiated requirements for various units according to the EPA's analysis of the effectiveness of their pre-existing permit conditions. Further, to the extent that a given unit's permits already require SCR performance that would meet the backstop emissions rate established in this rule, or to the extent that allowance prices would incentivize the unit to operate the SCR anyway, the EPA expects that the backstop daily emissions rate provisions (as finalized with a 50-ton threshold to address emissions outside an EGU's control before the 3-for-1 surrender ratio applies) will cause no incremental cost for the unit.

The EPA disagrees with the suggested changes to applicability of the backstop emissions rate provisions. With respect to the comments advocating broader coverage, the EPA discusses its reasons for applying the provisions only to coal-fired EGUs in section VI.B.1.c of this document, including the fact that operation of SCR controls is a well-established practice among the best performing coal-fired boilers but not for non-coal-fired units.³³⁴ The comments indicate a preference for a less flexible trading program design than the EPA has found appropriate but do not demonstrate that EPA's decision to allow greater flexibility is either impermissible or unreasonable; our reasoning in this regard is further explained in section VI.B.1.c.i of this

³³⁴ Nationwide and among operating units in 2021, EPA identified the best performing quartile (*i.e.*, lowest ozone season emissions rate) of coal-fired EGU boilers (excluding CFB units). Nearly 100 percent of these units (159 of 160 units) were equipped with SCR controls.

document. With respect to the comments advocating narrower coverage, the commenters have provided no information indicating that the sources for which exemptions are sought could not comply with the provisions, including through the surrender of additional allowances if necessary. The EPA notes that emissions from coal-fired units operating at low capacity factors may be concentrated around days of high electricity demand when incentives to minimize such emissions may be most helpful in mitigating downwind air quality problems. The EPA also notes that to the extent the comments are intended to support exemptions for units without existing SCR controls, the final rule defers application of the backstop emissions rate provisions to such units until the 2030 control period, providing additional flexibility to develop alternatives to the use of such units if the owners choose not to equip them with SCR controls.

Finally, the EPA also disagrees with the comments asserting that the backstop emissions rate provisions would cause unintended and counterproductive consequences. With respect to units already equipped with SCR controls, the EPA expects that by far the most important effect of the provisions will be to incentivize the units to operate and optimize their controls. The EPA sees no basis for speculation that such units would choose to operate in a manner that would result in large amounts of emissions becoming subject to the 3-for-1 allowance surrender ratio or in generation being shifted to sources outside the trading program. The results of the EPA's modeling of benefits and costs of the rule show little leakage of emissions to non-covered sources, and commenters have presented no analysis to the contrary. For instance, as shown in Table 4.6 of the *RIA*, non-covered state ozone season NO_x emissions increased on average by 1 percent over the 2023–2030 time period between the base and final rule scenarios, while covered state emissions fell by 14 percent on average over the same period. With respect to units without existing SCR controls, the EPA expects the backstop emissions rate provisions, when they would take effect for such units, to provide a strong incentive against extensive operation (unless and until such controls are installed), again not resulting in large amounts of emissions becoming subject to the 3-for-1 allowance surrender ratio.

Comment: For units with existing SCR controls, the aspect of the backstop daily emissions rate provisions that

received the most attention in comments was how emissions outside the operator's control should be treated. Multiple commenters expressed concern that the backstop daily emissions rate would be exceeded on days when the SCR equipment cannot be operated for all or a portion of the day. The most commonly cited example of a situation where SCR equipment cannot be operated was unit startups, although some commenters also mentioned unit shutdowns, boiler or emissions control malfunctions, and unit maintenance or tests. The commenters expressed the view that emissions that cannot be controlled by SCR equipment should be exempted from the backstop emissions rate provisions and suggested a variety of approaches for implementing an exemption.

Some commenters also stated that the backstop emissions rate provisions would not sufficiently accommodate sustained low-load operation, such as where an SCR-equipped unit operates for extended periods at a load level too low to permit SCR operation so that the unit is ready to ramp up to higher load levels in less time than would be required for a startup. The commenters suggested that implementation of a backstop daily rate would reduce the ability to operate the units in this manner, generally reducing system flexibility. Some noted that the need for flexibility of this nature is increasing because of the rapid growth in intermittent renewable generation.

Additional comments on the backstop daily emissions rate provisions for units with existing SCR controls addressed the level of the daily emissions rate and the implementation timing. With respect to the rate level, various commenters suggested rates from 0.08 to 0.20 lb/mmBtu. With respect to implementation timing, some commenters stated that because immediate compliance was possible, the good neighbor provision required implementation as of the 2023 control period rather than the 2024 control period as proposed. Other commenters expressed the view that units with existing SCR controls should not be required to comply with the backstop emissions rate provisions earlier than units without existing SCR controls. Some owners of SCR-equipped EGUs that exhaust to stacks shared with EGUs without SCR suggested that their particular units with existing SCR controls should not be required to comply with the backstop emissions rate provisions earlier than units without existing SCR controls in order to avoid the cost of upgrading their emissions monitoring equipment.

Response: With respect to the topic of emissions outside an operator's control, as a general matter the EPA agrees that the backstop daily emissions rate provisions are intended to incentivize good SCR operation and that it was not the Agency's intent to apply a higher surrender ratio to emissions that are truly unavoidable, such as emissions occurring before an operator could reasonably initialize SCR operation when a unit is started up. As explained elsewhere in this section, the EPA selected the level of the backstop rate based on analysis of 2021 emissions data showing that for SCR-equipped coal-fired units achieving seasonal average NO_x emissions rates at or below 0.08 lb/mmBtu, more than 99 percent of the units' emissions would fall below a backstop daily emissions rate of 0.14 lb/mmBtu. In response to the comments summarized previously, the EPA has further analyzed 2021 and 2022 emissions data to determine what if any modifications to the proposal might be appropriate to limit the imposition of a 3-to-1 allowance surrender requirement for emissions caused by circumstances outside an operator's control while preserving the intended incentive to operate and optimize SCR controls whenever possible. The analysis showed that for the same set of units achieving seasonal average emissions rates at or below 0.08 lb/mmBtu, the highest total amount of emissions exceeding the backstop daily emissions rate in either the 2021 or 2022 control period for any unit was 48 tons. The Agency views this amount as a reasonable upper bound on the quantity of emissions that might contribute to an exceedance of the backstop emissions rate arising from circumstances outside an operator's control for any coal-fired unit, not just the well-controlled units in the data set analyzed, because the amount generally encompasses all of a unit's emissions occurring in hours when an SCR could not be operated over an ozone season.

Based on this analysis, the backstop daily emissions rate provisions in this final rule exclude the first 50 tons of a unit's emissions in a given control period exceeding the backstop daily emissions rate from incremental allowance surrender requirements. The EPA finds that establishing a threshold of this nature will provide an appropriate maximum exclusion to all coal-fired units for unavoidable emissions caused by circumstances outside the operator's control while maintaining the incentives for less well-controlled units to improve their emissions performance on all days of

the ozone season. Well-controlled units will likely have no emissions over the threshold that will be subject to incremental allowance surrender requirements, while for SCR-equipped units not already achieving a seasonal average emissions rates sufficiently low to routinely operate at daily average emissions rates of 0.14 lb/mmBtu or less, the incentive to reduce daily emissions rates will remain in place, because the 50-ton threshold is not expected to encompass all emissions exceeding the backstop daily emissions rate for such units. In contrast to more complicated exceptions suggested by commenters, the 50-ton threshold can be easily integrated into the overall trading program structure with minimal additional recordkeeping and reporting requirements.

With respect to the comments claiming that the inability of some SCR-equipped units to operate their SCR controls at sustained low load levels likewise merits alteration of the backstop daily emissions rate provisions, the EPA disagrees. There is no dispute concerning the technical need for a unit to attain and maintain a certain range of exhaust gas temperatures at the SCR inlet in order to achieve optimal SCR performance and no dispute concerning the general relationship between a unit's load level in a given hour and its ability to attain and maintain that exhaust gas temperature range in that hour. However, the EPA is also aware that at least in some cases, units whose role in the integrated electric system currently calls for them to operate at low load levels for sustained periods (such as overnight) in fact may be able to operate at slightly higher load levels that would accommodate SCR operation during those periods and still meet the needs of the integrated electric system, thereby avoiding operation of the unit for sustained periods with the SCR out of service. Figure B.5 in the EGU NO_x Mitigation Strategies Final Rule TSD illustrates this opportunity using data reported for the 2021 and 2022 ozone seasons by a large SCR-equipped EGU in Pennsylvania. In both ozone seasons, the unit often cycled daily between its maximum load of approximately 900 MW during the daytime and a lower load level overnight, and in both ozone seasons the unit's typical daytime emissions rate was between 0.05 and 0.07 lb/mmBtu. However, while in the 2021 ozone season, the unit cycled down to a load level of approximately 440 MW overnight and did not operate its SCR, in the 2022 ozone season, when allowance prices were considerably

higher, the unit cycled down to a load level of approximately 540 MW overnight and did operate its SCR. Despite the higher nighttime generation levels, the result was a decrease of roughly 50 percent in the unit's seasonal average NO_x emissions rate, from approximately 0.14 lb/mmBtu to approximately 0.07 lb/mmBtu, and a comparable reduction in NO_x mass emissions. This unit is not uniquely situated; operating data for several other large SCR-equipped EGUs in Pennsylvania show the same past pattern of cycling down to low load levels at which the SCR controls cannot be operated, and these other units have similar opportunities to cycle down to somewhat higher load levels (necessarily subject to the needs and constraints of the integrated electric system) at which their SCR controls can be operated.³³⁵ No commenter has submitted data to the contrary. Furthermore, this example demonstrates the need for this rule's backstop emissions rate provision, which (had it been in place) would have motivated this facility to operate its SCR overnight during the 2021 ozone season when the prevailing allowance price provided an insufficient incentive to do so.

The EPA disagrees with the comments advocating for a backstop daily emissions rate lower or higher than 0.14 lb/mmBtu. In general, these comments simply represent disagreements with the EPA's conclusions regarding the identification of required emissions reductions under this rule, as reflected in part by the EPA's conclusion that a seasonal average emissions rate of 0.08 lb/mmBtu reasonably reflects the seasonal average emissions rate achievable through optimization of controls by existing SCR-equipped units that are not already achieving a lower seasonal average emissions rate. Comments concerning the selection of the 0.08 lb/mmBtu seasonal average emissions rate are addressed in section V of this document. Commenters did not challenge the EPA's analysis identifying a daily emissions rate of 0.14 lb/mmBtu as comparable in stringency to a seasonal average emissions rate of 0.08 lb/mmBtu (see further discussion elsewhere in this section).

The EPA also disagrees with the comments stating that the backstop daily emissions rate provisions should apply to units with existing SCR controls starting in a control period earlier or later than the 2024 control period. The EPA does not consider

implementation of the provisions in the 2023 control period feasible because it is currently unknown whether the necessary updates to the emissions recordkeeping and reporting software for all the affected sources could be completed and tested before July 30, 2023, which is the first quarterly reporting deadline for the 2023 control period. Moreover, as discussed in section VI.B.1.c.i of this document, implementing the requirements starting in 2024 will provide a window for EGUs to improve the consistency of SCR operation or in some cases to optionally install additional emissions monitoring equipment. As for the suggestion that implementation timing of the backstop daily emissions rate provisions for units with existing SCR controls should be synchronized with the later implementation timing for units without existing SCR controls, the EPA is not persuaded that there is any inequity in implementing provisions intended to incentivize operation of SCR controls first at sources that already have such controls and later at sources that do not already have such controls, allowing time for the latter sources to install the controls. In any event, in this instance, where some upwind sources have an immediate and highly cost-effective option for controlling their emissions, the statutory requirement for significant contribution to be eliminated as expeditiously as practicable so as to provide downwind states with the protection intended by the Good Neighbor provision overrides these sources' claim of inequity relative to sources whose emissions control options would take longer and have higher cost. We conclude that the backstop daily emissions rate is an important aspect of the elimination of significant contribution and should be applied at the relevant units. It is only out of recognition of unique circumstances associated with facilitating power-sector transition as identified by commenters, that we defer the application of the rate for the minority of units that have not yet installed SCR controls.

Finally, with respect to the SCR-equipped units that share common stacks with units that do not have SCR, the EPA disagrees that monitoring cost considerations merit a later implementation date for the backstop daily emissions rate provisions. As discussed in section VI.B.10 of this document, five plants with this configuration are covered by the rule (one of which has announced plans to retire in 2023). Under this rule, as proposed, the owner of a plant with this

³³⁵ See the spreadsheet "Conemaugh and Keystone unit 2021 to 2022 hourly ozone season data" in the docket.

configuration can choose between either upgrading the plant's monitoring systems so as to obtain unit-specific NO_x emissions rate data for each unit subject to the backstop daily emissions rate or else using the NO_x emissions rate data from the common stack, recognizing that the common stack emissions rate would generally be biased upwards relative to the emissions rate that could be reported for the SCR-equipped unit if that unit's emissions were monitored separately. Commenters have suggested a third option of a temporary exemption from the backstop emissions rate to avoid the cost of upgrading their monitoring systems. With the timing for implementation of the backstop emissions rate provisions for currently uncontrolled units in the proposal, the temporary exemption for the SCR-equipped units would have been in place for three control periods, from 2024 through 2026. With the final rule's deferral of the implementation of the backstop emissions rate provisions for the uncontrolled units for up to three years, the suggested temporary exemption for the SCR-equipped units would be in effect for up to six control periods, from 2024 through 2029. The EPA does not consider it reasonable to allow these SCR-equipped units an exemption from the backstop rate provisions for six years to avoid the cost of upgrading their monitoring systems, particularly given that the additional costs of monitoring at the individual-unit level are already borne by the large majority of other plants and the rule already provides these plants with an alternative to the monitoring system upgrades, if desired, by allowing the plants to use the emissions rate data from the common stack.³³⁶

Comment: With respect to units without existing SCRs, some commenters viewed the backstop daily emissions rate provisions as likely to make units without SCR altogether unwilling or unable to operate and characterized the provisions as a mandate for such units to install such controls or retire as of the control period when the provisions are implemented. Other commenters acknowledged that the provisions are not actually hard limits but stated that the higher allowance surrender ratio for emissions in excess of the backstop daily rate would nevertheless reduce the ability of

such units to operate as needed to back up intermittent renewable generation. Some commenters claimed that inclusion of the backstop daily emissions rate provisions would substantially eliminate the potential benefits of allowance trading, because all units would have to meet the same emissions rate.

Some commenters stated that the proposed application of the daily backstop emissions rate provisions in the 2027 control period in some cases would occur only slightly before the units' otherwise planned retirement dates, and that short-term reliability considerations could create the need to make substantial investments in new controls at the units, which in turn could result in deferral of the units' retirement plans. In the proposal, the EPA requested comment on the possibility of deferring the application of the backstop emissions rate provisions to units without existing SCR controls until the 2029 control period if the owners provided the EPA with information indicating with sufficient certainty that the units would retire by the end of 2028. Commenters in favor of this concept suggested longer deferral periods, ranging from 2029 through 2032, and some also suggested that the EPA should simultaneously enlarge the emissions budgets to provide more allowances for units subject to the deferred requirement. Other commenters opposed any deferral of the applicability of the backstop rate provisions.

Response: The EPA disagrees that implementation of the backstop daily emissions rate provisions for EGUs without existing SCR controls constitutes a mandate for such units to install controls or retire but agrees that, as intended, the provisions would create strong incentives to minimize operation of the units unless and until controls are installed, and further agrees that in some instances retirement and replacement may be a more economically attractive option for the unit's customers and/or owners than installation of new controls. The EPA's rationale for determining at Step 3 that the control stringency required to address states' good neighbor obligations includes achievement of emissions rates consistent with good SCR performance at all large coal-fired EGUs (other than circulating fluidized bed boilers) is discussed in section V.D.1 of this document, and the EPA's rationale for determining at Step 4 that the trading program should include strong unit-level incentives to implement these controls is discussed in section VI.B.1.c. of this document. As

noted in section VI.B.1.c of this document, the backstop daily emissions rate provisions are structured as incremental allowance surrender requirements rather than as directly enforceable emissions limits to incentivize improved emissions performance at the individual unit level while continuing to preserve, to the extent possible, the advantages that the flexibility of a trading program brings to the electric power sector. The EPA appreciates that, in comparison to previous transport rules using a trading program mechanism for the power sector, the degree of flexibility available under this rule is reduced both by the greater stringency of the overall emissions reduction requirements, which leave less room to accommodate emissions from high-emitting units such as uncontrolled coal-fired units, and by the backstop daily emissions rate provisions. However, the EPA maintains that the trading program structure still is significantly more flexible than an array of directly enforceable emissions limits imposed on all EGUs or even on all coal-fired EGUs, and the comments do not show otherwise.

With respect to the comments concerning the timing for application of the backstop daily emissions rate provisions to EGUs without existing SCR controls, in the final rule the provisions will apply to these units starting with the second control period in which newly installed SCR controls are operational at the unit, but not later than the 2030 control period. As discussed in section VI.B.1.d of this document, the purpose of this change from the proposal is to address concerns expressed by RTOs and other commenters that application of the backstop daily NO_x emissions rate to EGUs without existing SCR controls starting in the 2027 control period would provide insufficient time for planning and investments needed to facilitate the unit retirements they viewed as likely to be a preferred compliance pathway for some owners. The EPA recognizes that retrofitting new emissions controls on aging coal-fired EGUs may be less environmentally efficient than the alternative of retirement and replacement, which could yield lower cumulative emissions of NO_x and multiple other pollutants over time. The EPA also recognizes that several coal-fired EGUs have already been considering retirement in 2028 (or earlier) under compliance pathways available under the Clean Water Act effluent guidelines³³⁷ and the coal combustion residuals rule under the

³³⁶ The owner of one of the five plants with common stacks submitted comments stating that no location in the plant's ductwork could meet the criteria for a unit-specific monitoring location. As discussed in section VI.B.10 of this document, EPA staff have reviewed the comment and do not believe the commenter has provided sufficient information to reach such a conclusion.

³³⁷ See 40 CFR 423.11(w).

Resource Conservation and Recovery Act.³³⁸ The year 2028 also represents the end of the second planning period under the Regional Haze program, and thus is a significant year in states' planning of strategies to make reasonable progress towards natural visibility at Class I areas.³³⁹ In addition, other regulatory actions at the state or Federal level are being or recently have been proposed. This includes among other things a proposed revision to the PM NAAQS for which transport SIPs would be due later in the 2020s. We understand that EGUs may wish to take the entire regulatory and market landscape into account when deciding whether to invest in SCR or pursue other NO_x reduction strategies. To facilitate a unit-level compliance alternative under this rule that maintains the NO_x reductions corresponding to SCR-level emissions control performance required by the state budgets from 2026 forward and that is potentially superior both economically and environmentally across multiple regulatory programs than installation of new, capital-intensive, post-combustion controls, the EPA is providing the fleet more flexibility in how to achieve those emissions reductions in the years through 2029. Relatedly, the deferral of the application of the backstop emissions rate provisions to uncontrolled units also addresses commenters' concerns that the provisions otherwise would reduce the ability of uncontrolled units to operate as needed to back up intermittent renewable generation (subject of course to the allowance-holding requirements to cover emissions). The deferral addresses this concern directly for the period through 2029, by eliminating application of the backstop provisions to uncontrolled EGUs through this period, and also indirectly after 2029, by ensuring the availability of sufficient time for owners and operators to complete other investments that may be needed to back up renewable generation after that point.

The EPA disagrees with the comments stating that application of the backstop daily emissions rate provisions to uncontrolled units should not be deferred and also disagrees with the comments stating that deferral should be accompanied by increases in the state emissions budgets reflecting higher assumed emissions rates for these units. The responses to these two comments are related. This rule complies with the mandate for the EPA to address good

neighbor obligations as expeditiously as practicable and is based on a demonstration that emissions reductions commensurate with the overall emissions control strategy at Step 3 can be achieved beginning in the 2027 ozone season (following a two-year phase in of emissions reductions associated with installation of SCR retrofits). In the *RIA*, we demonstrate that EGUs will have multiple pathways to meeting the state budgets even if they choose not to install the SCR controls—thus no relaxation in the stringency of these budgets has been demonstrated to be warranted based on feasibility, necessity, or impossibility. The EGU economic modeling discussed in the *RIA* illustrates that many sources identified as currently having SCR retrofit potential elect not to install a SCR, and those that do retrofit SCR make no such installation until 2030. Yet, the fleet is able to comply with 2026 state emissions budgets (whose emissions reductions are premised in large part on assumed SCR retrofits) through reduced utilization (many of these units are projected to retire, and thus reduce emissions). While these changes in coal fleet utilization are not required or imposed through the EPA's state emissions budgets, they are projected to be an economic preference for a substantial portion of the unretrofitted fleet owing to future market and policy conditions. If sources do ultimately elect this pathway, then compliance will occur with significantly less demand on SCR retrofit labor and material markets than assumed at Step 3. The daily emissions rates are a backstop to the broader emissions reduction requirements, which we view as an important and necessary component to the elimination of significant contribution. But we also recognize that the objectives to be accomplished by the backstop must be balanced with larger economic and environmental conditions facing EGUs for which a deferral of the backstop rate ultimately is the most reasonable approach given these competing concerns. See *Wisconsin*, 938 F.3d at 320 (“EPA, though, possesses a measure of latitude in defining which upwind contribution ‘amounts’ count as ‘significant[]’ and thus must be abated.”). As noted in section VI.B.1.d of this document, the EPA finds that as long as state emissions budgets continue to reflect the required degree of emissions reductions at least for an interim period until the backstop rate would apply more uniformly, deferral of the backstop rate requirement for uncontrolled units in recognition of the

transition period identified by commenters can be justified on the basis of the greater long-term environmental benefits obtained through greater compliance flexibility.

8. Unit-Specific Emissions Limitations Contingent on Assurance Level Exceedances

As emphasized by the D.C. Circuit in its decision invalidating CAIR, under the CAA's good neighbor provision, emissions “within the State” that contribute significantly to nonattainment or interfere with maintenance of a NAAQS in another state must be prohibited. *North Carolina v. EPA*, 531 F.3d 896, 906–08 (D.C. Cir. 2008). The CAIR trading programs contained no provisions limiting the degree to which a state could rely on net purchased allowances as a substitute for making in-state emissions reductions, an omission which the court found was inconsistent with the requirements of the good neighbor provision. *Id.* In response to that holding, the EPA established the CSA PR trading programs' assurance provisions to ensure that, in the context of a flexible trading program, the emissions reductions required under the good neighbor provision in fact will take place within the state. The EPA believes the assurance provisions have generally been successful in achieving that objective, as evidenced by the fact that since the assurance provisions took effect in 2017, out of the nearly 300 instances where a given state's compliance with the assurance provisions of a given CSA PR trading program for a given control period has been assessed, a state's collective emissions have exceeded the applicable assurance level only four times.

Unfortunately, the EPA also recognizes that the assurance provisions' very good historical compliance record is not good enough. The four past exceedances all occurred under the Group 2 trading program: sources in Mississippi collectively exceeded their applicable assurance levels in the 2019 and 2020 control periods, and sources in Missouri collectively exceeded their applicable assurance levels in the 2020 and 2021 control periods.³⁴⁰ Both of the exceedances by Missouri sources could easily have been avoided if the owner and operator of several SCR-equipped,

³⁴⁰ Information on the assurance level exceedances in the 2019, 2020, and 2021 control periods is available in the final notices concerning EPA's administration of the assurance provisions for those control periods. 85 FR 53364 (August 28, 2020); 86 FR 52674 (September 22, 2021); 87 FR 57695 (September 21, 2022).

³³⁸ See 40 CFR 257.103(b).

³³⁹ See 40 CFR 51.308(f).

coal-fired steam units had not chosen to idle the units' controls and rely instead on net out-of-state purchased allowances. The exceedances were large, and ample quantities of allowances to cover the resulting 3-for-1 allowance surrender requirements were purchased in advance, suggesting that the assurance level exceedances may have been anticipated as a possibility. In the case of the Mississippi exceedances, the exceedances were smaller, operational variability (manifesting as increased heat input) appears to have been a material contributing factor, and the EPA has not concluded that the owners and operators anticipated the exceedances. However, an additional contributing factor was the fact that several large, gas-fired steam units without SCR controls emitted NO_x at average rates much higher than the average emissions rates the same units had achieved in previous control periods. In short, while the Missouri exceedances appear far more significant, the EPA's analysis indicates that all four past exceedances could have been avoided if the units most responsible had achieved emissions rates more comparable to the same units' previous performance. In the EPA's view, the operation of the Missouri units in particular—although not prohibited by the current regulatory requirements—cannot be reconciled with the statutory requirements of the good neighbor provision. The fact that such operation is not prohibited by the current regulations therefore indicates a deficiency in the current regulatory requirements.

To correct the deficiency in the regulatory requirements, the EPA in this rulemaking is revising the Group 3 trading program regulations to establish an additional emissions limitation to more effectively deter avoidable assurance level exceedances starting with the 2024 control period. Because the pollutant involved is ozone season NO_x and the particular sources for which deterrence is most needed are located in states that are transitioning from the Group 2 trading program to the Group 3 trading program, the EPA is promulgating the strengthening provisions as revisions to the Group 3 trading program regulations rather than the Group 2 trading program regulations.³⁴¹

³⁴¹ The EPA believes that the occurrence of avoidable assurance level exceedances under the Group 2 trading program, combined with the express statutory directive that good neighbor obligations must be addressed "within the state," and through "prohibition," would also provide a sufficient legal basis for the Agency to promulgate

The two historical emissions-related compliance requirements in the Group 3 trading program regulations are both structured in the form of requirements to hold allowances. The first requirement applies at the source level: specifically, at the compliance deadline after each control period, the owners and operators of each source covered by the program must surrender a quantity of allowances that is determined based on the emissions from the units at the source during the control period. The second requirement applies at the designated representative level (which typically is the owner or operator level): if the state's sources collectively emit in excess of the state's assurance level, the owners and operators of each set of sources determined to have contributed to the exceedance must surrender an additional quantity of allowances. As long as a source's owners and operators comply with these two allowance surrender requirements (and meet certain other requirements not related to the amounts of the sources' emissions), they are in compliance with the program.

In light of the operation of the Missouri sources, the EPA is doubtful that strengthening the assurance provisions by increasing allowance surrender requirements at the unit, source, or designated representative level would create a sufficient deterrent. Accordingly, the EPA is instead adding a new, unit-level emissions limitation structured as a prohibition to emit NO_x in excess of a defined amount. A violation of the prohibition will not trigger additional allowance surrender requirements beyond the surrender requirements that would otherwise apply, but will trigger the possible application of the CAA's enforcement authorities. The new emissions limitation will be in addition to, not in lieu of, the other requirements of the Group 3 trading program. This point is being made explicit by relabeling the source-level allowance holding requirement, currently called the "emissions limitation," as the "primary emissions limitation" and labeling the

the same revisions to the assurance provisions for all the other CSAPR trading programs. The EPA is not doing so at this time because the Agency has seen no reason to expect exceedances of the assurance levels under any of the other CSAPR trading programs by any of the states that will remain subject to the respective trading programs after this rulemaking, except possibly by Missouri under the CSAPR NO_x Annual Trading Program. The EPA expects that reductions in Missouri's seasonal NO_x emissions sufficient to comply with the proposed provisions of the revised Group 3 trading program, including the secondary emissions limitations, would also prevent exceedances of Missouri's currently applicable assurance level for annual NO_x emissions.

new unit-level requirement as the "secondary emissions limitation." (The regulations label the designated representative-level requirement as "compliance with the . . . assurance provisions.")

Because the purpose of the new unit-level secondary emissions limitation is to deter conduct causing exceedances of a state's assurance level, the EPA is conditioning applicability of the new limitation on (1) the occurrence of an exceedance of the state's assurance level for the control period, and (2) the apportionment of at least some of the responsibility for the assurance level exceedance to the set of units represented by the unit's designated representative. Apportionment of responsibility for the assurance level exceedance will be carried out according to the existing assurance provision procedures and will therefore depend on the designated representative's shares of both the state's total emissions for the control period and the state's assurance level for the control period. To ensure that the secondary emissions limitation is focused on units where the need for improved incentives is greatest, and also to ensure that the limitation will not apply to units used only to meet peak electricity demand, the limitation applies only to units that are equipped with post-combustion controls (*i.e.*, SCR or SNCR) and that operated for at least ten percent of the hours in the control period in question and in at least one previous control period.

For units to which a secondary emissions limitation applies in a given control period based on the conditions just summarized, the limitation is defined by a formula in the regulations. The formula is generally designed to compute the potential amount the unit would have emitted during the control period, given its actual heat input during the control period, if the unit had achieved an average emissions rate equal to the unit's lowest average emissions rate in a previous control period plus a margin of 25 percent. To ensure that the data used to establish the unit's lowest previous average emissions rate are representative and of high quality, only past control periods where the unit participated in a CSAPR trading program for ozone season NO_x and operated in at least ten percent of the hours in the control period are considered. Further, to avoid causing units that achieve emissions rates lower than 0.08 lb/mmBtu from becoming subject to more stringent secondary emissions limitations in subsequent control periods, the secondary emissions limitation formula uses a

floor emissions rate of 0.10 lb/mmBtu (which is 0.08 lb/mmBtu plus the formula’s 25 percent margin). In addition to making sure that performance better than 0.08 lb/mmBtu is not disincentivized, the inclusion of the floor emissions rate also ensures that no unit achieving an average emissions rate of 0.10 lb/mmBtu or less in a given control period will exceed a secondary emissions limitation in that control period. Finally, the formula includes a 50-ton threshold, which will avert violations for small performance deviations at large EGUs and also ensure that no unit emitting less than 50 tons in a given control period will exceed a secondary emissions limitation in that control period.

In summary, a secondary emissions limitation is applicable to a unit for a given control period only if the state’s assurance level is exceeded, responsibility for the exceedance is apportioned at least in part to the set of

units represented by the unit’s designated representative, the unit is equipped with post-combustion controls, and the unit operated for at least ten percent of the hours in the control period. Where a secondary emissions limitation applies to a unit for a given control period, the amount of the limitation is computed as the sum of 50 tons plus the product of (1) the unit’s heat input for the control period times (2) a NO_x emissions rate of 0.10 lb/mmBtu or, if higher, 125 percent times the lowest seasonal average NO_x emissions rate achieved by the unit in a previous control period when the unit participated in a CSAPR trading program for ozone season NO_x emissions and operated in at least ten percent of the hours in the control period.³⁴²

Table VI.B.8–1 shows the secondary emissions limitations that the formula would have produced and which units would have exceeded those limitations

if the limitations and formula had been in effect for the Group 2 trading program in 2020 and 2021 when assurance level exceedances occurred in Missouri. Following consideration of comments, the EPA believes that in each case the formula functions in a reasonable manner, and the Missouri units identified as exceeding their respective secondary emissions limitations are sources for which an enforcement deterrent under CAA sections 113 and 304 would have been appropriate to compel better control of NO_x emissions. Table VI.B.8–1 does not show any units that would have been identified as subject to secondary emissions limitations in the case of the 2019 and 2020 assurance level exceedances in Mississippi because no units in the state meeting all conditions for applicability—including the requirement to be equipped with post-combustion controls—exceeded their respective limitations.

TABLE VI.B.8–1—ILLUSTRATIVE RESULTS OF APPLYING SECONDARY EMISSIONS LIMITATION IN PREVIOUS INSTANCES OF ASSURANCE LEVEL EXCEEDANCES

Owner/operator	Unit	125% of Lowest previously achieved NO _x emissions rate (lb/mmBtu)	Actual NO _x emissions rate (lb/mmBtu)	Secondary emissions limitation (tons)	Actual NO _x emissions (tons)	Exceedance (tons)
Missouri—2020						
Assoc. Elec. Coop	New Madrid 1	0.135	0.670	961	4,524	3,563
Assoc. Elec. Coop	New Madrid 2	0.131	0.497	866	3,108	2,242
Assoc. Elec. Coop	Thomas Hill 1	0.123	0.526	374	1,384	1,010
Assoc. Elec. Coop	Thomas Hill 2	0.122	0.537	548	2,187	1,639
Assoc. Elec. Coop	Thomas Hill 3	0.104	0.195	780	1,374	594
Missouri—2021						
Assoc. Elec. Coop	New Madrid 1	0.135	0.652	353	1,466	1,113
Assoc. Elec. Coop	New Madrid 2	0.131	0.611	1,054	4,700	3,646
Assoc. Elec. Coop	Thomas Hill 1	0.123	0.146	421	440	19
Assoc. Elec. Coop	Thomas Hill 2	0.122	0.400	600	1,801	1,201

For further illustrations of the application of the secondary emissions limitation formula to other units in the states to be subject to the expanded Group 3 trading program in the control periods from 2016 through 2021, see the spreadsheet “Illustrative Calculations Using Proposed Secondary Emissions Limitation Formula,” available in the docket. The EPA notes that, with the exception of the units listed in Table VI.B.8–1, no unit shown in the spreadsheet as having emissions exceeding the illustrative secondary emissions limitation calculated for the unit would have violated the prohibition because no violation would occur in the absence of an exceedance of the assurance level and

apportionment of responsibility for a share of the exceedance to the unit under the assurance provisions.

The secondary emissions limitation provisions are being finalized as proposed except for the addition of the condition that a unit to which the provisions apply must be equipped with post-combustion controls. The EPA’s responses to comments concerning the secondary emissions limitation provisions, including the comments giving rise to the change just mentioned, are in the remainder of this section and section 5 of the RTC document.

Comment: Some commenters stated that the secondary emissions limitation is not necessary, or would be a disproportionate remedy, because

experience shows that exceedances of the assurance level have been rare, and where exceedances of a state’s assurance level have occurred, the 3-for-1 surrender ratio under the existing regulations has applied, providing a sufficient remedy.

Response: The EPA disagrees with these comments. The purpose of the assurance provisions in the CSAPR trading programs is to ensure that the emissions reductions required to address a state’s obligations under the Good Neighbor Provision occur “within the state” as mandated by the CAA. See *North Carolina v. EPA*, 531 F.3d 896, 906–08 (D.C. Cir. 2008). Prior to this action, the sole consequence for an exceedance of a state’s assurance level

³⁴² For the actual regulatory language, see 40 CFR 97.1025(c) as added by this rule.

has been a requirement to surrender two additional allowances for each ton of the exceedance. The repeated, large, foreseeable, and easily avoidable exceedances of Missouri's assurance level under the Group 2 trading program in 2020 and 2021 have made clear that a remedy based solely on additional allowance surrenders is insufficient to address this statutory requirement and that a materially stronger deterrent is needed.

Comment: Some commenters stated that the secondary emissions limitation could apply to exceedances caused by factors outside the control of the EGU operator, going beyond the EPA's intent of deterring exceedances that are foreseeable and avoidable. For example, commenters pointed out that some units that typically combust gas may sometimes be ordered to combust oil at times when supplies of gas are constrained and expressed concern that the resulting higher NO_x emissions could cause a unit to exceed its secondary emissions limitation. Another commenter stated that it is not uncommon for units' seasonal average NO_x emissions rate to vary by more than 25 percent across control periods.

Response: The EPA agrees that the secondary emissions limitation is intended to apply to units in a position to avert an exceedance of a state's assurance level. The contention that year-to-year variability of 25 percent in units' seasonal average emissions rates is common is not in itself a persuasive reason to omit the secondary emissions limitation from the final rule, because the mere existence of such variability says nothing about whether the operators of those units could reduce that variability through their operational decisions, and the commenter provided no data regarding the extent to which the historical variability was avoidable. However, the EPA agrees that a secondary emissions limitation should be designed to avoid application to a unit whose increase in emissions rate was caused by mandated combustion of a higher-NO_x fuel than the unit's normal fuel. Moreover, based on the analysis of the secondary emissions limitation formula prepared for the proposal, the EPA has reviewed the applicability of the limitation more generally and has determined that it should apply only to units with post-combustion controls, which are the units with the greatest ability to manage their emissions rates through their operating behavior. This modification will avoid application of a secondary emissions limitation in situations where a unit's increase in seasonal average NO_x emissions rate relative to past

control periods is caused by factors in that control period beyond the operator's control, such as being mandated by a regulator to combust a higher proportion of oil or operating for a higher proportion of hours at load levels where the unit has a higher NO_x emissions rate for reasons other than non-operation of emissions controls.

Comment: Some commenters asserted that because it is not known if a state's assurance level has been exceeded until after the end of the control period, EGU operators would be unable to know whether the secondary emissions limitation would apply to them during the control period. Some of these commenters suggested that where a unit has been found to have contributed to an assurance level exceedance, the EPA should apply a secondary emissions limitation to the unit not in that control period but instead in the following control period.

Commenters suggested that uncertainty about whether a unit would be subject to a secondary emissions limitation could have a variety of undesirable consequences. For example, they asserted that some EGUs could become unwilling to operate when needed for reliability because they would be concerned that merely operating more than in previous control periods could cause a unit to exceed its limitation. One commenter asserted that the uncertainty would make it difficult for an owner of multiple EGUs to use allowances allocated to one EGU to meet another EGU's surrender requirements, possibly leading to operating restrictions on multiple EGUs.

Response: The EPA disagrees with these comments. While an operator cannot be certain that the secondary emissions limitation *will* apply to a particular EGU until after the end of a control period, the operator can be certain that the limitation *will not* apply to a particular EGU simply by ensuring that the unit's seasonal average NO_x emissions rate does not exceed the higher of 0.10 lb/mmBtu or 125 percent of the unit's lowest seasonal average NO_x emissions rate in a previous control period under a CSAPR trading program (excluding control periods where the unit operated for less than 10 percent of the hours). Because any operator of a unit with post-combustion controls can readily avoid being subject to the limitation, there is no need for application of the limitation to be deferred to the following control period. Deferral of the limitation's application would also have the effect of excusing a unit's first contribution to an assurance level exceedance, which the

EPA views as inappropriate when that exceedance could have been avoided.

The asserted possible consequences of uncertainty about whether the limitation would apply rest on mischaracterizations of the provision. The formula for the limitation reflects the unit's actual heat input for the control period, so there is no penalty for increased operation as long as the unit's seasonal NO_x average emissions rate stays below the level just referenced. Finally, nothing about the secondary emissions limitation disincentivizes an EGU fleet owner from transferring allocated allowances among the fleet's EGUs, because apportionment of responsibility for an assurance level exceedance—one of the conditions for application of the secondary emissions limitation—is determined at the level of the group of units represented by a common designated representative (typically the set of all units operated by a particular owner) rather than the individual unit.

Comment: Some commenters stated that the EPA should revise the secondary emissions limitation formula so that where a limitation applies to a unit, the unit's previous NO_x emissions rate used in the formula would not be subject to any floor. These commenters also recommended that if the secondary emissions limitation provisions are not finalized, the EPA instead should raise the allowance surrender ratio applied to exceedances of the assurance level in this final rule.

Response: The EPA disagrees with the suggestion to remove the emissions rate floor from the secondary emissions limitation formula, which would have the effect of making the limitation more stringent for any unit that has achieved a seasonal average NO_x emissions rate lower than 0.08 lb/mmBtu in a past control period. As indicated by their label, the secondary emissions limitation provisions play a secondary role in the Group 3 trading program regulations, specifically to provide the strongest possible deterrent against conduct leading to foreseeable and avoidable exceedances of a state's assurance level. The distinguishing feature of the secondary emissions limitation provisions is therefore the remedy for an exceedance, which is potential application of the CAA's enforcement authorities. The trading program's primary role of achieving required emissions reductions in a more flexible and cost-effective manner than command-and-control regulation is played by the primary emissions limitation provisions, which are structured as allowance surrender requirements. Within this overall

trading program structure, the EPA considers it sufficient for the operation of units at emissions rates lower than 0.08 lb/mmBtu to be incentivized through the allowance surrender requirements instead of being mandated through potential application of the CAA's enforcement authorities.

The recommendation to raise the allowance surrender ratio applicable to exceedances of the assurance level if the secondary emissions limitation is not finalized is moot because the secondary emissions limitation is being finalized.

9. Unit-Level Allowance Allocation and Recordation Procedures

In this rule, the EPA is establishing default procedures for allocating CSAPR NO_x Ozone Season Group 3 allowances ("Group 3 allowances") in amounts equal to each state emissions budget for each control period among the sources in the state for use in complying with the Group 3 trading program. Like the allocation processes established in CSAPR, the CSAPR Update, and the Revised CSAPR Update, the revised allocation process finalized in this rule is designed to provide default allowance allocations to all units that are subject to allowance holding requirements. The EPA's allocations and allocation procedures apply for the 2023 control period³⁴³ and, by default, for subsequent control periods unless and until a state or tribe provides state-determined or tribe-determined allowance allocations under an approved SIP revision or tribal implementation plan.³⁴⁴

The default allocation process for the Group 3 trading program as updated in this rule involves three main steps. First, portions of each state emissions budget for each control period are reserved for potential allocation to units that are subject to allowance holding requirements and that might not otherwise receive allowance allocations in the overall allocation process, including both "existing" units in any

³⁴³ The rule does not include an option for states to replace the EPA's unit-level allocations for the 2023 control period because the Agency believes a process for obtaining appropriately authorized allowance allocations determined by a state or tribe could not be completed in time for those allocations to be recorded before the end of the 2023 control period.

³⁴⁴ The options for states to submit SIP revisions that would replace the EPA's default allowance allocations are discussed in sections VI.D.1, VI.D.2, and VI.D.3 of this document. Similarly, for a covered area of Indian country not subject to a state's CAA implementation planning authority, a tribe could elect to work with the EPA under the Tribal Authority Rule to develop a full or partial tribal implementation plan under which the tribe would determine allowance allocations that would replace the EPA's default allocations for subsequent control periods.

areas of Indian country not subject to a state's CAA implementation planning authority as well as "new" units anywhere within a state's borders.³⁴⁵ Second, in advance of each control period, the unreserved portion of the state budget is allocated among the state's eligible existing units, any portion of the state budget reserved for existing units in Indian country not subject to the state's CAA implementation planning authority is allocated among those units, and the allocations are recorded in the respective sources' compliance accounts. Finally, after the control period but before the compliance deadline by which sources must hold allowances to cover their emissions for the control period, allowances from the portion of the budget reserved for new units are allocated to qualifying units, any remaining reserved allowances not allocated to qualifying units are allocated among the state's existing units, and the allocations are recorded in the respective sources' compliance accounts.

While the overall three-step allocation process summarized in this section was also followed in CSAPR, the CSAPR Update, and the Revised CSAPR Update, in this rule the EPA is making revisions to each step to better address units in Indian country and to better coordinate the unit-level allocation process with the dynamic budget-setting process discussed in section VI.B.4 of this document. The revisions to the three steps are discussed in sections VI.B.9.a, VI.B.9.b, and VI.B.9.c, respectively.

a. Set-Asides of Portions of State Emissions Budgets

The first step of the overall unit-level allocation process for a given control period involves reserving portions of each state's budget for the control period in "set-asides." In this rule, the EPA is making several revisions affecting the establishment of set-asides. The first revision, which is largely unrelated to the other aspects of this

³⁴⁵ Under this rule, the unit-level allocations to "existing" units are generally computed in the year before the year of each control period, and the determination of whether to treat a particular unit as existing for purposes of that control period's allocations is made as part of the allocation process, generally based on whether the Agency has the data needed to compute an allocation for the unit as an existing unit. A unit that is subject to allowance holding requirements for a given control period and that did not receive an allocation for that control period as an existing unit is generally eligible to receive an allocation from the portion of the budget reserved for "new" units. For further discussion of which units are considered eligible for allocations as existing units or new units in particular control periods, see sections VI.B.9.b and VI.B.9.c.

rulemaking, will update the regulations for the Group 3 trading program³⁴⁶ to reflect the D.C. Circuit's holding in *ODEQ v. EPA* that the relevant states have initial CAA implementation planning authority in non-reservation areas of Indian country until displaced by a demonstration of tribal jurisdiction over such an area.³⁴⁷ Consistent with this holding, the EPA is revising language in the Group 3 trading program regulations that prior to this rule, for purposes of allocating allowances from a given state's emissions budget, distinguished between (1) the set of units within the state's borders that are not in Indian country and (2) the set of units within the state's borders that are in Indian country. As revised, the provisions now distinguish between (1) the set of units within the state's borders that are not in Indian country or are in areas of Indian country covered by the state's CAA implementation planning authority and (2) the set of units within the state's borders that are in areas of Indian country not covered by the state's CAA implementation planning authority. The revised language more accurately distinguishes which units are, or are not, covered by a state's CAA implementation planning authority, which is the underlying purpose for which the term "Indian country" is currently used in the allowance allocation provisions. The effect of the revision is that any units located in areas of "Indian country" as defined in 18 U.S.C. 1151 that are covered by a state's CAA implementation planning authority will be treated for allowance allocation purposes in the same manner as units in areas of the state that are not Indian country, consistent with the *ODEQ* holding.³⁴⁸

The remaining revisions, which are interrelated, concern the types of set-asides that in the context of this rule will best accomplish the goal of ensuring the availability of allocations to units that are subject to allowance holding requirements and that would

³⁴⁶ As discussed in section VI.B.13, the EPA is also making this revision to the regulations for the other CSAPR trading programs in addition to the Group 3 trading program.

³⁴⁷ For additional discussion of the *ODEQ v. EPA* decision and other issues related to the CAA implementation planning authority of states, tribes, and the EPA in various areas of Indian country, see section III.C.2.

³⁴⁸ The EPA notes that the units that will be treated for allocation purposes in the same manner as units not in Indian country will include units in any areas of Indian country subject to a state's CAA implementation planning authority, whether those are non-reservation areas (consistent with *ODEQ*) or reservation areas (such as areas of Indian country within Oklahoma's borders covered by the EPA's October 1, 2020 approval of Oklahoma's request under SAFETEA, as discussed in section III.C.2).

not otherwise receive allowance allocations. One revision to the types of set-asides addresses allocations to existing units in Indian country. The revised geographic scope of the Group 3 trading program under this rule will for the first time include an existing EGU in Indian country not covered by a state's CAA implementation planning authority—the Bonanza coal-fired unit in the Uintah and Ouray Reservation within Utah's borders. To provide an option for Utah (or a similarly situated state in the future) to replace the Agency's default allowance allocations to most existing units with state-determined allocations through a SIP revision while continuing to ensure the availability of a default allocation to the Bonanza unit, which is not subject to the state's jurisdiction or control (or similarly situated units in the future), the EPA is revising the Group 3 trading program regulations to provide for "Indian country existing unit set-asides." Specifically, for each state and for each control period where the set of units within a state's borders eligible to receive allocations as existing units includes one or more units³⁴⁹ in an area of Indian country not covered by the state's CAA implementation planning authority, the EPA will reserve a portion of the state's emissions budget in an Indian country existing unit set-aside for the unit or units. The amount of each Indian country existing unit set-aside will equal the sum of the default allocations that the units covered by the set-aside would receive if the allocations to all existing units within the state's borders were computed according to EPA's default allocation procedure (which is discussed in section VI.B.9.b of this document). Immediately after determining the amount of a state's emissions budget for a control period (and after reserving a portion for potential allocation to new units, as discussed later in this section), the EPA will first determine the default allocations for all existing units within the state's borders, then allocate the appropriate quantity of allowances to the Indian country existing unit set-aside, then allocate the allowances from the set-aside to the covered units in Indian country, and finally record the allocations in the sources' compliance

³⁴⁹ In coordination with the dynamic budgeting process discussed in section VI.B.4, each unit included in the unit inventory used to determine a state's dynamic emissions budget for a given control period in 2026 or a later year will be considered an "existing" unit for that control period for purposes of the determination of unit-level allowance allocations. In other words, there will no longer be a single fixed date that divides "existing" from "new" units.

accounts at the same time as the allocations to other sources not in Indian country. The existence of the Indian country existing unit set-aside thus will have no substantive effect unless and until the relevant state chooses to replace the EPA's default allowance allocations through a SIP revision, in which case the state would have the ability to establish state-determined allocations for the units subject to the state's CAA implementation planning authority while the EPA would continue to administer the Indian country existing unit set-aside for the units in Indian country not covered by the state's CAA implementation planning authority.³⁵⁰ The EPA believes the establishment of Indian country existing unit set-asides accomplishes the objective of allowing states to control allowance allocations to units covered by their CAA implementation planning authority while ensuring that the allocations to units in Indian country not covered by such authority remain under Federal authority (unless replaced by a tribal implementation plan).

The remaining revisions to the types of set-asides address the set-asides used to ensure availability of allowance allocations to *new* units in light of the division of the budget for *existing* units into a reserved portion for existing units in Indian country and an unreserved portion for other existing units. Under the Group 3 trading program regulations as in effect before this rule, allowances for new units have been provided from separate new unit set-asides and Indian country new unit set-asides. Under this rule, the EPA is combining these two types of set-asides starting with the 2023 control period by eliminating the Indian country new unit set-asides and expanding eligibility for allocations from the new unit set-asides to include units anywhere within the relevant states' borders. However, as with the Indian country new unit set-asides under the current regulations, the EPA will continue to administer the new unit set-asides in the event a state chooses to replace the EPA's default allocations to existing units with state-determined allocations, thereby ensuring the availability of allocations to any new units not covered by a state's CAA implementation planning authority.

The reason for the revisions to the new unit set-asides and Indian country

³⁵⁰ As noted in section VI.D, a tribe could elect to work with EPA under the Tribal Authority Rule to develop a full or partial tribal implementation plan under which the tribe would determine allowance allocations for units in the relevant area of Indian country that would replace EPA's default allocations for subsequent control periods.

new unit set-asides is to avoid unnecessary and potentially inequitable changes to the degree to which individual existing units contribute to, or benefit from, the new unit set-asides. The allowances used to establish these set-asides are reserved from each state emissions budget before determination of the allocations from the unreserved portion of the budget to existing units, so that certain existing units—generally those receiving the largest allocations—contribute to creation of the set-asides through roughly proportional reductions in their allocations. Later, if any allowances in a set-aside are not allocated to qualifying new units, the remaining allowances are reallocated to the existing units in proportion to their initial allocations from the unreserved portion of the budget, so that certain existing units—again, generally those receiving the largest allocations—benefit from the reallocations in rough proportion to their previous contributions.³⁵¹ The EPA believes maintaining this symmetry, where the same existing units—whether in Indian country or not—both contribute to and potentially benefit from the set-asides, is a reasonable policy objective, and doing so requires that the EPA continue to administer the new unit set-asides in the event a state chooses to replace the EPA's default allocations to existing units with state-determined allocations, because otherwise the EPA would be unable to maintain Federal implementation authority and ensure that the units in Indian country would receive an appropriate share of any reallocated allowances.³⁵² The principal difference between the new unit set-asides and the Indian country new unit set-asides under the regulations in effect before this rule was that, if a state chose to replace the EPA's default allocations with state-determined allocations, the state would take over administration of the new unit set-aside, but not any Indian country new unit set-aside.

³⁵¹ Under the regulations in effect before this final rule, allowances from an Indian country new unit set-aside that are not allocated to qualifying new units in Indian country are first transferred to the state's new unit set-aside, and if the allowances are not allocated to qualifying new units elsewhere within the state's borders, the allowances are then reallocated to the state's existing units.

³⁵² If units in Indian country were unable to share in the benefits of reallocation of allowances from the new unit set-asides, it would be possible to achieve a different form of symmetry by simultaneously exempting the units in Indian country from the obligation to share in the contribution of allowances to the new unit set-asides. However, some stakeholders might view this alternative as potentially inequitable because existing units in Indian country would then make no contributions toward the new unit set-aside while other existing units would still be required to do so.

Under the revised regulations finalized in this rule, states will not be able to take over administration of the new unit set-asides in this situation. Therefore, there is no longer any reason to establish separate Indian country new unit set-asides in order to preserve Federal (and potentially tribal) authority to implement the rule in areas of Indian country subject to tribal jurisdiction.

With respect to the total amounts of allowances that will be set aside for potential allocation to new units from the emissions budgets for each state, for the control periods in 2023 through 2025 (but not for subsequent control periods, as discussed later in this section), the EPA is establishing total set-aside amounts equal to the projected amounts of emissions from any planned units in the state for the control period, plus an additional base 2 percent of the state emissions budget to address any unknown new units, with a minimum total amount of 5 percent. For example, if planned units in a state are projected to emit 4 percent of the state's NO_x ozone season emissions budget, then the

new unit set-aside for the state would be set at 6 percent, which is the sum of the 4 percent for planned units plus the base 2 percent for unknown new units. Alternatively, if planned new units are projected to emit only 1 percent of the state's budget, the new unit set-aside would be set at the minimum 5 percent amount. Except for the addition of the 5 percent minimum, which is a change being made in response to comments, the approach to setting the new unit set-aside amounts is generally the same approach previously used to establish the amounts of new unit set-asides in CSAPR, the CSAPR Update, and the Revised CSAPR Update for all the CSAPR trading programs. *See, e.g.*, 76 FR 48292 (August 8, 2011).

As under the Revised CSAPR Update, the EPA is making an exception for New York for the 2023 through 2025 control periods, establishing a total new unit set-aside amount for each control period of 5 percent of the state's emissions budget, with no additional consideration for planned units, because this approach is consistent with New

York's preferences as reflected in an approved SIP addressing allowance allocations for the Group 2 trading program.

The final regulations issued under this rule specify the new unit set-aside amounts in terms of the percentages of the state emissions budgets. The amounts are shown in Tables VI.B.9.a–1, VI.B.9.a–2, and VI.B.9.a–3 of this document show the tonnage amounts of the new unit set-asides for the control periods in 2023 through 2025 that are computed by multiplying the new unit set-aside percentages by the preset budgets finalized in this rule for those control periods. The amounts of the 2023 new unit set-asides are illustrative because they do not reflect the impact of transitional adjustments included in the rule that that are likely to affect the 2023 budgets as implemented.³⁵³ The amounts of the 2024 and 2025 new unit set-asides are the actual amounts, because the 2024 and 2025 budgets computed in this rule are the budgets that will be implemented, without any need for transitional adjustments.

TABLE VI.B.9.a–1—ILLUSTRATIVE CSAPR NO_x OZONE SEASON GROUP 3 NEW UNIT SET-ASIDE (NUSA) AMOUNTS FOR THE 2023 CONTROL PERIOD

State	Emissions budgets (tons)	New unit set-aside amount (percent)	New unit set-aside amount (tons)
Alabama	6,379	5	319
Arkansas	8,927	5	446
Illinois	7,474	5	374
Indiana	12,440	5	622
Kentucky	13,601	5	680
Louisiana	9,363	5	468
Maryland	1,206	5	60
Michigan	10,727	5	536
Minnesota	5,504	5	275
Mississippi	6,210	5	311
Missouri	12,598	5	630
Nevada	2,368	9	213
New Jersey	773	5	39
New York	3,912	5	196
Ohio	9,110	6	547
Oklahoma	10,271	5	514
Pennsylvania	8,138	5	407
Texas	40,134	5	2,007
Utah	15,755	5	788
Virginia	3,143	5	157
West Virginia	13,791	5	690
Wisconsin	6,295	5	315

³⁵³ As discussed in section VI.B.12, the EPA expects that this final rule will become effective after May 1, 2023, causing the emissions budgets for the 2023 control period to be adjusted under the

rule's transitional provisions so as to ensure that the new budgets will apply only after the rule's effective date. The actual new unit set-asides for the 2023 control period will be computed using the

adjusted budgets, but the 2023 budget amounts shown in Table VI.B.9.a–1 do not reflect these adjustments.

TABLE VI.B.9.a-2—CSAPR NO_x OZONE SEASON GROUP 3 NEW UNIT SET-ASIDE (NUSA) AMOUNTS FOR THE 2024 CONTROL PERIOD

State	Emissions budgets (tons)	New unit set-aside amount (percent)	New unit set-aside amount (tons)
Alabama	6,489	5	324
Arkansas	8,927	5	446
Illinois	7,325	5	366
Indiana	11,413	5	571
Kentucky	12,999	5	650
Louisiana	9,363	5	468
Maryland	1,206	5	60
Michigan	10,275	5	514
Minnesota	4,058	5	203
Mississippi	5,058	5	253
Missouri	11,116	5	556
Nevada	2,589	9	233
New Jersey	773	5	39
New York	3,912	5	196
Ohio	7,929	6	476
Oklahoma	9,384	5	469
Pennsylvania	8,138	5	407
Texas	40,134	5	2,007
Utah	15,917	5	796
Virginia	2,756	5	138
West Virginia	11,958	5	598
Wisconsin	6,295	5	315

TABLE VI.B.9.a-3—CSAPR NO_x OZONE SEASON GROUP 3 NEW UNIT SET-ASIDE (NUSA) AMOUNTS FOR THE 2025 CONTROL PERIOD

State	Emissions budgets (tons)	New unit set-aside amount (percent)	New unit set-aside amount (tons)
Alabama	6,489	5	324
Arkansas	8,927	5	446
Illinois	7,325	5	366
Indiana	11,413	5	571
Kentucky	12,472	5	624
Louisiana	9,107	5	455
Maryland	1,206	5	60
Michigan	10,275	5	514
Minnesota	4,058	5	203
Mississippi	5,037	5	252
Missouri	11,116	5	556
Nevada	2,545	9	229
New Jersey	773	5	39
New York	3,912	5	196
Ohio	7,929	6	476
Oklahoma	9,376	5	469
Pennsylvania	8,138	5	407
Texas	38,542	5	1,927
Utah	15,917	5	796
Virginia	2,756	5	138
West Virginia	11,958	5	598
Wisconsin	5,988	5	299

For control periods in 2026 and later years, the EPA will allocate a total of 5 percent of each state emissions budget to a new unit set-aside, with no additional amount for planned new units. The amounts of the set-asides for each state and control period will be computed when the emissions budgets for the control period are established, by May 1 of the year before the year of the

control period. The procedure for determining the amounts of the set-asides based on the amounts of the state emissions budgets is being codified in the Group 3 trading program regulations and will reflect the same percentage of the emissions budget for all states.

The purpose of the change to the procedure for establishing the amounts of the set-asides is to coordinate with

the dynamic budget-setting process that may be used to determine budgets beginning with the 2026 control period. As discussed in section VI.B.4 of this document, under the dynamic budget-setting process, each state's budget for each control period will be computed using fleet composition information and the total ozone season heat input reported by all affected units in the state

for the most recent control periods before the budget-setting computations. (For example, 2026 emissions budgets would be based on 2022–2024 state-level heat input data.) Moreover, as discussed in section VI.B.9.b of this document, the set of units eligible to receive allocations as “existing” units in a given control period will generally be the set of units that operated in the control period two years earlier (with the exception of any units whose monitor certification deadlines fell after the start of that earlier control period). Consequently, by the 2025 control period, all or almost all units that commenced commercial operation before issuance of this rule will be considered “existing” units for purposes of budget-setting and allocations, and units commencing commercial operation after issuance of this rule generally will be considered “existing” units for all but their first two full control periods of operation (and possibly a preceding partial control period). Given that new units will not be relying on the new unit set-asides as a permanent source of allowances, as is the case for “new” units under the other CSAPR trading programs, the EPA believes it is unnecessary to establish set-aside percentages for some states that are permanently larger than 5 percent based solely on the fact that projected emissions from planned new units happen to be a somewhat larger proportion of those states’ overall budgets at the time of this rule’s issuance.

The changes to the structure and amounts of set-asides in this rule largely follow the proposal. The EPA received few comments on these topics. As noted previously, one commenter expressed the view that if the amounts of the new unit set-asides were based on 2 percent of the respective states’ budgets, the set-asides would be too small in certain circumstances, and in response the final rule bases the amounts of the set-asides on a floor percentage of 5 percent instead of 2 percent. The remaining commenters expressed a concern that the final rule’s provisions regarding set-asides should ensure that any tribal decisions relating to allowance allocations would not be constrained by state decisions. The EPA had this same concern in mind when designing the rule and believes that the final set-aside structure—encompassing Indian country existing unit set-asides as well as EPA-administered new unit set-asides for sources in all areas within each state’s borders—fully addresses the concern, is equitable, and preserves Federal and tribal authority under this

rule for areas of Indian country subject to tribal jurisdiction. The comments and the EPA’s responses are discussed in greater detail in section 1 of the *RTC* document.

b. Allocations to Existing Units, Including Units That Cease Operation

In conjunction with the new and revised state emissions budget-setting methodology for the Group 3 trading program finalized in this rulemaking, the EPA is necessarily establishing a revised procedure for making unit-level allocations of Group 3 allowances to existing units.³⁵⁴ The procedure that the EPA is employing to compute the unit-level allocations is very similar but not identical to the procedure used to compute unit-level allocations for units subject to the Group 3 trading program in the Revised CSAPR Update. The steps of the procedure for determining allocations from each state emissions budget for each control period are described in detail in the Unit-Level Allowance Allocations Final Rule TSD. The steps are summarized in the following paragraphs, with changes from the procedure followed in the Revised CSAPR Update noted.

In the first step, the EPA identifies the list of units eligible to receive allocations for the control period. The unit inventories used to compute unit-level allocations for the control periods in 2023 through 2025 are the same inventories that have been used to determine the preset emissions budget for these control periods. These inventories have been determined in this rulemaking in essentially the same manner as in the Revised CSAPR Update. The procedures for updating the unit inventories for these control periods are discussed in section VI.B.4 of this document, and the criteria that the EPA has applied to determine whether a unit’s scheduled retirement is sufficiently certain to serve as a basis for adjusting emissions budgets and unit-level allocations, are discussed in section V.B of this document and in the Ozone Transport Policy Analysis Final Rule TSD.

The unit inventories used to compute unit-level allocations for control periods in 2026 and later years will be determined in the year before the control period in question based on the latest reported emissions and operational data, which is an extension

³⁵⁴ The revisions to the procedures for computing unit-level allowance allocations in this rulemaking apply only to the Group 3 trading program. In this rulemaking, the EPA is not reopening the methodology for computing the amounts of allowances allocated to any unit under any other CSAPR trading program.

of the methodology used in the Revised CSAPR Update to reflect more recent data (for example, the unit inventories used to compute 2026 budgets and allocations will reflect reported data up through the 2024 control period). These inventories, which are generally the same as the inventories used to compute dynamic budgets for each control period, include any unit whose monitor certification deadline was no later than the start of the relevant historical control period and that reported emissions data during the relevant historical control period. The EPA notes that basing the list of eligible units on the list of units that reported heat input in the control period two years earlier than the control period for which allocations are being determined represents a revision to the Group 3 trading program regulations as in effect before this rule concerning the treatment of allocations to retired units. Under the prior regulations, units that cease operations for two consecutive control periods would continue to receive allocations as existing units for three additional years (that is, a total of five years) before the allowances they would otherwise have received are reallocated to the new unit set-aside for the state. Under the regulations as revised in this rule, units that cease operation will receive allocations for only two full control periods of non-operation. While the EPA has in prior transport rulemakings noted a qualitative concern that ceasing allowance allocations prematurely could distort the economic incentives of EGUs to continue operating when retirement is more economical, the EPA believes that anticipated market conditions (in particular, the incentives toward power sector transition to cleaner generating sources), particularly in the later 2020s, are such that a continuation of allowance allocations to retiring units likely has no more than a de minimis effect on the consideration of an EGU whether to retire or not.

In the second step of the procedure for determining allocations to existing units, the EPA will compile a database containing for each eligible unit the unit’s historical heat input and total NO_x emissions data for the five most recent ozone seasons. For each unit, the EPA will compute an average heat input value based on the three highest non-zero heat input values over the 5-year period, or as the average of all the non-zero values in the period if there are fewer than three non-zero values. For each unit, the EPA will also determine the maximum total NO_x emissions value over the 5-year period. For coal-

fired units of 100 MW or larger, the EPA will further determine a “maximum controlled baseline” NO_x emissions value, computed as the unit’s maximum heat input over the 5-year period times a NO_x emissions rate of 0.08 lb/mmBtu. The maximum controlled baseline will serve as an additional cap on unit-level allocations for all such coal-fired units starting with the control periods in which the assumed use of SCR controls at the units is reflected in the state emissions budgets. Thus, the maximum controlled baseline will apply for purposes of allocations to units with existing SCR controls for all control periods starting with the 2024 control period and for all other coal-fired units of 100 MW or more (except circulating fluidized bed units) starting with the 2027 control period. These procedures are nearly identical to the procedures used in the Revised CSAPR Update, with three exceptions. First, instead of using only the data available at the time of the rulemaking, for each control period the EPA will use data from the most recent five control periods for which data had been reported. (For example, for the 2026 control period, the EPA will use data for the 2020–2024 control periods.) Second, to simplify the data compilation process, the EPA will use only a five-year period for NO_x mass emissions, in contrast to the 8-year period used in the Revised CSAPR Update for NO_x mass emissions. Third, the use of the maximum controlled baseline as an additional cap on emissions is a change adopted in this rule in response to comments received on the proposal. Specifically, commenters observed that if a state’s emissions budget is decreased to reflect an assumption that a particular unit in the state is capable of reducing its emissions through the installation of new SCR controls, but the historical emissions cap applied to that unit in the unit-level allocation methodology does not reflect use of the new controls, then the allocation methodology could have the effect of reducing unit-level allocations to the other units in the state whose historical emissions already reflect use of existing controls rather than the unit assumed to install new controls. The EPA agrees with the comment and in this rule has added the maximum controlled baseline provision to the allocation methodology to mitigate the potential effect identified by the commenters.

In the third step of the procedure for determining allocations to existing units in each state, the EPA will allocate the available allowances for that state among the state’s eligible units in

proportion to the share each unit’s average heat input value represents of the total of the average heat input values for all the state’s eligible units, but not more than the unit’s maximum total NO_x value or, if applicable, the unit’s maximum controlled baseline. If the allocations to one or more units are curtailed because of the units’ applicable caps, the EPA will iterate the calculation procedure as needed to allocate the remaining allowances, excluding from each successive iteration any units whose allocations have already reached their caps. (If all units in a state reach their caps, any remaining allowances are allocated in proportion to the units’ average heat input values, notwithstanding the caps.) This calculation procedure is identical to the calculation procedure used in the Revised CSAPR Update (as well as the CSAPR Update and CSAPR), but using caps that reflect both the units’ maximum historical NO_x values and also, where applicable, the maximum controlled baseline values.

Illustrative unit-level allocations for the 2023 control period and final unit-level allocations for the 2024 and 2025 control periods are being determined in this rulemaking based on the emissions budgets for those control periods also determined in the rulemaking and are included in the docket. The 2023 allocations are only illustrative because, as discussed in section VI.B.12.a, the EPA expects the effective date of the rule to occur after the start of the 2023 control period and consequently expects the 2023 control period to be a transitional period in which the emissions budgets determined in this rulemaking apply only for the portion of the control period occurring on and after the rule’s effective date, while any previously determined emissions budgets apply for the portion of the control period before the rule’s effective date. The rule’s effective date will become known when the rule is published in the **Federal Register**. As soon as practicable thereafter, the EPA will calculate the final prorated or blended 2023 state emissions budgets and 2023 unit-level allocations based on the transitional formulas finalized in this action (see section VI.B.12.a of this document) and will communicate the information to the public through a notice of data availability. The 2023 and 2024 allocations will then be recorded 30 days after the effective date of the final rule (to provide an interval in which to execute the recall of 2023 and 2024 Group 2 allowances, as discussed in section VI.B.12.c of this document),

while the 2025 allocations will be recorded by July 1, 2024.³⁵⁵

The default unit-level allocations for each control period in 2026 or a later year will be computed immediately following the determination of the state emissions budgets for the control period. The EPA will perform the computations and issue a notice of data availability concerning the preliminary unit-level allocations for each control period by March 1 of the year before the control period. There will be a 30-day period in which objections to the data and preliminary computations may be submitted, and the EPA will then make any appropriate revisions and issue another notice of data availability by May 1 of the year before the control period. The EPA will then record the allocations by July 1 of the year before the control period.³⁵⁶

All covered states also have options to establish state-determined allowance allocations for control periods in 2024 and later years. As discussed in section VI.D.1 of this rule, a state choosing to establish state-determined allocations for the 2024 control period would need to submit a letter of intent to the EPA by August 4, 2023, and would need to submit the SIP revision with the allocations by September 1, 2023. The EPA would defer recordation of the 2024 allocations for the state’s sources until March 1, 2024, to provide time for this process to be completed. As discussed in sections VI.D.2 and VI.D.3 of this rule, a state choosing to establish state-determined allocations for control periods in 2025 and later years would need to submit a SIP revision by December 1 of the year two years before the first year for which state-determined allocations are being established—*e.g.*, by December 1, 2023, for allocations for the 2025 control period—and would need to submit the allocations for each control period by June 1 of the year before the control period—*e.g.*, by June 1, 2024, for allocations for the 2025

³⁵⁵ The recordation schedule for the 2023 and 2024 allocations represents an expected acceleration of the recordation schedule in effect immediately before this final rule, which called for allocations of 2023 and 2024 Group 3 allowances to existing units to be recorded by September 1, 2023. See *Deadlines for Submission and Recordation of Allowance Allocations Under the Cross-State Air Pollution Rule (CSAPR) Trading Programs and the Texas SO₂ Trading Program (the “Recordation Rule”)*, 87 FR 52473 (August 26, 2022).

³⁵⁶ The current recordation schedule, which provides for almost all allowance allocations to existing units for a given control period under all the CSAPR trading programs to be recorded by July 1 of the year before the year of that control period, was adopted in the Recordation Rule.

control period.³⁵⁷ The EPA would record any state-determined allocations for control periods in 2025 and later years by July 1 of the year before the control period, simultaneously with the recordation of allocations to units in states where the EPA determines the unit-level allocations.

The EPA notes that for the three states with approved SIP revisions establishing their own methodologies for allocating Group 2 allowances—Alabama, Indiana, and New York—the EPA will follow the states' methodologies to the extent possible in developing the EPA's allocations of Group 3 allowances to the units in those states for the control periods in 2023 through 2025.³⁵⁸ The EPA will not follow any state-specific methodologies as part of the procedures for determining default unit-level allocations of Group 3 allowances for control periods in 2026 or later years. However, like other states, these three states have options to replace the EPA's default allocations with state-determined allocations through SIP revisions starting with the 2024 control period.

As an exception to all of the recordation deadlines that would otherwise apply, the EPA will not record any allocations of Group 3 allowances in a source's compliance account unless that source has complied with the requirements to surrender previously allocated 2023–2024 Group 2 allowances. The surrender requirements are necessary to maintain the previously established levels of stringency of the Group 2 trading program for the states and sources that remain subject to that program under this final rule. The EPA finds that it is reasonable to condition the recordation of Group 3 allowances on compliance with the surrender requirements because the condition will spur compliance and will not impose an inappropriate burden on sources. The EPA considers establishment of this

³⁵⁷ The current deadlines for states to submit state-determined allowance allocations to the EPA were adopted in the Recordation Rule and are coordinated with the schedule for computation of state emissions budgets for control periods in 2026 and later years. For example, for the 2026 control period, by May 1, 2025, the EPA will publish the final state emissions budgets and the EPA's default unit-level allocations; by June 1, 2025, states will submit any state-determined unit-level allocations that would replace the default allocations; and by July 1, 2025, the EPA will record the default unit-level allocations or the state-determined unit-level allocations, as applicable, in sources' compliance accounts.

³⁵⁸ For discussion of how the EPA is using the previously approved allocation methodologies for Alabama, Indiana, and New York to determine allocations to units in these states for the 2023–2025 control periods, see the Allowance Allocation Final Rule TSD.

condition, which will facilitate the continued functioning of the Group 2 trading program, to be an appropriate exercise of the Agency's authority under CAA section 301 (42 U.S.C. 7601) to prescribe such regulations as are necessary to carry out its functions under the Act.

The provisions governing allocations to existing units are being finalized substantially as proposed, except for the addition of an additional cap on unit-level allocations in response to comments. The EPA's responses to comments on the unit-level allocation provisions for existing units are in section 5 of the *RTC* document.

c. Allocations From Portions of State Emissions Budgets Set Aside for New Units

The Group 3 trading program regulations provide for the EPA to allocate allowances from each new unit set-aside after the end of the control period at issue. An eligible new unit for purposes of allocations from a set-aside for a given control period is generally any unit in the relevant area that reported emissions subject to allowance surrender requirements during the control period and that was not eligible to receive an allowance allocation as an "existing" unit for the control period. Thus, in addition to units that have not yet completed two full control periods of operation since their monitor certification deadlines, units eligible for allocations from the new unit set-asides may also include existing coal-fired units that first lose their eligibility for allocations from the unreserved portion of the applicable state budget by ceasing operation, and then resume operation in a later control period. The regulations call for the EPA to allocate allowances to any eligible "new" units in the state generally in proportion to their respective emissions during the control period, up to the amounts of those emissions if the relevant set-aside contains sufficient allowances, and not exceeding those emissions. However, in the case of a unit whose allocation for the control period would have been subject to a maximum controlled baseline if the unit was eligible to receive allocations as an existing unit, the unit's allocation from the new unit set-aside will not exceed a cap equal to the unit's reported heat input for the control period times an emissions rate of 0.08 lb/mmBtu.

Any allowances remaining in a new unit set-aside after the allocations to new units are reallocated to the existing units in the state in proportion to those units' previous allocations for the control period as existing units. The

EPA issues a notice of data availability concerning the proposed allocations by March 1 following the control period, provides an opportunity for submission of objections, and issues a final notice of data availability and record the allocations by May 1 following the control period, one month before the June 1 compliance deadline.

This EPA notes that the revisions to other provisions of the Group 3 trading program regulations discussed elsewhere in this document will reduce the portions of the state emissions budgets that are allocated through the new unit set-asides. Specifically, because the new unit set-asides will no longer receive any additional allowances when units retire, for control periods in 2025 and later years the amounts of allowances in the new unit set-asides will always be 5 percent of the respective state emissions budgets for the respective control periods. This limit on growth of the new unit set-asides is appropriate given that the number of consecutive control periods for which any particular unit is likely to receive allocations from a state's new unit set-aside will be reduced to two full control periods (and possibly a partial control period before those two control periods) before the unit becomes eligible to receive allocations as an "existing" unit from the unreserved portion of the state's emissions budget. This approach contrasts with the approach under the other CSAPR trading programs where a new unit never becomes eligible to receive allocations from the unreserved portion of the emissions budget and where the new unit set-aside therefore needs to grow to accommodate an ever-increasing share of the state's total emissions.

The EPA also notes that, as discussed in sections VI.D.2 and VI.D.3 of this document, in the event that a state chooses to replace EPA's default allowance allocations under the Group 3 trading program with state-determined allocations through a SIP revision, the EPA will continue to administer the portion of each state emissions budget reserved in a new unit set-aside to ensure the availability of allowance allocations to new units in any areas of Indian country within the state not covered by the state's CAA implementation planning authority.

The final rule's provisions concerning unit-level allocations from the new unit set-asides are unchanged from the proposal except for the addition of the allocation cap in a given control period for any unit that would have been subject to a maximum controlled baseline if the unit was eligible to receive an allocation as an existing unit

for that control period.³⁵⁹ This change was made to address the same comments discussed in section VI.B.9.b of this document that caused the Agency to add the maximum controlled baseline provision to the procedure for allocating allowances to existing units. The Agency did not receive any other comments on the proposed provisions concerning unit-level allocations of allowances from the new unit set-asides.

d. Incorrectly Allocated Allowances

The Group 3 trading program regulations as promulgated in the Revised CSAPR Update include provisions addressing incorrectly allocated allowances. With regard to any allowances that were incorrectly allocated and are subsequently recovered, the provisions as in effect prior to this rule have generally called for the recovered allowances to be reallocated to other units in the relevant state (or Indian country within the borders of the state) through the process for allocating allowances from the new unit set-aside (or Indian country new unit set-aside) for the state. If the procedures for allocating allowances from the set-asides have already been carried out for the control period for which the recovered allowances were issued, the allowances would be allocated through the set-asides for subsequent control periods.

The EPA continues to view the current provisions for disposition of recovered allowances as reasonable in the case of any allowances that are recovered before the deadline for recording allocations of allowances from the new unit set-aside for the control period for which the recovered allowances were issued. However, in the case of any allowances that are recovered after that deadline, adding the recovered allowances to the new unit set-aside for a subsequent control period, as provided in the current regulations, would be inconsistent with the trading program enhancements discussed elsewhere in this document, where the amounts of allowances provided in the state emissions budgets for each control period are designed to reflect the most current available information on fleet composition and utilization and where the quantities of banked allowances available for use in each control period are recalibrated for consistency with the state emissions budgets. The EPA is therefore finalizing

³⁵⁹ As discussed in section IX.B of this rule, the EPA is relocating some of the regulatory provisions relating to administration of the new unit set-asides and is also removing certain provisions that are made obsolete by revisions to other provisions of the Group 3 trading program regulations.

revisions to provide that, starting with allowances allocated for the 2024 control period, any incorrectly allocated allowances that are recovered after the deadline for allocating allowances from the new unit set-aside for that control period (*i.e.*, May 1 of the year following the control period) will be transferred to a surrender account instead of being reallocated to other units in the state. The EPA received no comments on this proposed revision, which is being finalized as proposed.

10. Monitoring and Reporting Requirements

The Group 3 trading program requires monitoring and reporting of emissions and heat input data in accordance with the provisions of 40 CFR part 75. Under 40 CFR part 75, a given unit may have several options for monitoring and reporting. Any unit can use CEMS. Qualifying gas- or oil-fired units can use certain excepted monitoring methodologies that rely in part on fuel-flow metering in combination with CEMS-based or testing-based NO_x emissions rate data. Certain non-coal-fired, low-emitting units can use a low mass emissions (LME) methodology, and sources can seek approval of alternative monitoring systems approved by the Administrator through a petition process. Each CEMS must undergo rigorous initial certification testing and periodic quality assurance testing thereafter, including the use of relative accuracy test audits and 24-hour calibrations. In addition, when a monitoring system is not operating properly, standard substitute data procedures are applied to produce a conservative estimate of emissions for the period involved. Further, 40 CFR part 75 requires electronic submission of quarterly emissions reports to the Administrator, in a format prescribed by the Administrator. The quarterly reports will contain all the data required concerning ozone season NO_x emissions under the Group 3 trading program.

In this rulemaking, as proposed, the EPA is making two changes to the Group 3 trading program's previous requirements related to monitoring, recordkeeping, and reporting. First, the EPA is revising the monitor certification deadline in the Group 3 trading program regulations applicable to certain units that have not already certified monitoring systems for use under 40 CFR part 75. This revision is expected to provide approximately 15 EGUs in Nevada and Utah with 180 days following the rule's effective date to certify monitoring systems, with the consequence that the units are expected to become subject to allowance holding

requirements under the Group 3 trading program starting with the 2024 control period. Second, to implement the trading program enhancements, the EPA is adding certain new recordkeeping and reporting requirements, which will be implemented through amendments to the regulations in 40 CFR part 75 and will apply starting January 1, 2024. Sources generally will be able to meet the additional recordkeeping and reporting requirements using the data that are already collected by their current monitoring systems, and the EPA is not requiring the installation of additional monitoring systems at any source. However, a small number of sources with common stacks could find it advantageous to upgrade their monitoring systems so as to monitor at the individual units instead of monitoring at the common stack. The Group 3 trading program monitor certification deadline revisions and the additional recordkeeping and reporting requirements are discussed in sections VI.B.10.a and VI.B.10.b, respectively.³⁶⁰

a. Monitor Certification Deadlines

In general, a unit subject to the Group 3 trading program must monitor and report emissions data using certified monitoring systems starting as of the date the unit enters the trading program or, if later, 180 days after the unit commences commercial operation. Where an EGU has already certified and maintained monitoring systems in accordance with 40 CFR part 75 for purposes of another trading program, no recertification solely for purposes of entering the Group 3 trading program is required. Under these pre-existing provisions of the Group 3 trading program regulations, nearly all currently operating EGUs transitioning to the trading program under this rule are positioned to begin monitoring and reporting under the trading program as of their dates of entry (or if later, 180 days after they commence commercial operation) because of the units' previous requirements to monitor and report emissions under other programs including the CSAPR NO_x Ozone Season Group 2 Trading Program (for

³⁶⁰ The EPA is not amending the existing provisions of the Group 3 trading program regulations that govern whether units covered by the program must record and report required data on a year-round basis or may elect to record and report required data on an ozone season-only basis. See 40 CFR 97.1034(d)(1); see also 40 CFR 75.74(a)-(b). Thus, for units that are required or elect to report other data on a year-round basis, the additional recordkeeping and reporting requirements will also apply year-round, while for units that are allowed and elect to report other data on an ozone season-only basis, the additional requirements will also apply for the ozone season only.

units in Alabama, Arkansas, Mississippi, Missouri, Oklahoma, Texas, and Wisconsin), the CSAPR NO_x Annual Trading Program (for units in Minnesota), and the Acid Rain Program (for most units in Nevada and Utah).

As discussed in section VI.B.3 of this document, the EPA has identified 15 potentially affected units in Nevada and Utah that commenced commercial operation more than 180 days before the effective date of this rule and that do not currently report emissions data to the Agency under 40 CFR part 75.³⁶¹ To ensure that units in this situation have sufficient time to certify monitoring systems as required under this rule, the final rule establishes a monitoring certification deadline of 180 days after the effective date of the rule for affected units that are not already required to report emissions under 40 CFR part 75 under another program, equivalent to the 180-day window already provided to units commencing commercial operation after (or less than 180 days before) the final rule's effective date. The 180th day for units in this situation will likely fall after the end of the 2023 ozone season, with the result that the certification deadline will be extended until May 1, 2024, the first day of the 2024 ozone season. Because the Group 3 trading program's allowance holding requirements apply to a given unit only after that unit's monitor certification deadline, the units in this situation consequently will become subject to allowance holding requirements as of the 2024 ozone season rather than the 2023 ozone season.

The EPA received no comments on the provisions establishing a monitor certification deadline 180 days after the effective date of this rule for affected units that are not already required to report emissions under 40 CFR part 75, and the provisions are being finalized as proposed.

b. Additional Recordkeeping and Reporting Requirements

To facilitate implementation of the backstop daily NO_x emissions rates for certain coal-fired units, the secondary emissions limitations for units contributing to assurance level exceedances, and the revised default unit-level allowance allocation procedures, the final rule amends 40 CFR part 75 to establish two sets of additional recordkeeping and reporting requirements. The first set of additional recordkeeping and reporting requirements is specific to the backstop daily emissions rate provisions. Starting January 1, 2024, units listing coal as a

fuel in their monitoring plans, serving generators of 100 MW or larger, and equipped with SCR controls on or before the end of the previous control period (except circulating fluidized bed units) will be required to record and report total daily NO_x emissions and total daily heat input, daily average NO_x emissions rate, and daily NO_x emissions exceeding the backstop daily NO_x emissions rate. The units will also be required to record and report cumulative NO_x emissions exceeding the backstop daily NO_x emissions rate for the ozone season and any portion of such cumulative NO_x emissions exceeding 50 tons. Starting January 1, 2030, the same recordkeeping and reporting requirements will apply to all units listing coal as a fuel in their monitoring plans and serving generators of 100 MW or larger (except circulating fluidized bed units), including units not equipped with SCR controls. These data will be used to determine the allowance surrender requirements related to the backstop daily NO_x emissions rates. Implementation of these additional recordkeeping and reporting requirements would necessitate a one-time update to the units' data acquisition and handling systems but would not require any changes to the monitoring systems already needed to meet other requirements under 40 CFR part 75.

The second type of additional recordkeeping and reporting requirements applies to units exhausting to common stacks. For these units, 40 CFR part 75 includes options that often allow monitoring to be conducted at the common stack on a combined basis for all the units as an alternative to installing separate monitoring systems for the individual units in the ductwork leading to the common stack. The units then keep records and report hourly and cumulative NO_x mass emissions and in many cases heat input data on a combined basis for all units exhausting to the common stack. With respect to heat input data, but not NO_x mass emissions data, most such units have also been required historically to record and report hourly and cumulative data on an individual-unit basis, and where necessary they typically have computed the necessary unit-level hourly heat input values by apportioning the combined hourly heat input values for the common stack in proportion to the individual units' recorded hourly output of electricity or steam. See generally 40 CFR 75.72.

In this rulemaking, the provisions governing default unit-level allowance allocations, backstop daily NO_x

emissions rates for certain coal-fired units, and secondary emissions limitations for units contributing to assurance level exceedances all require the use of unit-level reported data on NO_x mass emissions (or unit-level NO_x emissions rates computed in part based on unit-level reported data on NO_x mass emissions). To facilitate the implementation of these provisions, the final rule requires all units covered by the Group 3 trading program exhausting to common stacks to record and report unit-level hourly and cumulative NO_x mass emissions data starting January 1, 2024. To obtain the necessary unit-level hourly mass emissions values, the revised regulations rule allow the units to apportion hourly mass emissions values determined at the common stack in proportion to the individual units' recorded hourly heat input. The apportionment procedure is very similar to the apportionment procedure that most such units already apply to compute reported unit-level heat input data. Where sources choose to obtain the additional required data values through apportionment, implementation of the additional recordkeeping and reporting requirements will necessitate a one-time update to the units' data acquisition and handling systems but will not require any changes to the monitoring systems already needed to meet other requirements under 40 CFR part 75.

For most units sharing common stacks, the EPA expects that the reported unit-specific hourly NO_x emissions values computed through the apportionment procedures will reasonably approximate the values that could be obtained through installation and operation of separate monitoring systems for the individual units, because the units exhausting to the common stack would be expected to have similar NO_x emissions rates. However, the EPA also recognizes that at some plants, particularly those where SCR-equipped and non-SCR-equipped coal-fired units share a common stack, unit-level values determined through apportionment based on electricity or steam output could overstate the reported NO_x mass emissions for the SCR-equipped units and correspondingly understate the reported NO_x mass emissions for the non-SCR-equipped units.³⁶² As proposed, the

³⁶² The EPA is aware of five plants in the states covered by this rule where SCR-equipped and non-SCR-equipped coal-fired units exhaust to a common stack: Clifty Creek in Indiana; Cooper, Ghent, and Shawnee in Kentucky; and Sammis in Ohio. The owners of the Sammis plant have announced plans to retire the plant in 2023.

³⁶¹ The units are listed in Table VI.B.3-1.

final rule leaves in place the existing options under 40 CFR part 75 for plants to upgrade their monitoring equipment to monitor on a unit-specific basis instead of at the common stack. Plant owners may find this option attractive if they believe it would reduce the quantities of reported emissions exceeding the backstop daily emissions rate.

The EPA is finalizing the additional recordkeeping and reporting requirements generally as proposed, with modifications as needed to accommodate the changes in the backstop daily emissions rate provisions from proposal discussed in sections VI.B.1.c.i and VI.B.1.7. No comments were received on the recordkeeping and reporting requirements added to facilitate implementation of the backstop daily emissions rate. Comments on the requirement to report unit-specific NO_x emissions data for units sharing common stacks are addressed in the following paragraphs.

Comment: Some commenters claimed that for plants where SCR-equipped and non-SCR-equipped coal-fired units share common stacks, the rule as proposed would have effectively mandated installation of unit-specific monitoring systems in order to comply with the backstop daily emissions rate provisions. The commenters generally requested that application of the backstop daily rate provisions be delayed for plants with common stacks until all units sharing the stacks were subject to the provisions. Alternatively, they claimed that the EPA should consider the cost of the additional unit-specific monitoring system to be a cost of the rule.

One commenter claimed that the option to install unit-specific monitoring systems for the units sharing a common stack at its plant was not feasible because of a lack of locations in the units' ductwork suitable for installation of the monitoring equipment. Specifically, the commenter claimed that EPA Method 1 requires monitoring equipment to be located at least eight duct diameters downstream and two duct diameters upstream of any flow disturbance and stated that the units had no straight runs of ductwork sufficiently long to meet these criteria.

Response: The EPA's response to comments about the application of backstop rate requirements to units sharing common stacks is in section VI.B.7 of this document. With respect to assertions that the rule effectively mandates installation of unit-specific monitoring systems, the EPA disagrees. Although the EPA pointed out the option in the proposal, anticipating that

owners of some units sharing common stacks might find it advantageous to upgrade their monitoring systems, the final rule does not mandate such upgrades and explicitly provides a reporting option that can be used if a plant owner continues to monitor only at the common stack. For example, a plant owner might choose not to upgrade monitoring systems if the owner does not plan to operate the non-SCR-equipped units sharing the stack frequently. Regarding the contention that the cost of additional monitoring systems should be considered a cost of the rule, the EPA notes that the monitoring cost estimates that the Agency regularly develops for 40 CFR part 75 already reflect the conservative assumption that all affected units perform monitoring on a unit-specific basis.

With respect to the comment asserting an inability to install unit-specific monitoring equipment because of a lack of suitable locations, the EPA does not believe the commenter has provided sufficient information to support the assertion. Although the commenter cites the EPA Method 1 location criteria, the CEMS location provisions in 40 CFR part 75 do not reference those location criteria but instead reference the EPA Performance Specification 2 location criteria, which recommend that a CEMS be located at least two duct diameters downstream and a half duct diameter upstream from a point at which a change in pollutant concentration may occur.³⁶³ Thus, while the commenter states that its units do not have straight runs of ductwork ten duct diameters long, the relevant siting criteria actually call for straight runs of ductwork only 2.5 duct diameters long, and the commenter has not provided information indicating that these criteria could not be met. Moreover, even EPA Method 1 does not require monitoring equipment to be located eight duct diameters upstream and two duct diameters downstream of any flow disturbance. While the method recommends those distances as the first option, the method also allows for locations two duct diameters upstream and a half duct diameter upstream from any flow disturbance, as well as other locations if certain performance criteria can be met.³⁶⁴

³⁶³ Appendix B to 40 CFR part 60, Performance Specification 2, sec. 8.1.2; *see also* appendix A to 40 CFR part 75, section 1.1.

³⁶⁴ Appendix A-1 to 40 CFR part 60, Method 1, sec. 11.1.

11. Designated Representative Requirements

As noted in section VI.B.1.a of this document, a core design element of all the CSAPR trading programs is the requirement that each source must have a designated representative who is authorized to represent all of the source's owners and operators and is responsible for certifying the accuracy of the source's reports to the EPA and overseeing the source's Allowance Management System account. The necessary authorization of a designated representative is certified to the EPA in a certificate of representation.

The existing designated representative provisions in the Group 3 trading program regulations already provide that the EPA will interpret references to the Group 2 trading program in certain documents—including a certificate of representation as well as a notice of delegation to an agent or an application for a general account—as if the documents referenced the Group 3 trading program instead of the Group 2 trading program. For these reasons, sources that have participated in the Group 2 trading program and that are transitioning to the Group 3 trading program under this rule will not need to submit any new forms as part of the transition, because previously submitted forms will be valid for purposes of the Group 3 trading program.

For a source that is newly affected under the Group 3 trading program and that is not currently affected under the Group 2 trading program, a designated representative who has been duly authorized by the source's owners and operators must submit a new or updated certificate of representation to the EPA. The EPA will not record any Group 3 allowances allocated to a source in the source's compliance account until a certificate of representation has been submitted for the source. If a source is also affected under other CSAPR trading programs or the Acid Rain Program, the same individual must be the source's designated representative for purposes of all the programs.

The EPA did not propose and is not finalizing any changes to the designated representative requirements. The EPA received no comments on the provisions of the proposal relating to these requirements.

12. Transitional Provisions

This section discusses several provisions that the EPA will implement to address the transition of sources into the Group 3 trading program as revised. The purposes of the transitional provisions are generally the same as the

purposes of the analogous transitional provisions promulgated in the Revised CSAPR Update: first, addressing the likelihood that the effective date of this rule will fall after the starting date of the first affected ozone season (which in this case is, May 1, 2023); second, establishing an appropriately-sized initial allowance bank through the conversion of previously banked allowances; and third, preserving the intended stringency of the Group 2 trading program for the sources that will continue to be subject to that program.³⁶⁵ However, the sources that will be participants in the revised Group 3 trading program under this rule are transitioning from several different starting points—with some sources already in the existing Group 3 trading program, some sources coming from the Group 2 trading program, and some sources not currently participating in any seasonal NO_x trading program. The EPA is therefore finalizing transitional provisions that differ across the sets of potentially affected sources based on the sources' different starting points.

a. Prorating Emissions Budgets, Assurance Levels, and Unit-Level Allowance Allocations in the Event of an Effective Date After May 1, 2023

The EPA expects that the effective date of this rule will fall after the start of the Group 3 trading program's 2023 control period on May 1, 2023, because the effective date of the rule will be 60 days after the date of the final rule's publication in the **Federal Register**. The EPA is addressing this circumstance by determining the amounts of emissions budgets and unit-level allowance allocations on a full-season basis in the rulemaking and by also including provisions in the revised regulations to prorate the full-season amounts as needed to ensure that no sources become subject to new or more stringent regulatory requirements before the final rule's effective date.³⁶⁶ Variability

³⁶⁵ As discussed in section VI.B.1.d, the EPA is not creating a "safety valve" mechanism in this rule analogous to the voluntary supplemental allowance conversion mechanism established under the Revised CSAPR Update, but intends in the near future to propose and take comment on potential amendments to the Group 3 trading program that would add an auction mechanism to the regulations for the purpose of further increasing allowance market liquidity in conjunction with other appropriate changes to ensure program stringency is maintained. While these changes may provide an additional measure of assurance to the market that allowances will be available for compliance to a degree consistent with the Step 3 emissions control stringency, the EPA does not anticipate that market liquidity concerns pose a challenge to the feasibility of sources to comply with the Group 3 trading program as finalized in this action.

³⁶⁶ As discussed in sections VI.B.7 and VI.B.8, the revisions establishing unit-specific backstop daily

limits, assurance levels, and unit-level allocations for 2023 will all be computed using the appropriately prorated emissions budgets amounts.³⁶⁷

As discussed in section VI.B.2 of this document, in the case of the three states (and Indian country within the states' borders) whose sources do not currently participate in either the Group 2 trading program or the Group 3 trading program—Minnesota, Nevada, and Utah—the sources will begin participating in the Group 3 trading program on the later of May 1, 2023, or the rule's effective date. For these states, in the rulemaking the EPA has computed the full-season emissions budgets that would have applied for the entire 2023 control period if the final rule had become effective no later than May 1, 2023, and were therefore in effect for the entire 153-day control period from May 1, 2023, through September 30, 2023. Assuming that the final rule becomes effective after May 1, 2023, as expected, the EPA will determine prorated emissions budgets for the 2023 control period by multiplying each full-season emissions budget by the number of days from the rule's effective date through September 30, 2023, dividing by 153 days, and rounding to the nearest allowance. The prorated variability limits for the 2023 control period will be computed by first determining for each state the percentage by which the state's reported heat input for the full 2023 ozone season (*i.e.*, May 1, 2023 through September 30, 2023) exceeds the heat input used to compute the state's full-season 2023 emissions budget under this rule and then multiplying the higher of this percentage or 21 percent by the state's prorated emissions budget and rounding to the nearest allowance, yielding prorated assurance levels that equal a minimum of 121 percent of the prorated emissions budgets. To determine unit-level allocation amounts from the prorated emissions budgets, the EPA will apply the unit-level allocation procedure described in section VI.B.9 to the prorated budgets. All calculations required to determine the prorated emissions budgets, the minimum 21 percent variability limits, and the unit-level allocations for the 2023 control period will be carried out as soon as possible after the EPA learns the rule's effective date. The unit-level

emissions rates and, for units contributing to assurance level exceedances, secondary unit-specific emissions limitations, will not take effect until the 2024 control period or later.

³⁶⁷ The EPA notes that transitional provisions similar to the prorating provisions being finalized in this rule were finalized and implemented without issue under the Revised CSAPR Update.

allocations for both the 2023 and 2024 control periods will be recorded in facilities' compliance accounts approximately 30 days after the rule's effective date, as discussed in section VI.B.9.b of this document.

In the case of the states (and Indian country within the states' borders) whose sources currently participate in the Group 3 trading program—Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, New Jersey, New York, Ohio, Pennsylvania, Virginia, and West Virginia—the sources will continue to participate in the Group 3 trading program for the 2023 control period, subject to prorating procedures designed to ensure that the changes in 2023 emissions budgets and assurance levels will not substantively affect the sources' requirements prior to the rule's effective date. For these states, in the rulemaking the EPA has computed the full-season emissions budgets that would have applied for the entire 2023 control period if the final rule had become effective no later than May 1, 2023, but the EPA has also retained in the regulations the full-season emissions budgets for the 2023 control period that were established in the Revised CSAPR Update rulemaking. The EPA has added a provision to the regulations indicating that the emissions budgets promulgated in the Revised CSAPR Update will apply on a prorated basis for the portion of the 2023 control period before the final rule's effective date and the emissions budgets established in this rulemaking will apply on a prorated basis for the portion of the 2023 control period on and after the final rule's effective date. Under this provision, the EPA will determine a blended emissions budget for each state for the 2023 control period, computed as the sum of the appropriately prorated amounts of the state's previous and revised emissions budgets. (For example, if the final rule becomes effective on the eleventh day of the 153-day 2023 control period, the blended emissions budget will equal the sum of 10/153 times the previous emissions budget plus 143/153 times the revised emissions budget, rounded to the nearest allowance.) Blended variability limits for the 2023 control period will be computed by first determining for each state the percentage by which the state's reported heat input for the full 2023 ozone season exceeds the heat input used to compute the state's full-season 2023 emissions budget under this rule and then multiplying the higher of this percentage or 21 percent by the state's prorated emissions budget and rounding to the nearest allowance,

yielding blended assurance levels that equal a minimum of 121 percent of the blended emissions budgets. Unit-level allocations will be determined by applying the allocation procedure described in section VI.B.9 to the blended budgets. Again, all calculations required to determine the prorated emissions budgets, the minimum 21 percent variability limits, and the unit-level allocations for the 2023 control period will be carried out as soon as possible after the EPA learns the effective date of this rule. The unit-level allocations for both the 2023 and 2024 control periods will be recorded in facilities' compliance accounts approximately 30 days after the final rule's effective date, as discussed in section VI.B.9.b of this document.

In the case of the states (and Indian country within the states' borders) whose sources currently participate in the Group 2 trading program—Alabama, Arkansas, Mississippi, Missouri, Oklahoma, Texas, and Wisconsin—the sources will begin to participate in the Group 3 trading program as of May 1, 2023, regardless of the rule's effective date, as discussed in section VI.B.2 of this document, subject to prorating procedures designed to ensure that the transition from the Group 2 trading program to the Group 3 trading program will not substantively affect the sources' requirements prior to the rule's effective date. The prorating procedures for these states mirror the procedures for the states currently in the Group 3 trading program, except that because no emissions budgets currently appear in the Group 3 trading program regulations for the states that are currently covered by the Group 2 trading program, the EPA has added two sets of emissions budgets for these states to the Group 3 trading program regulations: first, the states' emissions budgets for the 2023 control period that currently appear in the Group 2 trading program regulations, which are being included in the revised Group 3 trading program regulations to represent the states' emissions budgets for the portion of the 2023 control period before the rule's effective date, and second, the emissions budgets for the 2023 control period established for the states in this rulemaking, which are being included in the revised Group 3 trading program regulations to represent the state's emissions budgets for the portion of the 2023 control period on and after the rule's effective date. The procedures and timing for determining blended emissions budgets, variability limits and assurance levels, and unit-level allowance allocations, as well as the

timing for the recordation of unit-level allocations, are the same as for the states currently in the Group 3 trading program.

Beginning administrative implementation of the Group 3 trading program starting on May 1, 2023, for sources currently in the Group 2 trading program imposes no new or different requirements on these sources. It would serve the public interest and greatly aid in administrative efficiency for most elements of the Group 3 trading program—specifically, all elements of the trading program other than the elements designed to establish more stringent emissions limitations for the sources coming from the Group 2 trading program—to apply to the sources starting on May 1, 2023. This is how the EPA handled the earlier transition of twelve states from the Group 2 to the Group 3 trading program in the Revised CSAPR Update, which was accomplished successfully and without incident. *See* 86 FR 23133–34. This approach would facilitate implementation of the Group 3 trading program in an orderly manner for the entire 2023 ozone season and reduce compliance burdens and potential confusion. Each of the CSAPR trading programs for ozone season NO_x is designed to be implemented over an entire ozone season. Implementing the transition from the Group 2 trading program to the Group 3 trading program in a manner that required the covered sources to participate in the Group 2 trading program for part of the 2023 ozone season and the Group 3 trading program for the remainder of that ozone season would be complex and burdensome for sources. Attempting to address the issue by splitting the Group 2 and Group 3 requirements for these sources into separate years is not a viable approach, because the EPA has no legal basis for releasing the transitioning Group 2 sources from the emissions reduction requirements found to be necessary in the CSAPR Update for a portion of the 2023 ozone season, and the EPA similarly has no legal basis for deferring implementation of the 2023 emissions reduction requirements found to be necessary under this rule for the transitioning Group 2 sources until 2024. Moreover, the requirements of the current Group 2 trading program and the revised Group 3 trading program for the 2023 control period are substantively identical as to almost all provisions, such that with respect to those provisions, a source will not need to alter its operations in any manner or face different compliance obligations as a consequence of a transition from the

Group 2 trading program to the Group 3 trading program. Thus, the EPA believes that no substantive concerns regarding retroactivity arise from transitioning the sources currently in the Group 2 trading program to the Group 3 trading program starting on May 1, 2023, as long as those aspects of the revised Group 3 trading program for the 2023 control period that *do* meaningfully differ from the analogous aspects of the Group 2 trading program—that is, the relative stringencies of the two trading programs, as reflected in the emissions budgets and associated assurance levels—are applied only as of the effective date of the final rule.

In all respects other than prorating the emissions budgets, variability limits and assurance levels, and unit-level allowance allocations, with respect to the sources currently participating in the Group 2 trading program or the Group 3 trading program, the EPA will implement the revised Group 3 trading program for the 2023 control period in a uniform manner for the entire control period. Thus, emissions will be monitored and reported for the entire 2023 ozone season (*i.e.*, May 1, 2023, through September 30, 2023), and as of the allowance transfer deadline for the 2023 control period (*i.e.*, June 1, 2024) each source will be required to hold in its compliance account vintage-year 2023 Group 3 allowances not less than the source's emissions of NO_x during the entire 2023 ozone season. Any efforts undertaken by one of these sources to reduce its emissions during the portion of the 2023 ozone season before the effective date of the rule will aid the source's compliance by reducing the amount of Group 3 allowances that the source would need to hold in its compliance account as of the allowance transfer deadline, increasing the range of options available to the source for meeting its compliance obligations under the revised Group 3 trading program.

In the case of the sources in the three states that do not currently participate in the Group 2 trading program or the Group 3 trading program, the 2023 control period will begin on the effective date of the rule, and because the effective date of the rule is expected to fall after May 1, 2023, the 2023 control period for the sources in these states will be shorter than the 153-day length of the 2023 control period for the sources in the remaining states. However, the EPA similarly will implement the revised Group 3 trading program for the sources in these states in a uniform manner for the entire shorter control period.

The prorating provisions are being finalized as proposed. The EPA received no comments on the portion of the proposal discussing these provisions.

b. Creation of Additional Group 3 Allowance Bank for 2023 Control Period

In the CSAPR Update, where the EPA established the Group 2 trading program and transitioned over 95 percent of the sources that had been participating in what is now the CSAPR NO_x Ozone Season Group 1 Trading Program (the “Group 1 trading program”) to the new program, the EPA determined that it was reasonable to establish an initial bank of allowances for the Group 2 trading program by converting almost all allowances banked under the Group 1 trading program at a conversion ratio determined by a formula. In the Revised CSAPR Update, where the EPA established the Group 3 trading program and transitioned approximately 55 percent of the sources that had been participating in the Group 2 trading program to the new program, the EPA similarly determined that it was reasonable to provide for an initial bank of allowances for the Group 3 trading program by converting allowances banked under the Group 2 trading program at a conversion ratio determined by a formula, using a conversion procedure that was modified to leave much of the Group 2 allowance bank available for use by the approximately 45 percent of sources then in the Group 2 trading program that would remain in that program. Any conversion of banked allowances from a previous trading program for use in a new trading program must ensure that implementation of the new trading program will result in NO_x emissions reductions sufficient to address significant contribution by all states that would be participating in the new trading program, while also providing industry certainty (and obtaining an environmental benefit) through continued recognition of the value of saving allowances through early reductions in emissions. The EPA’s approach to balancing these concerns in the CSAPR Update through the conversion of banked allowances from the Group 1 trading program to the Group 2 trading program was upheld in *Wisconsin v. EPA*, 938 F.3d at 321.

Under this final rule, applying the same balancing principle as in the CSAPR Update and the Revised CSAPR Update, the EPA will carry out a further conversion of allowances banked for control periods before 2023 under the Group 2 trading program into allowances usable in the Group 3 trading program in control periods in

2023 and later years. Because the EPA is transitioning over 80 percent of the remaining sources in the Group 2 trading program to the Group 3 trading program—much closer to the situation in the CSAPR Update than the situation in the Revised CSAPR Update—in this rule the EPA is applying a conversion procedure similar to the procedure followed in the CSAPR Update. Under the conversion procedure in this rule, the EPA has not set a predetermined conversion ratio in the regulations (as was done in the Revised CSAPR Update) but instead has established provisions identifying the target amount of new Group 3 allowances that will be created and defining the types of accounts whose holdings of Group 2 allowances will be converted to Group 3 allowances (as was done in the CSAPR Update). The conversion date will be carried out by September 18, 2023, which is expected to be approximately 2 months after the compliance deadline for the 2022 control period under the Group 2 trading program and approximately ten months before the compliance deadline for the 2023 control period under the Group 3 trading program. The actual conversion ratio will be determined as of the conversion date and will be the ratio of the total amount of Group 2 allowances held in the identified types of accounts prior to the conversion to the total amount of Group 3 allowances being created.

With respect to the numerator of the conversion ratio—that is, the total amount of Group 2 allowances being converted—the EPA has defined the types of accounts included in the conversion to include all accounts except the facility accounts of sources in states that will remain in the Group 2 trading program, consistent with the approach taken in the CSAPR Update.³⁶⁸ Thus, the accounts whose holdings of Group 2 allowances will be converted to Group 3 allowances will include (1) the facility accounts of all sources in the states transitioning from the Group 2 trading program to the Group 3 trading program, (2) the facility accounts of all sources in the states already participating in the Group 3 trading program, (3) the facility accounts of all sources in any other states not covered by the Group 2 trading program that happen to hold Group 2 allowances as of the conversion date, and (4) all general accounts (that is, accounts that are not facility

³⁶⁸The states whose sources will continue to participate in the Group 2 trading program for the 2023 control period will be Iowa, Kansas, and Tennessee.

accounts, including other accounts controlled by source owners as well as accounts controlled by non-source entities such as allowance brokers). Creating the new Group 3 allowances through conversion of previously banked Group 2 allowances will also help preserve the stringency of the Group 2 trading program for the states that remain covered by that trading program at levels consistent with the stringency found to be appropriate to address those states’ good neighbor obligations with respect to the 2008 ozone NAAQS in the CSAPR Update.

With respect to the denominator of the conversion ratio—that is, the target amount of Group 3 allowances that will be created in the conversion process—the EPA has followed the same approach for setting the target amount that was used in the Revised CSAPR Update for creation of the initial Group 3 allowance bank. Specifically, the target amount of Group 3 allowances to be created in this rule will be computed as the sum of the minimum 21 percent variability limits for the 2024 control period³⁶⁹ established for the ten states being added to the Group 3 trading program, prorated to reflect the portion of the 2023 control period occurring on and after the effective date of the final rule. Based on the amounts of the state emissions budgets and variability limits, the full-season target amount for the conversion would be 23,094 Group 3 allowances. The quantity of banked Group 2 allowances currently held in accounts other than the facility accounts of sources in Iowa, Kansas, and Tennessee exceeding the quantity of allowances likely to be needed for 2022 compliance is approximately 149,386 allowances. Thus, if the quantities of banked Group 2 allowances held in the accounts being included in the conversion do not change between now and the conversion date, and if there was no prorating adjustment, the conversion ratio would be approximately 6.5-to-1, meaning that one Group 3 allowance would be created for every 6.5 Group 2 allowances deducted in the conversion process.³⁷⁰

As noted in section VI.B.12.a of this document, the EPA expects that the effective date of this rule will occur after

³⁶⁹Similar to the approach taken in the Revised CSAPR Update, because emissions reductions from some of the emissions controls that EPA has identified as appropriate to use in setting budgets are first reflected in the 2024 state budgets rather than the 2023 state budgets, the EPA is basing the bank target amount on the sum of the states’ 2024 variability limits rather than the 2023 variability limits.

³⁷⁰By comparison, the analogous conversion ratio under the Revised CSAPR Update was 8-to-1.

the start of the 2023 ozone season, and prorating provisions are being promulgated in this rule to ensure that the increased stringency of this rule's state budgets and state assurance levels (*i.e.*, the sums of the budgets and variability limits) will take effect only after the rule's effective date. Consistent with these other procedures, the EPA will similarly prorate the bank target amount used in the conversion process. For example, if the effective date of the final rule is the eleventh day of the 153-day 2023 ozone season, the full-season initial bank target amount of 23,094 allowances would be prorated to an initial bank target amount of 21,585 allowances.³⁷¹ The EPA notes that prorating the bank amount in this manner will not reduce sources' compliance flexibility for the 2023 ozone season, because the amounts of Group 3 allowances that sources will receive for the portion of the 2023 ozone season before the rule's effective date will be based on the trading program budgets for the 2023 control period that were in effect before this rulemaking. These trading program budgets exceed the sources' collective 2022 emissions by approximately 29,789 tons, indicating potentially surplus allowances roughly 1.3 times the full-season bank conversion target amount of 23,094 allowances. Thus, although the prorating procedure will reduce the amount of Group 3 allowances that would be available to sources in the form of an initial bank, the reduction in the quantity of these allowances will be more than offset by the quantities of Group 3 allowances that will be allocated in excess of sources' recent historical emissions levels for the portion of the ozone season before the final rule's effective date.

As in the CSAPR Update and the Revised CSAPR Update, the EPA's overall objective in establishing the target amount for the allowance conversion is to achieve a total target amount for the bank at a level high enough to accommodate year-to-year variability in operations and emissions, as reflected in states' variability limits, but not high enough to allow sources collectively to plan to emit in excess of the collective state budgets. The EPA believes that a well-established trading program should be able to function with an allowance bank lower than the full amount of the covered states' variability limits, as discussed in section VI.B.6 of this document with respect to the bank recalibration process that will begin with the 2024 control period. However, the EPA also believes there are several

compelling reasons in this instance to use a bank target higher than the minimum practicable level.

First, making an allowance bank available for use in the 2023 control period that is somewhat higher than the minimum practicable level will help to address concerns that might otherwise arise regarding the transition to a new set of compliance requirements, for some sources, and the transition to compliance requirements based on revised emissions budgets different from the emissions budgets that the sources had reason to anticipate under previous rulemakings, for the remaining sources. Although the EPA is confident that the emissions budgets being established in this rulemaking for the 2023 control period are readily achievable, the EPA also believes that the existence of a somewhat larger allowance bank at this transition point will promote sources' confidence in their ability to meet their 2023 compliance obligations in general and in a liquid allowance market in particular. Second, because the large majority of the remaining Group 2 allowances that will be converted to Group 3 allowances in this rulemaking are held by the sources currently in the Group 2 trading program, while the large majority of the initial bank of Group 3 allowances previously created in the conversion under the Revised CSAPR Update are held by the sources already in the Group 3 trading program, basing the conversion in this rulemaking on a target bank amount set in the same manner as the target bank amount used in the Revised CSAPR Update is expected to result in a less concentrated distribution of holdings of banked Group 3 allowances following the conversion than would be the case if a more stringent target bank amount were used under this rulemaking than was used in the Revised CSAPR Update. A lower concentration of holdings of banked Group 3 allowances would generally be expected to help ensure allowance market liquidity. Third, the EPA considers it equitable to treat the sources in the states transitioning from the Group 2 trading program to the Group 3 trading program in this rulemaking roughly similarly to the sources in the states that transitioned between the same two trading programs in the Revised CSAPR Update with respect to the benefit they would receive under the Group 3 trading program for any efforts they may have made to make emissions reductions under the Group 2 trading program beyond the minimum efforts that were required to comply with the emissions budgets under that program. Finally, to the extent that the

conversion results in a larger bank of allowances remaining after the 2023 control period than is considered necessary to sustain a well-functioning trading program in subsequent control periods, the excess will be removed from the program in the bank recalibration process that will be implemented starting with the 2024 control period and therefore will not weaken sources' incentives to control emissions on a permanent basis.

The rule's provisions relating to the creation of an incremental Group 3 allowance bank are being finalized as proposed. Comments on the creation of the incremental allowance bank are discussed in section 5 of the *RTC*.

c. Recall of Group 2 Allowances Allocated for Control Periods After 2022

To maintain the previously established levels of stringency of the Group 2 trading program for the states and sources that remain subject to that program, the EPA is recalling CSAPR NO_x Ozone Season Group 2 allowances equivalent in amount and usability to all vintage year 2023–2024 CSAPR NO_x Ozone Season Group 2 allowances previously allocated to sources in states and areas of Indian country transitioning to the Group 3 trading program and recorded in the sources' compliance accounts. The recall provisions apply to all sources in jurisdictions newly added to the Group 3 trading program in whose compliance accounts CSAPR NO_x Ozone Season Group 2 allowances for a control period in 2023 or 2024 were recorded, including sources where some or all units have permanently retired or where the previously recorded 2023–2024 allowances have been transferred out of the compliance account. The recall provisions provide a flexible compliance schedule intended to accommodate any sources that have already transferred the previously recorded 2023–2024 allowances out of their compliance accounts and allow Group 2 allowances of earlier vintages to be surrendered to achieve compliance. Like the similar recall provisions finalized in the Revised CSAPR Update, the recall provisions include specifications for how the recall provisions apply in instances where a source and its allowances have been transferred to different parties and for the procedures that the EPA will follow to implement the recall.

Under the Group 2 trading program regulations, each Group 2 allowance is a "limited authorization to emit one ton of NO_x during the control period in one year," where the relevant limitations include the EPA Administrator's

³⁷¹ 23,094 × (153 – 10) ÷ 153 = 21,585.

authority “to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.” 40 CFR 97.806(c)(6)(ii). The Administrator is determining that, to effectively implement the Group 2 trading program as a compliance mechanism through which states not subject to the Group 3 trading program may continue to meet their obligations under CAA section 110(a)(2)(D)(i)(I) with regard to the 2008 ozone NAAQS, it is necessary to limit the use of Group 2 allowances equivalent in quantity and usability to all Group 2 allowances previously allocated for the 2023–2024 control periods and recorded in the compliance accounts of sources in the newly added Group 3 jurisdictions. The Group 2 allowances that have already been allocated to sources in the newly added Group 3 states for the 2023–2024 control periods and recorded in the sources’ compliance accounts represent the substantial majority of the total remaining quantity of Group 2 allowances that have been allocated and recorded for the 2023–2024 control periods and that were not already made subject to recall when other jurisdictions were transferred from the Group 2 trading program to the Group 3 trading program in the Revised CSAPR Update. Because allowances can be freely traded, if the use of the 2023–2024 Group 2 allowances previously recorded in newly added Group 3 sources’ compliance accounts (or equivalent Group 2 allowances) were not limited, the effect would be the same as if the EPA had issued to sources in the states that will remain covered by the Group 2 trading program a quantity of allowances available for compliance under the 2023–2024 control periods many times the levels that the EPA determined to be appropriate emissions budgets for these states in the CSAPR Update. Through the use of banked allowances, the excess Group 2 allowances would affect compliance under the Group 2 trading program in control periods after 2024 as well. Continued implementation of the Group 2 trading program at levels of stringency consistent with the levels contemplated under the CSAPR Update therefore requires that the EPA limit the use of the excess allowances, as the EPA is doing through the recall provisions.

In this rule, the EPA is implementing limitations on the use of the excess 2023–2024 Group 2 allowances through requirements to surrender, for each 2023–2024 Group 2 allowance recorded in a newly added Group 3 source’s

compliance account, one Group 2 allowance of equivalent usability under the Group 2 trading program. The surrender requirements apply to the owners and operators of the Group 3 sources in whose compliance account the excess 2023–2024 Group 2 allowances were initially recorded. In general, each source’s current owners and operators are required to comply with the surrender requirements for the source by ensuring that sufficient allowances to complete the deductions are available in the source’s compliance account by one of two possible deadlines discussed later in this section. However, an exception is provided if a source’s current owners and operators obtained ownership and operational control of the source in a transaction that did not include rights to direct the use and transfer of some or all of the 2023–2024 Group 2 allowances allocated and recorded (either before or after that transaction) in the source’s compliance account. The rule provides that in such a circumstance, with respect to the 2023–2024 Group 2 allowances for which rights were not included in the transaction, the surrender requirements apply to the most recent former owners and operators of the source before any such transactions occurred. Because in this situation a source’s former owners and operators might lack the ability to access the source’s compliance account for purposes of complying with the surrender requirements, the former owners and operators would instead be allowed to meet the surrender requirements with Group 2 allowances held in a general account.³⁷²

To provide as much flexibility as possible consistent with the need to limit the use of the excess Group 2 allowances, for each 2023–2024 Group 2 allowance recorded in a Group 3 source’s compliance account, the EPA will accept the surrender of either the same specific 2023–2024 Group 2 allowance or any other Group 2 allowance with equivalent (or greater) usability under the Group 2 trading program. Thus, a surrender requirement with regard to a Group 2 allowance allocated for the 2023 control period could be met through the surrender of any Group 2 allowance allocated for the 2023 control period or the control period in any earlier year—in other words, any 2017–2023 Group 2 allowance.³⁷³ Similarly, the surrender

³⁷² The EPA is currently unaware of any source that would need to use this flexibility but has included the option in the rule to address the theoretical possibility of such a situation.

³⁷³ The first control period for the Group 2 trading program was in 2017.

requirement with regard to a 2024 Group 2 allowance could be met through the surrender of any 2017–2024 Group 2 allowance.

Owners and operators subject to the surrender requirements can choose from two possible deadlines for meeting the requirements. The optional first deadline will be 15 days after the effective date of this rule.³⁷⁴ As soon as practicable or after this date, the EPA will make a first attempt to complete the deductions of Group 2 allowances required for each Group 3 source from the source’s compliance account. The EPA will deduct Group 2 allowances first to address any surrender requirements for the 2023 control period and then to address any surrender requirements for the 2024 control period. When deducting Group 2 allowances to address the surrender requirements for each control period, EPA will first deduct allowances allocated for that control period and then will deduct allowances allocated for each successively earlier control period. This order of deductions is intended to ensure that whatever Group 2 allowances are available in the account are applied to the surrender requirements in a manner that both maximizes the extent to which all of the source’s surrender requirements will be met and also ensures that any Group 2 allowances left in the source’s compliance account after completion of all required deductions will be the earliest allocated, and therefore most useful, Group 2 allowances possible. Among the Group 2 allowances allocated for a given control period, The EPA will first deduct allowances that were initially recorded in that account, in the order of recordation, and will then deduct allowances that were transferred into that account after having been initially recorded in some other account, in the order of recordation.

Following the first attempt to deduct Group 2 allowances to address Group 3 sources’ surrender requirements, the

³⁷⁴ As discussed later in this section and in section VI.B.9.b, the EPA has conditioned recordation of any allocations of Group 3 allowances in a source’s compliance account on the source’s prior compliance with the recall requirements for Group 2 allowances. The purpose of providing an optional first deadline for the recall provisions 15 days after a final rule’s effective is to ensure that sources have an early opportunity to comply with the recall provisions to be eligible to have allocations of Group 3 allowances recorded in their accounts 30 days after the final rule’s effective date. Because the vast majority of sources subject to the recall provisions already hold sufficient Group 2 allowances to comply with the recall provisions, the EPA anticipates that the sources will easily be able to comply with the optional first recall deadline.

EPA will send a notification to the designated representative for each such source (as well as any alternate designated representative) indicating whether all required deductions were completed and, if not, the additional amounts of Group 2 allowances usable in the 2023 or 2024 control periods that must be held in the appropriate account by the second surrender deadline of September 15, 2023. Each notification will be sent to the email addresses most recently provided to the EPA for the recipients and will include information on how to contact the EPA with any questions. The EPA has provided that no allocations of Group 3 allowances will be recorded in a source's compliance account until all the source's surrender requirements with regard to 2023–2024 Group 2 allowances have been met. For this reason, the principal consequence to a source of failure to fully comply with the surrender requirements by 15 days after the effective date of this rule will be that any Group 3 allowances allocated to the units at the source for the 2023 and 2024 control periods that would otherwise have been recorded in the source's compliance account by 30 days after the effective date of a final rule will not be recorded as of that recordation date.

If all surrender requirements of 2023–2024 Group 2 allowances for a source have not been met in EPA's first attempt, the EPA will make a second attempt to complete the required deductions from the source's compliance account (or from a specified general account, in the limited circumstance noted previously) as soon as practicable on or after September 15, 2023. The order in which Group 2 allowances are deducted will be the same as described previously for the first attempt.

If the second attempt to deduct Group 2 allowances to meet the surrender requirements through deductions from the source's compliance account (or from a specified general account) is unsuccessful for a given source, as soon as practicable on or after November 15, 2023, to the extent necessary to address the unsatisfied surrender requirements for the source, the EPA will deduct the 2023–2024 Group 2 allowances that were initially recorded in the source's compliance account from whatever accounts the allowances are held in as of the date of the deduction, except for any allowances where, as of April 30, 2022, no person with an ownership interest in the allowances was an owner or operator of the source, was a direct or indirect parent or subsidiary of an owner or operator of the source, or was

directly or indirectly under common ownership with an owner or operator of the source.³⁷⁵ Before making any deduction under this provision, the EPA will send a notification to the authorized account representative for the account in which the allowance is held and will provide an opportunity for submission of objections concerning the data upon which the EPA is relying. In EPA's view, this provision does not unduly interfere with the legitimate expectations of participants in the allowance markets because the provision will not be invoked in the case of any allowance that was transferred to an independent party in an arms-length transaction before EPA's intent to recall 2023–2024 Group 2 allowances became widely known. The provision would apply only to a Group 2 allowance that, as of April 30, 2022, was still controlled either by the owners and operators of the source in whose compliance account it was initially recorded or by an entity affiliated with such an owner or operator. The EPA believes that by April 30, 2022, all market participants had ample opportunity to become informed of the proposed rule provisions to recall 2023–2024 Group 2 allowances recorded in Group 3 sources' compliance accounts, particularly since the EPA implemented a closely analogous recall of Group 2 allowances in the Revised CSAPR Update.³⁷⁶

The final revised regulations provide that failure of a source's owners and operators to comply with the surrender requirements will be subject to possible enforcement as a violation of the CAA, with each allowance and each day of the control period constituting a separate violation.

To eliminate any possible uncertainty regarding the amounts of Group 2 allowances allocated for the 2023–2024 control periods (or earlier control periods) that the owners and operators

³⁷⁵ The provision under which the EPA will not deduct Group 2 allowances transferred to unrelated parties before April 30, 2022 from the transferees' accounts does not relieve the source to which the Group 2 allowances were originally allocated from the obligation to comply with the recall requirements. Specifically, the source would be required to comply with the recall requirements by obtaining and surrendering other Group 2 allowances.

³⁷⁶ Even before publication of the proposed rule, the EPA posted information on its websites to notify market participants that a pending rulemaking could have consequences for the value and usability of Group 2 allowances. The posted locations included the electronic portal that authorized account representatives use to enter allowance transfers for recordation by the EPA in the Allowance Management System. Additionally, the EPA emailed a notice identifying the possibility of such consequences to the representatives for all Allowance Management System accounts.

of each Group 3 source are required to surrender under the recall provisions, the EPA has prepared a list of the sources in the additional Group 3 states and areas of Indian country in whose compliance accounts allocations of 2023–2024 Group 2 allowances were recorded, with the amounts of the allocations recorded in each such compliance account for the 2023 and 2024 control periods. An additional list shows, for each newly added Group 3 source, the specific Group 2 allowances (batched by serial number) allocated for each control period and recorded in the source's compliance account and indicates whether, as of April 30, 2022, that batch of allowances was held in the source's compliance account, in an account believed to be partially or fully controlled by a related party (*i.e.*, an owner or operator of the source or an affiliate of an owner or operator of the source), or in an account believed to be fully controlled by independent parties. The lists are in a spreadsheet titled, "Recall of Additional CSAPR NO_x Ozone Season Group 2 Allowances," available in the docket for this rule. After the first and second surrender deadlines, the EPA intends to update the lists to indicate for each Group 3 source whether the surrender requirements for the source under the recall provisions have been fully satisfied. The EPA will post the updated lists on a publicly accessible website to ensure that all market participants have the ability to determine which specific 2023–2024 Group 2 allowances initially recorded in any given Group 3 source's compliance account do or do not remain subject to potential deduction to address the source's surrender requirements under the recall provisions.

The recall provisions have been finalized without change from the proposal. The EPA received no comments on the proposed provisions.

13. Conforming Revisions to Regulations for Other CSAPR Trading Programs

As noted in section VI.B.1.a of this document, in addition to the Group 3 trading program, EPA currently administers five other CSAPR trading programs, all of which have provisions that in most respects parallel the provisions of the Group 3 trading program.³⁷⁷ In this rulemaking, in addition to the revisions to the Group 3 trading program, the EPA is finalizing a set of conforming revisions that concern how various areas of Indian country are

³⁷⁷ The regulations for the Group 3 Trading Program are at 40 CFR part 97, subpart GGGGG. The regulations for the other five CSAPR trading programs are at 40 CFR part 97, subparts AAAAA, BBBBB, CCCCC, DDDDD, and EEEEE.

treated for purposes of the allowance allocation provisions of the regulations for all the CSAPR trading programs.³⁷⁸

As discussed in section VI.B.9.a of this document, to reflect the D.C. Circuit's holding in *ODEQ v. EPA* that states have initial CAA implementation planning authority in non-reservation areas of Indian country until displaced by a demonstration of tribal jurisdiction over such an area, the EPA is revising the allowance allocation provisions in the Group 3 trading program regulations so that, instead of distinguishing between the sets of units within a given state's borders that either are not or are in Indian country, the revised regulations distinguish between (1) the set of units within the state's borders that are not in Indian country or are in areas of Indian country covered by the state's CAA implementation planning authority and (2) the set of units within the state's borders that are in areas of Indian country not covered by the state's CAA implementation planning authority. For the same reasons stated in section VI.B.9.a of this document for the Group 3 trading program, the EPA is revising the allowance allocation provisions in the regulations for all the other CSAPR trading programs establishing the same substantive distinction among the sets of units within each state's borders. The specific regulatory provisions that are affected are identified in section IX.D of this document. The EPA is unaware of any currently operating units that would be affected by this revision to the regulations for the other CSAPR trading programs.

The conforming revisions to the regulations for the other CSAPR trading programs concerning Indian country are being finalized as proposed with no changes. The EPA received no comments on this portion of the proposal.

C. Regulatory Requirements for Stationary Industrial Sources

The EPA is finalizing FIPs with requirements for certain non-EGU industry sources for 20 of the states covered in this final rule. See section II.B of this document for the list of states. The FIPs include new emissions limitations for units in nine non-EGU industries that the EPA finds (as discussed in sections IV and V of this final rule) are significantly contributing

to nonattainment or interfering with maintenance in other states. The emissions control requirements of these FIPs for non-EGU sources apply only during the ozone season (May through September) each year, beginning in 2026.

To achieve the necessary non-EGU emissions reductions for these 20 states, the EPA is finalizing the proposed emissions limitations with some adjustments as a result of information received during the public comment period. The final emissions limits apply to the most impactful types of units in the relevant industries and are achievable with the control technologies identified in this preamble and further discussed in the Final Non-EGU Sectors TSD. The non-EGU regulatory requirements unique to each industry that EPA is finalizing after considering public comments are discussed in sections VI.C.1 through VI.C.6 of this document.

These final FIP requirements apply to both new and existing emissions units. The non-EGU emissions limits and compliance requirements will apply in all 20 states (and, as discussed in section III.C.2 of this document, in areas of Indian country within the borders of those states), even if some of those states do not currently have emissions units in a particular source category. This approach is consistent with the approach that the EPA proposed, and the EPA did not receive any comments specifically objecting to our proposal to regulate new units. This approach will ensure that all new sources constructed in any of the 20 states will be subject to the same good neighbor requirements that apply to existing units under this final rule. This will also avoid creating incentives to move production from an existing non-EGU source to a new non-EGU source of the same type but lacking the relevant emissions control requirements either within a linked state or in another linked state.

Comment: The EPA received several comments regarding the proposed approach of establishing unit-specific emissions limitations for non-EGUs instead of an emissions trading program. Some commenters suggested that a trading program for non-EGUs could provide for operational flexibility and that EPA should allow sources to work with regulatory authorities to develop a trading program. Other commenters generally supported EPA's proposed approach and the decision to not include non-EGUs in an emissions trading program, because the EPA would not need to require sources to unnecessarily install CEMS. Commenters from several states and

industry groups generally supported other monitoring options over CEMS, such as parametric monitoring, performance testing, and predictive emissions monitoring systems (PEMS). Additional commenters voiced concern with the expense and burden of continuous parametric monitoring and semi-annual performance tests. Specifically, commenters explained that semi-annual testing should not be required when the emissions limits only apply during the ozone season. Commenters also noted that many non-EGU boilers have recently been relieved from meeting the CEMS requirements under the 1998 NO_x SIP Call and that implementing CEMS on many of the non-EGU sources would be difficult and unnecessary.

Response: The EPA is finalizing a unit-specific approach with rate-based emissions limitations set on a uniform basis for the different segments of non-EGU emissions units using applicability criteria based on size and type of unit and, in some cases, emissions thresholds. In response to public comments, the EPA has adjusted these requirements as necessary to ensure that the emissions control requirements are achievable while ensuring that the FIPs achieve the necessary emissions reductions from the covered units to eliminate significant contribution to nonattainment and interference with maintenance as discussed in section V of this document. The EPA has concluded that a unit-specific approach is more appropriate for non-EGUs at this time than implementing a trading program and requiring all units to implement rigorous part 75 monitoring and reporting requirements. As explained in the proposal, to be considered for a trading program, non-EGU sources would have to comply with requirements for monitoring and reporting of hourly mass emissions in accordance with 40 CFR part 75 as we have required for all previous trading programs. Monitoring and reporting under part 75 include CEMS (or an approved alternative method), rigorous initial certification testing, and periodic quality assurance testing thereafter, such as relative accuracy test audits and daily calibrations. Consistent and accurate measurement of emissions is necessary to ensure that each allowance actually represents one ton of emissions and that one ton of reported emissions from one source would be equivalent to one ton of reported emissions from another source. See 75 FR 45325 (August 2, 2010). Moreover, these monitoring requirements generally would need to be in place for at least

³⁷⁸ Additional conforming revisions concerning the schedules for the EPA to record allowance allocations in source's compliance accounts and for states to submit state-determined allowance allocations to the EPA for subsequent recordation were finalized in an earlier final rule in this docket. See 87 FR 52473 (August 26, 2022).

one full ozone season to establish baseline data before it would be appropriate to rely on a trading program as the mechanism to achieve the required emissions reductions. Many industry and state commenters provided information confirming that many non-EGU units subject to this rulemaking do not currently utilize CEMS and specifically requested that EPA avoid requiring CEMS for all non-EGU industries. The EPA generally agrees that CEMS is not necessary for all non-EGU industries under the approach of this final rule and is finalizing other continuous monitoring, recordkeeping, and reporting requirements, as appropriate, that are specific to each non-EGU industry. The EPA has determined that establishing unit-specific emissions limitations for non-EGUs is a preferable approach in part because it avoids the rigorous monitoring requirements that would be applied to non-EGUs for the first time under a trading program.

Furthermore, to address commenters' concerns regarding non-EGU requirements for performance testing on a semi-annual basis, the EPA has also reduced the frequency of all required performance testing for non-EGU sources to once per calendar year. As commenters correctly pointed out, the emissions limits in these final FIPs only apply during the ozone season and testing once per calendar year should be sufficient to confirm the accuracy of the parameters being monitored to demonstrate continuous compliance during the ozone season. The EPA also agrees with commenters that the annual testing requirements need not occur during the ozone season.

In addition, the EPA is modifying the applicability criteria and other regulatory requirements in response to public comments to provide certain compliance flexibilities for non-EGU industries where appropriate. As discussed further in section V.C.1 of this document, the EPA is modifying the requirements for Pipeline Transportation of Natural Gas by finalizing an exemption for emergency engines and allowing any owner or operator of an affected unit to propose a "Facility-Wide Averaging Plan" that would, if approved by EPA, provide an alternative means for compliance with the emissions limits in this final rule. Further, as discussed in section VI.C.5 of this document, the EPA is finalizing a low-use exemption for non-EGU boilers that operates less than 10 percent per year on an hourly basis, based on the three most recent years of use and no more than 20 percent in any one of the three years. These final rule

provisions require controls on the most impactful non-EGU industrial sources while providing the flexibility needed to accommodate unique circumstances on a case-by-case basis.

Comment: Commenters from several non-EGU industries and states raised general concerns regarding the ability for all sources to comply with the proposed emissions limits. Some commenters suggested that the EPA allow for case-by-case limits where necessary, similar to case-by-case RACT determinations. Specifically, commenters operating boilers, furnaces, and MWCs provided general explanations of how some units might not be able to meet the proposed emissions limits and requested that EPA provide for compliance flexibility where a source can demonstrate technical and economical infeasibility.

Response: As explained more in sections VI.C.1 through VI.C.6, the EPA has made several adjustments to the proposed applicability criteria, emissions limits, and compliance requirements in response to public comments and to reduce the costs of compliance with the final rule. For Pipeline Transportation and Natural Gas, the EPA is finalizing emissions averaging provisions and exemptions for emergency engines to allow facilities to avoid installing controls on units with lower actual emissions where the installation of controls would be less cost effective compared to higher-emitting units. For Cement and Concrete Product Manufacturing, the EPA has removed the daily source cap that would have resulted in an artificially restrictive NO_x emissions limit for affected cement kilns that have operated at lower levels due to the COVID-19 pandemic. For Iron and Steel and Ferroalloy Manufacturing, the EPA is finalizing a "test-and-set" requirement for reheat furnaces that will require the installation of low-NO_x burners or equivalent technology. The EPA has addressed the economic concerns raised by commenters regarding installation of controls at Iron and Steel facilities by not finalizing the other ten proposed emissions limits that were intended to require the installation of SCR at these facilities. For Glass and Glass Product Manufacturing, the EPA is finalizing alternative standards that apply during startup, shutdown, and idling conditions. For boilers in Basic Chemical Manufacturing, Petroleum and Coal Products Manufacturing, Pulp, Paper, and Paperboard Mills, Metal Ore Mining, and the Iron and Steel Industry, the EPA is finalizing a low-use exemption to eliminate the need to install controls on boilers that would

have resulted in relatively small reductions in emissions. Finally, the EPA has modified the monitoring and recordkeeping requirements for all non-EGU industries where possible to reduce the testing frequency to once a year and to provide for alternative monitoring protocols where appropriate, which should further reduce the costs of compliance on non-EGU sources. With these modifications to the final rule in response to comments, the non-EGU sources subject to this rule should be able to meet the applicable control requirements established in this final rule.

The EPA also recognizes, however, that there may be unique circumstances the Agency cannot anticipate that would, for a particular source, render the final emissions control requirements technically impossible or impossible without extreme economic hardship. To address these limited circumstances, the EPA is finalizing a provision that allows a source to request EPA approval of a case-by-case emissions limit based on a showing that an emissions unit cannot meet the applicable standard due to technical impossibility or extreme economic hardship. The EPA has modeled the case-by-case emissions limit mechanism on case-by-case RACT requirements and certain facility-specific emissions limits under 40 CFR part 60 identified by commenters.³⁷⁹ The owner or operator of a source seeking a case-by-case emissions limit must submit a request meeting specific requirements to the EPA by August 5, 2024, one year after the effective date of this final rule. The applicable emissions limits established in this final rule remain in effect until the EPA approves a source's request for a case-by-case emissions limit. Given the May 1, 2026 compliance date that generally applies to all affected units in the non-EGU industries covered by this final rule, we encourage owners and operators of affected units who believe they must seek case-by-case emissions limits to submit their requests to the EPA before the one-year deadline for such requests, if possible, to ensure adequate time for EPA review and to install the necessary controls.

For a source requesting a case-by-case limit due to technical impossibility, the final rule requires that the request include emissions data obtained through CEMS or stack tests, an analysis

³⁷⁹ For examples of case-by-case RACT provisions and source specific limits for boilers in subpart Db of the EPA's NSPS, see 40 CFR 60.44b(f); Regulations of Connecticut State Agencies section 22a-174-22e; Code of Maryland Regulations section 26.11.09.08(B)(3); and Code of Maine Rules section 096-138-3, subsection (I).

of all available control technologies based on an engineering assessment by a professional engineer or data from a representative sample of similar sources, and a recommendation concerning the most stringent emissions limit the source can technically achieve.

For a source requesting a case-by-case limit on the basis of extreme economic hardship, the final rule requires that the request include at least three vendor estimates from three separate vendors that do not have a corporate or business-affiliation with the source of the costs of installing the control technology necessary to meet the applicable emissions limit and other information that demonstrates, to the satisfaction of the Administrator, that the cost of compliance with the applicable emissions limit for that particular source would present an extreme economic hardship relative to the costs borne by other comparable sources in the industry under this rule. In evaluating a source's request for a case-by-case limit due to extreme economic hardship, the EPA will consider the emissions reductions and costs identified in this final rulemaking (and related support documents) for other sources in the relevant industry and whether the costs of compliance for the source seeking the case-by-case limit would significantly exceed the highest representative end of the range of estimated cost-per-ton figures identified for any source in the relevant industry as discussed in section V of this document.

As discussed in section VI.A of this document, in *Wisconsin* the court held that some deviation from the CAA's mandate to eliminate prohibited transport by downwind attainment deadlines may be allowed only "under particular circumstances and upon a sufficient showing of necessity," e.g., when compliance with the statutory mandate amounts to an impossibility.³⁸⁰ Given these directives, the EPA cannot allow a covered source to avoid complying with the emissions limits established in this final rule unless the source can demonstrate that compliance with the limit would either be impossible as a technical matter or result in an extreme economic hardship—i.e., exceed the high end of the cost-effectiveness estimates that informed the EPA's Step 3 determination of significant contribution, as discussed in section V of this document. The criteria that must

be met to qualify for a case-by-case limit are designed to meet this statutory mandate.

Comment: Several commenters raised concerns about the EPA's differing applicability criteria for the various non-EGU industries. Specifically, the commenters questioned why EPA set applicability criteria for engines in Pipeline Transportation of Natural Gas and non-EGU boilers based on design capacity instead of potential to emit (PTE). Commenters also requested that the EPA allow each non-EGU category to rely on operating permits or other federally enforceable instruments to avoid being subject to the rule, such as limits to the PTE or limits on fuels used.

Response: The 100 tpy PTE threshold and comparable design capacity thresholds of 1,000 horsepower (hp) for engines and 100 mmBtu/hr for boilers are appropriate to ensure that the final rule reduces emissions from the most impactful units. The EPA finds the control technologies assumed to be installed to meet the final emissions limits would not be as readily available or cost effective for emissions units with PTE or design capacities lower than the applicability thresholds in this final rule.

With regard to the selection of design capacity thresholds for boilers and engines, the EPA finds that most RACT requirements and other standards reviewed by the EPA establish applicability criteria for engines and boilers based on design capacity rather than PTE. We further explain our basis for establishing applicability thresholds based on design capacity for these two source categories in sections VI.C.1. and VI.C.5. For consistency with preexisting requirements for engines and boilers and to capture the sizes of units identified in Step 3 of our analysis, the EPA selected design capacities of 1,000 hp for engines and 100 mmBtu/hr for boilers. The EPA recognizes that these applicability thresholds captured more units than the EPA intended, particularly some low-use units. Therefore, as explained in sections VI.C.1 and VI.C.5., the EPA is establishing exemptions for low-use boilers and emergency engines, as well as new emissions averaging provisions for engines, to ensure that this final rule focuses on larger, more impactful units.

The EPA also agrees with commenters that the applicability criteria should allow for sources to rely on enforceable requirements that limit a source's PTE and is finalizing a regulatory definition of PTE that is generally consistent with the definitions of that term in the EPA's title V and NSR permit programs. *See, e.g.,* 40 CFR 51.165(a)(1)(iii), 70.2. In

constructing the list of potential sources subject to the final rule, the EPA relied on available information to identify the PTE of the emissions units in the various non-EGU industries that are captured by the applicability criteria. *See Memo to Docket titled Summary of Final Rule Applicability Criteria and Emissions Limits for Non-EGU Emissions Units, Assumed Control Technologies for Meeting the Final Emissions Limits, and Estimated Emissions Units, Emissions Reductions, and Costs.* Thus, the EPA's Step 3 analysis takes into account available information about currently enforceable emissions limits and physical and operational limitations identified in existing permits. The EPA finds it necessary to define PTE consistent with its use in the title V and NSR permit programs to ensure that the requirements of the final FIPs apply to the most impactful units identified in Step 3 of our analysis. However, to ensure that these FIPs achieve the emissions reductions necessary to eliminate significant contribution or interference with maintenance as described in this final rule, the applicability criteria for the Cement and Concrete Manufacturing, Iron and Steel and Ferroalloy Manufacturing, and Glass and Glass Product Manufacturing industries take into account only those enforceable PTE limits in effect as of the effective date of this final rule. Thus, any emissions unit in these three industries that has a PTE equal to or greater than 100 tons per year and thus meets the definition of an "affected unit" as of August 4, 2023, will remain subject to the applicable FIPs, without regard to any PTE limit that the emissions unit may subsequently become subject to. Each affected unit in these three industries must submit an initial notification of applicability to the EPA by December 4, 2023, that identifies its PTE as of the effective date of this final rule. Additionally, any owner or operator of an existing emissions unit that is not an affected unit as of August 4, 2023, but subsequently meets the applicability criteria (e.g., due to a change in fuel use that increases the unit's PTE) will become an affected unit subject to the applicable requirements of this final rule at that time.

Comment: In responding to the EPA's request for comment on whether some non-EGU units would need to run controls required by the final FIP year-round, one commenter anticipated that control equipment would be operated as necessary to achieve applicable emissions limits, but that operational

³⁸⁰ *Wisconsin*, 938 F.3d at 316 and 319–320 (noting that any such deviation must be "rooted in Title I's framework" and "provide a sufficient level of protection to downwind States").

flexibility, cost considerations and equipment longevity would warrant operation of certain control equipment on a schedule such that the equipment would not be used when unnecessary to meet emissions limits and/or outside of ozone season (*i.e.*, during winter months). The commenter further explained that flexibility in the operation of certain control equipment when unnecessary to meet emissions limits will allow for routine maintenance and repairs without requiring variances or similar exemptions from continuous operation requirements.

Response: Based on the feedback received during the public comment period, the EPA is finalizing requirements for non-EGU sources that will apply only during the ozone season, which runs annually from May to September. As discussed in the proposed rule, this is consistent with EPA's prior practice in Federal actions to eliminate significant contribution of ozone in the 1998 NO_x SIP Call, CAIR, CSAPR, CSAPR Update, and the Revised CSAPR Update. In addition, the EPA did not receive any information during the public comment period suggesting that sources would have to run the necessary controls year-round due to the nature of those controls. We note, however, that certain emissions-control technologies, such as combustion controls that are integrated into the unit itself, would likely function to reduce NO_x emissions year-round as a practical engineering matter.

Comment: Regarding electronic reporting through the Compliance and Emissions Data Reporting Interface (CEDRI), one commenter requested that CEDRI reporting requirements be consolidated in one location rather than repeated in each section. Another commenter requested that EPA include electronic reporting requirements for MWCs and specifically require that MWCs report CEMS data to CEDRI. Another commenter requested that EPA allow for extensions of time for electronic reports due to technical glitches.

Response: To increase the ease and efficiency of data submittal and data accessibility, the EPA is finalizing, as proposed, a requirement that owners and operators of non-EGU sources subject to the final FIPs, including MWCs, submit electronic copies of required initial notifications of applicability, performance test reports, performance evaluation reports, quarterly and semi-annual reports, and excess emissions reports through EPA's Central Data Exchange (CDX) using the CEDRI. The final rule requires that

performance test results collected using test methods that are supported by the EPA's Electronic Reporting Tool (ERT) as listed on the ERT website³⁸¹ at the time of the test be submitted in the format generated through the use of the ERT or an electronic file consistent with the XML schema on the ERT website and that other performance test results be submitted in portable document format (PDF) using the attachment module of the ERT. Similarly, the EPA is finalizing a requirement that performance evaluation results of CEMS measuring relative accuracy test audit (RATA) pollutants that are supported by the ERT at the time of the test be submitted in the format generated through the use of the ERT or an electronic file consistent with the XML schema on the ERT website, and a requirement that other performance evaluation results be submitted in PDF using the attachment module of the ERT. The final rule also requires that initial notifications of applicability, annual compliance reports, and excess emissions reports be submitted in PDF uploaded in CEDRI.

Furthermore, the EPA is finalizing, as proposed, provisions that allow owners and operators to seek extensions of time to submit electronic reports due to circumstances beyond the control of the owner or operator (*e.g.*, due to a possible outage in CDX or CEDRI or a *force majeure* event) in the time just prior to a report's due date, as well as provisions specifying how to submit such a claim. Public commenters supported these proposed provisions.

The EPA agrees with commenters that the CEDRI reporting requirements could be centralized and has moved the CEDRI reporting requirements to 40 CFR 52.40.

1. Pipeline Transportation of Natural Gas

Applicability

The EPA is finalizing regulatory requirements for the Pipeline Transportation of Natural Gas industry that apply to stationary, natural gas-fired, spark ignited reciprocating internal combustion engines ("stationary SI engines") within these facilities that have a maximum rated capacity of 1,000 hp or greater. Based on our review of the potential emissions from stationary SI engines, we find that use of a maximum rated capacity of 1,000 hp reasonably approximates the 100 tpy PTE threshold used in the *Screening Assessment of Potential Emissions Reductions, Air Quality*

Impacts, and Costs from Non-EGU Emissions Units for 2026, as described in section V.B of this document.

The EPA is also modifying certain provisions in response to public comments to provide compliance flexibilities for the Pipeline Transportation of Natural Gas industry sector in order to focus emissions reduction efforts on the highest emitting units. Specifically, the EPA is finalizing an exemption for emergency engines, and establishing provisions that allow any owner or operator of an affected unit to propose a Facility-Wide Averaging Plan that would, if approved by EPA, provide an alternative means for compliance with the emissions limits in this final rule.

For purposes of this rule, the EPA is clarifying and narrowing the definition of "pipeline transportation of natural gas" to mean the transport or storage of natural gas prior to delivery to a local distribution company custody transfer station or to a final end-user (if there is no local distribution company custody transfer station). The revised definition of this term in § 52.41(a) is consistent with the EPA's regulatory definition of "natural gas transmission and storage segment" in 40 CFR 60.5430(a) (subpart OOOOa, Standards of Performance for Crude Oil and Natural Gas Facilities for Which Construction, Modification, or Reconstruction Commenced After September 18, 2015).

The EPA is also adding definitions of the terms "local distribution company" and "local distribution company custody transfer station" that are consistent with the definitions found in 40 CFR 98.400 (subpart NN, Suppliers of Natural Gas and Natural Gas Liquids) and 40 CFR 60.5430(a) (subpart OOOOa, Standards of Performance for Crude Oil and Natural Gas Facilities for Which Construction, Modification, or Reconstruction Commenced After September 18, 2015), respectively.

Comment: Several commenters asked EPA to exclude emergency engines in the final rule and one commenter recommended that the EPA revise the definition of affected unit to specifically exempt emergency engines.

Commenters stated that doing so would not only be consistent with other regulations applicable to stationary SI engines, but it would also be more consistent with EPA's applicability analysis, which assumes stationary SI engines will operate for 7,000 hours a year, something emergency engines are prohibited from doing by Federal regulation. Commenters also stated that emergency generators are currently exempt from requirements applicable to non-emergency RICE covered by both

³⁸¹ The ERT website is located at <https://www.epa.gov/electronic-reporting-air-emissions/electronic-reporting-tool-ert>.

the relevant NSPS rule (subpart JJJJ), as well as the relevant NESHAP rule (subpart ZZZZ), and that although the NSPS and NESHAP standards EPA has adopted for emergency RICE do not limit the amount of time they may run for emergency purposes, EPA has recognized in the past that states may assume a maximum of 500 hours of operation to estimate the “potential to emit” in issuing air permits for emergency RICE. One commenter asserted that emergency engines operating under other standards currently only operate for emergencies or for a few hours at a time to periodically conduct regular maintenance, that their emissions are low, and that their contribution to the ozone transport issues EPA’s proposal seeks to address is negligible. Another commenter stated that the EPA has traditionally exempted emergency engines in past standards because the EPA has typically found that the use of add-on emissions controls cannot be justified due to the cost of the technology relative to the emissions reduction that would be obtained.

Response: With respect to stationary SI emergency engines, the EPA has reviewed the information submitted by the commenters and has decided to exempt such engines from the requirements of the final rule. Exemption of emergency engines is generally consistent with the EPA’s treatment of emergency engines in other CAA rulemakings. *See, e.g.*, 40 CFR 63.6585(f). The EPA expects that this change from the proposed rule addresses the concerns expressed by the commenters about the requirements for stationary emergency engines.

The final rule defines emergency engines as engines that are stationary and operated to provide electrical power or mechanical work during an emergency situation. These engines are typically used only a few hours per year, and the costs of emissions control are not warranted when compared to the emissions reductions that would be achieved.

In the final rule, emergency engines are subject to certain compliance requirements on a continuous basis. Continuous compliance requirements include operating limitations that apply during non-emergency use but do not include emissions testing of emergency engines.

Comment: Several commenters raised concerns about the EPA’s proposal to establish applicability criteria for engines in Pipeline Transportation of Natural Gas based on design capacity rather than PTE. Other commenters asserted that the horsepower rating of an engine does not necessarily correspond to its annual emissions and that engines with a rated capacity of more than 1,000 hp in this industry sector may operate at low load and/or infrequently and be associated with limited NO_x emissions. One commenter stated that most of the subject facilities in their state that have natural gas fired SI engines with a nameplate capacity rating of 1,000 hp or greater have annual NO_x emissions less than 100 tpy, with nearly 25 percent of them less than 25 tpy. The commenter suggested that the 1,000 hp applicability threshold would result in overcontrol. According to one commenter, the EPA has overestimated the emissions rates and operating hours of engines with a rated capacity of more than 1,000 hp and thus underestimated the size of pipeline RICE that would be expected to emit more than 100 tpy of NO_x annually. According to this commenter, only engines much larger than 1,000 hp are likely to emit at the level EPA deemed appropriate for regulation.

Another commenter suggested that the EPA should use a 150 ton per year threshold that the commenter alleges was used in the Revised CSAPR Update rulemaking so that stationary SI engines are regulated on equal footing with EGUs and raise the 1,000 hp threshold to 2,000 hp, which according to the commenter would not sacrifice the emissions reductions to be achieved.

Response: As explained in the proposal, the EPA found that most RACT requirements and other standards reviewed by the EPA establish applicability criteria for engines based on design capacity rather than PTE. For consistency with preexisting requirements for engines, the EPA selected a design capacity of 1,000 hp for engines to capture the sizes of units identified in Step 3 of our analysis. Based on the Non-EGU Screening Assessment memorandum, engines with a potential to emit of 100 tpy or greater had the most significant potential for NO_x emissions reductions. The EPA recognizes that the use of a 1,000 hp design capacity as part of the applicability criteria may capture low-

use units and some units with emissions of less than 100 tons per year. However, it is also not possible to guarantee without an effective emissions control program that all such units could not increase emissions in the future. As discussed in section V of this document, we continue to find that collectively engines with a design capacity of 1,000 hp or higher in the states and industries covered by this final rule emit substantial amounts of NO_x that significantly contribute to downwind air quality problems.

However, in response to concerns raised by commenters while continuing to ensure that this rule establishes an effective emissions control program for these units that is consistent with our Step 3 determinations, the EPA is establishing a compliance alternative using facility-wide emissions averaging, which will allow facilities to prioritize emissions reductions from larger, higher-emitting units. (As previously discussed, we are also establishing an exemption for emergency engines, which also helps ensure that this final rule focuses on larger, more impactful units in this industry.) The facility-wide emissions averaging alternative is explained in the following paragraphs.

Emissions Limitations and Rationale

In developing the emissions limits for the Pipeline Transportation of Natural Gas industry, the EPA reviewed RACT NO_x rules, air permits, and OTC model rules. While some permits and rules express engine emissions limits in parts per million by volume (ppmv), the majority of rules and source-specific requirements express the emissions limits in grams per horsepower per hour (g/hp-hr). The EPA has historically set emissions limits for these types of engines using g/hp-hr and finds that method appropriate for this final FIP as well.

Based on the available information for this industry, including applicable State and local air agency rules and active air permits issued to sources with similar engines, the EPA is finalizing the following emissions limits for stationary SI engines in the covered states. Beginning in the 2026 ozone season and in each ozone season thereafter, the following emissions limits apply, based on a 30-day rolling average emissions rate during the ozone season:

TABLE VI.C-1—SUMMARY OF FINAL NO_x EMISSIONS LIMITS FOR PIPELINE TRANSPORTATION OF NATURAL GAS

Engine type and fuel	Final NO _x emissions limit (g/hp-hr)
Natural Gas Fired Four Stroke Rich Burn	1.0
Natural Gas Fired Four Stroke Lean Burn	1.5
Natural Gas Fired Two Stroke Lean Burn	3.0

The EPA anticipates that, in some cases, affected engines will need to install NO_x controls to comply with the final emissions limits in Table VI.C-1. The emissions limits for four stroke rich burn engines, four stroke lean burn engines and two stroke lean burn engines are designed to be achievable by installing Non-Selective Catalytic Reduction (NSCR) on existing four stroke rich burn engines; installing SCR on existing four stroke lean burn engines; and retrofitting layer combustion on existing two stroke lean burn engines as identified in the Final Non-EGU Sectors TSD. Sources have the flexibility to install any other control technologies that enable the affected units to meet the applicable emissions limit on a continuous basis.

The EPA is establishing provisions that allow any owner or operator of an affected unit in the Pipeline Transportation of Natural Gas Industry to propose a Facility-Wide Averaging Plan that would, if approved by EPA, provide an alternative means for compliance with the emissions limits in this final rule. These provisions will provide some flexibility to owners and operators of affected units to determine which engines to control and at what level, so long as the average emissions across all covered units, on a weighted basis, meet the applicable emissions limits for each engine type. This approach allows facilities to target the most cost-effective emissions reductions and to avoid installing controls on equipment that is infrequently operated.

We provide a more detailed discussion of the basis for the final emissions limits and the anticipated control technologies to be installed in the Final Non-EGU Sectors TSD.

Four Stroke Rich Burn and Four Stroke Lean Burn Engines

The EPA requested comment on whether a lower emissions limit is appropriate for four stroke rich burn engines since even an assumed reduction of 95 percent would result in most engines being able to achieve an emissions rate of 0.5 g/hp-hr. The EPA also requested comment on whether a lower or higher emissions limit is

appropriate for four stroke lean burn engines.

Comment: One commenter stated that the limits as proposed were not technically feasible in all circumstances. The commenter explained that its company has 150 four stroke rich burn engines in its fleet and that some of those engines cannot achieve the proposed 1.0 g/hp-hr limit even with both NSCR and layered combustion due to the vintage design of the individual cylinder geometry and the fact that most of those engines are not in production today, which limits availability of parts and retrofit technologies. The commenter asserted that 10 of its four stroke rich burn engines have all available controls on them and half of those still exceed the proposed limits. The commenter estimated that 10 of its four stroke lean burn engines would require SCR to meet the 1.5 g/hp-hr limit and that this control installation would require custom retrofit due to the age of these engines. Furthermore, the commenter stated that if current limits are not achievable in all circumstances, then lower limits are likewise impossible for four stroke rich burn engines and four stroke lean burn engines in even more circumstances. The commenter stated that the technical feasibility of installing controls on any single existing engine varies and depends, in part, on site-specific and engine-specific considerations such as space for the installation of the control, the availability of sufficient power, the emissions reductions required to meet the applicable standards, and the vintage, make, and model of a particular engine. Another commenter recommended tightening the proposed emissions standards for four stroke lean burn engines to an emissions limit similar to Colorado’s limit of 1.2 g/hp-hr. A third commenter noted that the District of Columbia Department of Energy and Environment has NO_x emissions limits for both rich- and lean burn engines burning natural gas at 0.7 g/hp-hr.

Response: The EPA is finalizing the emissions limits for both four stroke rich burn engines and four stroke lean burn engines as proposed but also establishing alternative compliance

provisions and criteria for establishing case-by-case alternative emissions limits in response to the concerns raised by commenters. NSCR can achieve NO_x reductions of 90 to 99 percent, and engines in California, Colorado, Pennsylvania and Texas have achieved the emissions limits that the EPA had proposed. Based on this information and the emissions limits and NO_x controls analysis developed by the OTC in a report entitled *Technical Information Oil and Gas Sector Significant Stationary Sources of NO_x Emissions* (October 17, 2012), the EPA is finalizing a 1.0 g/hp-hr emissions limit for four stroke rich burn engines and a 1.5 g/hp-hr emissions limit for four stroke lean burn engines. The Final Non-EGU Sectors TSD provides a more detailed explanation of the basis for these emissions limits.

To address the concerns raised by some commenters that not all engines may be able to achieve the emissions limits as proposed due to engine vintage and technical constraints, the final rule allows any owner or operator of an affected unit to request a Facility-Wide Averaging Plan that would, if approved by EPA, provide an alternative means for compliance with the emissions limits in the final rule. An approved Facility-Wide Averaging Plan would allow the owner or operator of the facility to identify the most cost-effective means for installing the necessary controls (*i.e.*, by installing controls on the subset of engines that provide the greatest emissions reduction potential at lowest costs). In addition to the Facility-Wide Averaging Plan provisions, the final rule allows owners and operators to seek EPA approval of alternative emissions limits, on a case-by-case basis, where necessary due to technical impossibility or to avoid extreme economic hardship. The provisions governing case-by-case alternative limits are explained in more detail in section VI.C of this document.

Two Stroke Lean Burn Engines

The EPA requested comment on whether a lower emissions limit would be achievable with layered combustion alone for the two stroke lean burn engines covered by this final rule. The

EPA also sought comment on whether these engines could install additional control technology at or below the marginal cost threshold to achieve a lower emissions rate.

Comment: Commenters did not specifically address whether a lower emissions limit would be achievable with layered combustion alone at two stroke lean burn engines. However, one commenter stated that older two stroke lean burn engines generally would not be able to achieve the proposed NO_x emissions limits. The commenter stated that conversion kits are available for several models that can reduce emissions but that such kits are not made for all models, especially older stationary engines. Commenters further stated that where conversion kits are not available, a company would likely have no choice but to replace the older four stroke or two stroke stationary engines, typically at a cost of \$2 million to \$4 million each.

Two commenters stated that they are required by their state agency to have RACT, BACT, or BART controls, at minimum. Commenters stated that requiring additional controls at facilities already equipped with RACT, BACT or BART control technologies would not achieve the anticipated emissions reductions due to operational factors inherent in the preexisting and pre-controlled equipment and that the achievability of targeted control levels is highly dependent upon a number of variables at each facility.

Another commenter suggested that the EPA set lower limits for two stroke lean burn engines similar to the OTC-recommended limits in the range of 1.5–2.0 g/hp-hr.

Response: Information currently available to the EPA indicates that the amount of emissions reductions achievable with layered combustion controls is unit specific and can range from a 60 to 90 percent reduction in NO_x emissions. The EPA estimates that existing uncontrolled two stroke lean burn engines would need to reduce emissions by up to 80 percent to comply with a 3.0 g/hp-hr emissions limit. The EPA has found that engines in California, Colorado, Pennsylvania and Texas have achieved these emissions rates. Based on this information and the emissions limits and NO_x controls analysis developed by the OTC in a report entitled *Technical Information Oil and Gas Sector Significant Stationary Sources of NO_x Emissions* (October 17, 2012), the EPA is finalizing a 3.0 g/hp-hr emissions limit for two stroke lean burn engines. Although some affected units may be able to achieve a lower emissions rate, we find

that a 3.0 g/hp-hr emissions limit generally reflects a level of control that is cost-effective for the majority of the affected units and sufficient to achieve the necessary emissions reductions. As explained in the proposed rule and expressed by public commenters, if the EPA were to establish an emissions limit lower than 3.0 g/hp-hr, some two stroke lean burn engines would not be able to meet the emissions limit with the installation of layered combustion control alone. In that case, the lower limit might require the installation of SCR, which the EPA did not find to be cost-effective for two stroke lean burn engines in its Step 3 analysis.³⁸² The Final Non-EGU Sectors TSD provides a more detailed explanation of the basis for this emissions limit.

In response to commenters' concerns about the difficulties involved in retrofitting or replacing older stationary engines to achieve the EPA's proposed emissions limit, the final rule allows any owner or operator of an affected unit to request a Facility-Wide Averaging Plan that would, if approved by EPA, provide an alternative means for compliance with the emissions limits in the final rule. In addition to the Facility-Wide Averaging Plan provisions, the final rule allows owners and operators to seek EPA approval of alternative emissions limits, on a case-by-case basis, where necessary due to technical impossibility or to avoid extreme economic hardship. However, in the context of older or "vintage," high-emitting engines in this industry for which commenters claim emissions control technology retrofit is not feasible, the Agency anticipates taking into consideration the cost associated with alternative compliance strategies, such as replacement with new, far more efficient and less polluting engines, in evaluating claims of extreme economic hardship.

Facility-Wide Averaging Plan

The EPA is finalizing regulatory text that provides for an emissions limit compliance alternative using facility-level emissions averaging. An approved Facility-Wide Averaging Plan will allow the owner or operator of the facility to average emissions across all participating units and thus to select the most cost-effective means for installing the necessary controls (*i.e.*, by installing controls on the subset of engines that provide the greatest emissions reduction potential at lowest costs and avoiding

³⁸² 87 FR 20036, 20143 (noting that an emissions limit below 3.0 g/hp-hr may require some two stroke lean burn engines to install additional controls beyond the EPA's cost threshold).

installation of controls on equipment that is infrequently operated or otherwise less cost-effective to control). So long as all of the emissions units covered by the Facility-Wide Averaging Plan collectively emit less than or equal to the total amount of NO_x emissions (in tons per day) that would be emitted if each covered unit individually met the applicable NO_x emissions limitations, the covered units will be in compliance with the final rule. Under this alternative compliance option, facilities have the flexibility to prioritize emissions reductions from larger, dirtier engines.

Comment: Several commenters recommended that the EPA promulgate emissions averaging provisions, as it did in the 2004 NO_x SIP Call Phase 2 rule (69 FR 21604), in which the EPA evaluated and supported reliance on emissions averaging for RICE in the Pipeline Transportation of Natural Gas industry sector. The commenter stated that the EPA's guidance to states on developing an appropriate SIP in response to the SIP Call provided companies the "flexibility" to use a number of control options, as long as the collective result achieved the required NO_x reductions, and that many states built their revised SIPs around the emissions averaging approach addressed in this guidance document.³⁸³ One commenter recommended that the EPA allow intra-state emissions averaging across all pipeline RICE owned or operated by the same company. Another commenter asserted that units of certain vintages and units from certain manufacturers will not be able to meet the emissions rate limits the EPA had proposed. The commenter claimed that, absent a system based on source-specific emissions limits, emissions averaging is one of the only practical mechanisms for addressing these challenges.

One commenter stated that it had evaluated the cost of controls for engines in its fleet and that the variety in cost-per-ton for each potential project counsels for a more flexible approach, like an averaging program. Another commenter advocated for an emissions averaging plan that would allow an engine-by-engine showing of economic infeasibility to ensure a cost-effective application of the emissions standards, a reduced impact on natural gas capacity, and a means for addressing the problem presented by achieving

³⁸³ The commenter refers to an August 22, 2002 memorandum from Lydia N. Wegman, Director, EPA, Air Quality Strategies and Standards Division to EPA Air Division Directors, entitled "State Implementation Plan (SIP) Call for Reducing Nitrogen Oxides (NO_x)—Stationary Reciprocating Internal Combustion Engines."

compliance on engines that are technically impossible to retrofit.

One commenter stated that the EPA should also consider allowing companies to choose a mass-based alternative that would ensure emissions reductions align with the tons per year reductions upon which the EPA based its significant contribution and over-control analyses.

Response: Based upon the EPA's 2019 NEI emissions inventory data, the EPA estimates that a total of 3,005 stationary SI engines are subject to the final rule. The EPA recognizes that many low-use engines are captured by the 1,000 hp design capacity applicability threshold. In the process of reviewing public comments, the EPA reviewed emissions averaging plans found in state air quality rules for Colorado, Illinois, Louisiana, New Jersey, and Tennessee.³⁸⁴ Based on these additional reviews, the EPA is finalizing in § 52.41(c) of this final rule an emissions limit compliance alternative using facility-level emissions averaging. Emissions averaging plans will allow facility owners and operators to determine how to best achieve the necessary emissions reductions by installing controls on the affected engines with the greatest emissions reduction potential rather than on units with lower actual emissions where the installation of controls would be less cost effective. The final rule defines "facility" consistent with the definition of this term as it generally applies in the EPA's NSR and title V permitting regulations,³⁸⁵ with one addition to make clear that, for purposes of this final rule, a "facility" may not extend beyond the boundaries of the 20 states covered by the FIP for industrial sources, as identified in § 52.40(b)(2). Because a facility cannot extend beyond this geographic area, a Facility-Wide Averaging Plan also cannot extend beyond the 20-state area covered by the FIP.

To estimate the number of facilities that may take advantage of the Facility-

Wide Averaging Plan provisions, and the number of affected units that would install controls under such an emissions averaging plan, the EPA conducted an analysis on a subset of the estimated 3,005 stationary IC engines subject to the final rule. The EPA evaluated the reported actual NO_x emissions data in tpy from a subset of facilities in the covered states using 2019 NEI data for stationary IC engines with design capacities of 1,000 hp or greater. The EPA then identified a number of facilities that have more than one affected engine, calculated each facility's emissions "cap" as the total NO_x emissions (in tpy) allowed facility-wide based on the unit-specific NO_x emissions limits applicable to all affected units at the facility, and identified a number of higher-emitting engines at each facility that were candidates for having controls installed. For engines that EPA identified were likely to install controls, the EPA assumed that four stroke rich burn engines, four stroke lean burn engines, and two stroke lean burn engines could achieve a NO_x emissions rate of 0.5 g/hp-hr with the installation of SCR based on data obtained from the Ozone Transport Commission report entitled *Technical Information Oil and Gas Sector Significant Stationary Sources of NO_x Emissions* (October 17, 2012). For the remaining engines identified as uncontrolled, the EPA assumed a NO_x emissions rate of 16 g/hp-hr for all engine types. Thus, under the assumed averaging scenarios, engines with controls installed would achieve emissions levels below the emissions limits in the final rule and would offset the higher emissions from the remaining uncontrolled units.

The EPA then calculated the total facility-wide emissions (in tpy) under various assumed averaging scenarios and compared those totals to each facility's calculated emissions cap (in tpy) to estimate the number of affected units at each facility that would need to install controls to ensure that total facility-wide emissions remained below the emissions cap. Based on these analyses, the EPA found that emissions averaging should allow most facilities to install controls on approximately one-third of the engines at their sites, on average, while complying with the applicable NO_x emissions cap on a facility-wide basis. For a more detailed discussion of the EPA's analysis and related assumptions, see the Final Non-EGU Sectors TSD.

The Facility-Wide Averaging Plan provisions that the EPA is finalizing provide the flexibility needed to address the concerns about the costs of

emissions control installations for certain stationary SI engines, by allowing facility owners and operators to average emissions across all participating units and thus to select the most cost-effective means for installing the necessary controls (*i.e.*, by installing controls on the subset of engines that provide the greatest emissions reduction potential at lowest costs and avoiding installation of controls on equipment that is infrequently operated or otherwise less cost-effective to control).

An owner or operator of a facility containing more than one affected unit may elect to use an EPA-approved Facility-Wide Averaging Plan as an alternative means of compliance with the NO_x emissions limits in § 52.41(c). The owner or operator of such a facility must submit a request to the EPA that, among other things, specifies the affected units that will be covered by the plan, provides facility and unit-level identification information, identifies the facility-wide emissions "cap" (in tpd) that the facility must comply with on a 30-day rolling average basis, and provides the calculation methodology used to demonstrate compliance with the identified emissions cap. The EPA will approve a request for a Facility-Wide Averaging Plan if the EPA determines that the facility-wide emissions total (in tpd), based on a 30-day rolling emissions average basis during the ozone season, is less than the emissions cap (in tpd) and the plan establishes satisfactory means for determining initial and continuous compliance, including appropriate testing, monitoring, and recordkeeping requirements.

Compliance Assurance Requirements

The EPA is requiring owners and operators of affected units to conduct annual performance tests in accordance with 40 CFR 60.8 to demonstrate compliance with the NO_x emissions limit in this final rule. The EPA is also requiring owners and operators to monitor and record hours of operation and fuel consumption and to use continuous parametric monitoring systems to demonstrate ongoing compliance with the applicable NO_x emissions limit. For example, owners and operators of engines that utilize layered combustion controls will need to monitor and record temperature, air to fuel ratio, and other parameters as appropriate to ensure that combustion conditions are optimized to reduce NO_x emissions and assure compliance with the emissions limit. For engines using SCR or NSCR, owners and operators must monitor and record parameters such as inlet temperature to the catalyst

³⁸⁴ See Code of Colorado Regulations, Regulation Number 7 (5 CCR 1001-9), Part E, Section I.D.5.c., Illinois Administrative Code, Title 35, Section 217.390, Louisiana Administrative Code, Title 33, Section 2201, New Jersey Administrative Code, Title 7, Chapter 27, Section 19.6, and Rules of the Tennessee Dept. of Environment and Conservation, Rule 1200-03-27-.09.

³⁸⁵ See 40 CFR 51.165(a)(1)(ii)(A), 51.166(b)(6)(i), and 52.21(b)(6)(i) (defining "building, structure, facility, or installation" for Nonattainment New Source Review and Prevention of Significant Deterioration permits) and *Natural Resources Defense Council v. EPA*, 725 F.2d 761 (D.C. Cir. 1984) (vacating and remanding EPA's categorical exclusion of vessel activities from this definition); see also 40 CFR 70.2 (defining "major source" for title V operating permits).

and pressure drop across the catalyst. For affected engines that meet the certification requirements of § 60.4243(a), however, the facility-wide emissions calculations may be based on certified engine emissions standards data pursuant to § 60.4243(a), instead of performance tests.

In calculating the facility-wide emissions total during the ozone season, affected engines covered by the Facility-Wide Averaging Plan must be identified by each engine's nameplate capacity in horsepower, its actual operating hours during the ozone season, and its emissions rates in g/hp-hr from certified engine data or from the most recent performance test results for non-certified engines according to § 52.41(e).

Comment: Several commenters stated that semi-annual performance testing would not be appropriate due to its high costs and limited benefits. One commenter proposed a "step-down" testing alternative that could be conducted after establishing an engine's initial compliance via performance testing. Under this approach, owners and operators would conduct one performance test and would only need to conduct a second performance test within a given year if the first performance test demonstrated that an engine was not meeting the applicable emissions standards.

Another commenter asserted that to test all of its 950 units, a minimum of 12 months would be needed rather than the six months the EPA had proposed to provide (or five months if the EPA would require one of the semi-annual tests to be conducted during the ozone season). The commenter stated that the EPA had accounted for these operational realities in the past and that under the NSPS and NESHAP, testing is generally required only once for every 8,760 hours of run time. The commenter asserted that there is no reason to require more frequent testing than those required under the NSPS and NESHAP.

Several commenters requested that the EPA allow for reduction in the frequency of testing to once every two years if testing shows that NO_x emissions are no more than 75 percent of permitted NO_x emissions limits. In addition, several commenters stated that since the rule is intended to address the ozone season, a single, annual test is more feasible than semi-annual testing and reporting.

Response: For the stationary SI engines subject to this final rule, the

EPA is revising the frequency of required performance tests from a semi-annual basis to once per calendar year. As commenters correctly pointed out, the emissions limits in these final FIPs only apply during the 5-month ozone season and testing once per calendar year should be sufficient to confirm the accuracy of the parameters being monitored to determine continuous compliance during the ozone season. The EPA also agrees with commenters that the annual tests required under the final rule need not occur during the ozone season. However, where sources are able to do so, we recommend conducting a stack test in the period relatively soon before the start of the ozone season. This would provide the greatest assurance that the emissions control systems are working as intended and the applicable emissions limit will be met when the ozone season starts.

Comment: Commenters generally stated that requiring CEMS would add an unnecessary cost and complexity, would provide no emissions reduction benefit for the affected units the proposed FIP intends to control and are not warranted due to the availability of other established methods of compliance assurance, such as parametric monitoring and periodic testing. One commenter stated that requiring CEMS would add unnecessary CEMS testing obligations. Another commenter stated that the costs associated with CEMS and frequent performance testing on affected RICE would be as much, if not more, than the costs associated with installation and operation of some of the control technologies EPA has considered in setting the proposed emissions limits. According to one commenter, the EPA has traditionally agreed with this viewpoint on the high cost of CEMS, as most stationary engines are not currently required under the NSPS or NESHAP to install or operate CEMS.

Another commenter stated that in addition to cost, there are other barriers to installing CEMS on RICE across the Pipeline Transportation of Natural Gas industry. Many RICE in the Pipeline Transportation of Natural Gas industry are located at remote, unstaffed locations, meaning that there would be no staff available to respond and react to communication or alarms from CEMS.

Response: The EPA acknowledges the costs associated with the installation and maintenance of CEMS at affected

units in the Pipeline Transportation of Natural Gas industry and agrees that it is not necessary to require CEMS for purposes of compliance with the requirements of this final rule for this industry. Accordingly, the EPA is not finalizing requirements for affected units in this industry sector to install or operate CEMS. Instead, the EPA is requiring parametric monitoring protocols, as described earlier, coupled with an annual performance test, which will ensure that the emissions limits are legally and practically enforceable on a continuous basis, and that data are recorded, reported, and can be made publicly available, ensuring the ability of state and Federal regulators and other persons under CAA sections 113 and 304 to enforce the requirements of the Act.

2. Cement and Concrete Product Manufacturing Applicability

For cement kilns in the Cement and Cement Product Manufacturing industry, the EPA is finalizing the proposed applicability provisions without change. The affected units in this industry are cement kilns that emit or have a PTE of 100 tpy or more of NO_x. The EPA received comments regarding the definition of PTE, which we address in section VI.C, but no comments concerning the 100 tpy PTE threshold for applicability purposes.

Emissions Limitations and Rationale

As explained in the proposal, the EPA based the proposed emissions limits for cement kilns on the types of limits being met across the nation in RACT NO_x rules, NSPS, air permits, and consent decrees. Based on these requirements, the EPA proposed emissions limits in the form of mass of pollutant emitted (in pounds) per kiln's clinker output (in tons), *i.e.*, pounds of NO_x emitted per ton of clinker produced during a 30-operating day rolling average period. Further, the EPA proposed specific emissions limits for long wet, long dry, preheater, precalciner, and combined preheater/precalciner kilns. The EPA also proposed a daily source cap limit that would apply to all units at a facility. Based on information received from public comments, the EPA is removing the daily source cap limit but finalizing the emissions limits as proposed in all other respects, as shown in Table VI.C-2.

TABLE VI.C-2—SUMMARY OF NO_x EMISSIONS LIMITS FOR KILN TYPES IN CEMENT AND CONCRETE PRODUCT MANUFACTURING

Kiln type	NO _x emissions limit (lb/ton of clinker)
Long Wet	4.0
Long Dry	3.0
Preheater	3.8
Precalciner	2.3
Preheater/Precalciner	2.8

Comment: Numerous commenters raised concerns about designing a source cap limit based on average annual production in tons of clinker and kiln type. Commenters stated that the source cap limit equation as used in a prior action applied to long wet and dry preheater-precalsiner or precalsiner kilns and did not include other kiln types. Commenters expressed concern that the CAP2015 Ozone Transport equation the EPA proposed in this rule could lead to artificially low and restrictive daily emissions caps for facilities that experienced a temporary decrease in production due to the COVID-19 pandemic, during the historical three-year period proposed for use in determining the NO_x source cap. Also, commenters expressed concern that the proposed daily emissions cap limit originated as a local or regional limit for a single county and would not be appropriate for national application without further evaluation taking into account the specific characteristics of cement kilns in other states. One commenter suggested more stringent emissions limits than those the EPA had proposed for individual kiln types.

Response: The EPA is not finalizing the proposed daily source cap limit as the Agency agrees with the commenters that this proposed limit would be unnecessarily restrictive and was based on a formula that did not include all kiln types. Given the unusual reduction in cement production activities due to the COVID-19 pandemic, production rates during the 2019–2021 period are not representative of cement plants activities generally. Accordingly, use of the proposed daily source cap limit would result in an artificially restrictive NO_x emissions limit for affected cement kilns, particularly when this sector operates longer hours during the spring and summer construction season. With respect to those comments supporting more stringent emissions limits than those the EPA proposed for individual kiln types, we disagree given the significant differences among different kilns in design, configuration, age, fuel capabilities, and raw material composition. The EPA finds that the

ozone season emissions limits for individual kiln types listed in Table VI.C-2 will achieve the necessary emissions reductions for purposes of eliminating significant contribution as defined in section V and is, therefore, finalizing these emissions limitations without change.

Comment: One commenter supported retirement of existing long wet kilns and replacement of these kilns with modern kilns. Other commenters opposed the phase out and retiring of these kilns, stating that many of the screened kilns have SNCR already installed and questioning whether replacement of existing long wet kilns is cost-effective. Some commenters also stated that according to EPA’s “NO_x Control Technologies for the Cement Industry, Final Report,” SNCR is not an appropriate NO_x control technique for long wet kilns.

Response: The EPA appreciates the challenges identified by commenters, such as site-specific technical evaluation and review and significant capital investment associated with undertaking kiln conversions or to install new kilns and is not finalizing any requirements to replace existing long wet kilns in this rule.

Comment: Several commenters expressed concern about the supply chain issues relevant to the procurement, design, construction, and installation of control devices, as well as securing related contracts, for the cement industry, particularly when cement sources will be competing with the EGU and other industrial sectors for similar services. One commenter stated that many preheater/precalsiner kilns are already equipped with SNCR and that one facility not equipped with SNCR is already meeting NO_x emissions levels of 1.95 lb/ton of clinker or less. The commenter stated that the EPA should revise its assessment of potential NO_x reductions and cost estimates by accurately accounting for existing operating efficiencies and control devices at cement kilns.

Response: The EPA’s response to comments on the time needed for installation of controls for non-EGU

sources is provided in section VI.A. Regarding the comment that certain facilities may already have SNCR control technology installed, we recognize that many sources throughout the EGU sector and non-EGU industries covered by this rule may already be achieving enforceable emissions performance commensurate with the requirements of this action. This is entirely consistent with the logic of our 4-step interstate transport framework, which is designed to bring all covered sources within the region of linked upwind states up to a uniform level of NO_x emissions performance during the ozone season. *See EME Homer City*, 572 U.S. at 519. Sources that are already achieving that level of performance will face relatively limited compliance costs associated with this rule.

Compliance Assurance Requirements

The EPA received no comments on the proposed test methods and procedures provisions for the cement industry. Therefore, we are finalizing the proposed test methods and procedures for affected cement kilns without change.

Comment: Commenters generally supported requiring performance testing or installation of CEMS on affected cement kilns. Some commenters suggested that no performance testing should be required and others suggested that performance testing should only be required when a title V permit is due for renewal (every 5 years). One commenter suggested requiring sources to conduct stack tests during the ozone season.

Response: Affected kilns that operate a NO_x CEMS may use CEMS data consistent with the requirements of 40 CFR 60.13 in lieu of performance tests to demonstrate compliance with the requirements of this final rule. For affected kilns subject to this final rule that do not employ NO_x CEMS, the EPA is adjusting the performance testing frequency and requiring kilns to conduct a performance test on an annual basis during a given calendar

year.³⁸⁶ The EPA finds that annual performance testing and recordkeeping of cement production and fuel consumption during the ozone season will assure compliance with the emissions limits during the ozone season (May through September) each year for purposes of this rule. The required annual performance test may be performed at any time during the calendar year. However, where sources are able to do so, we recommend conducting a stack test in the period relatively soon before the start of the ozone season. This would provide the greatest assurance that the emissions control systems are working as intended and the applicable emissions limit will be met when the ozone season starts.

Comment: One commenter stated that CEMS has been used successfully at its facility. Another commenter explained that the inside of a cement kiln is an extremely challenging environment for making any kind of continuous measurement as temperatures are high, and there is a lot of dust and tumbling clinker can damage in situ measuring instruments.

Response: The majority of cement kilns in the United States are already equipped with CEMS. However, in response to commenters concerns regarding the installation of CEMS, the EPA is finalizing alternative compliance requirements in lieu of CEMS. Owners or operators of affected emissions units without CEMS installed must conduct annual performance testing and continuous parametric monitoring to demonstrate compliance with the emissions limits in this final rule. Specifically, owners or operators of affected units without CEMS must monitor and record stack exhaust gas flow rate, hourly production rate, and stack exhaust temperature during the initial performance test and subsequent annual performance tests to assure compliance with the applicable emissions limit. The owner or operator must then continuously monitor and record those parameters to demonstrate continuous compliance with the NO_x emissions limits.

3. Iron and Steel Mills and Ferroalloy Manufacturing

Applicability

The EPA is establishing emissions control requirements for the Iron and Steel Mills and Ferroalloy Manufacturing source category that apply to reheat furnaces that directly emit or have the potential to emit 100

tpy or more of NO_x. After review of all available information received during public comment, the EPA has determined that there is sufficient information to determine that low-NO_x burners can be installed on reheat furnaces. As explained further in the Final Non-EGU Sectors TSD, the EPA identified 32 reheat furnaces with low-NO_x burners installed and has concluded that low-NO_x burners are a readily available and widely implemented emissions reduction strategy.³⁸⁷ This rule defines reheat furnaces to include all furnaces used to heat steel product—metal ingots, billets, slabs, beams, blooms and other similar products—to temperatures at which it will be suitable for deformation and further processing.

Comment: Several industry commenters requested that the EPA not include certain iron and steel emissions units—including blast furnaces, basic oxygen furnaces (BOFs), ladle and tundish preheaters, annealing furnaces, vacuum degassers, taconite kilns, coke ovens, and electric arc furnaces (EAFs)—in the final rule as proposed due to, among other things, the uniqueness of each emissions unit, various design-related challenges, and expected impossibility of successful implementation of add-on NO_x control technology. Commenters expressed concern about requirements to install SCR for all iron and steel units for which the EPA proposed emissions limits. The commenters stated that iron and steel units had not installed SCR except in a few rare instances for experimental reasons and that SCR technology was not readily available or known for the iron and steel industry, unlike the control technologies expected to be installed in other non-EGU industries. Furthermore, commenters stated that SCR had not been applied for RACT, BACT, or LAER purposes on iron and steel units.

Response: In light of the comments we received on the complex economic and, in some cases, technical challenges associated with implementation of NO_x control technologies on certain emissions units in this sector, the EPA is not finalizing the proposed emissions limits for blast furnaces, BOFs, ladle and tundish preheaters, annealing furnaces, vacuum degassers, taconite kilns, coke ovens, or EAFs.

The EPA is aware of many examples of low-NO_x technology utilized at furnaces, kilns, and other emissions units in other sectors with similar stoichiometry, including taconite kilns, blast furnace stoves, electric arc

furnaces (oxy-fuel burners), and many other examples at refineries and other large industrial facilities. The EPA anticipates that with adequate time, modeling, and optimization efforts, such NO_x reduction technology may be achievable and cost-effective for these emissions units in the Iron and Steel Mills and Ferroalloy Manufacturing sector as well. However, the data we have reviewed is insufficient at this time to support a generalized conclusion that the application of NO_x control technologies such as LNB, is currently both technically feasible and cost effective on a fleetwide basis for these emission source types in this industry. We provide a more detailed discussion of the economic and technical issues associated with implementation of NO_x control technologies on these emissions units, including information provided by commenters, in section 4 of the Final Non-EGU Sectors TSD.

Reheat furnaces are the only type of emissions unit within the Iron and Steel Mills and Ferroalloy Manufacturing industry that this final rule applies to. Low-NO_x controls (e.g., low-NO_x burners) are a demonstrated control technology that many reheat furnaces have successfully employed.

Comment: One commenter claimed that the proposed definition of “reheat furnaces” is overly vague and requested that the EPA amend the definition. Specifically, the commenter asserted that the EPA’s proposed definition does not indicate what counts as “steel product” and whether this includes only products that have already been manufactured into some form before being introduced to a reheat furnace, or whether it also includes steel that has never left the original production process, such as hot steel coming directly from a connected casting process which has not yet been formed into a definitive product. The commenter referenced the definition of reheat furnaces in Ohio’s RACT regulations as an example to consider.

Response: In response to these comments, the EPA is finalizing a definition of reheat furnaces that is consistent with the definition in Ohio’s NO_x RACT regulations. See Ohio Admin. Code 3745–110–01(b)(35) (March 25, 2022). Specifically, the EPA is defining reheat furnaces to mean “all furnaces used to heat steel product, including metal ingots, billets, slabs, beams, blooms and other similar products, to temperatures at which it will be suitable for deformation and further processing.”

³⁸⁶ 40 CFR 63.11237 “Calendar year” defined as the period between January 1 and December 31, inclusive, for a given year.

³⁸⁷ See Final Non-EGU Sectors TSD, Section 4.

Emissions Control Requirements, Testing, and Rationale

Based on the available information for this industry, applicable Federal and state rules, and active air permits or enforceable orders issued to affected facilities in the iron and steel and ferroalloy manufacturing industry, the EPA is finalizing requirements for each facility with an affected reheat furnace to design, fabricate and install high-efficiency low-NO_x burners designed to reduce NO_x emissions from pre-installation emissions rates by at least 40 percent by volume, and to conduct performance testing before and after burner installation to set emissions limits and verify emissions reductions from pre-installation emissions rates. Each low-NO_x burner shall be designed to achieve at least 40 percent NO_x reduction from existing reheat furnace exhaust emissions rates. Each facility with an affected reheat furnace shall, within 60 days of conclusion of the post-installation performance test, submit testing results to the EPA to establish NO_x emissions limits over a 30-day rolling average. Each proposed emissions limit must be supported by performance test data and analysis.

In evaluating potential emissions limits for the Iron and Steel and Ferroalloy Manufacturing industry, the EPA reviewed RACT NO_x rules, NESHAP rules, air permits and related emissions tests, technical support documents, and consent decrees. These rules and source-specific requirements most commonly express emissions limits for this industry in terms of mass of pollutant emitted (pounds) per operating hour (hour) (*i.e.*, pounds of NO_x emitted per production hour), pounds per energy unit (*i.e.*, million British thermal unit (mmBtu)), or pounds of NO_x per ton of steel produced. Regulated iron and steel facilities, including facilities operating reheat furnaces in this sector, routinely monitor and keep track of production in terms of tons of steel produced per hour (heat rate) as it pertains to each facility's rate of iron and steel production. Several facilities, including Steel Dynamics, Columbia, Indiana, Cleveland-Cliffs, Cleveland, Ohio, and Cleveland-Cliffs, Burns Harbor, Indiana, are already operating various types of reheat furnaces with low-NO_x burners and achieving emissions rates as low as 0.11 lb/mmBtu of NO_x. The EPA identified at least nine reheat furnaces with a PTE greater than 100 tpy, including slab, rotary hearth, and walking beam furnaces, that have

installed low-NO_x burners and are achieving various emissions rates.³⁸⁸

Due to variations in the emissions rates that different types of reheat furnaces can achieve, the EPA is not finalizing one emissions limit for all reheat furnaces and is instead requiring the installation of low-NO_x burners or equivalent low-NO_x technology designed to achieve a minimum 40 percent reduction from baseline NO_x emission levels, together with source specific emissions limits to be set thereafter based on performance testing. Specifically, the final rule requires that each owner or operator of an affected unit submit to the EPA, within one year after the effective date of the final rule, a work plan that identifies the low-NO_x burner or alternative low-NO_x technology selected, the phased construction timeframe by which the owner or operator will design, install, and consistently operate the control device, an emissions limit reflecting the required 40 percent reduction in NO_x emission levels, and, where applicable, performance test results obtained no more than five years before the effective date of the final rule to be used as baseline emissions testing data providing the basis for the required emissions reductions. If no such data exist, then the owner or operator must perform pre-installation testing to establish baseline emissions data.

Comment: One commenter stated that the standard practice for setting NO_x limits for iron and steel sources often requires consideration of site or unit-specific issues. Similarly, another commenter stated that a single limit would not provide an adequate basis for establishing NO_x emissions limits that will universally apply to multiple, unique facilities. The same commenter stated that NO_x reduction in certain furnaces is routinely achievable by combustion controls or measures other than SCR.

Response: The EPA acknowledges the difficulty in crafting one emissions limit for multiple iron and steel facilities and units of varying size, age, and design, in light of the unique issues associated with varying unit types in this particular industry. We also acknowledge that in some cases, reheat furnaces are equipped with recently

installed, high-efficiency low-NO_x burners. Many sources throughout the EGU sector and non-EGU industries covered by this rule may already be achieving enforceable emissions performance commensurate with the requirements of this action. This is entirely consistent with the logic of our 4-step interstate transport framework, which is designed to bring all covered sources within the region of linked upwind states up to a uniform level of NO_x emissions performance during the ozone season. *See EME Homer City*, 572 U.S. at 519. Sources that are already achieving that level of performance will face relatively limited compliance costs associated with this rule.

The EPA is finalizing requirements for reheat furnaces to install high-efficiency low-NO_x burners designed to reduce NO_x emissions from pre-installation emissions rates by 40 percent by volume, and to perform pre- and post-installation performance testing at exhaust outlets to determine rate-based emissions limits for reheat furnaces in lb/hour, lb/mmBtu, or lb/ton on a rolling 30-operating day average. Owners and operators of affected units must also monitor NO_x emissions from reheat furnaces using CEMS or annual performance testing and recordkeeping and operate low-NO_x burners in accordance with work practice standards set forth in the regulatory text. Due to the many types of emissions units within the Iron and Steel Mills and Ferroalloy Manufacturing industry, and the limited information available at this time regarding NO_x control options that are achievable for these units, the EPA is finalizing requirements only for reheat furnaces at this time.

Comment: Commenters expressed concern that the proposed emissions limits identified both a 3-hour and a 30-day averaging time for the same limits and requested that the EPA clarify the averaging time in the final rule. Commenters requested that the EPA finalize limits with a 30-day averaging time consistent with the requirements for other non-EGU industries.

Response: In determining the appropriateness of 30-day rolling averaging times, the EPA initially reviewed the NESHAP for Iron and Steel Foundries codified at 40 CFR part 63, subpart EEEEE, the NESHAP for Integrated Iron and Steel manufacturing facilities codified at 40 CFR part 63, subpart FFFFF, the NESHAP for Ferroalloys Production: Ferromanganese and Silicomanganese codified at 40 CFR part 63, subpart XXX, and the NESHAP for Ferroalloys Production Facilities codified at 40 CFR part 63, subpart YYYYYY. The EPA also reviewed

³⁸⁸ Specifically, through a review of title V permits, the EPA identified reheat furnaces with low-NO_x burners installed at Steel Dynamics in Columbia City, Indiana (two furnaces), Steel Dynamics in Butler, Indiana (one furnace), Cleveland Cliffs in Burns Harbor, Indiana (four furnaces), Cleveland Cliffs in East Chicago, Indiana (one furnace), and Cleveland Cliffs in Cleveland, Ohio (one furnace). For a further discussion of the limits and information on these facilities, see the Final Non-EGU Sectors TSD.

various RACT NO_x rules from states located within the OTR, several of which have chosen to implement OTC model rules and recommendations. Based on this information and the information provided by public commenters, the EPA is requiring a 30-operating day rolling average period as the averaging timeframe for reheat furnaces. The EPA finds that a 30-operating day rolling average period provides a reasonable balance between short term (hourly or daily) and long term (annual) averaging periods, while providing the flexibility needed to address fluctuations in operations and production.

Compliance Assurance Requirements

The EPA is finalizing requirements for each owner or operator of an affected unit in the Iron and Steel Mills and Ferroalloy Manufacturing industry to use CEMS or annual performance tests and continuous parametric monitoring to determine compliance with the 30-day rolling average emissions limit during the ozone season. Facilities choosing to use CEMS must perform an initial RATA per CEMS and maintain and operate the CEMS according to the applicable performance specifications in 40 CFR part 60, appendix B. Facilities choosing to use testing and continuous parametric monitoring for compliance purposes must use the test methods and procedures in 40 CFR part 60, appendix A–4, Method 7E, or other EPA-approved (federally enforceable) test methods and procedures.

Comment: Several commenters raised concerns with the requirement to install and operate CEMS to monitor NO_x emissions. Commenters cited the high relative costs of installing CEMS, especially for smaller units with lower actual emissions, and the complexities with installing CEMS on mobile reheat furnaces. Further, commenters explained that due to the unique configuration of certain facilities, it would be impossible for a CEMS to differentiate emissions from a reheat furnace and other units, like waste heat boilers. As an alternative to CEMS, commenters requested that the EPA finalize similar monitoring and recordkeeping requirements as proposed for the Cement and Concrete Product Manufacturing industry in the proposed rule, which allow for CEMS or performance testing and recordkeeping. Commenters explained that for reheat furnaces that are natural gas-fired, emissions can be tracked by relying on vendor guarantees and emissions factors and natural gas throughput.

Response: The EPA reviewed comments received from the industry

regarding their concerns of affected units within the iron and steel mills and ferroalloy manufacturing sector being required to demonstrate compliance through CEMS. The EPA acknowledges the cost associated with the installation and maintenance of CEMS to demonstrate compliance with the finalized emissions standards for reheat furnaces. In this final rule, the EPA is revising the compliance assurance requirements to provide flexibility to owners or operators of affected units. Compliance may be demonstrated through CEMS or annual performance testing and continuous parametric monitoring to demonstrate compliance with the emissions limits in this final rule. If an affected unit does not use CEMS, the final rule requires the owner or operator to monitor and record stack exhaust gas flow rate, hourly production rate, and stack exhaust temperature during the initial performance test and subsequent annual performance tests to assure compliance with the applicable emissions limit. The owner or operator must then continuously monitor and record those parameters to demonstrate continuous compliance with the NO_x emissions limits. Affected units that operate NO_x CEMS meeting specified requirements may use CEMS data in lieu of performance testing and monitoring of operating parameters. For sources relying on annual performance tests and continuous parametric monitoring to assure compliance, the EPA is requiring that sources keep records of production and fuel usage during the ozone season to assure compliance with the emissions limits on a 30-day rolling average basis. To avoid challenges in scheduling and availability of testing firms, the annual performance test required under this final rule does not have to be performed during the ozone season. However, where sources are able to do so, we recommend conducting a stack test in the period relatively soon before the start of the ozone season. This would provide the greatest assurance that the emissions control systems are working as intended and the applicable emissions limit will be met when the ozone season starts.

4. Glass and Glass Product Manufacturing Applicability

The EPA is finalizing regulatory requirements for the Glass and Glass Product Manufacturing source category that apply to furnaces that directly emit or have a PTE of 100 tpy or more of NO_x. For this industry, the EPA is

finalizing the proposed applicability provisions without change.

Comment: One commenter requested that the applicability threshold for glass manufacturing furnaces should be based on a unit's design production capacity instead of the proposed applicability criteria (*i.e.*, units that directly emit or have the potential to emit 100 TPY or more of NO_x). The commenter stated that the production capacity for glass manufacturing furnaces is a more relevant basis for applicability and would focus the EPA analysis on cost-effective regulations.

Response: During the EPA's development of the proposed emissions limits, the EPA reviewed the applicability provisions in various state RACT NO_x rules, air permits, consent decrees, and Federal regulations applicable to glass manufacturing furnaces. Most of these applicability provisions were expressed in terms of actual emissions or PTE. Given the significant differences in the types, designs, configurations, ages, and fuel capabilities among glass furnaces, and differences in raw material compositions within the sector, the EPA finds that applicability criteria based on emissions or potential to emit are the most appropriate way to capture higher-emitting glass manufacturing furnaces that contribute NO_x emissions to downwind receptors.

Emissions Limitations and Rationale

The EPA is finalizing the proposed NO_x emissions limits for furnaces within the Glass and Glass Product Manufacturing industry, except that for flat glass manufacturing furnaces the EPA is finalizing an emissions limit slightly lower than the limit we had proposed, based on a correction to a factual error in our proposal. For further discussion of the basis for the form and level of the final emissions limits, see the proposed rule, 87 FR 20036, 20146 (April 6, 2022) (discussing EPA review of state RACT rules, NSPS, and other regulations applicable to the Glass and Glass Product Manufacturing industry). Several comments supported the EPA's effort to regulate sources within the Glass and Glass Product Manufacturing industry but also requested that the EPA establish more stringent emissions limits for this industry.

Comment: One commenter stated that NO_x emissions from the Glass and Glass Product Manufacturing industry are not currently subject to any Federal NSPS and that the industry is expected to grow in the coming years. The commenter stated that while the EPA's proposed limits on glass furnaces fell within the ranges of limits required by

various states and air districts, they fell at the weakest levels within those ranges. For example, the commenter stated that the EPA had proposed a 4.0 lb/ton NO_x emissions limit for container glass manufacturing furnaces, while state and local NO_x emissions limits for these emissions units range from 1 to 4 lb/ton. Similarly, the commenter stated that the EPA had proposed a 4.0 lb/ton NO_x emissions limit for pressed/blown glass manufacturing furnaces, while state and local NO_x emissions limits for these emissions units range from 1.36 to 4 lb/ton, and that EPA had proposed a 9.2 lb/ton NO_x emissions limit for flat glass manufacturing furnaces, while state NO_x emissions limits for these emissions units range from 5–9.2 lb/ton. The commenter urged the EPA to establish emissions limits lower than those the EPA had proposed.

Response: The EPA is finalizing the emissions limits for affected units in the glass and glass product manufacturing industry as proposed for all but flat glass manufacturing furnaces, for which the EPA is finalizing a slightly lower emissions limit to reflect a correction to a factual error in our proposal. During the EPA’s development of the proposed emissions limits, the EPA reviewed the control requirements or recommendations and related analyses in various RACT NO_x rules, air permits, Alternative Control Techniques (ACT) documents, and consent decrees to

determine the appropriate NO_x emissions limits for the different types of glass manufacturing furnaces. Based on these reviews and given the significant differences in the types, designs, configurations, ages, and fuel capabilities among glass furnaces, and differences in raw material compositions within the sector, the EPA has concluded that it is appropriate to finalize the emissions limits for this industry as proposed, except for the limit proposed for flat glass manufacturing furnaces. For flat glass manufacturing furnaces, the EPA had proposed a NO_x emissions limit of 9.2 pounds (lbs) per ton of glass pulled but is finalizing a limit of 7.0 lbs/ton of glass pulled on a 30-day rolling average basis. This is based on our review of specific state RACT NO_x regulations that contain a 9.2 lbs/ton limit averaged over a single day but contain a 7.0 lbs/ton limit over a 30-day averaging period. This change aligns the final limit for flat glass manufacturing furnaces with the correct averaging time and is consistent with both the state RACT regulations that we reviewed³⁸⁹ and our evaluation of cost-effective controls for this industry in the supporting documents for the proposed and final rule.

The EPA acknowledges that NO_x emissions from some glass manufacturing furnaces are subject to control under other regulatory programs, such as those adopted by

states to meet CAA RACT requirements, and that some of these programs have implemented more stringent emissions limits than those the EPA is finalizing in these FIPs. However, as noted in the preamble to the proposed rule and related TSD, many OTR states do not establish specific NO_x emissions limits for glass manufacturing sources.³⁹⁰ See 87 FR 20146. In addition to state RACT rules, air permits, ACT documents, and consent decrees applicable to this industry, the EPA reviewed reports and recommendations from the National Association of Clean Air Agencies (NACAA), the European Union Commission, and EPA’s Menu of Control Measures (MCM) to identify potentially available control measures for reducing NO_x emissions from the glass manufacturing industry. The EPA also reviewed permit data for existing glass manufacturing furnaces to identify control devices currently in use at these sources. Based on these reviews, we find that the final emissions limits for the Glass and Glass Product Manufacturing industry provided in Table VI.C.3–1 generally reflect a level of control that is cost-effective for the majority of the affected units and sufficient to achieve the necessary emissions reductions. The Final Non-EGU Sectors TSD provides a more detailed explanation of the basis for these emissions limits.

TABLE VI.C.3–1—SUMMARY OF FINALIZED NO_x EMISSIONS LIMITS FOR FURNACE UNIT TYPES IN GLASS AND GLASS PRODUCT MANUFACTURING

Furnace type	NO _x emissions limit (lbs/ton of glass produced, 30 operating-day rolling average)
Container Glass Manufacturing Furnace	4.0
Pressed/Blown Glass Manufacturing Furnace or Fiberglass Manufacturing Furnace	4.0
Flat Glass Manufacturing Furnace	7.0

Alternative Emissions Standards During Periods of Start-Up, Shutdown, and Idling

Comment: Numerous commenters urged the EPA to provide additional flexibilities, alternative NO_x emissions limits, or exceptions to the NO_x emissions limits for glass manufacturing furnaces during periods of startup, shutdown and idling. Commenters requested that the EPA consider excluding days with low glass pull (e.g.,

abnormally low production rate), furnace start-up days, furnace maintenance days, and malfunction days from the definition of “operating day” to allow for exclusion of these days from the calculation of an emissions unit’s 30-operating day rolling average emissions. The commenters argued that because the glass furnace temperature is much lower during these periods than they are during normal operating conditions, it

would be technologically infeasible to equip furnaces with NO_x control devices including SCR. Commenters also stated that because control equipment cannot be operated during these periods without damaging the equipment, it would be very difficult or impossible to meet the proposed NO_x limits during these periods.

Response: After review of the comments received and the EPA’s assessment of current practices within

³⁸⁹ For example, Pennsylvania’s RACT NO_x emission limits for flat glass furnaces are 7.0 lbs of NO_x per ton of glass produced on 30-day rolling average. See Title 25, Part I, Subpart C, Article III, Section 129.304, available at <https://casetext.com/>

[regulation/pennsylvania-code-rules-and-regulations/title-25-environmental-protection/part-i-department-of-environmental-protection/subpart-c-protection-of-natural-resources/article-iii-air-resources/chapter-129-standards-for-sources/](https://www.epa.gov/regulation/pennsylvania-code-rules-and-regulations/title-25-environmental-protection/part-i-department-of-environmental-protection/subpart-c-protection-of-natural-resources/article-iii-air-resources/chapter-129-standards-for-sources/)

[control-of-nox-emissions-from-glass-melting-furnaces/section-129304-emission-requirements](https://www.epa.gov/control-of-nox-emissions-from-glass-melting-furnaces/section-129304-emission-requirements).

³⁹⁰ See Proposed Non-EGU Sectors TSD at 56, EPA–HQ–OAR–2021–0668–0145.

the glass manufacturing industry, the EPA is establishing provisions for alternative work practice standards and emissions limits that may apply in lieu of the emissions limits in § 52.44(c) during periods of start-up, shutdown, and idling. The emissions limits for glass melting furnaces in § 52.44(c) do not apply during periods of start-up, shutdown, and/or idling at affected units that comply instead with the alternative requirements for start-up, shutdown, and/or idling periods specified in § 52.44(d), (e), and/or (f), respectively. The EPA has modeled these alternative requirements that apply during startup, shutdown, and idling to some extent on State RACT requirements identified by commenters.³⁹¹ These alternative work practice standards adequately address the seven criteria that the EPA has recommended states consider when establishing appropriate alternative emissions limitations for periods of startup and shutdown.³⁹² We provide a more detailed evaluation of these provisions in the TSD supporting this final rule.

Specifically, each owner or operator of an affected unit seeking to comply with alternative work practice standards in lieu of emissions limits during startup or shutdown periods must submit specific information to the Administrator no later than 30 days prior to the anticipated date of startup or shutdown. The required information is necessary to ensure that the furnace will be properly operated during the startup or shutdown period, as applicable. The final rule establishes limits on the number of days when the owner or operator may comply with alternative work practice standards in lieu of emissions limits during startup and shutdown, depending on the type of glass furnace. Additionally, the owner or operator must maintain operating records and additional documentation as necessary to demonstrate compliance with the alternative requirements during startup or shutdown periods. For startups, the owner or operator must place the emissions control system in

operation as soon as technologically feasible to minimize emissions. For shutdowns, the owner or operator must operate the emissions control system whenever technologically feasible to minimize emissions.

For periods of idling, the owner or operator of an affected unit may comply with an alternative emissions limit calculated in accordance with a specific equation to limit emissions to an amount (in pounds per day) that reflects the furnace's permitted production capacity in tons of glass produced per day. Additionally, the owner or operator must maintain operating records as necessary to demonstrate compliance with the alternative emissions limitations during idling periods. During idling, the owner or operator must operate the emissions control system to minimize emissions whenever technologically feasible.

All-Electric Glass Furnaces

The EPA solicited comment on whether it is feasible or appropriate to phase out and retire existing glass manufacturing furnaces in the affected states and replace them with more energy efficient and less emitting units like all-electric melter installations. The EPA also requested comment on the time needed to complete such a task. All-electric melters are glass melting furnaces in which all the heat required for melting is provided by electric current from electrodes submerged in the molten glass.³⁹³ The EPA received numerous comments from the glass industry regarding their concerns with replacing an existing glass manufacturing furnace with an all-electric melter. The commenters stated that various operational restrictions present within all-electric furnaces prevent these units from being implemented throughout the industry, including limited glass production output, reduced glass furnace life, and increased glass plant operating cost due to high levels of electric current usage. Based on the EPA's review of comments submitted on this issue, the EPA has decided not to establish any requirements to replace existing glass manufacturing furnaces with all-electric furnaces at this time. We provide in the following paragraphs a summary of the comments and the EPA's responses thereto.

Comment: One commenter stated that the lifetime of an all-electric glass melting furnace is only about three to five years before it must be rebricked, compared to well-maintained natural gas or hybrid furnace that may be

operated continuously for as long as fifteen to twenty years between rebricking events. The commenter also states that electric furnaces for manufacture of glass containers are limited to a maximum glass production of about 120 tons per day, which is a stark contrast to large natural gas fired glass melting furnaces, which are capable of producing over 400 tons of glass per day. The commenter also stated that the cullet percentage is greatly reduced in all-electric furnaces which increases energy consumption in the affected facility.

Response: At proposal, the EPA solicited comment on whether it is feasible or appropriate for owners or operators of existing glass manufacturing furnaces to phase out and retire their units and replace them with less emitting units like all-electric furnace installations. As explained in the Final Non-EGU Sectors TSD, over the last few decades the demand for flat, container, and pressed/blown glass has continued to grow annually. Nitrogen oxides remain one of the primary air pollutants emitted during the production and manufacturing of glass products. However, no current Federal CAA regulation controls NO_x emissions from the industry on a category-wide basis.³⁹⁴ Therefore, the glass manufacturing industry has conducted various pollution prevention and research efforts to help identify preferred techniques for the control of NO_x. Some of these studies revealed recent trends to control NO_x emissions in the glass industry, including the use of all-electric glass furnaces. We understand based on the comments received from the glass manufacturing industry that significant differences exist in the design, configuration, age, and replacement cost of glass furnaces and in the feasibility of controls and raw material compositions. These differences as well as the production limitations present with all-electric furnaces create difficulties in implementing all-electric furnaces across the industry while keeping up with glass product demands. Therefore, the EPA is not mandating any requirement for owners or operators of existing glass manufacturing furnaces to replace their units with all-electric furnaces.

Combustion Modification and Post-Combustion Modification Control Devices

According to the EPA's "Alternative Control Techniques Document—NO_x Emissions from Glass

³⁹¹ See Pennsylvania Code, Title 25, Part I, Subpart C, Article III, Sections 129.305–129.307 (effective June 19, 2010), available at <https://www.pacodeandbulletin.gov/Display/pacode?file=/secure/pacode/data/025/chapter129/chap129toc.html&d=reduce> and San Joaquin Valley Unified Air Pollution Control District, Rule 4354, "Glass Melting Furnaces," sections 5.5–5.7 (amended May 19, 2011), available at <https://www.valleyair.org/rules/currentrules/R4354%20051911.pdf>.

³⁹² See 80 FR 33840, 33914 (June 12, 2015) (identifying the EPA's recommended criteria for developing and evaluating alternative emissions limitations applicable during startup and shutdown).

³⁹³ See definitions in 40 CFR part 60, subpart CC.

³⁹⁴ See Final Non-EGU Sectors TSD.

Manufacturing.”³⁹⁵ glass manufacturing furnaces may utilize combustion modifications equivalent to low-NO_x burners and oxy-firing. At proposal, the EPA solicited comments on whether it is feasible or appropriate to require sources with existing glass manufacturing furnaces in affected states that currently utilize these combustion modifications to add or operate a post-combustion modifications control device like SNCR or SCR to further improve their NO_x removal efficiency. The EPA received numerous comments from the glass industry that detailed the differences present in glass furnace designs, operations and finished product that influenced the type of combustion modification or post-combustion modification control device that is feasible for such unit. Several commenters have requested that the EPA focus on establishing an emissions limit rather than specifying the use of a particular control technology given the significant differences across glass furnaces. As a result of the comments received, the EPA is not specifically requiring affected units to install combustion modification and post-combustion controls to meet the finalized emissions limits. The EPA is finalizing the emissions limits as proposed, which may be met with combustion modifications (e.g., low-NO_x burners, oxy-firing), process modifications (e.g., modified furnace, cullet preheat), and/or post-combustion controls (SNCR or SCR) and thus provide sources some flexibility to choose the control technology that works best for their unique circumstances.

Comment: Multiple commenters responded to EPA’s request for comments by stating it is unnecessary and unhelpful for the proposed rule to specify use of particular post-combustion control device. The commenters note that various flat glass furnaces have a variety of combustion and post-combustion control options. Each furnace is different in its design, operations, and finished product produced. The commenters state that it is more appropriate for EPA to establish an emissions limit in the proposed rule than it is for the EPA to specify use of a particular control technology.

Response: In response to these comments, the EPA is not establishing any requirements for affected units to install specific control technologies to meet the emissions limits. The EPA is

finalizing the limits as proposed to offer sources some flexibility to choose the control technology that works best for their unique circumstances.

Compliance Assurance Requirements

The EPA proposed to require owners or operators of an affected facility that is subject to the NO_x emissions standards for glass manufacturing furnaces to install, calibrate, maintain and operate a CEMS for the measurement of NO_x emissions discharged. The EPA also solicited comments on alternative monitoring systems or methods that are equivalent to CEMS to demonstrate compliance with the emissions limits. The EPA received numerous comments from the glass industry expressing concern with any requirement to use CEMS at affected units. After review of the comments received and EPA’s assessment of practices conducted within the glass manufacturing industry, the EPA is finalizing compliance assurance requirements that allow affected glass manufacturing furnaces to demonstrate compliance through annual testing or use CEMS, or similar alternative monitoring system data in lieu of a performance test. The EPA is also establishing recordkeeping provisions that require owners or operators of affected units to conduct parametric monitoring of fuel use and glass production during performance testing to assure continuous compliance on a 30-operating day rolling average.

Comment: Commenters representing the glass industry stated that a requirement to install and operate CEMS would present significant costs and technical complexities in a situation where emissions can be effectively monitored using stack testing rather than continuous monitoring. Commenters also objected to the EPA’s proposal to require CEMS together with semi-annual stack testing. Commenters stated that a requirement to both operate CEMS and conduct semi-annual testing would be unnecessary and excessive and would not provide commensurate benefit unless a facility’s emissions are near or above the proposed emissions limit. Commenters requested that owners or operators of affected units be allowed to use alternative monitoring systems, e.g., parametric emissions monitoring. The commenters stated that parametric monitoring requires less initial and ongoing manpower requirements, has lower capital and operating costs than CEMS, does not require spare parts, and is accurate over a mapped range.

Response: The EPA is establishing compliance assurance requirements that

provide flexibility to owners or operators of affected units. Compliance with the emissions limits in this final rule may be demonstrated through CEMS or via annual performance test and continuous parametric monitoring. If an affected unit does not use CEMS, the final rule requires the owner or operator to monitor and record stack exhaust gas flow rate, hourly production rate, and stack exhaust temperature during the initial performance test and subsequent annual performance tests to assure compliance with the applicable emissions limit. The owner or operator must then continuously monitor and record those parameters to demonstrate continuous compliance with the NO_x emissions limits. Affected units that operate NO_x CEMS meeting specified requirements may use CEMS data in lieu of performance testing and monitoring of operating parameters. To avoid challenges in scheduling and availability of testing firms, the annual performance test required under this final rule does not have to be performed during the ozone season.

5. Boilers at Basic Chemical Manufacturing, Petroleum and Coal Products Manufacturing, Pulp, Paper, and Paperboard Mills, Iron and Steel and Ferroalloys Manufacturing, and Metal Ore Mining facilities

Applicability

The EPA is finalizing regulatory requirements for the Iron and Steel Mills and Ferroalloy Manufacturing industry, Basic Chemical Manufacturing industry, Petroleum and Coal Products Manufacturing industry, Pulp, Paper, and Paperboard Mills industry, and the Metal Ore Mining industry that apply to boilers that have a design capacity of 100 mmBtu/hr or greater. The Non-EGU Screening Assessment memorandum developed in support of Step 3 of our proposal identified emissions from large boilers in certain industries (i.e., those projected to emit more than 100 tpy of NO_x in 2026) as having adverse impacts on downwind receptors. As discussed in the proposed rule, we developed applicability criteria for boilers based on design capacity (i.e., heat input), rather than on potential emissions, because use of a boiler design capacity of 100 mmBtu/hr reasonably approximates the 100 tpy threshold used in the Non-EGU Screening Assessment memorandum to identify impactful boilers. In this final rule, we are establishing the heat input-based applicability criteria described in our proposal, with some adjustments as explained further in this section. Additionally, we have determined that boilers meeting these applicability

³⁹⁵ EPA, Alternative Control Techniques Document—NO_x Emissions from Glass Manufacturing, EPA-453/R-94-037, June 1994.

criteria exist within the following five industries: Basic Chemical Manufacturing, Petroleum and Coal Products Manufacturing, Pulp, Paper, and Paperboard Mills, Metal Ore Mining, and Iron and Steel Mills and Ferroalloy Manufacturing.

As we explained in the proposed rule, the potential emissions from industrial boilers with a design capacity of 100 mmBtu/hr or greater burning coal, residual or distillate oil, or natural gas can equal or exceed the 100 tpy threshold that we used to identify

impactful boilers within the Non-EGU Screening Assessment memorandum. We are finalizing NO_x emissions limits that apply to boilers with design capacities of 100 mmBTU/hr or greater located at any of the five identified industries in any of the 20 covered states with non-EGU emissions reduction obligations. In response to comments on our proposed rule, however, the EPA is finalizing a low-use exemption for industrial boilers that operate less than 10 percent per year

and provisions for EPA approval of alternative emissions limits on a case-by-case basis, where specific criteria are met. Additionally, only boilers that combust, on a BTU basis, 90 percent or more of coal, residual or distillate oil, natural gas, or combinations of these fuels are subject to the requirements of these final FIPs.

The EPA has determined that boilers meeting the applicability criteria of this section exist within the five industrial sectors identified in Table VI.C.5–1:

TABLE VI.C.5—1: NON-EGU INDUSTRIES WITH LARGE BOILERS AND ASSOCIATED NAICS CODES

Industry	NAICS code
Basic Chemical Manufacturing	3251xx
Petroleum and Coal Products Manufacturing	3241xx
Pulp, Paper, and Paperboard Mills	3221xx
Iron and Steel and Ferroalloys Manufacturing	3311xx
Metal Ore Mining	2122xx

Comment: Several commenters requested that the EPA establish PTE-based applicability criteria for boilers as it had proposed to do for other non-EGU sectors and stated that using heat input as the basis for determining applicability would result in low-emitting boilers being subject to the final rule’s control requirements. Commenters stated that the EPA should provide a low-use exemption for infrequently run units because these units produce a lower amount of emissions.

Response: The EPA is finalizing applicability criteria for boilers based on boiler design capacity for a number of reasons. First, Federal emissions standards applicable to boilers³⁹⁶ and all of the state RACT rules that we reviewed contain applicability criteria based on boiler design capacity. Second, as explained in the Final Non-EGU Sectors TSD, most boilers with design capacities of 100 mmBTU/hr or greater that are fueled by coal, oil, or gas have the potential to emit 100 tpy or more of NO_x. Thus, use of a boiler design capacity of 100 mmBtu/hr for applicability purposes reasonably approximates the 100 tpy threshold used in the Non-EGU Screening Assessment memorandum to identify impactful boilers. Finally, use of a boiler’s design capacity for applicability purposes facilitates applicability determinations given that a boiler’s design capacity is, in most cases, clearly

indicated by the manufacture on the unit’s nameplate.

In response to the comments expressing concern that infrequently-operated boilers would be captured by the EPA’s proposed applicability criteria, the EPA is finalizing a low-use exemption for industrial boilers that operate less than 10 percent per year on an hourly basis, based on the three most recent years of use and no more than 20 percent in any one of the three years. Such boilers will be exempt from the emissions limits in these FIPs provided they operate less than 10 percent per year, on an hourly basis, based on the three most recent years of use and no more than 20 percent in any one of the three years, but will have recordkeeping obligations. The EPA finds it appropriate to exempt such low-use boilers from the emissions limits in this final rule because the amount of air pollution emitted from a boiler is directly related to its operational hours, and installation of controls on infrequently operated units results in reduced air quality benefits.

Comment: Commenters asked whether the EPA’s proposed emissions limits for boilers would apply to emissions units that burn fuels other than coal, residual or distillate oil, or natural gas. For example, one commenter stated that some biomass boilers start up by co-firing oil or gas and that some NO_x controls such as low-NO_x burners (LNB) cannot be used on biomass boilers. The commenter requested clarification on whether boilers burning biomass would be covered by the EPA’s proposed requirements. Other commenters noted

that some industrial boilers burn natural gas in conjunction with other gaseous fuels, such as hydrogen/methane off-gas and vent gas from various on-site processes, and may not be able to meet the EPA’s proposed 0.08 lb/mmBtu NO_x emissions limit for boilers burning natural gas. One commenter stated that it operated a boiler that burns hazardous waste and is subject to 40 CFR part 63, subpart EEE, National Emission Standards for Hazardous Air Pollutants from Hazardous Waste Combustors, and that this boiler uses natural gas for start-up and at other times to stabilize operations but also combusts other fuels such as liquid waste. The commenter asserted that such boilers should not be covered by the final rule.

Response: In recognition and consideration of comments received on our proposal, the EPA is finalizing requirements for boilers that apply only to boilers burning 90 percent or more coal, residual or distillate oil, or natural gas or combinations of these fuels on a heat-input basis. Public commenters presented information indicating that the burning of fuels other than coal, residual or distillate oil, or natural gas at levels exceeding 10 percent may interfere with the functions of the control technologies that may be necessary to meet the final rule, like SCR. The EPA does not have sufficient information at this time to conclude that units burning more than 10 percent fuels other than coal, residual or distillate oil, or natural gas can operate the necessary controls effectively and at a reasonable cost. Therefore, boilers that burn greater than 10 percent fuels other than coal, residual or distillate oil,

³⁹⁶ See, e.g., 40 CFR 60.44b (subpart Db, Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units).

natural gas, or combinations of these three fuels are not subject to the emissions limits and other requirements of this final rule.

Comment: Some commenters claimed that the EPA cannot include emissions limits for boilers that burn combinations of coal, residual or distillate oil, and natural gas, because the EPA did not propose limits for such boilers. Other commenters suggested it would be appropriate to establish emissions limits for such boilers as long as the EPA provides criteria for establishing such emissions limits.

Response: The EPA disagrees with the claim that boilers burning combinations of coal, residual or distillate oil, or natural gas cannot be covered by the final FIP because the EPA did not propose specific emissions limits for

these boilers and agrees with commenters who stated that the EPA’s proposed emissions limits can be extended to such boilers provided the EPA provides criteria for doing so. The applicability criteria in the final rule cover boilers burning combinations of coal, residual or distillate oil, or natural gas and include a methodology for determining the emissions limits for such units based on a simple formula that correlates the amount of heat input expended while burning each fuel with the corresponding emissions limit for that particular fuel. For example, a boiler with a heat input of 85 percent natural gas and 15 percent distillate oil would be subject to an emissions limit derived by multiplying the natural gas emissions limit by 0.85 and adding to that the distillate oil emissions limit

multiplied by 0.15. Thus calculated, the NO_x emissions limits for boilers burning combinations of coal, residual or distillate oil, or natural gas are consistent with the NO_x emissions limits identified in our proposed rule for each of these individual fuels.

Emissions Limitations and Rationale

The EPA is finalizing all of the proposed NO_x emissions limits for industrial boilers and adding a formula for calculating emissions limits for multi-fueled units as shown in Table VI.C.5–2. The emissions limits apply to boilers with design capacities of 100 mmBtu/hr or greater located at any of the five industries identified in Table II.A–1 within any of the 20 states covered by the non-EGU requirements of this final rule.

TABLE VI.C.5–2—NO_x EMISSIONS LIMITS FOR BOILERS >100 mmBtu/hr
[Based on a 30-day rolling average]

Unit type	Emissions limit (lbs NO _x /mmBtu)
Coal	0.20.
Residual oil	0.20.
Distillate oil	0.12.
Natural gas	0.08.
Multi-fueled unit	Limit derived by formula based on heat input contribution from each fuel.

Additional information on the EPA’s derivation of these proposed emissions rates for boilers is provided in the Final Non-EGU Sectors TSD.

Comment: Some commenters noted that many boilers are already subject to other state and Federal controls, and that programs such as RACT, NSR, BACT, NSPS, and maximum achievable control technology (MACT) are all achieving emissions reductions from boilers.

Response: The EPA acknowledges that some affected units may already be meeting the emissions limits established in this rule as a result of controls installed to comply with other regulatory programs, such as the CAA’s RACT requirements. However, emissions from the universe of boilers subject to the applicability requirements of this final rule are not being uniformly reduced by these programs to the same extent that the limits we are adopting will require, nor for the same reason, which is to mitigate the impact of emissions from upwind sources on downwind locations that are experiencing air quality problems. The EPA has determined that the limits we are finalizing in this action are readily achievable and are already required in practice in many parts of the country.

Regarding RACT controls, some of the sources covered by the final rule are not subject to RACT requirements because RACT is only applicable to sources located in ozone nonattainment areas and in the OTR, and many sources covered by the final rule are not located within such jurisdictions. Regarding sources that are subject to RACT, we note that unlike RACT requirements applicable to sources of VOCs, where a majority of such sources are covered by state RACT rules adopted to conform with uniform “presumptive” limits contained within the EPA’s Control Technique Guidelines (CTGs), in most cases presumptive NO_x emissions limits have not been established for industrial sources of this pollutant. In light of this, NO_x RACT requirements are primarily determined on a state-by-state basis and exhibit a range of stringencies as determined by each state. Additionally, RACT requirements tend to become more stringent with the passage of time as existing control options are improved, and new options become available. Thus, older RACT determinations may not be as stringent as more recent determinations made for similar equipment types. As noted in our proposal, we based our NO_x emissions limits for coal, residual or

distillate oil, and natural gas-fired industrial boilers on RACT limits that are already in place in many areas of the country.

Regarding NSR control requirements, we note that the NSR program was created by the 1977 amendments to the CAA and applies only to new or modified stationary sources. Many of the boilers covered by the applicability requirement of this final rule were initially installed or last modified prior to 1977 and have not undergone NSR analysis, such as a BACT analysis for sources located within an attainment area or a LAER analysis for sources located within nonattainment areas. Additionally, BACT and LAER determinations made many years ago are not likely to be as stringent as more recent determinations.

Regarding NSPS requirements, 40 CFR part 60, subpart Db, Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units, contains NO_x emissions limits for boilers with capacities of 100 mmBTU/hr or greater that were constructed or modified after June 19, 1984, and so boilers constructed or modified prior to that date are not subject to its requirements. Additionally, the limits for coal, residual or distillate oil, and

gas-fired units are not as stringent as more recent limits adopted by states pursuant to RACT control obligations.

Lastly, MACT controls are primarily designed to reduce emissions of hazardous air pollutants, not to reduce NO_x emissions. We anticipate the MACT program's boiler tune-up requirement should reduce NO_x emissions to some extent, but not to the extent that compliance with the limits adopted within this final rule will achieve.

Comment: One commenter noted that a 2017 OTC survey found that boilers, including those used in the paper products, chemical, and petroleum industries, are already required to achieve more stringent limits, and pointed to limits for distillate oil that are lower than what the EPA considered in developing the proposal. The commenter also noted that California's South Coast Air Quality Management District has adopted a facility-wide NO_x emissions limit of 0.03 lb/mmBtu at petroleum refineries. The commenter noted that CEMS data shows a residual oil-fired boiler at the Ravenswood Steam Plant in New York achieves an average NO_x emissions rate of 0.0716 lb NO_x/MMBtu and that CEMS data shows that a gas-fired boiler in Johnsonville, Tennessee, achieves an average NO_x emissions rate of 0.0058 lb NO_x/mmBTU. Regarding coal-fired boilers, the commenter stated that a coal boiler at the Ingredient Incorporated Argo Plant in Illinois achieves an average NO_x emissions rate of 0.1153 lb NO_x/MMBtu with selective non-catalytic control technology, and the Axiall Corporation facility in West Virginia achieves a 0.1162 lb/mmBtu using low-NO_x burner technology with overfire air. The commenter also noted that more than half of the gas-fired boilers included in the air markets program database already emit NO_x at rates below the EPA's proposed emissions rate, and that the RACT/BACT/LAER Clearinghouse (RBLC) shows more stringent limits for gas boilers than the limits the EPA proposed, with many facilities being required to meet a NO_x limit of less than 0.0400 lb/mmBtu.

Response: The EPA's intent was not to set the NO_x emissions limits for coal, residual or distillate oil, and natural gas-fired boilers to match the lowest levels required elsewhere by state or local authorities, but rather to establish limits that are commensurate with broadly applicable RACT limits currently in place in a number of states as noted within our proposal. The limits we selected were not the most stringent of the state RACT rules we reviewed but were relatively close to that value. We

did not select the most stringent limits because such limits may reflect case-specific technological and economic feasibility considerations that do not apply more broadly across the industry. Furthermore, although the EPA acknowledges that some industrial boilers powered by coal, residual or distillate oil, natural gas, or combinations of these fuels can meet very low NO_x emissions limits as noted by the commenter, it is unlikely that all such units could meet these limits given case-specific considerations such as boiler design and operation, some of which limit the types of control technology that may be available to a particular unit.

a. Coal-Fired Industrial Boilers

As we proposed, coal-fired industrial boilers subject to the applicability requirements of this section are required to meet a NO_x emissions limit of 0.2 lb/mmBtu on a 30-day rolling average basis. Various forms of combustion and post-combustion NO_x control technology exist that should enable most facilities to retrofit with equipment to meet this emissions limit. As we explained in our proposal, many states containing ozone nonattainment areas or located within the OTR have already adopted RACT emissions limits similar to or more stringent than the limits in this final rule, and most of those RACT limits apply statewide and extend to boilers located at commercial and institutional facilities, not just to boilers located in the industrial sector.

Comment: One commenter noted that the coal-fired boilers it operates already use combustion controls to reduce NO_x emissions and contended that the effectiveness of SNCR on these boilers is unknown but would likely be on the low end of the control effectiveness range because they experience variable loads, which would compromise the proper functioning of an SNCR control system. The commenter stated that the only way their coal-fired boilers would be able to comply with the EPA's proposed NO_x limit would be to install SCR. The commenter added that for coal-fired industrial boilers with a heat input rating of 100 MMBtu/hr or more, a review of the available RBLC records indicates that out of the 23 RBLC entries identified, nine units (less than half) were subject to an emissions limit at or below 0.2 lb/mmBtu, and eight of these nine units were equipped with SNCR. The commenter stated that based on a review of the available data in the RBLC and given the technical difficulties and low control efficiencies when applying SNCR to swing boilers, the EPA's proposed limit for coal firing does not

appear achievable for industrial coal-fired boilers that experience load swings unless SCR is installed. Other commenters stated that while there have been recent advancements in SNCR technology, such as the setting up of multiple injection grids and the addition of sophisticated CEMs-based feedback loops, implementing SNCR on industrial load-following boilers continues to pose several technical challenges, including lack of achievement of optimal temperature range for the reduction reactions to successfully complete, and inadequate reagent dispersion in the injection region due to boiler design which can lead to significant amounts of unreacted ammonia exhausted to the atmosphere (*i.e.*, large ammonia slip). The commenter noted that at least one pulp mill boiler had to abandon its SNCR system due to problems caused by poor dispersion of the reagent within the boiler, and that SNCR has yet to be successfully demonstrated for a pulp mill boiler with constant swing loads.

Response: To the extent the commenter's concerns pertain primarily to SNCR control technology, we note that the final rule does not mandate the use of any particular type of control technology and that other types of control equipment such as SCR should be examined as a means for meeting the final emissions limits. The EPA acknowledges that some coal-fired industrial boilers subject to this section of the final rule may need to install SCR to meet the NO_x emissions limits. This is reflected in our evaluation of costs for the non-EGU sector contained within the Non-EGU Screening Assessment memorandum and the cost calculations for the final rule discussed in section V and the *Memo to Docket—Non-EGU Applicability Requirements and Estimate Emissions Reductions and Costs*. We note that although the RBLC contains information on emissions limits and control technology for some units, it only provides information on a relatively small number of units subject to NO_x emissions limits and operating NO_x controls. Additionally, our final rule provides an exemption for units that operate infrequently (*i.e.*, "low-use boilers"), and also allows a facility owner or operator to submit a request for a case-by-case alternative emissions limit in cases where compliance with the emissions limit in this final rule is technically impossible or would result in extreme economic hardship. We note that non-EGU boilers share many similarities with EGU boilers, many of which already operate SCR to control NO_x emissions or will be required to

install and operate SCR systems under the requirements for EGUs contained in this final rule. Lastly, we note that information collected during the development of updates to the EPA's MACT requirements for industrial, commercial, and institutional (ICI) boilers indicates that over 150 ICI boilers have installed SCR control systems to reduce their NO_x emissions. This information is available in the docket for this final rule.

All affected units must install and operate NO_x control equipment as necessary to meet the applicable emissions limits in the final rule, except that if the owner or operator requests, and the EPA approves, a case-by-case emissions limit based on a showing of technical impossibility or extreme economic hardship, the affected unit would be required to comply with the EPA-approved case-by-case emissions limit instead.

b. Residual or Distillate Oil-Fired Industrial Boilers

Most oil-fired boilers are fueled by either residual (heavy) oil or distillate (light) oil. We proposed a NO_x emissions limit of 0.2 lb/mmBtu³⁹⁷ for residual oil-fired boilers and proposed a NO_x emissions limit of 0.12 lb/mmBtu for distillate oil-fired boilers. We are finalizing both limits as proposed, based on a 30-day rolling average. As with coal-fired industrial boilers, a number of combustion and post-combustion NO_x control technologies exist that should generally enable facilities meeting the applicability criteria of this section to meet these emissions limits, and the Final Non-EGU Sectors TSD identifies numerous states that have already adopted emissions limits similar to the limits in this final rule. There are relatively few boilers fueled by residual or distillate oil within the industries affected by this final rule that meet the applicability criteria of this section, and we received relatively few comments regarding our proposed emissions limits for them.

c. Natural Gas-Fired Industrial Boilers

We proposed a NO_x emissions limit of 0.08 lb/mmBtu based on a 30-day rolling average for natural gas-fired boilers meeting the applicability criteria of this section, and we are finalizing this emissions limit and averaging time as proposed. As explained in our proposal,

³⁹⁷ Section 52.45(c) of the regulatory text in our proposed rule identified a proposed emissions limit of 0.15 lb/mmBtu for residual oil-fired boilers, but the emissions limit that we intended to propose for this equipment and discussed both in the preamble to the proposed rule and in the TSD supporting the proposed rule was 0.20 lb/mmBtu.

numerous combustion and post-combustion NO_x control technologies exist that should generally enable facilities meeting the applicability criteria of this section to meet this emissions limit. Additionally, many states have already adopted emissions limits similar to the emissions limit in this final rule, and some natural gas-fired industrial boilers may be able to meet the 0.08 lb/mmBtu emissions limit by modifying existing NO_x control equipment installed to meet the requirements in 40 CFR 60.44b (subpart Db of 40 CFR part 60, Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units), which already requires that natural gas-fired units meet a NO_x emissions limit of between 0.1 to 0.2 lbs/MMBtu.

Compliance Assurance Requirements

We proposed compliance provisions for boilers subject to the requirements of this section similar to the emissions monitoring requirements found in 40 CFR 60.45 (subpart D of 40 CFR part 60, Standards of Performance for Fossil-Fuel-Fired Steam Generators). Those requirements include, among other provisions, the performance of an initial compliance test and installation of a CEMS unless the initial performance test indicates the unit's emissions rate is 70 percent or less of the emissions limit in this final rule. We received a number of comments on this portion of our proposal and provide responses to some of these comments in the following paragraphs. Our full responses to comments are provided in the response to comments document included in the docket for this action.

Comment: A number of commenters stated that CEMS monitoring is too expensive and unnecessary for ensuring compliance with the emissions limits for boilers and requested that alternative monitoring techniques be allowed.

Response: The EPA acknowledges that the installation and operation of CEMS systems is more expensive than other monitoring techniques and may not be necessary for smaller sized boilers that typically produce less emissions than larger ones. In response to these comments, we have modified the monitoring requirements in the final rule such that boilers rated with heat-input capacities less than 250 mmBTU/hr can demonstrate compliance by conducting an annual stack test as an alternative to monitoring using a CEMS system and by complying with the provisions of a monitoring plan meeting specific criteria that enables the facility owner or operator to demonstrate continuous compliance with the emissions limits of this final rule.

Comment: One commenter stated that the proposed reporting obligations require the submittal of excess emissions reports, continuous monitoring, and quarterly emissions reports. The commenter suggested that since the NO_x emissions standards only apply during the ozone season (May 1–September 30), the reporting requirements should only apply during the second and third quarters of the year and should require that only emissions and monitoring data from this time period be included in these reports.

Response: In response to these comments, the EPA is finalizing recordkeeping, monitoring, and reporting requirements that are designed to ensure compliance with the applicable emissions limits only during the ozone season. Additionally, the final rule requires annual reports rather than the proposed quarterly reports as annual reports are adequate to determine compliance with the emissions limits during the ozone season.

Comment: A number of commenters stated that some of their boilers that may potentially be subject to a final FIP already have a NO_x CEMS installed and requested that the EPA clarify whether a 30-day initial compliance test is required in such cases.

Response: The EPA's final rule provides that in instances where a boiler meeting the applicability requirements of this section has already installed a NO_x CEMS that meets the requirements for such equipment located within 40 CFR 60.13 or 40 CFR part 75, Continuous Emissions Monitoring, pursuant to a federally enforceable requirement, a 30-day initial compliance test is not required.

Comment: One commenter stated that § 52.45(d) of the EPA's proposed rule included requirements to complete an initial 30-day compliance test within 90 days of installing pollution control equipment but did not specify whether the test must be complete prior to the May 1, 2026, ozone season or by some later date.

Response: In response to this comment, the EPA is finalizing provisions requiring that initial compliance tests occur prior to the May 1, 2026 compliance date.

6. Municipal Waste Combustors Applicability

The EPA is finalizing regulatory requirements that apply to municipal solid waste combustors located in a state subject to the non-EGU requirements of this final rule (*i.e.*, the 20 states with linkages that persist in 2026 as identified in section II.B) and

that combust greater than or equal to 250 tons per day of municipal solid waste (“affected units”). See 40 CFR 52.46(d) for guidelines on calculating municipal waste combustor unit capacity. This applicability threshold was supported by commenters and is consistent with the applicability criteria in 40 CFR part 60, subpart Eb, Standards of Performance for New Stationary Sources and Emission Guidelines for Existing Sources: Large Municipal Waste Combustors. State RACT rules for MWCs and the OTC MWC report similarly define large MWC units as units with a combustion capacity greater than or equal to 250 tons per day.

Across the 20 states subject to the non-EGU requirements, this applicability threshold captures 28 MWC facilities with a total of 80 affected units. The identified affected units include mass burn waterwall units, mass burn rotary waterwall units, refuse derived fuel (RDF) units, and one CLEERGAS™ (“Covanta Low Emissions Energy Recovery Gasification”) modular system.³⁹⁸ The EPA analyzed actual emissions from the facilities captured by this threshold and found that on average, a unit with a design capacity of 250 tons per day has a PTE of approximately 138 tons per year,³⁹⁹ which is similar to the PTE threshold applied to other non-EGU sources under this rulemaking.

Emissions Limitations and Rationale

Based on the available information for this industry, including information provided during the public comment period, the OTC MWC Report, a review of State and local RACT rules that apply to MWCs, and active air permits issued to MWCs, the EPA is finalizing the following emissions limits for municipal solid waste combustors.

TABLE VI.C.6–1—NO_x EMISSIONS LIMITS FOR LARGE MUNICIPAL WASTE COMBUSTORS

NO _x Limit (ppmvd) corrected to 7 percent oxygen	Averaging period
110	24-hour.
105	30-day.

At proposal, the EPA noted that the NO_x limits for large MWCs constructed on or before September 20, 1994 under NSPS subpart Cb are found within Tables 1 and 2 of 40 CFR 60.39b and

³⁹⁸ See the Final Non-EGU Sectors TSD for additional information on this inventory.

³⁹⁹ See the Final Non-EGU Sectors TSD for additional information on the calculation of PTE for large MWCs.

range from 165 to 250 ppm depending on the combustor design type. The NO_x limits for large MWCs constructed after September 20, 1994 or for which modification or reconstruction is commenced after June 19, 1996 under NSPS subpart Eb are found at 40 CFR 60.52b(d) and are 180 ppm during a unit’s first year of operation and 150 ppm afterwards, applicable across all combustor types. These limits correspond to NO_x emissions rates of 0.31 and 0.26 lb/mmBtu, respectively. In reviewing active air permits for MWCs, the EPA found that most MWCs are meeting emissions limits similar to those reflected in the applicable NSPS.⁴⁰⁰

The EPA also cited the OTC’s MWC report that evaluated the emissions reduction potential of large MWCs located in the OTR from two different control levels, one based on a NO_x concentration of 105 to 110 ppm, and another based on a limit of 130 ppm. The OTC MWC report found that a control level of 105 ppmvd on a 30-day rolling average basis and a 110 ppmvd on a 24-hour block averaging period would reduce NO_x emissions from MWCs by approximately 7,300 tons annually, and that a limit of 130 ppmvd on a 30 day-average could achieve a 4,000 ton reduction. The OTR MWC Report noted that at the time of publication, eight MWC units were already subject to permit limits of 110 ppm, seven in Virginia, and one in Florida. In consideration of control costs, the report cited multiple studies evaluating MWCs similar in design to the large MWCs in the OTR and found NO_x reductions could be achieved at costs ranging from \$2,900 to \$6,600 per ton of NO_x reduced.

To further inform the EPA’s consideration of emissions limits for MWCs, the EPA requested comment on the emissions limit and averaging time MWCs should be required to meet, and specifically whether the EPA should adopt emissions rates of 105 ppmvd on a 30-day rolling averaging basis and 110 ppmvd on a 24-hour block averaging basis.

Comment: The agency received several comments regarding emissions limits and averaging time for MWCs. Many commenters asserted that the EPA should set a 24-hour emissions limit no higher than 110 ppm, noting that recent studies have shown that there are a variety of technologies that can help a wide range of MWC types achieve this limit at costs that are significantly below the \$7,500/ton cost effectiveness

⁴⁰⁰ For further discussion of the permits reviewed, see the Final Non-EGU Sectors TSD.

threshold that the EPA identified at proposal. Some commenters confirmed the accuracy of the OTC workgroup’s estimated cost of controls for reducing NO_x emissions from MWCs of \$2,900 to \$6,600 while others stated that the cost of controls is well below \$7,500. One commenter asserted that the EPA should set a 24-hour NO_x emissions limit of 50 ppmvd for MWCs, which could be achieved by the installation of SCR technology. Alternatively, the commenters stated that the EPA should set a 24-hour emissions limit no higher than 110 ppm based on less effective, though still widely available, control technology. Although some commenters stated that MWCs should not be included in the rulemaking, no commenters specifically identified units or categories of units that could not achieve emissions limits of 105 ppmvd on a 30-day rolling averaging basis and 110 ppmvd on a 24-hour block averaging basis.

Response: The EPA recognizes that there have been instances where MWCs have installed SCR and achieved emissions rates of 50 ppmvd on a 24-hr averaging basis and 45 ppmvd on a 30-day rolling averaging basis with cost effectiveness estimates around \$10,296/ton to \$12,779/ton of NO_x reduced. Given uncertainties pertaining to whether SCR can be installed on all types of MWCs, the EPA has decided not to establish emissions limits as low as 50 ppmvd for MWCs using SCR at this time. However, as generally supported by most commenters, the EPA is finalizing emissions limits of 105 ppmvd at 7 percent oxygen (O₂) on a 30-day rolling average and 110 ppmvd at 7 percent O₂ on a 24-hour block average that apply at all times except during periods of startup and shutdown. The EPA recognizes that the final emissions limits for steady-state operations cannot be achieved during periods of startup, shutdown, and malfunction. This is primarily due to the fact that during periods of startup and shutdown, additional ambient air is introduced into the units, resulting in higher oxygen concentrations. Therefore, the EPA is finalizing provisions applicable during periods of startup and shutdown that do not require correction of CEMS data to 7 percent oxygen but do require that such data be measured at stack oxygen content. This approach is consistent with EPA regulations applicable during startup and shutdown periods for other solid-waste incinerators under the NSPS for Commercial and Industrial Solid Waste Incineration Units. See 40 CFR part 60, subparts CCCC and DDDD.

Information received from public commenters generally aligned with the results from studies showing that the emissions limits of 105 ppmvd on a 30-day rolling averaging basis and 110 ppmvd on a 24-hour block averaging basis can be reached using ASNCR or low NO_x technology in addition to SNCR.⁴⁰¹ The EPA recognizes that not all units can implement low NO_x technology, including those using Aerial grate technology, those operating RFD units, and those with rotary combustor units. Of the 80 affected MWC units that the EPA identified, nine units across two facilities are classified as rotary combustors, four units at a single facility are classified as RDF, and no units captured are classified as using Aerial grate technology. One affected unit is classified as CLEERGAS gasification while the remaining 64 affected units are classified as mass burn waterwall combustors, which have not been explicitly identified as units unable to install low NO_x technology. For those units unable to install low NO_x technology or SNCR, the EPA has identified ASCNR as an alternative control technology that has been shown to enable units to achieve emissions limits of 105 ppmvd on a 30-day rolling averaging basis and 110 ppmvd on a 24-hour block averaging basis, either as a new retrofit technology or as a significant upgrade to existing SNCR. The EPA finds that the availability of ASNCR or SNCR and low NO_x burners provides sufficient flexibility for MWCs to meet the emissions limits in the final rule, especially considering 74 of the 80 affected units already have SNCR installed. Although there is uncertainty on the cost effectiveness of ASNCR for achieving significant NO_x reductions in small MWCs, small MWCs that combust less than 250 tons per day of municipal solid waste are not included in this rulemaking.

While commenters noted discrepancies across cost effectiveness values for specific types of control technology, no commenters specifically indicated that emissions control technology could not be cost effectively installed on large MWCs to achieve an emissions limit of 105 ppmvd on a 30-day rolling averaging basis and 110 ppmvd on a 24-hour block averaging

⁴⁰¹ The only demonstrated use of low NO_x technology in addition to SNCR at MWC facilities is at Covanta facilities using Covanta's proprietary low NO_x combustion system (LNTM). For the purpose of this rule, EPA is assuming Covanta facilities will take advantage of this technology and others will use ASNCR. However, other iterations of low NO_x technology could become available, or facilities could work with Covanta to apply this technology to their units.

basis. Studies show that these limits can be achieved through a variety of emissions controls, including ASNCR and the addition of low NO_x technology to existing SNCR.⁴⁰² Of the 80 MWC units subject to this rule, 55 units already have SNCR installed, 16 units already have SNCR and low NO_x technology installed, and three units already have ASNCR installed. Applying the cost values provided in the OTC's MWC report to the MWC inventory in section 7 of the Final Non-EGU Sectors TSD, the estimated weighted average cost effectiveness of applying advanced SNCR to units with and without existing SNCR and adding low NO_x technology to eligible units with SNCR was found to be approximately \$7,929.02/ton.⁴⁰³ This value is in line with the control technology costs for other non-EGU sectors and the EGU costs associated with this final rule.

Compliance Assurance Requirements

In this final rule, the EPA is establishing compliance requirements for MWCs similar to the NSPS requirements for large MWCs under 40 CFR part 60, subpart Eb. Those requirements include, among other provisions, the performance of an initial performance test and installation of a CEMS. At proposal, the EPA requested comment on whether it would be appropriate to rely on existing testing, monitoring, recordkeeping, and reporting requirements for MWCs under applicable NSPS or other requirements.

Comment: Some commenters noted that all large MWCs are already required to use CEMS to demonstrate compliance with NO_x limits under the NSPS program. These commenters asserted that the EPA should improve electronic reporting requirements beyond current requirements in the NSPS. The commenters suggested that an owner or operator of an MWC subject to a limit

⁴⁰² See OTC MWC Report at 6–7; Trinity Consultants, *Project Report Covanta Alexandria/ Arlington, Inc., Reasonably Available Control Technology Determination for NO_x* (September 2017); Trinity Consultants, *Project Report Covanta Fairfax, Inc., Reasonably Available Control Technology Determination for NO_x* (September 2017); Babcock Power Environmental, *Waste to Energy NO_x Feasibility Study*, Prepared for: Wheelabrator Technologies Baltimore Waste to Energy Facility Baltimore, MD (February 20, 2020); White, M., Goff, S., Deduck, S., Gohlke, O., *New Process for Achieving Very Low NO_x, Proceedings of the 17th Annual North American Waste-to-Energy Conference, NAWTEC17* (May 2009); Letter from the State of New Jersey to Michael Klein, In Reference to Covanta Energy Group, Inc. Essex County Resource Recovery Facility, Newark Annual Stack Test Program (March 14, 2019).

⁴⁰³ See Final Non-EGU Sectors TSD for more information on these cost effectiveness estimates were generated.

under the final rule should be required to report NO_x CEMS data electronically at least annually to the EPA's CEDRI and any other database that the EPA will utilize when considering revisions to the NSPS for large MWCs. The commenters asserted that MWC operators should be required to report NO_x CEMS data to the EPA's Clean Air Markets database, to allow the public access to MWC CEMS data on a large scale for the first time.

Response: The EPA is finalizing provisions that require MWCs subject to the requirements of this section to install, calibrate, maintain, and operate a CEMS for the measurement of NO_x emissions discharged into the atmosphere from the affected facility. This is consistent with NSPS requirements for large MWCs under 40 CFR part 60, subparts Ea and Eb, and state RACT rules that are applicable to MWCs in many of the states covered under this rulemaking.⁴⁰⁴ Additionally, each emissions unit will be required to conduct an initial performance test. With regard to electronic reporting, the final rule requires performance tests and reports, including CEMS data, to be submitted to CEDRI, as required for all non-EGU industries covered by this final rule.

D. Submitting a SIP

A state may submit a SIP at any time to address CAA requirements that are covered by a FIP, and if the EPA approves the SIP it would replace the FIP, in whole or in part, as appropriate. As discussed in this section, states may opt for one of several alternatives that the EPA has provided to take over all or portions of the FIP. However, as discussed in greater detail further in this section, the EPA also recognizes that states retain the discretion to develop SIPs to replace a FIP under approaches that differ from those the EPA has finalized.

The EPA has established certain specialized provisions for replacing FIPs with SIPs within all the CSAPR trading programs, including the use of so-called "abbreviated SIPs" and "full SIPs," see 40 CFR 52.38(a)(4) and (5) and (b)(4), (5), (8), (9), (11), and (12); 40 CFR 52.39(e), (f), (h), and (i). For a state to remove all FIP provisions through an approved SIP revision, a state would need to address all of the required reductions addressed by the FIP for that state, *i.e.*, reductions achieved through both EGU control and non-EGU control,

⁴⁰⁴ For examples of RACT provisions applicable to MWCs that require CEMS, see Regulations of Connecticut State Agencies section 22a-174-22e; and Virginia Administrative Code section 5-40-6730, subsection (D).

as applicable to that state. Additionally, tribes in Indian country within the geographic scope of this rule may elect to work with EPA under the Tribal Authority Rule to replace the FIP for areas of Indian country, in whole or in part, with a tribal implementation plan or reasonably severable portions of a tribal implementation plan.

Under the FIPs for the 22 states whose EGUs are required to participate in the CSAPR NO_x Ozone Season Group 3 Trading Program with the modifications finalized in this rule, EPA continues to offer “abbreviated” and “full” SIP options for states. An “abbreviated SIP” allows a state to submit a SIP revision that establishes state-determined allowance allocation provisions replacing the default FIP allocation provisions but leaving the remaining FIP provisions in place. A “full SIP” allows a state to adopt a trading program meeting certain requirements that allow sources in the state to continue to use the EPA-administered trading program through an approved SIP revision, rather than a FIP. In addition, as under past CSAPR rulemakings, states have the option to adopt state-determined allowance allocations for existing units for the second control period under this rule—in this case, the 2024 control period—through streamlined SIP revisions. *See* 76 FR 48326–48332 for additional discussion of full and abbreviated SIP options; *see also* 40 CFR 52.38(b).

Comments: Some commenters alleged that by taking this action, EPA is depriving states of the ability to develop SIPs to implement good neighbor obligations for the 2015 ozone NAAQS or from choosing their own compliance strategies. Commenters also claimed that the EPA cannot require states to implement emissions reductions equivalent to the emissions control stringency that the EPA determined at Step 3 if their proposed SIPs are otherwise shown to be adequate to eliminate significant contribution. Other commenters raised concerns that the trading program enhancements for EGUs made it too uncertain what a state could develop as an approvable replacement SIP. At least one commenter argued that the EPA must give states a single, mass-based emissions budget so that they can understand how to replace the FIP with a SIP.

Response: The EPA disagrees that it is depriving States of the opportunity to replace the FIP with a SIP or preventing states from targeting alternative emissions reductions strategies that can be shown to be equivalent to the FIP. States have always possessed the authority and the opportunity to revise

their SIPs at any point. The EPA has repeatedly emphasized that states are free to develop a SIP revision to replace a transport FIP and submit that to the EPA for approval, and this remains true. *See* 87 FR 20036, 20051 (April 6, 2022); 86 FR 23054, 23062 (April 30, 2021); 81 FR 74504, 74506 (Oct. 26, 2016). In the FIP proposal, as in prior transport actions, the EPA discussed a number of ways in which states could take over or replace a FIP, *see* 87 FR 20036, 20149–51 (section VII.D: “Submitting A SIP”); *see also id.* at 20040 (noting as one purpose in proposing the FIP that “this proposal will provide states with as much information as the EPA can supply at this time to support their ability to submit SIP revisions to achieve the emissions reductions the EPA believes necessary to eliminate significant contribution”). The EPA provides further guidance on submitting SIPs in this section. If, and when, the EPA receives a SIP submission that satisfies the requirements of CAA section 110(a)(2)(D)(i)(I) and 110(l), the Agency will take action to approve those SIP submissions and withdraw the FIP.

At the outset, we note that the Agency does not anticipate revisiting its findings at Steps 1 or 2 of the transport framework. Those findings establish that the projected baseline anthropogenic emissions from these states contribute to downwind nonattainment or maintenance receptors in 2023, and, for certain states, that contribution continues through 2026. Those represent critical analytical years for downwind areas as they are the last full ozone season before the Moderate and Serious area attainment dates. Those findings, for those years, establish the basis for an upwind state’s linkage, from which we proceed to evaluate emissions control opportunities and their implementation at Steps 3 and 4.

We cannot prejudge now whether state submissions to replace the EPA’s FIP will be approvable, but we note a number of statutory and implementation considerations states should be aware of if designing a replacement SIP. We have demonstrated that the EPA’s transport FIP is adequate to eliminate significant contribution to downwind air quality problems for purposes of the 2015 ozone NAAQS, and that the FIP does not result in overcontrol. The level of reductions required by the FIP therefore provides an important benchmark for states in evaluating the equivalency of possible replacement SIPs. As discussed in more detail in this section, in order to comply with their obligation under CAA section 110(a)(2)(D)(i)(I), we generally anticipate that states seeking to replace the FIP

with a SIP that takes an alternative approach would need to establish, at a minimum, an equivalent level of emissions reduction to what the FIP requires at Step 3, and any such replacement SIP will need to comply with CAA section 110(l).

The concept of equivalency is important for the state to consider. Under CAA section 110(l), “the Administrator shall not approve a revision of a plan if the revision would interfere with any applicable requirement concerning attainment . . . or any other applicable requirement of this chapter.” Section 110(l) applies to all CAA requirements, including 110(a)(2)(D) requirements relating to interstate transport. The EPA interprets section 110(l) such that states have two main options to make a noninterference demonstration. First, the state could demonstrate that emissions reductions removed from the SIP are replaced with new control measures that achieve equivalent or greater emissions reductions. Thus, a 110(l) analysis would generally need to show that the SIP revision, or, in this case, a potential SIP submission replacing an existing FIP, will not interfere with any area’s ability to continue to attain or maintain the affected NAAQS or other CAA requirements. The EPA further has interpreted section 110(l) as requiring such substitute measures to be quantifiable, permanent, and enforceable, among other considerations. For section 110(l) purposes, “permanent” means the state cannot modify or remove the substitute measure without EPA review and approval. Second, the state could conduct air quality modeling or develop an attainment or maintenance demonstration based on the EPA’s most recent technical guidance to show that, even without the control measure or with the control measure in its modified form, significant contribution from the state would continue to be prohibited as the Act requires. As discussed further in this section, for purposes of interstate ozone transport, such an analysis entails important questions of consistency and equity among states for resolving air quality problems that the EPA would need to carefully evaluate.⁴⁰⁵

⁴⁰⁵ For instance, future circumstances in which the receptor or receptors to which a state is linked come fully into attainment or to which the upwind state’s linkage drops below 1 percent of the NAAQS would likely not, solely on those grounds, be sufficient to relax transport requirements established by the FIP or justify approving a less stringent SIP. First, the emissions reductions achieved by the FIP are part of the reason that a receptor may come into attainment or a linkage may drop below 1 percent of the NAAQS. Simply

Continued

In the EPA's experience implementing the CAA criteria pollutant program, reductions arising from the good neighbor provision have been critically important to the improvement of air quality in downwind areas struggling with attainment and maintenance of the NAAQS, and states' reliance on good neighbor FIP reductions will need to be taken into account in any replacement SIP. In order for a nonattainment area to be redesignated to attainment, the CAA requires not only that an area attain the standard, but also the Administrator must determine "that the improvement in air quality is due to permanent and enforceable reductions in emissions resulting from implementation of the applicable implementation plan and applicable Federal air pollutant control regulations and other permanent and enforceable reductions." CAA section 107(d)(3)(E)(i) and (iii). Many nonattainment areas across the country that have attained various PM_{2.5} and ozone NAAQS have done so in part due to the imposition of Federal good neighbor emissions control measures, and, per CAA section 107(d)(3)(E)(iii), states have specifically relied on the emissions reductions required by those programs in order to be redesignated to attainment. *See, e.g.*, 84 FR 8422, 8425 (March 8, 2019) (noting that "[a]t least 140 EPA final actions redesignating areas in 20 states to attainment with an ozone NAAQS or a fine particulate matter (PM_{2.5}) NAAQS—because NO_x is a precursor to PM_{2.5} as well as ozone—have relied in part on the NO_x SIP Call's emissions reductions"); *see also Sierra Club v. EPA*, 774 F.3d 383, 397–99 (7th Cir. 2014) (upholding EPA's approval of a redesignation, and specifically EPA's determination that reductions from Federal good neighbor transport trading programs could reasonably be

removing emissions control requirements the moment this occurs is illogical, since those reductions are part of the solution by which the attaining air quality was achieved or the linkage was resolved. *See* CAA section 107(d)(3)(E)(iii) (areas cannot be redesignated unless based on permanent and enforceable reductions); *see also Wisconsin*, 938 F.3d at 324–25 (explaining that upwind states are held to a contribution standard, not a but-for causation standard and thus cannot escape good neighbor obligations on the basis that other emissions "cause" the NAAQS to be exceeded). There is a risk of inconsistency and inequity in removing any requirements in this manner in that any increase in emissions that could occur in one upwind state would likely need to be reviewed in relation to the obligations other upwind states would continue to meet. Further, any such relaxation in upwind state requirements could then unreasonably shift the burden for maintaining air quality onto the downwind states where receptors are located. These issues may entail complex state- or case-specific analyses that would need to be evaluated at the time such a SIP revision is submitted; these issues are not ripe for resolution in this action.

considered "permanent and enforceable" under the statute); *Sierra Club v. EPA*, 793 F.3d 656, 665–68 (6th Cir. 2015) (same). States seeking area redesignations are also required under CAA section 107(d)(3)(E)(iv) to develop revisions to their state implementation plans that provide for maintenance of the NAAQS. In so doing, states develop air quality modeling, in which they project future air quality based on emissions inputs that account for enforceable emissions reductions, or states project emissions in the future relative to emissions in an attainment year, showing that the future emissions (which, again, account for on-the-books, enforceable emissions limits) do not exceed emissions in the baseline attainment year. *See* "Procedures for Processing Requests to Redesignate Areas to Attainment," Memo from John Calcagni to EPA Regions, September 4, 1992, at 9. Reductions required by Federal good neighbor programs may therefore also be relied upon by states seeking area redesignations in the context of how states demonstrate that areas will maintain the NAAQS.

We anticipate that air quality in areas struggling to attain and maintain the 2015 ozone NAAQS will improve due to the emissions reductions required by EPA's FIP. We also anticipate that, consistent with EPA's historical experience implementing the NAAQS and acting on state requests for nonattainment area redesignations, emissions reductions associated with EPA's transport FIP for the 2015 ozone NAAQS are likely to be a critical component in those requests for redesignation. Where states have relied and are relying on the FIP's reductions in order to attain and maintain the NAAQS, EPA will look very critically at any replacement SIP that appears to fall short of equivalent emissions reductions—in terms of the level of reductions or the permanence of those reductions.

Finally, we disagree with commenters that the absence of fixed, mass-based emissions budgets for each state make it impossible to replace the FIP with an equivalent SIP. In the case of the trading program enhancements for EGUs, the EPA recognizes that the dynamic budgeting methodology will generally function to impose a continuous incentive on relevant EGUs to continue to implement the emissions control strategies determined at Step 3. Further, the backstop rate and banking recalibration enhancements also are designed to ensure that EGUs implement emissions controls consistent with Step 3 determinations on a continuous basis throughout each

ozone season. As explained in section V.D.4 of this document, these aspects of the trading program do not in themselves introduce an overcontrol concern. Nonetheless, consistent with the more general principles discussed in this section with respect to the potential bases on which states may replace the FIP with SIPs, we reserve judgment at this time on whether some future demonstration could successfully establish that revision of the FIP or its replacement with a SIP could be acceptable even if the way that significant contribution is eliminated is through means that differ from the trading program enhancements included for EGUs in this action. As discussed further in this section, a state may choose to withdraw its EGUs from the trading program and instead subject those EGUs to daily emissions rates commensurate with installation and optimization of state-of-the-art combustion and post-combustion controls as the EPA determined at Step 3. Likewise, states are free to explore an alternative set of emissions controls on non-EGU industrial sources (or other sources in the state), so long as they can demonstrate that an equivalent amount of emissions is eliminated. In any case, we need not resolve these questions here. The EPA, in promulgating a FIP, is not obligated to identify each way a state could replace it with a SIP revision. Several options are discussed further in this section, and, as always, EPA Regional Offices will work closely with states who wish to explore these options or other alternatives.

1. SIP Option To Modify Allocations for 2024 Under EGU Trading Program

As with the start of past CSAPR rulemakings, the EPA is finalizing the option to allow a state to use a similar process to submit a SIP revision establishing allowance allocations for existing EGU units in the state for the second control period of the new requirements, *i.e.*, in 2024, to replace the EPA-determined default allocations. A state must submit a letter to EPA by August 4, 2023, indicating its intent to submit a complete SIP revision by September 1, 2023. The SIP would provide in an EPA-prescribed format a list of existing units within the state and their allocations for the 2024 control period. If a state does not submit a letter of intent to submit a SIP revision, the EPA-determined default allocations will be recorded by September 5, 2023. If a state submits a timely letter of intent but fails to submit a SIP revision, the EPA-determined default allocations will be recorded by September 15, 2023. If a state submits a timely letter of intent

followed by a timely SIP revision that is approved, the approved SIP allocations will be recorded by March 1, 2024.

The EPA received no comments on the proposed option to modify allowance allocations under the Group 3 trading program for EGUs for the 2024 control period through a SIP revision and is finalizing the provisions as proposed.

2. SIP Option To Modify Allocations for 2025 and Beyond Under EGU Trading Program

For the 2025 control period and later, states in the CSAPR NO_x Ozone Season Group 3 Trading Program can modify the EPA-determined default allocations with an approved SIP revision. For the 2025 control period and later, SIPs can be full or abbreviated SIPs. See 76 FR 48326–48332 for additional discussion of full and abbreviated SIP options; see also 40 CFR 52.38(b).

In this final rule, the EPA is removing the previous regulatory text defining specific options for states to expand CSAPR NO_x Ozone Season Group 3 trading program applicability to include EGUs between 15 MWe and 25 MWe or, in the case of states subject to the NO_x SIP Call, large non-EGU boilers and combustion turbines. These options for expanding trading program applicability through SIP revisions have been available to states since the start of the CSAPR trading programs for small EGUs and since the CSAPR Update for large non-EGU boilers and combustion turbines, and no state has chosen to use the SIP process for this purpose. Additionally, the EPA did not receive comment supporting these expansion options during the comment period for this rule. The EPA is finalizing a methodology for updating the affected EGU portion of the budget in this rule, and the regulatory text defining the applicability expansion to non-EGUs did not include a mechanism for updating the incremental non-EGU portion of a state's budget based on changes over time of the non-EGU fleet; therefore, continuation of the option to expand applicability to certain non-EGUs subject to the NO_x SIP Call would be inconsistent with the trading program as applied to EGUs in this rule.

However, the EPA recognizes that states may seek to include non-EGUs covered in this action in an emissions trading program, subject to important considerations to ensure equivalency in emissions reductions is maintained. While the EPA is not offering specific regulatory text to implement an option to expand the trading program applicability, a state could submit a SIP to expand the CSAPR NO_x Ozone

Season Group 3 Trading Program applicability, which the EPA would evaluate on a case-by-case basis. The SIP revision would need to address critical program elements, and include: (1) high-quality baseline data, (2) ongoing Part 75 monitoring, and (3) provisions to update the non-EGU portion of the budget to appropriately reflect changes to the fleet over time.

For states that want to modify the EPA-determined default allocations, the EPA proposed that a state could submit a SIP revision that makes changes only to that provision while relying on the FIP for the remaining provisions of the EGU trading program. This abbreviated SIP option allows states to tailor the FIP to their individual choices while maintaining the FIP-based structure of the trading program. To ensure the availability of allowance allocations for units in any Indian country within a state not covered by the state's CAA implementation planning authority, if the state chose to replace the EPA's default allocations with state-determined allocations, the EPA would continue to administer any portion of each state emissions budget reserved as a new unit set-aside or an Indian country existing unit set-aside.

The SIP submittal deadline for this type of revision is December 1, 2023, if the state intends for the SIP revision to be effective beginning with the 2025 control period. For states that submit this type of SIP revision, the deadline to submit state-determined allocations beginning with the 2025 control period under an approved SIP is June 1, 2024, and the deadline for the EPA to record those allocations is July 1, 2024. Similarly, a state can submit a SIP revision beginning with the 2026 control period and beyond by December 1, 2024, with state allocations for the 2026 control period due June 1, 2025, and EPA recordation of the allocations by July 1, 2025.

The EPA received no comment on the option to replace certain allowance allocation provisions under the Group 3 trading program for EGUs for control periods in 2025 and later years through a SIP revision and is finalizing the provisions generally as proposed, with the exception that any potential expansion of trading program applicability under a SIP revision would be evaluated on a case-by-case basis.

3. SIP Option To Replace the Federal EGU Trading Program With an Integrated State EGU Trading Program

For the 2025 control period and later, states in the CSAPR NO_x Ozone Season Group 3 Trading Program can choose to replace the Federal EGU trading

program with an integrated State EGU trading program through an approved SIP revision. Under this option, a state can submit a SIP revision that makes changes only to modify the EPA-determined default allocations and that adopts identical provisions for the remaining portions of the EGU trading program. This SIP option allows states to replace these FIP provisions with state-based SIP provisions while continuing participation in the larger regional trading program. As with the abbreviated SIP option discussed previously, to ensure the availability of allowance allocations for units in any Indian country within a state not covered by the state's CAA implementation planning authority, if the state chooses to replace the EPA's default allocations with state-determined allocations, the EPA would continue to administer any portion of each state emissions budget reserved as a new unit set-aside or an Indian country existing unit set-aside. Also, for the same reasons discussed with respect to the abbreviated SIP option, the EPA is removing the option for states to expand CSAPR NO_x Ozone Season Group 3 trading program applicability to include EGUs between 15 MWe and 25 MWe or, in the case of states subject to the NO_x SIP Call, large non-EGU boilers and combustion turbines.

Deadlines for this type of SIP revision are the same as the deadlines for abbreviated SIP revisions. For the SIP-based program to start with the 2025 control period, the SIP deadline is December 1, 2023, the deadline to submit state-determined allocations for the 2025 control period under an approved SIP is June 1, 2024, and the deadline for the EPA to record those allocations is July 1, 2024, and so on.

The EPA received no comment on the option to replace the Federal trading program for EGUs with an integrated state trading program for EGUs for control periods in 2025 and later years through a SIP revision and is finalizing the provisions generally as proposed, with the exception that any potential expansion of trading program applicability under a SIP revision would be evaluated on a case-by-case basis.

4. SIP Revisions That Do Not Use the Trading Program

States can submit SIP revisions to replace the FIP that achieve the necessary EGU emissions reductions but do not use the CSAPR NO_x Ozone Season Group 3 Trading Program. For a transport SIP revision that does not use the CSAPR NO_x Ozone Season Group 3 Trading Program, the EPA would evaluate the transport SIP based on the

particular control strategies selected and whether the strategies as a whole provide adequate and enforceable provisions ensuring that the necessary emissions reductions (*i.e.*, reductions equal to or greater than what the Group 3 trading program will achieve) will be achieved. To address the applicable CAA requirements, the SIP revision should include the following general elements: (1) a comprehensive baseline 2023 statewide NO_x emissions inventory (which includes existing control requirements), which should be consistent with the 2023 emissions inventory that the EPA used to calculate the required state budget in this final rule (unless the state can explain the discrepancy); (2) a list and description of control measures to satisfy the state emissions reduction obligation and a demonstration showing when each measure would be implemented to meet the 2023 and successive control periods; (3) fully-adopted state rules providing for such NO_x controls during the ozone season; (4) for EGUs greater than 25 MWe, monitoring and reporting under 40 CFR part 75, and for other units, monitoring and reporting procedures sufficient to demonstrate that sources are complying with the SIP (*see* 40 CFR part 51, subpart K (“source surveillance” requirements)); and (5) a projected inventory demonstrating that state measures along with Federal measures will achieve the necessary emissions reductions in time to meet the 2023 and successive compliance deadlines (*e.g.*, enforceable reductions commensurate with installation of SCR on coal-fired EGUs by the 2027 ozone season). The SIPs must meet procedural requirements under the Act, such as the requirements for public hearing, be adopted by the appropriate state board or authority, and establish by a practically enforceable regulation or permit(s) a schedule and date for each affected source or source category to achieve compliance. Once the state has made a SIP submission, the EPA will evaluate the submission(s) for completeness before acting on the SIP. EPA’s criteria for determining completeness of a SIP submission are codified at 40 CFR part 51, appendix V.

For further background information on considerations for replacing a FIP with a SIP, *see* the discussion in the final CSAPR rulemaking (76 FR 48326).

5. SIP Revision Requirements for Non-EGU or Industrial Source Control Requirements

EPA’s promulgation of a non-EGU transport FIP would in no way affect the ability of states to submit, for review and approval, a SIP that replaces the

requirements of the FIP with state requirements. To replace the non-EGU portion of the FIP in a state, the state’s SIP must provide adequate provisions to prohibit NO_x emissions that contribute significantly to nonattainment or interfere with maintenance of the 2015 ozone NAAQS in any other state. The state SIP submittal must demonstrate that the emissions reductions required by the SIP would continue to ensure that significant contribution from that state has been eliminated through permanent and enforceable measures. The non-EGU requirements of the FIP would remain in place in each covered state until a state’s SIP has been approved by the EPA to replace the FIP.

The most straightforward method for a state to submit a presumptively approvable SIP revision to replace the non-EGU portion of the FIPs for the state would be to provide a SIP that includes emissions limits at an equivalent or greater level of stringency than is specified for non-EGU sources meeting the applicability criteria and associated compliance assurance provisions for each of the unit types identified in section VI.C of this document.

Comment: One commenter stated that they believed EPA’s assertion in the proposal that any SIP submittal would have to achieve equal or greater reductions for non-EGUs than the FIP was unlawful. The commenter asserted that a state’s ability to replace the FIP must be tied to whether it has addressed the underlying nonattainment/maintenance concerns by reducing significant contribution from sources in the state below the significance threshold, (as opposed to whether it prohibits equivalent emissions to the FIP).

Response: The EPA recognizes that states may select emissions reductions strategies that differ from the emissions limitations included in the proposed non-EGU FIP; this is discussed in response to comments earlier in this section. For example, some states may desire to include non-EGUs in a trading program. This may be possible subject to taking into account a number of considerations as discussed earlier in this section to ensure equivalency between the different approaches. But the state must still demonstrate that the replacement SIP provides an equivalent or greater amount of emissions reductions as the proposed FIP to be presumptively approvable. The EPA anticipates that such emissions reductions strategies would have to achieve reductions equivalent to or beyond those emissions reductions already projected to occur in EPA’s

emissions projections and air quality modeling conducted at Steps 1 and 2. Such reductions must also be achieved by the 2026 ozone season.

EPA further acknowledges that a demonstration of equivalency using other control strategies is complicated by the fact that the final emissions limits for non-EGU sources are generally unit-specific and expressed in a variety of forms; comparative analysis with alternative control requirements to determine equivalency would need to take this into account. Similarly, we recognize that the emissions trading program for EGUs in this action includes a number of enhancements to ensure that the Step 3 determination of which emissions are “significant” and must be eliminated continues to be implemented over time. Although there is not a fixed, mass-based emissions budget established for each state in this action, there are other objective metrics that could guide states in developing replacement SIPs. For example, for non-EGUs, states may choose to conduct an analysis of their industrial stationary sources and present an alternative set of emissions limits applying to specific units that it believes would achieve an equivalent level of emissions reduction. States could apply cost-effectiveness thresholds for emissions control technologies that could be applied to establish that some alternative emissions control strategy results in equivalent or greater improvement at downwind receptors. The EPA anticipates that such a comparison may entail review of both baseline emissions information and growth projections between the different sets of units to ensure that a truly equivalent or greater degree of emissions reduction is achieved; additionality and emissions shifting potential may also need to be considered. We note that the CAMx policy case run for 2026 provides a benchmark for assessing the level of air quality improvement anticipated at receptors with implementation of the FIP. This data may be of use to states as part of a demonstration that a replacement SIP achieves an equivalent or greater level of air quality improvement to the FIP; however, the use of such modeling in such a demonstration would need to be more fully evaluated at the time of such a SIP revision.

In all cases, a SIP submitted by a state to replace the non-EGU components of the FIPs would very likely need to rely on permanent and practically enforceable controls measures that are included in the SIP and, once approved by the EPA, rendered federally enforceable. So-called “demonstration-

only” or “non-regulatory” SIPs would very likely be insufficient; see discussion in response to comments earlier in this section. Further, the EPA anticipates that states would bear the burden of establishing that the state’s alternative approach achieves at least an equivalent level of emissions reduction as the FIP.

E. Title V Permitting

This final rule, like CSAPR, the CSAPR Update, and the Revised CSAPR Update does not establish any permitting requirements independent of those under Title V of the CAA and the regulations implementing Title V, 40 CFR parts 70 and 71.⁴⁰⁶ All major stationary sources of air pollution and certain other sources are required to apply for title V operating permits that include emissions limitations and other conditions as necessary to ensure compliance with the applicable requirements of the CAA, including the requirements of the applicable SIP. CAA sections 502(a) and 504(a), 42 U.S.C. 7661a(a) and 7661c(a). The “applicable requirements” that must be addressed in title V permits are defined in the title V regulations (40 CFR 70.2 and 71.2 (definition of “applicable requirement”).

The EPA anticipates that, given the nature of the units subject to this final rule, most if not all of the sources at which the units are located are already subject to title V permitting requirements and already possess a title V operating permit. For sources subject to title V, the interstate transport requirements for the 2015 ozone NAAQS that are applicable to them under the FIPs finalized in this action would be “applicable requirements” under title V and therefore must be addressed in the title V permits. For example, EGU requirements concerning designated representatives, monitoring, reporting, and recordkeeping, the requirement to hold allowances covering emissions, the compliance assurance provisions, and liability, and for non-EGUs, the emissions limits and compliance requirements are, to the extent relevant to each source, “applicable requirements” that must be addressed in the permits.

Consistent with EPA’s approach under CSAPR, the CSAPR Update and the Revised CSAPR Update, the applicable requirements resulting from the FIPs generally will have to be incorporated into affected sources’ existing title V permits either pursuant

⁴⁰⁶ Part 70 addresses requirements for state title V programs, and part 71 governs the Federal title V program.

to the provisions for reopening for cause (40 CFR 70.7(f) and 71.7(f)), significant modifications (40 CFR 70.7(e)(4)) or the standard permit renewal provisions (40 CFR 70.7(c) and 71.7(c)).⁴⁰⁷ For sources newly subject to title V that are affected sources under the FIPs, the initial title V permit issued pursuant to 40 CFR 70.7(a) should address the final FIP requirements.

As was the case in the CSAPR, the CSAPR Update and the Revised CSAPR Update, the new and amended FIPs impose no independent permitting requirements and the title V permitting process will impose no additional burden on sources already required to be permitted under title V.

1. Title V Permitting Considerations for EGUs

Title V of the CAA establishes the basic requirements for state title V permitting programs, including, among other things, provisions governing permit applications, permit content, and permit revisions that address applicable requirements under final FIPs in a manner that provides the flexibility necessary to implement market-based programs such as the trading programs established in CSAPR, the CSAPR Update, the Revised CSAPR Update and this final rule. 42 U.S.C. 7661a(b); 40 CFR 70.6(a)(8) & (10); 40 CFR 71.6(a)(8) & (10).

In CSAPR, the CSAPR Update and the Revised CSAPR Update, the EPA established standard requirements governing how sources covered by those rules would comply with title V and its regulations.⁴⁰⁸ 40 CFR 97.506(d), 97.806(d) and 97.1006(d). For any new or existing sources subject to this rule, identical title V compliance provisions will apply with respect to the CSAPR NO_x Ozone Season Group 3 Trading Program. For example, the title V regulations provide that a permit issued under title V must include “[a] provision stating that no permit revision

⁴⁰⁷ A permit is reopened for cause if any new applicable requirements (such as those under a FIP) become applicable to an affected source with a remaining permit term of 3 or more years. If the remaining permit term is less than 3 years, such new applicable requirements will be added to the permit during permit renewal. See 40 CFR 70.7(f)(1)(i) and 71.7(f)(1)(i).

⁴⁰⁸ The EPA has also issued a guidance document and template that includes instructions for how to incorporate the applicable requirements into a source’s Title V permit. See Memorandum dated May 13, 2015, from Anna Marie Wood, Director, Air Quality Policy Division, and Reid P. Harvey, Director, Clean Air Market Division, EPA, to Regional Air Division Directors, Subject: “Title V Permit Guidance and Template for the Cross-State Air Pollution Rule” (“2015 Title V Guidance”), available at https://www.epa.gov/sites/default/files/2016-10/documents/csapr_title_v_permit_guidance.pdf.

shall be required under any approved . . . emissions trading and other similar programs or processes for changes that are provided for in the permit.” 40 CFR 70.6(a)(8) and 71.6(a)(8). Consistent with these provisions in the title V regulations, in CSAPR, the CSAPR Update and the Revised CSAPR Update, the EPA included a provision stating that no permit revision is necessary for the allocation, holding, deduction, or transfer of allowances. 40 CFR 97.506(d)(1), 97.806(d)(1) and 97.1006(d)(1). This provision is also included in each title V permit for an affected source. This final rule maintains the approach taken under CSAPR, the CSAPR Update and the Revised CSAPR Update that allows allowances to be traded (or allocated, held, or deducted) without a revision to the title V permit of any of the sources involved.

Similarly, this final rule would also continue to support the means by which a source in the final trading program can use the title V minor modification procedure to change its approach for monitoring and reporting emissions, in certain circumstances. Specifically, sources may use the minor modification procedure so long as the new monitoring and reporting approach is one of the prior-approved approaches under CSAPR, the CSAPR Update and the Revised CSAPR Update (*i.e.*, approaches using a continuous emissions monitoring system under subparts B and H of 40 CFR part 75, an excepted monitoring system under appendices D and E to 40 CFR part 75, a low mass emissions excepted monitoring methodology under 40 CFR 75.19, or an alternative monitoring system under subpart E of 40 CFR part 75), and the permit already includes a description of the new monitoring and reporting approach to be used. See 40 CFR 97.506(d)(2), 97.806(d)(2) and 97.1006(d)(2); 40 CFR 70.7(e)(2)(i)(B) and 71.7(e)(1)(i)(B). As described in EPA’s 2015 Title V Guidance, sources may comply with this requirement by including a table of all of the approved monitoring and reporting approaches under CSAPR, the CSAPR Update and the Revised CSAPR Update trading programs in which the source is required to participate, and the applicable requirements governing each of those approaches.⁴⁰⁹ Inclusion of such a table in a source’s title V permit therefore allows a covered unit that seeks to change or add to its chosen monitoring and recordkeeping approach to easily comply with the regulations

⁴⁰⁹ *Id.*

governing the use of the title V minor modification procedure.

Under CSAPR, the CSAPR Update and the Revised CSAPR Update, to employ a monitoring or reporting approach different from the prior-approved approaches discussed previously, unit owners and operators must submit monitoring system certification applications to the EPA establishing the monitoring and reporting approach actually to be used by the unit, or, if the owners and operators choose to employ an alternative monitoring system, to submit petitions for that alternative to the EPA. These applications and petitions are subject to the EPA review and approval to ensure consistency in monitoring and reporting among all trading program participants. EPA's responses to any petitions for alternative monitoring systems or for alternatives to specific monitoring or reporting requirements are posted on EPA's website.⁴¹⁰ The EPA maintains the same approach for the trading program in this final rule.

2. Title V Permitting Considerations for Industrial Stationary Sources

For non-EGU sources, affected sources will need to work with their local, state, or tribal permitting authority to determine if the new applicable requirements should be incorporated into their existing title V permit under the reopening for cause, significant modification, or permit renewal procedures of the approved permitting program. Title V permits for existing sources will need to be updated to include the applicable requirements of this final rule and any necessary preconstruction permits obtained in order to comply with this final rule.

F. Relationship to Other Emissions Trading and Ozone Transport Programs

1. NO_x SIP Call

Sources in states affected by both the NO_x SIP Call for the 1979 ozone NAAQS and the requirements established in this final rule for the 2015 ozone NAAQS will be required to comply with the requirements of both rules. With respect to EGUs larger than 25 MW, in this rule the EPA is requiring NO_x ozone season emissions reductions from these sources in many of the NO_x SIP Call states, and at greater stringency than required by the NO_x SIP Call, by requiring the EGUs to participate in the CSAPR NO_x Ozone Season Group 3 Trading Program. The emissions reductions required under this rule are therefore sufficient to satisfy the

⁴¹⁰ <https://www.epa.gov/airmarkets/part-75-petition-responses>.

emissions reduction requirements under the NO_x SIP Call for these large EGUs.

With respect to the large non-EGU boilers and combustion turbines that formerly participated in the NO_x Budget Trading Program under the NO_x SIP Call, the EPA provided options under both the CSAPR Update and the Revised CSAPR Update for states to address these sources' ongoing NO_x SIP Call requirements by expanding applicability of the relevant CSAPR trading programs for ozone season NO_x emissions to include the sources, and no state chose to use these options. As discussed in sections VI.D.2 and VI.D.3, in this rule the EPA is removing the previous regulatory text defining specific options for states to expand trading program applicability to include these sources and instead will evaluate any SIP revisions seeking to include these sources in the Group 3 trading program on a case-by-case basis.⁴¹¹

2. Acid Rain Program

This rule does not affect any SO₂ and NO_x requirements under the Acid Rain Program, which are established separately under 40 CFR parts 72 through 78 and will continue to apply independently of this rule's provisions. Sources subject to the Acid Rain Program will continue to be required to comply with all requirements of that program, including the requirement to hold sufficient allowances issued under the Acid Rain Program to cover their SO₂ emissions after the end of each control period.

3. Other CSAPR Trading Programs

This rule does not substantively affect any provisions of the CSAPR NO_x Annual, CSAPR SO₂ Group 1, CSAPR SO₂ Group 2, CSAPR NO_x Ozone Season Group 1, or CSAPR NO_x Ozone Season Group 2 trading programs for sources that continue to participate in those programs. Sources subject to any of the CSAPR trading programs will continue to be required to comply with all requirements of all such trading programs to which they are subject, including the requirement to hold sufficient allowances issued under the respective programs to cover emissions after the end of each control period.

The EPA also notes that where a state's good neighbor obligations with respect to the 1997 ozone NAAQS or the 2008 ozone NAAQS have previously

⁴¹¹ Only one NO_x SIP Call state—Tennessee—continues to participate in the Group 2 trading program, and the EPA has already approved other SIP provisions addressing the ongoing NO_x SIP Call obligations for Tennessee's large non-EGU boilers and combustion turbines. See 84 FR 7998 (March 6, 2019); 86 FR 12092 (March 2, 2021).

been met by participation of the state's large EGUs in the CSAPR NO_x Ozone Season Group 2 Trading Program (or earlier by the CSAPR NO_x Ozone Season Group 1 Trading Program), the EPA will deem those obligations to be satisfied by the participation of the same sources in the CSAPR NO_x Ozone Season Group 3 Trading Program. Specifically, for all states covered by the Group 3 trading program under this rule except Minnesota, Nevada, and Utah, participation of the state's EGUs in the Group 3 trading program will be deemed to satisfy not only the EGU-related portion of the state's good neighbor obligations with respect to the 2015 ozone NAAQS but also the state's good neighbor obligations with respect to the 2008 ozone NAAQS. In addition, for Alabama, Arkansas, Illinois, Indiana, Kentucky, Louisiana, Michigan, Mississippi, Missouri, Oklahoma, and Wisconsin, participation of the state's EGUs in the Group 3 trading program will also be deemed to satisfy the state's good neighbor obligations with respect to the 1997 ozone NAAQS.⁴¹²

VII. Environmental Justice Analytical Considerations and Stakeholder Outreach and Engagement

Consistent with EPA's commitment to integrating environmental justice in the agency's actions, and following the directives set forth in multiple Executive orders, the Agency has analyzed the impacts of this final rule on communities with environmental justice concerns and engaged with stakeholders representing these communities to seek input and feedback. Executive Order 12898 is discussed in section X.J of this final rule and analytical results are available in Chapter 7 of the *RIA*. This analysis is being provided for informational purposes only.

A. Introduction

Executive Order 12898 directs EPA to identify the populations of concern who are most likely to experience unequal burdens from environmental harms; specifically, minority populations, low-income populations, and indigenous peoples.⁴¹³ Additionally, Executive

⁴¹² For the remaining state transitioning from the Group 2 trading program to the Group 3 trading program under this rule—Texas—as well as the remaining states that transitioned from the Group 2 trading program to the Group 3 trading program under the Revised CSAPR Update—Maryland, New Jersey, New York, Ohio, Pennsylvania, Virginia, and West Virginia—participation of the states' EGUs in the Group 2 trading program as required by the CSAPR Update was addressing good neighbor obligations of the states with respect to only the 2008 ozone NAAQS, not the 1997 ozone NAAQS. See 81 FR 74523–74526.

⁴¹³ 59 FR 7629, February 16, 1994.

Order 13985 is intended to advance racial equity and support underserved communities through Federal Government actions.⁴¹⁴ The EPA defines environmental justice as the fair treatment and meaningful involvement of all people regardless of race, color, national origin, or income, with respect to the development, implementation, and enforcement of environmental laws, regulations, and policies. The EPA further defines the term fair treatment to mean that “no group of people should bear a disproportionate burden of environmental harms and risks, including those resulting from the negative environmental consequences of industrial, governmental, and commercial operations or programs and policies.”⁴¹⁵ In recognizing that minority and low-income populations often bear an unequal burden of environmental harms and risks, the EPA continues to consider ways of protecting them from adverse public health and environmental effects of air pollution.

B. Analytical Considerations

The EPA’s environmental justice (EJ) technical guidance⁴¹⁶ states that:

The analysis of potential EJ concerns for regulatory actions should address three questions:

1. Are there potential EJ concerns associated with environmental stressors affected by the regulatory action for population groups of concern in the baseline?
2. Are there potential EJ concerns associated with environmental stressors affected by the regulatory action for population groups of concern for the regulatory option(s) under consideration?
3. For the regulatory option(s) under consideration, are potential EJ concerns created or mitigated compared to the baseline?

To address these questions in the EPA’s first quantitative EJ analysis in the context of a transport rule, the EPA developed a unique analytical approach that considers the purpose and specifics of the final rulemaking, as well as the nature of known and potential exposures and impacts. However, due to data limitations, it is possible that our analysis failed to identify disparities that may exist, such as potential environmental justice characteristics (e.g., residence of historically red lined areas), environmental impacts (e.g., other ozone metrics), and more granular spatial resolutions (e.g., neighborhood scale) that were not evaluated.

For the final rule, we employ two types of analytics to respond to the previous three questions: proximity analyses and exposure analyses. Both types of analyses can inform whether there are potential EJ concerns for population groups of concern in the baseline (question 1).⁴¹⁷ In contrast, only the exposure analyses, which are based on future air quality modeling, can inform whether there will be potential EJ concerns after implementation of the regulatory options under consideration (question 2) and whether potential EJ concerns will be created or mitigated compared to the baseline (question 3). While the exposure analysis can respond to all three questions, several caveats should be noted. For example, the air pollutant exposure metrics are limited to those used in the benefits assessment. For ozone, that is the maximum daily 8-hour average, averaged across the April through September warm season (AS–MO3) and for PM_{2.5} that is the annual average. This ozone metric likely smooths potential daily ozone gradients and is not directly relatable to the National Ambient Air Quality Standard (NAAQS), whereas the PM_{2.5} metric is more similar to the long term PM_{2.5} standard. The air quality modeling estimates are also based on state level emissions data paired with facility-level baseline emissions, and provided at a resolution of 12km². Additionally, here we focus on air quality changes due to this final rulemaking and infer post-policy exposure burden impacts.

Exposure analytic results are provided in two formats: aggregated and distributional. The aggregated results provide an overview of potential ozone exposure differences across populations at the national- and state-levels, while the distributional results show detailed information about ozone concentration changes experienced by everyone within each population.

In Chapter 7 of the *RIA* we utilize the two types of analytics to address the three EJ questions by quantitatively evaluating: (1) the proximity of affected facilities to potentially disadvantaged populations (section 7.3); and (2) the potential for disproportionate ozone and PM_{2.5} concentrations in the baseline and concentration changes after rule implementation across different demographic groups (section 7.4). Each of these analyses depends on mutually exclusive assumptions, was performed to answer separate questions, and is

associated with unique limitations and uncertainties.

Baseline demographic proximity analyses can be relevant for identifying populations that may be exposed to local pollutants, such as NO₂ emitted from affected sources in this final rule. However, such analyses are less useful here as they do not account for the potential impacts of this final rule on long-range concentration changes. Baseline demographic proximity analysis presented in the *RIA* suggest that larger percentages of Hispanics, African Americans, people below the poverty level, people with less educational attainment, and people linguistically isolated are living within 5 km and 10 km of an affected EGU, compared to national averages. It also finds larger percentages of African Americans, people below the poverty level, and with less educational attainment living within 5 km and 10 km of an affected non-EGU facility. Relating these results to question 1 from section 7.2 of the *RIA*, we conclude that there may be potential EJ concerns associated with directly emitted pollutants that are affected by the regulatory action (e.g., NO₂) for certain population groups of concern in the baseline. However, as proximity to affected facilities does not capture variation in baseline exposure across communities, nor does it indicate that any exposures or impacts will occur, these results do not in themselves demonstrate disproportionate impacts of affected facilities in the baseline and should not be interpreted as a direct measure of exposure or impact.

Whereas proximity analyses are limited to evaluating the representativeness of populations residing nearby affected facilities, the ozone and PM_{2.5} exposure analyses can provide insight into all three EJ questions. Even though both the proximity and exposure analyses can potentially improve understanding of baseline EJ concerns (question 1), the two should not be directly compared. This is because the demographic proximity analysis does not include air quality information and is based on current, not future, population information.

The baseline analysis of ozone and PM_{2.5} concentration burden responds to question 1 from EPA’s environmental justice technical guidance document more directly than the proximity analyses, as it evaluates a form of the environmental stressor targeted by the regulatory action. Baseline ozone and PM_{2.5} analyses show that certain populations, such as Hispanics, Asians, those linguistically isolated, those less

⁴¹⁴ 86 FR 7009, January 20, 2021.

⁴¹⁵ <https://www.epa.gov/environmentaljustice>.

⁴¹⁶ U.S. Environmental Protection Agency (EPA), 2015. Guidance on Considering Environmental Justice During the Development of Regulatory Actions.

⁴¹⁷ The baseline for proximity analyses is current population information (e.g., 2021), whereas the baseline for ozone exposure analyses are the future years in which the regulatory options will be implemented (e.g., 2023 and 2026).

educated, and children may experience somewhat higher ozone and PM_{2.5} concentrations compared to the national average. Therefore, also in response to question 1, there likely are potential environmental justice concerns associated with ozone and PM_{2.5} exposures affected by the regulatory action for population groups of concern in the baseline. However, these baseline exposure results have not been fully explored and additional analyses are likely needed to understand potential implications. In addition, we infer that disparities in the ozone and PM_{2.5} concentration burdens are likely to persist after implementation of the regulatory action or alternatives under consideration due to similar modeled concentration reductions across population demographics (question 2).

Question 3 asks whether potential EJ concerns will be created or mitigated as compared to the baseline. Due to the very small differences observed in the distributional analyses of post-policy ozone and PM_{2.5} exposure impacts across populations, we do not find evidence that potential EJ concerns related to ozone and PM_{2.5} concentrations will be created or mitigated as compared to the baseline.⁴¹⁸

C. Outreach and Engagement

Prior to proposal, the EPA hosted an outreach webinar with environmental justice stakeholders to share information about the proposed rule and solicit feedback about potential environmental justice considerations. The webinar was attended by representatives of state governments, federally recognized tribes, environmental NGOs, higher education institutions, industry, and the EPA.⁴¹⁹ Participants were invited to comment on pre-proposal environmental justice considerations during the webinar or submit written comments to a pre-proposal non-regulatory docket.

After proposal, the EPA opened a public comment period to invite the

public to submit written comments to the regulatory docket for this rulemaking.⁴²⁰ The EPA also invited the public to participate in a public hearing held on April 21, 2022. A transcript of the public hearing is available in the docket for this rulemaking. Additionally, on March 31, 2022, the EPA hosted an informational webinar with non-governmental groups and environmental justice stakeholders to answer questions and share information about the proposed rule. A record of this webinar, including the informational power point shared at the webinar is available in the docket for this rulemaking.

VIII. Costs, Benefits, and Other Impacts of the Final Rule

In the *RIA* for the Federal Good Neighbor Plan Addressing Regional Ozone Transport for the 2015 Ozone National Ambient Air Quality Standards, the EPA estimated the health and climate benefits, compliance costs, and emissions changes that may result from the final rule for the analysis period 2023 to 2042. The estimated health and climate benefits and compliance costs are presented in detail in this *RIA*. The EPA notes that for EGUs the estimated benefits and compliance costs are directly associated with fully operating existing SCRs during ozone season; fully operating existing SNCRs during ozone season; installing state-of-the-art combustion controls; imposing a backstop emissions rate on certain units that lack SCR controls; and installing SCR and SNCR post-combustion controls. The EPA also notes that for non-EGUs the estimated health benefits and compliance costs are directly associated with installing controls to meet the NO_x emissions requirements presented in section I.B of this document.

For EGUs, the EPA analyzed this action's emissions budgets using uniform control stringency represented by \$1,800 per ton of NO_x (2016\$) in 2023 and \$11,000 per ton of NO_x

(2016\$) in 2026. The EPA also analyzed a more and a less stringent alternative. The more and less stringent alternatives differ from the rule in that they set different NO_x ozone season emissions budgets for the affected EGUs and different dates for large, coal-fired EGUs' compliance with the backstop emissions rate.

For non-EGUs, the EPA developed an analytical framework to determine which industries and emissions unit types to include in a proposed Transport FIP for the 2015 ozone NAAQS transport obligations. A February 28, 2022 memorandum, titled "Screening Assessment of Potential Emissions Reductions, Air Quality Impacts, and Costs from Non-EGU Emissions Units for 2026," documents the analytical framework used to identify industries and emissions unit types included in the proposed FIP. To further evaluate the industries and emissions unit types identified and to establish the proposed emissions limits, the EPA reviewed Reasonably RACT rules, NSPS rules, NESHAP rules, existing technical studies, rules in approved SIP submittals, consent decrees, and permit limits. That evaluation is detailed in the Proposed Non-EGU Sectors TSD prepared for the proposed FIP. The EPA is retaining the industries and many of the emissions unit types included in the proposal in this final action. For the non-EGU industries, in the final rule we made some minor changes to the non-EGU emissions units covered, the applicability criteria, as well as provided for facility-wide emissions averaging for engines and for a low-use exemption to eliminate the need to install controls on low-use boilers.

Table VIII–1 provides the projected 2023 through 2027, 2030, 2035, and 2042 EGU NO_x, SO₂, PM_{2.5}, and CO₂ emissions reductions for the evaluated regulatory control alternatives. For additional information on emissions changes, see Table 4–6 and Table 4–7 in Chapter 4 of the *RIA*.

TABLE VIII–1—EGU OZONE SEASON NO_x EMISSIONS CHANGES AND ANNUAL EMISSIONS REDUCTIONS (TONS) FOR NO_x, SO₂, PM_{2.5}, AND CO₂ FOR THE REGULATORY CONTROL ALTERNATIVES FROM 2023–2042

	Final rule	Less stringent alternative	More stringent alternative
2023:			
NO _x (ozone season)	10,000	10,000	10,000
NO _x (annual)	15,000	15,000	15,000
SO ₂ (annual)	1,000	3,000	1,000
CO ₂ (annual, thousand metric tons)			

⁴¹⁸ Please note, exposure results should not be extrapolated to other air pollutant. Detailed environmental justice analytical results can be found in Chapter 7 of the *RIA*.

⁴¹⁹ This does not constitute EPA's tribal consultation under E.O. 13175, which is described in section X.I.F of this rule.

⁴²⁰ Comments and responses regarding environmental justice considerations are available in Section 6 of the *RTC* document for this rulemaking.

TABLE VIII-1—EGU OZONE SEASON NO_x EMISSIONS CHANGES AND ANNUAL EMISSIONS REDUCTIONS (TONS) FOR NO_x, SO₂, PM_{2.5}, AND CO₂ FOR THE REGULATORY CONTROL ALTERNATIVES FROM 2023–2042—Continued

	Final rule	Less stringent alternative	More stringent alternative
PM _{2.5} (annual)			
2024:			
NO _x (ozone season)	21,000	10,000	33,000
NO _x (annual)	25,000	15,000	57,000
SO ₂ (annual)	19,000	5,000	59,000
CO ₂ (annual, thousand metric tons)	10,000	4,000	20,000
PM _{2.5} (annual)	1,000		1,000
2025:			
NO _x (ozone season)	32,000	10,000	56,000
NO _x (annual)	35,000	15,000	99,000
SO ₂ (annual)	38,000	7,000	118,000
CO ₂ (annual, thousand metric tons)	21,000	8,000	40,000
PM _{2.5} (annual)	2,000	1,000	2,000
2026:			
NO _x (ozone season)	25,000	8,000	49,000
NO _x (annual)	29,000	12,000	88,000
SO ₂ (annual)	29,000	5,000	104,000
CO ₂ (annual, thousand metric tons)	16,000	6,000	34,000
PM _{2.5} (annual)	1,000		2,000
2027:			
NO _x (ozone season)	19,000	6,000	43,000
NO _x (annual)	22,000	9,000	78,000
SO ₂ (annual)	21,000	4,000	91,000
CO ₂ (annual, thousand metric tons)	10,000	3,000	28,000
PM _{2.5} (annual)	1,000		2,000
2030:			
NO _x (ozone season)	34,000	33,000	31,000
NO _x (annual)	62,000	59,000	50,000
SO ₂ (annual)	93,000	98,000	51,000
CO ₂ (annual, thousand metric tons)	26,000	23,000	8,000
PM _{2.5} (annual)	1,000	1,000	
2035:			
NO _x (ozone season)	29,000	30,000	27,000
NO _x (annual)	46,000	46,000	41,000
SO ₂ (annual)	21,000	19,000	15,000
CO ₂ (annual, thousand metric tons)	16,000	15,000	8,000
PM _{2.5} (annual)	1,000	1,000	
2042:			
NO _x (ozone season)	22,000	22,000	22,000
NO _x (annual)	23,000	22,000	21,000
SO ₂ (annual)	15,000	15,000	7,000
CO ₂ (annual, thousand metric tons)	9,000	8,000	4,000
PM _{2.5} (annual)			

Emissions changes for NO_x, SO₂, and PM_{2.5} are in tons.

Table VIII-2 provides a summary of the ozone season NO_x emissions for non-EGUs for the 20 states subject to the non-EGU emissions requirements

starting in 2026, along with the estimated ozone season NO_x reductions for 2026 for the rule and the less and more stringent alternatives. The analysis

in the RIA assumes that the estimated reductions in 2026 will be the same in later years.

TABLE VIII-2—OZONE SEASON NO_x EMISSIONS AND EMISSIONS REDUCTIONS (TONS) FOR NON-EGUS FOR THE FINAL RULE AND THE LESS AND MORE STRINGENT ALTERNATIVES

State	2019 Ozone season emissions ^a	Final rule—ozone season NO _x reductions	Less stringent—ozone season NO _x reductions	More stringent—ozone season NO _x reductions
AR	8,790	1,546	457	1,690
CA	16,562	1,600	1,432	4,346
IL	15,821	2,311	751	2,991
IN	16,673	1,976	1,352	3,428
KY	10,134	2,665	583	3,120
LA	40,954	7,142	1,869	7,687
MD	2,818	157	147	1,145
MI	20,576	2,985	760	5,087
MO	11,237	2,065	579	4,716
MS	9,763	2,499	507	2,650

TABLE VIII-2—OZONE SEASON NO_x EMISSIONS AND EMISSIONS REDUCTIONS (TONS) FOR NON-EGUS FOR THE FINAL RULE AND THE LESS AND MORE STRINGENT ALTERNATIVES—Continued

State	2019 Ozone season emissions ^a	Final rule—ozone season NO _x reductions	Less stringent—ozone season NO _x reductions	More stringent—ozone season NO _x reductions
NJ	2,078	242	242	258
NV ⁴²¹	2,544	0	0	0
NY	5,363	958	726	1,447
OH	18,000	3,105	1,031	4,006
OK	26,786	4,388	1,376	5,276
PA	14,919	2,184	1,656	4,550
TX	61,099	4,691	1,880	9,963
UT	4,232	252	52	615
VA	7,757	2,200	978	2,652
WV	6,318	1,649	408	2,100
Totals	302,425	44,616	16,786	67,728

^a The 2019 ozone season emissions are calculated as 5/12 of the annual emissions from the following two emissions inventory files: nonegu_SmokeFlatFile_2019NEI_POINT_20210721_controlupdate_13sep2021_v0 and oilgas_SmokeFlatFile_2019NEI_POINT_20210721_controlupdate_13sep2021_v0.

For EGUs, the EPA analyzed ozone season NO_x emissions reductions and the associated costs to the power sector using the Integrated Planning Model (IPM) and its underlying data and inputs. For non-EGUs, the EPA prepared an assessment summarized in the memorandum titled *Summary of Final Rule Applicability Criteria and Emissions Limits for Non-EGU Emissions Units, Assumed Control Technologies for Meeting the Final Emissions Limits, and Estimated Emissions Units, Emissions Reductions, and Costs*, and the memorandum includes estimated emissions reductions by state for the rule.⁴²¹

Table VIII-3 reflects the estimates of the changes in the cost of supplying electricity for the regulatory control alternatives for EGUs and estimates of

complying with the emissions requirements for non-EGUs. The costs presented in Table VIII-3 do not include monitoring and reporting costs, which EPA summarizes in section X.B.2 of this document. The monitoring and reporting costs presented in section X.B.2 are \$0.35 million per year for EGUs and \$3.8 million per year for non-EGUs. For EGUs, compliance costs are negative in 2026. While seemingly counterintuitive, estimating negative compliance costs in a single year is possible given IPM's objective function is to minimize the discounted net present value (NPV) of a stream of annual total cost of generation over a multi-decadal time period. As such the model may undertake a compliance pathway that pushes higher costs later

into the forecast period, since future costs are discounted more heavily than near term costs. This can result in a policy scenario showing single year costs that are lower than the Baseline, but over the entire forecast horizon, the policy scenario shows higher costs.⁴²² For a detailed description of these cost trends, please see Chapter 4, section 4.5.2, of the RIA. For a detailed description of the methods and results from the memorandum titled *Summary of Final Rule Applicability Criteria and Emissions Limits for Non-EGU Emissions Units, Assumed Control Technologies for Meeting the Final Emissions Limits, and Estimated Emissions Units, Emissions Reductions, and Costs*, see Chapter 4, sections 4.4 and 4.5.4 of the RIA.

TABLE VIII-3—TOTAL ESTIMATED COMPLIANCE COSTS (MILLION 2016\$), 2023–2042

	Final rule	Less-stringent alternative	More-stringent alternative
2023:			
EGUs	57	56	49
Non-EGUs			
Total	57	56	49
2024:			
EGUs	(5)	(35)	840
Non-EGUs			
Total	(5)	(35)	840
2025:			
EGUs	(5)	(35)	840
Non-EGUs			
Total	(5)	(35)	840
2026:			

⁴²¹ We are not aware of existing non-EGU emissions units in Nevada that meet the applicability criteria for non-EGUs in the final rule. If any such units in fact exist, they would be subject to the requirements of the rule just as in any other state. In addition, any new emissions unit in

Nevada that meets the applicability criteria in the final rule will be subject to the final rule's requirements. See section III.B.1.d.

⁴²² As a sensitivity, the EPA re-calculated costs assuming annual costs cannot be negative. This

resulted in annualized 2023–42 costs under the final rule increasing from \$448.6 million to \$449.5 million (less than 1%) and did not change the conclusions of the RIA. See Section 4.5.2 of the RIA for more information.

TABLE VIII-3—TOTAL ESTIMATED COMPLIANCE COSTS (MILLION 2016\$), 2023–2042—Continued

	Final rule	Less-stringent alternative	More-stringent alternative
EGUs	(5)	(35)	840
Non-EGUs	570	140	1,300
Total	570	110	2,100
2027:			
EGUs	24	(47)	760
Non-EGUs	570	140	1,300
Total	600	97	2,000
2028:			
EGUs	24	(47)	760
Non-EGUs	570	140	1,300
Total	600	97	2,000
2029:			
EGUs	24	(47)	760
Non-EGUs	570	140	1,300
Total	600	97	2,000
2030:			
EGUs	710	770	840
Non-EGUs	570	140	1,300
Total	1,300	920	2,100
2031:			
EGUs	710	770	840
Non-EGUs	570	140	1,300
Total	1,300	920	2,100
2032:			
EGUs	820	850	590
Non-EGUs	570	140	1,300
Total	1,400	990	1,900
2033:			
EGUs	820	850	590
Non-EGUs	570	140	1,300
Total	1,400	990	1,900
2034:			
EGUs	820	850	590
Non-EGUs	570	140	1,300
Total	1,400	990	1,900
2035:			
EGUs	820	850	590
Non-EGUs	570	140	1,300
Total	1,400	990	1,900
2036:			
EGUs	820	850	590
Non-EGUs	570	140	1,300
Total	1,400	990	1,900
2037:			
EGUs	820	850	590
Non-EGUs	570	140	1,300
Total	1,400	990	1,900
2038:			
EGUs	820	830	600
Non-EGUs	570	140	1,300
Total	1,400	970	1,900
2039:			
EGUs	820	830	600
Non-EGUs	570	140	1,300
Total	1,400	970	1,900
2040:			
EGUs	820	830	600

TABLE VIII-3—TOTAL ESTIMATED COMPLIANCE COSTS (MILLION 2016\$), 2023–2042—Continued

	Final rule	Less-stringent alternative	More-stringent alternative
Non-EGUs	570	140	1,300
Total	1,400	970	1,900
2041:			
EGUs	820	830	600
Non-EGUs	570	140	1,300
Total	1,400	970	1,900
2042:			
EGUs	820	830	600
Non-EGUs	570	140	1,300
Total	1,400	970	1,900

Tables VIII-4 and VIII-5 report the estimated economic value of avoided premature deaths and illness in each year relative to the baseline along with

the 95 percent confidence interval. In each of these tables, for each discount rate and regulatory control alternative, two benefits estimates are presented

reflecting alternative ozone and PM_{2.5} mortality risk estimates. For additional information on these benefits, see Chapter 5 of the *RIA*.

TABLE VIII-4—ESTIMATED DISCOUNTED ECONOMIC VALUE OF AVOIDED OZONE-RELATED PREMATURE MORTALITY AND ILLNESS FOR THE FINAL RULE AND THE LESS AND MORE STRINGENT ALTERNATIVES IN 2023 [95 Percent confidence interval; millions of 2016\$]^{a b}

Disc rate	Pollutant	Final rule	Less stringent alternative	More stringent alternative
3%	Ozone Benefits	\$100 [\$27 to \$220] ^c and \$820 [\$91 to \$2,100] ^d .	\$100 [\$27 to \$220] ^c and \$810 [\$91 to \$2,100] ^d .	\$110 [\$28 to \$230] ^c and \$840 [\$94 to \$2,200] ^d .
7%	Ozone Benefits	\$93 [\$17 to 210] ^c and \$730 [\$75 to \$1,900] ^d .	\$93 [\$17 to \$210] ^c and \$730 [\$75 to \$1,900] ^d .	\$96 [\$18 to \$210] ^c and \$750 [\$77 to \$2,000] ^d .

^a Values rounded to two significant figures. The two benefits estimates are separated by the word “and” to signify that they are two separate estimates. The estimates do not represent lower- and upper-bound estimates and should not be summed.

^b We estimated ozone benefits for changes in NO_x for the ozone season. This table does not include benefits from reductions for non-EGUs because reductions from these sources are not expected prior to 2026 when the final standards would apply to these sources.

^c Using the pooled short-term ozone exposure mortality risk estimate.

^d Using the long-term ozone exposure mortality risk estimate.

TABLE VIII-5—ESTIMATED DISCOUNTED ECONOMIC VALUE OF AVOIDED OZONE AND PM_{2.5}-RELATED PREMATURE MORTALITY AND ILLNESS FOR THE FINAL RULE AND THE LESS AND MORE STRINGENT ALTERNATIVES IN 2026 [95% Confidence interval; millions of 2016\$]^{a b}

Disc rate	Pollutant	Final rule	Less stringent alternative	More stringent alternative
3%	Ozone Benefits	\$1,100 [\$280 to \$2,400] ^c and \$9,400 [\$1,000 to \$25,000] ^d .	\$420 [\$110 to \$900] ^c and \$3,400 [\$380 to \$8,900] ^d .	\$1,900 [470 to \$4,000] ^c and \$15,000 [\$1,700 to \$40,000] ^d .
	PM Benefits	\$2,000 [\$220 to \$5,300] and \$4,400 [\$430 to \$12,000].	\$530 [\$57 to \$1,400] and \$1,100 [\$110 to \$3,100].	\$6,400 [\$690 to \$17,000] and \$14,000 [\$1,300 to \$37,000].
	Ozone plus PM Benefits.	\$3,200 [\$500 to \$7,700] ^c and \$14,000 [\$1,500 to \$36,000] ^d .	\$950 [\$160 to \$2,300] ^c and \$4,600 [\$490 to \$12,000] ^d .	\$8,300 [\$1,200 to \$21,000] ^c and \$29,000 [\$3,000 to \$77,000] ^d .
7%	Ozone Benefits	\$1,000 [\$180 to \$2,300] ^c and \$8,400 [\$850 to \$22,000] ^d .	\$380 [\$68 to \$850] ^c and \$3,100 [\$310 to \$8,100] ^d .	\$1,700 [\$300 to \$3,800] ^c and \$14,000 [\$1,400 to \$36,000] ^d .
	PM Benefits	\$1,800 [\$190 to \$4,700] and \$3,900 [\$380 to \$11,000].	470 [\$50 to \$1,200] and \$1,000 [\$100 to \$2,800].	\$5,800 [\$600 to \$15,000] and \$12,000 [\$1,200 to \$33,000].
	Ozone plus PM Benefits.	\$2,800 [\$370 to \$7,000] ^c and \$12,000 [\$1,200 to \$33,000] ^d .	\$850 [\$120 to \$2,100] ^c and \$4,100 [\$410 to \$11,000] ^d .	\$7,500 [\$910 to \$19,000] ^c and \$26,000 [\$2,600 to \$69,000] ^d .

^a Values rounded to two significant figures. The two benefits estimates are separated by the word “and” to signify that they are two separate estimates. The estimates do not represent lower- and upper-bound estimates and should not be summed.

^b We estimated changes in NO_x for the ozone season and annual changes in PM_{2.5} and PM_{2.5} precursors in 2026.

^c Sum of ozone mortality estimated using the pooled short-term ozone exposure risk estimate and the Di et al. (2017) long-term PM_{2.5} exposure mortality risk estimate.

^d Sum of the Turner et al. (2016) long-term ozone exposure risk estimate and the Di et al. (2017) long-term PM_{2.5} exposure mortality risk estimate.

In Tables VIII-6, VIII-7, and VIII-8, the EPA presents a summary of the monetized health and climate benefits, costs, and net benefits of the rule and the more and less stringent alternatives for 2023, 2026, and 2030, respectively. There are important water quality

benefits and health benefits associated with reductions in concentrations of air pollutants other than ozone and PM_{2.5} that are not quantified. Discussion of the non-monetized health, welfare, and water quality benefits is found in Chapter 5 of the *RIA*. In this action,

monetized climate benefits are presented for purposes of providing a complete economic impact analysis under E.O. 12866 and other relevant Executive orders. The estimates of GHG emissions changes and the monetized benefits associated with those changes

is not part of the record basis for this action, which is taken to implement the good neighbor provision, CAA section 110(a)(2)(D)(i)(I), for the 2015 ozone NAAQS.

TABLE VIII-6—MONETIZED BENEFITS, COSTS, AND NET BENEFITS OF THE FINAL RULE AND LESS AND MORE STRINGENT ALTERNATIVES FOR 2023 FOR THE U.S.

[3% Discount rate for benefits, millions of 2016\$]^{a b}

	Final rule	Less stringent alternative	More stringent alternative
Health Benefits ^c	\$100 and \$820	\$100 and \$810	\$110 and \$840.
Climate Benefits	\$5	\$4	\$5.
Total Benefits	\$100 and \$820	\$100 and \$820	\$110 and \$840.
Costs ^d	\$57	\$56	\$49.
Net Benefits	\$48 and \$760	\$48 and \$760	\$66 and \$800.

^a We focus results to provide a snapshot of costs and benefits in 2023, using the best available information to approximate social costs and social benefits recognizing uncertainties and limitations in those estimates.

^b Rows may not appear to add correctly due to rounding.

^c The health benefits are associated with two point estimates from two different epidemiologic studies. For the purposes of presenting the values in this table the health and climate benefits are discounted at 3 percent.

^d The costs presented in this table are 2023 annual estimates for each alternative analyzed. For EGUs, an NPV of costs was calculated using a 3.76 percent real discount rate consistent with the rate used in IPM's objective function for cost-minimization. For further information on the discount rate use, please see Chapter 4, Table 4-8 in the RIA.

TABLE VIII-7—MONETIZED BENEFITS, COSTS, AND NET BENEFITS OF THE FINAL RULE AND LESS AND MORE STRINGENT ALTERNATIVES FOR 2026 FOR THE U.S.

[3% Discount rate for benefits, millions of 2016\$]^{a b}

	Final rule	Less stringent alternative	More stringent alternative
Health Benefits ^c	\$3,200 and \$14,000	\$950 and \$4,600	\$8,300 and \$29,000.
Climate Benefits	\$1,100	\$420	\$2,100.
Total Benefits	\$4,300 and \$15,000	\$1,400 and \$5,000	\$10,000 and \$31,000.
Costs ^d	\$570	\$110	\$2,100.
Net Benefits	\$3,700 and \$14,000	\$1,300 and \$4,900	\$8,300 and \$29,000.

^a We focus results to provide a snapshot of costs and benefits in 2026, using the best available information to approximate social costs and social benefits recognizing uncertainties and limitations in those estimates.

^b Rows may not appear to add correctly due to rounding.

^c The health benefits are associated with two point estimates from two different epidemiologic studies. For the purposes of presenting the values in this table the health and climate benefits are discounted at 3 percent.

^d The costs presented in this table are 2026 annual estimates for each alternative analyzed. For EGUs, an NPV of costs was calculated using a 3.76 percent real discount rate consistent with the rate used in IPM's objective function for cost-minimization. For further information on the discount rate use, please see Chapter 4, Table 4-8 in the RIA.

TABLE VIII-8—MONETIZED BENEFITS, COSTS, AND NET BENEFITS OF THE FINAL RULE AND LESS AND MORE STRINGENT ALTERNATIVES FOR 2030 FOR THE U.S.

[3% Discount rate for benefits, millions of 2016\$]^{a b}

	Final rule	Less stringent alternative	More stringent alternative
Health Benefits ^c	\$3,400 and \$15,000	\$1,000 and \$4,900	\$9,000 and \$31,000.
Climate Benefits	\$1,500	\$1,300	\$500.
Total Benefits	\$4,900 and \$16,000	\$2,300 and \$6,200	\$9,500 and \$31,000.
Costs ^d	\$1,300	\$920	\$2,100.
Net Benefits	\$3,600 and \$15,000	\$1,400 and \$5,300	\$7,400 and \$29,000.

^a We focus results to provide a snapshot of costs and benefits in 2030, using the best available information to approximate social costs and social benefits recognizing uncertainties and limitations in those estimates.

^b Rows may not appear to add correctly due to rounding.

^c The health benefits are associated with two point estimates from two different epidemiologic studies. For the purposes of presenting the values in this table the health and climate benefits are discounted at 3 percent.

^d The costs presented in this table are 2030 annual estimates for each alternative analyzed. For EGUs, an NPV of costs was calculated using a 3.76 percent real discount rate consistent with the rate used in IPM's objective function for cost-minimization. For further information on the discount rate use, please see Chapter 4, Table 4-8 in the RIA.

In addition, Table VIII-9 presents estimates of the present value (PV) of the monetized benefits and costs and the equivalent annualized value (EAV), an estimate of the annualized value of

the net benefits consistent with the present value, over the twenty-year period of 2023 to 2042. The estimates of the PV and EAV are calculated using discount rates of 3 and 7 percent as

recommended by OMB's Circular A-4 and are presented in 2016 dollars discounted to 2023.

TABLE VIII–9—MONETIZED ESTIMATED HEALTH AND CLIMATE BENEFITS, COMPLIANCE COSTS, AND NET BENEFITS OF THE FINAL RULE AND LESS AND MORE STRINGENT ALTERNATIVES, 2023 THROUGH 2042

[Millions 2016\$, discounted to 2023]

	3 Percent discount rate		7 Percent discount rate	
	PV	EAV	PV	EAV
Health benefits				
Final Rule	\$200,000	\$13,000	\$130,000	\$12,000
Less Stringent Alternative	67,000	4,500	40,000	3,800
More Stringent Alternative	410,000	28,000	240,000	23,000
Climate Benefits^a				
Final Rule	15,000	970	15,000	970
Less Stringent Alternative	11,000	770	11,000	770
More Stringent Alternative	14,000	920	14,000	920
Compliance Costs				
Final Rule	14,000	910	9,400	770
Less Stringent Alternative	8,700	590	5,300	500
More Stringent Alternative	25,000	1,700	17,000	1,600
Net Benefits				
Final Rule	200,000	13,000	140,000	12,000
Less Stringent Alternative	70,000	4,700	42,000	4,000
More Stringent Alternative	400,000	27,000	240,000	22,000

^a Climate benefits are calculated using four different estimates of the social cost of carbon (SC–CO₂) (model average at 2.5 percent, 3 percent, and 5 percent discount rates; 95th percentile at 3 percent discount rate). For presentational purposes in this table, the climate benefits associated with the average SC–CO₂ at a 3-percent discount rate are used in the columns displaying results of other costs and benefits that are discounted at either a 3-percent or 7-percent discount rate.

As shown in Table VIII–9, the PV of the monetized health benefits of this rule, discounted at a 3-percent discount rate, is estimated to be about \$200 billion (\$200,000 million), with an EAV of about \$13 billion (\$13,000 million). At a 7-percent discount rate, the PV of the monetized health benefits is estimated to be \$130 billion (\$130,000 million), with an EAV of about \$12 billion (\$12,000 million). The PV of the monetized climate benefits of this rule, discounted at a 3-percent discount rate, is estimated to be about \$15 billion (\$15,000 million), with an EAV of about \$970 million. The PV of the monetized compliance costs, discounted at a 3-percent rate, is estimated to be about \$14 billion (\$14,000 million), with an EAV of about \$910 million. At a 7-percent discount rate, the PV of the compliance costs is estimated to be about \$9.4 billion (\$9,400 million), with an EAV of about \$770 million.

In addition to the analysis of costs and benefits as described above, for the final rule, the EPA was able to conduct a full-scale photochemical grid modeling run of the effects of the “final rule” emissions control scenario in 2026. This modeling can be used to estimate the impacts on projected 2026 ozone design values that are expected from the combined EGU and non-EGU

control emissions reductions in this final rule. These results do not replace the AQAT-generated estimates used for our Step 3 determinations, and the EPA needed to continue to use AQAT for Step 3 determinations in order to characterize various potential control scenarios to inform these regulatory determinations. Nonetheless, though they differ slightly from the AQAT-generated air quality estimates of the final rule control scenario conducted for purposes of our Step 3 analysis (as presented in section V.D of this document), these results using full-scale photochemical grid modeling complement those estimates and confirm in all cases the regulatory conclusions reached applying AQAT.⁴²³ Appendix 3A of the RIA presents the full results of the projected impacts of the final rule control scenario on ozone levels using CAMx. To briefly summarize, the largest reductions in

⁴²³ Note that the EPA’s “overcontrol” analysis relies primarily on a “Step 3” control scenario rather than the “full geography” scenario. The CAMx modeling described here captures the effects of the rule as a whole and so is more akin to the “full geography” scenario, which the EPA does not believe is the appropriate method for conducting overcontrol analysis. Nonetheless, as explained in the Ozone Transport Policy Analysis Final Rule TSD, the results under either scenario establish no overcontrol, and the CAMx results presented here do not call those conclusions into question.

ozone design values at identified receptors are predicted to occur in the Houston-Galveston-Brazoria, Texas area. In this area the reductions from the final rule case range from 0.7 to 0.9 ppb. At most of the receptors in both the Dallas/Ft Worth and the New York/Coastal Connecticut areas the reductions in ozone range from 0.4 to 0.5 ppb. At receptors in Indiana, Michigan, and Wisconsin near the shoreline of Lake Michigan, ozone is projected to decline by 0.3 to 0.4 ppb, but by as much as 0.5 ppb at the receptor in Muskegon, MI. Reductions of 0.1 ppb are predicted in the urban and near-urban receptors in Chicago. In the West, ozone reductions just under 0.2 ppb are predicted at receptors in Denver with slightly greater reductions, just above 0.2 ppb, at receptors in Salt Lake City. At receptors in Phoenix, California, El Paso/Las Cruces, and southeast New Mexico the reductions in ozone are predicted to be less than 0.1 ppb.

IX. Summary of Changes to the Regulatory Text for the Federal Implementation Plans and Trading Programs for EGUs

This section describes the amendments to the regulatory text that implement the findings and remedy discussed elsewhere in this rule with respect to EGUs. The primary CFR

amendments are revisions to the FIP provisions addressing states' good neighbor obligations related to ozone in 40 CFR part 52 as well as the revisions to the regulations for the CSAPR NO_x Ozone Season Group 3 Trading Program in 40 CFR part 97, subpart GGGGG. In conjunction with the amendments to the Group 3 trading program, the monitoring, recordkeeping, and reporting regulations in 40 CFR part 75 are being amended to reflect the addition of certain new reporting requirements associated with the amended trading program and the administrative appeal provisions in 40 CFR part 78 are being amended to identify certain additional types of appealable decisions of the EPA Administrator under the amended trading program. The provisions to address the transition of the EGUs in certain states from the Group 2 trading program to the Group 3 trading program are implemented in part through revisions to the regulations noted previously and in part through revisions to the regulations for the Group 2 trading program in 40 CFR part 97, subpart EEEEE.

In addition to these primary amendments, certain revisions are being made to the regulations for the other CSAPR trading programs in 40 CFR part 97, subparts AAAAA through EEEEE, for conformity with the amended provisions of the Group 3 trading program, as discussed in section VI.B.13. Documents have been included in the docket for this rule showing all of the revisions in redline-strikeout format.

A. Amendments to FIP Provisions in 40 CFR Part 52

The CSAPR, CSAPR Update, and Revised CSAPR Update FIP requirements related to ozone season NO_x emissions are set forth in 40 CFR 52.38(b) as well as other sections of part 52 specific to each covered state. The existing text of § 52.38(b)(1) identifies the trading program regulations in 40 CFR part 97, subparts BBBB, EEEEE, and GGGG, as constituting the relevant FIP provisions relating to seasonal NO_x emissions and transported ozone pollution. Because in this rulemaking the EPA is establishing new or amended FIP requirements not only for the types of EGUs covered by the trading programs but also for certain types of industrial sources, an amendment to § 52.38(b)(1) clarifies that the trading programs constitute the FIP provisions only for the sources meeting the applicability requirements of the trading programs. A parallel clarification is being added to §§ 52.38(a)(1) and

52.39(a) with respect to the CSAPR FIP requirements relating to annual NO_x emissions, SO₂ emissions, and transported fine particulate pollution.

The states whose EGU sources are required to participate in the CSAPR NO_x Ozone Season Group 1, Group 2, and Group 3 trading programs under the FIPs established in CSAPR, the CSAPR Update, and the Revised CSAPR Update, as well as the control periods for which those requirements apply, are identified in § 52.38(b)(2). The amendments to this paragraph expand the applicability of the Group 3 trading program to sources in the ten additional states that the EPA is adding to the Group 3 trading program starting with the 2023 control period and end the applicability of the Group 2 trading program (with the exception of certain provisions) for sources in seven of the ten states after the 2022 control period, as discussed in section VI.B.2.⁴²⁴ The paragraphs within § 52.38(b)(2) are being renumbered to clarify the organization of the provisions and to facilitate cross-references from other regulatory provisions. Regarding the two states currently participating in the Group 2 trading program through approved SIP revisions that replaced the previous FIPs issued under the CSAPR Update (Alabama and Missouri), a provision indicating that the EPA will no longer administer the state trading programs adopted under those SIP revisions after the 2022 control period is being added at § 52.38(b)(16)(ii)(B).

In the Revised CSAPR Update, the EPA established several options for states to revise their SIPs to modify or replace the FIPs applicable to their sources while continuing to use the Group 3 trading program as the mechanism for meeting the states' good neighbor obligations. As in effect before this rule, § 52.38(b)(10), (11), and (12) established options to replace allowance allocations for the 2022 control period, to adopt an abbreviated SIP revision for control periods in 2023 or later years, and to adopt a full SIP revision for control periods in 2023 or later years, respectively.⁴²⁵ As discussed in section VI.D, the EPA is retaining these SIP revision options and is making them available for all states covered by the Group 3 trading program after the geographic expansion. The option under

⁴²⁴ Like the previous text of § 52.38(b)(2), the final amended text expressly encompasses sources in Indian country within the respective states' borders.

⁴²⁵ Revisions to the deadlines for states with approved SIP revisions to submit their state-determined allowance allocations to the EPA for subsequent recordation were finalized in an earlier final rule in this docket. See 87 FR 52473 (August 26, 2022).

§ 52.38(b)(10) to replace allowance allocations for a single control period is being amended to be available for the 2024 control period, with attendant revisions to the years and dates shown in § 52.38(b)(10) (multiple paragraphs) and (b)(17)(i) as well as the Group 3 trading program regulations, as discussed in section IX.B. The options under § 52.38(b)(11) and (12) to adopt abbreviated or full SIP revisions are being amended to be available starting with the 2025 control period, with attendant revisions to § 52.38(b)(11)(iii), (b)(12)(iii), and (b)(17)(ii).⁴²⁶ The removal of the previous options for states to expand applicability of the trading programs for ozone season NO_x emissions to certain non-EGUs and smaller EGUs, discussed in sections VI.D.2 and VI.D.3, is accomplished by the removal or revision of multiple paragraphs of § 52.38(b), including most notably the removal of § 52.38(b)(4)(i), (b)(5)(i), (b)(8)(i)–(ii), (b)(9)(i)–(ii), (b)(11)(i)–(iii), and (b)(12)(i)–(iii).

The changes with respect to set-asides and the treatment of units in Indian country discussed in section VI.B.9, although implemented largely through amendments to the Group 3 trading program regulations, are also implemented in part through amendments to § 52.38(b)(11) and (12). First, the text in § 52.38(b)(11)(iii)(A) and (b)(12)(iii)(A) identifying the portion of each state trading budget for which a state may establish state-determined allowance allocations is being revised to exclude any allowances in a new unit set-aside or Indian country existing unit set-aside. Second, the text in § 52.38(b)(12)(vi) identifying provisions that states may not adopt into their SIPs (because the provisions concern regulation of sources in Indian country not subject to a state's CAA implementation planning authority) are being revised to include the provisions of the amended Group 3 trading program addressing allocation and recordation of allowances from all types of set-asides. Finally, the text in § 52.38(b)(12)(vii) authorizing the EPA to modify the previous approval of a SIP revision with regard to the assurance provisions "if and when a covered unit is located in Indian country" are being revised to account for the fact that at least one covered unit is already located in Indian country not subject to a state's CAA planning authority.

The transitional provisions discussed in sections VI.B.12.b and VI.B.12.c to

⁴²⁶ No state currently in the Group 3 trading program has submitted a SIP revision to make use of these options in control periods before the control periods in which the options can be used under the amended provisions.

convert certain 2017–2022 Group 2 allowances to Group 3 allowances and to recall certain 2023–2024 Group 2 allowances, although promulgated as amendments to the Group 2 trading program regulations, will necessarily be implemented after the end of the 2022 control period. Amendments clarifying that these provisions continue to apply to the relevant sources and holders of allowances notwithstanding the transition of certain states out of the Group 2 trading program after the 2022 control period are being added at § 52.38(b)(14)(iii). Cross-references clarifying that the EPA’s allocations of the converted Group 3 allowances are not subject to modification through SIP revisions are also being added to the existing provisions at § 52.38(b)(11)(iii)(D) and (b)(12)(iii)(D).

The general FIP provisions applicable to all states covered by this rule as set forth in § 52.38(b)(2) are being replicated in the state-specific subparts of 40 CFR part 52 for each of the ten states that the EPA is adding to the Group 3 trading program.⁴²⁷ In each such state-specific CFR subpart, provisions are being added indicating that sources in the state are required to participate in the CSAPR NO_x Ozone Season Group 3 Trading Program with respect to emissions starting in 2023. Provisions are also being added repeating the substance of § 52.38(b)(13)(i), which generally provides that the Administrator’s full and unconditional approval of a full SIP revision correcting the same SIP deficiency that is the basis for a FIP promulgated in this rulemaking would cause the FIP to no longer apply to sources subject to the state’s CAA implementation planning authority, and § 52.38(b)(14)(ii), which generally provides the EPA with authority to complete recordation of EPA-determined allowance allocations for any control period for which EPA has already started such recordation notwithstanding the approval of a state’s SIP revision establishing state-determined allowance allocations.

For each of the seven states that the EPA is removing from the Group 2 trading program, the provisions of the state-specific CFR subparts indicating that sources in the state are required to participate in that trading program are being revised to end that requirement with respect to emissions after 2022, and a further provision is being added

repeating the substance of § 52.38(b)(14)(iii), which identifies certain provisions that continue to apply to sources and allowances notwithstanding discontinuation of a trading program with respect to a particular state.⁴²⁸ In addition, for the five states that during their time in the Group 2 trading program have not exercised the option to adopt full SIP revisions to replace the FIPs issued under the CSAPR Update (all but Alabama and Missouri), obsolete provisions concerning the unexercised SIP revision option are being removed.

No amendments with respect to FIP requirements for EGUs are being made to the state-specific CFR subparts for the twelve states whose sources currently participate in the Group 3 trading program⁴²⁹ except as needed to update cross-references or to implement the changes related to the treatment of Indian country, as discussed in section IX.D.

B. Amendments to Group 3 Trading Program and Related Regulations

To implement the geographic expansion of the Group 3 trading program and the revised trading budgets that are being established under the new and amended FIPs in this rulemaking, several sections of the Group 3 trading program regulations are being amended. Revisions identifying the applicable control periods, deadlines for certification of monitoring systems, and deadlines for commencement of quarterly reporting for sources not previously covered by the Group 3 trading program are being made at §§ 97.1006(c)(3)(i), 97.1030(b)(1), and 97.1034(d)(2)(i), respectively. Revisions identifying the new or revised budgets and new unit set-asides for the control periods after 2022 for all covered states are being made at § 97.1010(a)(1) and (c)(2), respectively.

Each of the enhancements to the Group 3 trading program discussed in section VI.B is also implemented primarily through revisions to the trading program regulations. The dynamic budget-setting process discussed in sections VI.B.1.b.i and VI.B.4 is implemented at § 97.1010(a)(2) through (4), and the associated revised process for determining variability

limits and assurance levels discussed in section VI.B.5 is implemented at § 97.1010(e). The Group 3 allowance bank recalibration process discussed in sections VI.B.1.b.ii and VI.B.6 is implemented at § 97.1026(d). The backstop daily NO_x emissions rate component of the primary emissions limitation discussed in sections VI.B.1.c.i and VI.B.7 is implemented at §§ 97.1006(c)(1)(i) and 97.1024(b)(1) and (3), accompanied by the addition of a definition of “backstop daily NO_x emissions rate” and modification of the definition of “CSAPR NO_x Ozone Season Group 3 allowance” in §§ 97.1002 and 97.1006(c)(6). The secondary emissions limitation for sources found responsible for exceedances of the assurance levels discussed in sections VI.B.1.c.ii and VI.B.8 is implemented at §§ 97.1006(c)(1)(iii) and (iv) and (c)(3)(ii) and 97.1025(c), accompanied by the addition of a definition of “CSAPR NO_x Ozone Season Group 3 secondary emissions limitation” in § 97.1002.

The changes relating to set-asides, the treatment of Indian country, and unit-level allowance allocations discussed in section VI.B.9 of this document are implemented through revisions to multiple paragraphs of §§ 97.1010, 97.1011, and 97.1012, as well as limited revisions to §§ 97.1002 (definition of “allocate or allocation”) and 97.1006(b)(2). In § 97.1010, paragraphs (b), (c), and (d) address the amounts for each control period of the Indian country existing unit set-asides, new unit set-asides, and Indian country new unit set-asides, respectively.⁴³⁰ Paragraphs (b) and (d) reflect the establishment of Indian country existing unit set-asides starting with the 2023 control period and the discontinuation of Indian country new unit set-asides after the 2022 control period.

A newly added definition at § 97.1002 for “coal-derived fuel” (based on the existing definition in 40 CFR 72.2) helps in implementation of both the backstop daily NO_x emissions rate provisions and the unit-level allocation provisions by clarifying that the provisions apply without regard to how any coal combusted by a unit might have been processed before combustion. Another newly added definition at § 97.1002 for “historical control period” helps in implementation of the dynamic budget-setting provisions, the secondary emissions limitation provisions, and the

⁴³⁰ The former § 97.1011(c), which addresses the relationships of set-asides and variability limits to state trading budgets, is being relocated to § 97.1011(f).

⁴²⁷ See §§ 52.54(b) (Alabama), 52.184(a) (Arkansas), 52.1240(d) (Minnesota), 52.1824(a) (Mississippi), 52.1326(b) (Missouri), 52.1492 (Nevada), 52.1930(a) (Oklahoma), 52.2283(d) (Texas), 52.2356 (Utah), and 52.2587(e) (Wisconsin).

⁴²⁸ See §§ 52.54(b) (Alabama), 52.184(a) (Arkansas), 52.1824(a) (Mississippi), 52.1326(b) (Missouri), 52.1930(a) (Oklahoma), 52.2283(d) (Texas), and 52.2587(e) (Wisconsin).

⁴²⁹ See §§ 52.731(b) (Illinois), 52.789(b) (Indiana), 52.940(b) (Kentucky), 52.984(d) (Louisiana), 52.1084(b) (Maryland), 52.1186(e) (Michigan), 52.1584(e) (New Jersey), 52.1684(b) (New York), 52.1882(b) (Ohio), 52.2040(b) (Pennsylvania), 52.2440(b) (Virginia), and 52.2540(b) (West Virginia).

unit-level allocation provisions by facilitating references to data reported by a unit for periods before the unit's entry into the Group 3 trading program.

The revisions to § 97.1011 refocus the section exclusively on allocation to "existing" units from the portion of each state emissions budget not reserved in a new unit set-aside or Indian country new unit set-aside. In § 97.1011(a), the provision formerly in § 97.1011(a)(1) requiring allocations to existing units to be made in the amounts provided in NODAs issued by the EPA is being split into two separate provisions, with paragraph (a)(1) applying to existing units in the state and areas of Indian country covered by the state's CAA implementation planning authority and paragraph (a)(2) applying to existing units in areas of Indian country not covered by the state's CAA implementation planning authority.⁴³¹ This split will facilitate the submission and approval of SIP revisions by states interested in submitting state-determined allowance allocations for the units over which they exercise CAA implementation authority, while leaving allocations to any units outside their authority to be addressed either by the EPA or by the relevant tribe under an approved tribal implementation plan. The process for determining default allocations to existing units of allowances from state trading budgets starting with the 2026 control period is set forth in revised § 97.1011(b), while the former provisions of § 97.1011(b), which concern timing and notice procedures for allocations to new units, are being relocated to § 97.1012. The provisions addressing incorrectly allocated allowances at § 97.1011(c) are being streamlined by relocating the portions applicable to new units to § 97.1012(c). In addition, as discussed in section VI.B.9.d, § 97.1011(c)(5) is being revised to provide that, starting with the 2024 control period, any incorrectly allocated allowances recovered after May 1 of the year following the control period will not be reallocated to other units in the

state but instead would be transferred to a surrender account.

The revisions to § 97.1012 retain the section's current focus on allocations to "new" units, generally combining the former provisions at § 97.1012 with the former provisions at § 97.1011(b) and (c) that address new units. The text of multiple paragraphs in both § 97.1012(a) and (b) is being revised as needed to reflect the change in treatment of Indian country discussed in section VI.B.9.a, under which the new unit set-asides will be used to provide allowance allocations to new units both in non-Indian country and Indian country within the borders of the respective states for control periods starting in 2023.⁴³² The timing and notice provisions in § 97.1012(a)(13) and (b)(13) are relocated from former § 97.1011(b)(1) and (2). The text of § 97.1012(c), addressing incorrect allocations to new units, is largely relocated from § 97.1011(c) (which addresses incorrect allocations to existing units) and reflects a parallel revision addressing the disposition of recovered allowances, as discussed in section VI.B.9.d.

The amendments to § 97.1021 implement two distinct sets of changes discussed in sections VI.B.9 and VI.D.1. First, revisions to § 97.1021(b) through (e) replace the previous schedule for recording Group 3 allowances for the 2023 and 2024 control periods established in the August 2022 Recordation Rule with an updated recordation schedule tailored to the effective date of this rule. The updated schedule also eliminates the unused former option for states to provide state-determined allowance allocations for the 2022 control period and establishes a substantively equivalent new option for states to provide state-determined allowance allocations for the 2024 control period. Second, revisions to § 97.1021(g) through (j) begin recordation for Indian country existing unit set-asides starting with allocations for the 2023 control period, modify the text to eliminate references to state-determined allocations of allowances from new unit set-asides, and end recordation for Indian country new unit set-asides after allocations for the 2022 control period.

⁴³² Revisions are also being made to the text of § 97.1012(a) and (b) for the control periods in 2021 and 2022 consistent with the revisions to the parallel provisions in the regulations for the other CSAPR trading programs, generally calling for allocations to units in areas of Indian country subject to a state's CAA implementation planning authority to be made from the new unit set-asides instead of from the Indian country new unit set-asides.

⁴³¹ An additional provision currently in § 97.1011(a)(1), which clarifies that an allocation or lack of allocation to a unit in a NODA does not constitute a determination by the EPA that the unit is or is not a CSAPR NO_x Ozone Season Group 3 unit, is being relocated to § 97.1011(a)(3). The former § 97.1011(a)(2), which provides for certain existing units that cease operations to receive allocations for their first five control periods of non-operation and provides for the allowances for subsequent control periods to be allocated to the relevant state's new unit set-asides, is inconsistent with the proposed revisions to the set-asides and the default allowance allocation process, as discussed in section VI.B.9, and is being removed as obsolete.

Implementation of the revisions to the Group 3 trading program is also accomplished in part through amendments to regulations in other CFR parts. In 40 CFR part 75, which contains detailed monitoring, recordkeeping, and reporting requirements applicable to sources covered by the Group 3 trading program, the additional recordkeeping and reporting requirements discussed in section VI.B.10 of this document are implemented through the addition of §§ 75.72(f) and 75.73(f)(1)(ix) and (x) and revisions to § 75.75, and the procedures for calculating daily total heat input and daily total NO_x emissions and the procedures for apportioning NO_x mass emissions monitored at a common stack among the individual units using the common stack are being added at sections 5.3.3, 8.4(c), and 8.5.3 of appendix F to part 75. In 40 CFR part 78, which contains the administrative appeal procedures applicable to decisions of the EPA Administrator under the Group 3 trading program, § 78.1(b)(19) is being amended to add calculation of the dynamic budgets to the list of administrative decisions under the trading program regulations that will be appealable under those procedures.

C. Transitional Provisions

As discussed in section VI.B.12, the EPA is establishing several transitional provisions for sources entering the Group 3 trading program. The provisions discussed in section VI.B.12.a of this document, concerning the prorating of state emissions budgets, assurance levels, and unit-level allocations for the 2023 control period, are implemented through the Group 3 trading program regulations. Specifically, the state emissions budgets for the 2023 control period will be prorated according to procedures set out at § 97.1010(a)(1)(ii). Variability limits for the 2023 control period, and the resulting assurance levels, will be computed under § 97.1010(e) from the prorated state emissions budgets. Unit-level allocations to existing units for the 2023 control period will be computed from the prorated state emissions budgets according to procedures substantively the same as the procedures codified in § 97.1011(b) for calculating default allocations to existing units for later control periods, as discussed in section VI.B.9.b, and will be announced in the notice of data availability issued under § 97.1011(a)(1) and (2) for the 2023 through 2025 control periods.

The remaining transitional provisions are being implemented through the Group 2 trading program regulations.

The creation of an additional Group 3 allowance bank for the 2023 control period through the conversion of banked 2017–2022 Group 2 allowances as discussed in section VI.B.12.b of this document is implemented at § 97.826(e).⁴³³ Related provisions addressing the use of Group 3 allowances to satisfy after-arising compliance obligations under the Group 2 trading program or the Group 1 trading program are implemented at §§ 97.826(f)(2) and 97.526(e)(3), respectively, and related provisions addressing recordation of late-arising allocations of Group 1 allowances are implemented at § 97.526(d)(2)(iii). The recall of Group 2 allowances previously issued for the 2023 and 2024 control periods as discussed in section VI.B.12.c of this document is implemented at § 97.811(e).

Decisions of the Administrator related to the allowance bank creation provisions and the allowance recall provisions are identified as appealable decisions under 40 CFR part 78 through revisions to § 78.1(b)(17)(viii) and (ix).

D. Clarifications and Conforming Revisions

As discussed in section VI.B.13 of this document, the EPA is revising the provisions regarding allowance allocations for units in Indian country in all the CSAPR trading programs so that instead of distinguishing among units based on whether they are or are not located in Indian country, the revised provisions distinguish among units based on whether they are or are not covered by a state's CAA implementation planning authority. The revisions are implemented in multiple paragraphs of §§ 97.411(b), 97.412, 97.511(b), 97.512, 97.611(b), 97.612, 97.711(b), 97.712, 97.811(b), and 97.812. The associated revisions to states' options regarding SIP revisions to establish state-determined allowance allocations for units covered by their CAA implementation planning authority are implemented in multiple paragraphs of §§ 52.38(a) and (b) and 52.39 as well as the state-specific subparts of 40 CFR part 52.

Certain other revisions to the regulatory text in the FIP and trading program regulations are minor simplifications and clarifications. First, in the Group 2 trading program regulations, the paragraphs in § 97.810 setting forth the amounts of state emissions budgets, new unit set-asides,

Indian country new unit set-asides, and variability limits for states that the EPA is transitioning out of the Group 2 trading program are being modified to indicate that the amounts are applicable under that program only for control periods through 2022.

Second, as noted in sections VI.D.2 and VI.D.3, the existing options for states subject to the NO_x SIP Call to expand applicability of the Group 2 trading program to include certain non-EGUs and smaller EGUs are being eliminated. While the most directly affected provisions are the provisions setting forth the SIP options at § 52.38(b)(4), (5), (8), (9), (12), and (13), as discussed in section IX.A of this document, the changes also render references to “base” units and “base” sources in the regulations for the Group 2 trading program and the Group 3 trading program obsolete. Removal of the references to “base” units and “base” sources affects multiple paragraphs of §§ 97.802, 97.806, 97.825, 97.1002, 97.1006, and 97.1025.

Third, to clarify the regulatory text, the EPA is removing the language in the Group 3 trading program regulations that formerly appeared at §§ 97.1002 (definition of “common designated representative’s assurance level”), 97.1006(c)(2)(iii), 97.1010(d), and 97.1011(a)(1) referencing supplemental amounts of allowances issued for the 2021 control period and associated increments to the 2021 assurance levels (each state’s assurance level increment was described as 21 percent of the state’s supplemental amount of allowances). In place of the removed language, the EPA is restating the amounts of the 2021 state emissions budgets in § 97.1010(a)(1)(i) so as to include the supplemental amounts of allowances and is restating the amounts of the 2021 variability limits in § 97.1010(e)(1) so as to include the associated assurance level increments. The revised language is substantively equivalent to and simpler than the previous language.

Fourth, in 40 CFR part 75, the EPA is removing obsolete text in § 75.73(c) and (f) to clarify the context for other text being added to the section, as discussed in section IX.B of this document.

Fifth, in 40 CFR part 52, the EPA is adding §§ 52.38(a)(7)(iii) and 52.39(k)(3) to clarify in §§ 52.38 and 52.39 that the Allowance Management System housekeeping provisions added by the Revised CSAPR Update at §§ 97.426(c), 97.626(c), and 97.726(c) in the regulations for the CSAPR NO_x Annual, SO₂ Group 1, and SO₂ Group 2 trading programs, respectively, continue to apply after the sources in a given state

have been removed from the programs, consistent with the text of the latter provisions.

Finally, the EPA is updating cross-references throughout 40 CFR parts 52 and 97 for consistency with the other amendments being made in this rulemaking.

X. Statutory and Executive Orders Reviews

Additional information about these statutes and Executive orders (“E.O.”) can be found at <https://www2.epa.gov/laws-regulations/laws-and-executive-orders>.

A. Executive Order 12866: Regulatory Planning and Review and Executive Order 13563: Improving Regulation and Regulatory Review

This action is a significant regulatory action within the scope of section 3(f)(1) of Executive Order 12866 that was submitted to the Office of Management and Budget (OMB) for review. Any changes made in response to Executive Order 12866 review have been documented in the docket. The EPA prepared an analysis of the potential costs and benefits associated with this action. This analysis, which is contained in the “Regulatory Impact Analysis for Final Federal Good Neighbor Plan Addressing Regional Ozone Transport for the 2015 Ozone National Ambient Air Quality Standard” [EPA–452–R–23–001], is available in the docket and is briefly summarized in section VIII of this document.

B. Paperwork Reduction Act (PRA)

1. Information Collection Request for Electric Generating Units

The information collection activities in this rule have been submitted for approval to the Office of Management and Budget (OMB) under the PRA. The Information Collection Request (ICR) document that the EPA prepared has been assigned EPA ICR number 2709.01. The EPA has placed a copy of the ICR in the docket for this rule, and it is briefly summarized here.

The EPA is finalizing an information collection request (ICR), related specifically to electric generating units (EGU), for the Federal “Good Neighbor Plan” for the 2015 Ozone National Ambient Air Quality Standards. The rule would amend the Cross-State Air Pollution Rule (CSAPR) NO_x Ozone Season Group 3 trading program addressing seasonal NO_x emissions in various states. Under the amendments, all EGU sources in the original twelve Group 3 states (Illinois, Indiana,

⁴³³ The provision formerly at § 97.826(e)(1) is being relocated to § 97.826(f)(1), and the provision formerly at § 97.826(e)(2) is being removed as no longer necessary.

Kentucky, Louisiana, Maryland, Michigan, New Jersey, New York, Ohio, Pennsylvania, Virginia, and West Virginia) would remain. Additionally, EGU sources in seven states (Alabama, Arkansas, Mississippi, Missouri, Oklahoma, Texas, and Wisconsin) currently covered by the CSAPR NO_x Ozone Season Group 2 Trading Program would transition from the Group 2 program to the revised Group 3 trading program beginning with the 2023 ozone season. Further, sources in three states not currently covered by any CSAPR NO_x ozone season trading program would join the revised Group 3 trading program: Minnesota, Nevada, and Utah. In total, EGU sources in 22 states would now be covered by the Group 3 program.

There is an existing ICR (OMB Control Number 2060-0667), that includes information collection requirements placed on EGU sources for the six Cross-State Air Pollution Rule (CSAPR) trading programs addressing sulfur dioxide (SO₂) emissions, annual nitrogen oxides (NO_x) emissions, or seasonal NO_x emissions in various sets of states, and the Texas SO₂ trading program which is modeled after CSAPR. This ICR accounts for the additional respondent burden related to the amendments to the CSAPR NO_x Ozone Group 3 trading program.

The principal information collection requirements under the CSAPR and Texas trading programs relate to the monitoring and reporting of emissions and associated data in accordance with 40 CFR part 75. Other information collection requirements under the programs concern the submittal of information necessary to allocate and transfer emissions allowances and the submittal of certificates of representation and other typically one-time registration forms.

Affected sources under the CSAPR and Texas trading programs are generally stationary, fossil fuel-fired boilers and combustion turbines serving generators larger than 25 megawatts (MW) producing electricity for sale. Most of these affected sources are also subject to the Acid Rain Program (ARP). The information collection requirements under the CSAPR and Texas trading programs and the ARP substantially overlap and are fully integrated. The burden and costs of overlapping requirements are accounted for in the ARP ICR (OMB Control Number 2060-0258). Thus, this ICR accounts for information collection burden and costs under the CSAPR NO_x Ozone Season Group 3 trading program that are incremental to the burden and costs

already accounted for in both the ARP and CSAPR ICRs.

For most sources already reporting data under the CSAPR NO_x Ozone Season Group 3 or the CSAPR NO_x Ozone Group 2 trading programs, the reporting requirements will remain identical so there will be no incremental burden or cost. Certain sources currently reporting data will be subject to additional emissions reporting requirements under the rule requiring these sources to make a one-time monitoring plan and DAHS update. These sources include those with a common stack configuration and/or those that are large, coal-fired EGUs. Additionally, sources with a common stack configuration have the option to install additional monitoring equipment to measure emissions at each individual unit within the facility, and for purposes of estimating information collection costs and burden, the EPA assumes certain sources will utilize this option. Finally, the assessment of incremental cost and burden are required for those sources in the three states not currently reporting data under a CSAPR NO_x Ozone Season program. Sources in Minnesota are already reporting data for the CSAPR NO_x Annual program with almost identical information collection requirements, requiring only a one-time monitoring plan and DAHS update. Most of the affected sources in Nevada and Utah are already reporting data as part of the Acid Rain Program, thus only requiring a monitoring plan and DAHS update as well. There are a small number of sources in Nevada and Utah that do not report emissions data to the EPA under 40 CFR part 75 and will need to implement a Part 75 monitoring methodology which includes burdens related to installation, certification, and necessary updates.

Respondents/affected entities: Industry respondents are stationary, fossil fuel-fired boilers and combustion turbines serving electricity generators subject to the CSAPR and Texas trading programs, as well as non-source entities voluntarily participating in allowance trading activities. Potential state respondents are states that can elect to submit state-determined allowance allocations for sources located in their states.

Respondent's obligation to respond: Industry respondents: voluntary and mandatory (sections 110(a) and 301(a) of the Clean Air Act).

Estimated number of respondents: The EPA estimates that there would be 120 industry respondents.

Frequency of response: on occasion, quarterly, and annually.

Total estimated additional burden: 2,289 hours (per year). Burden is defined at 5 CFR 1320.03(b).

Total estimated additional cost: \$356,623 (per year); includes \$182,379 annualized capital or operation & maintenance costs.

An agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number. The OMB control numbers for the EPA's regulations in 40 CFR are listed in 40 CFR part 9. When OMB approves this ICR, the Agency will announce that approval in the **Federal Register** and publish a technical amendment to 40 CFR part 9 to display the OMB control number for the approved information collection activities contained in this final rule.

2. Information Collection Request for Non-Electric Generating Units

The information collection activities in this final rule have been submitted for approval to the Office of Management and Budget (OMB) under the PRA. The Information Collection Request (ICR) document that the EPA prepared has been assigned EPA ICR number 2705.02. The EPA has filed a copy of the non-EGU ICR in the docket for this rule, and it is briefly summarized here.

ICR No. 2705.02 is a new request and it addresses the burden associated with new regulatory requirements under the final rule. Owners and operators of certain non-Electric Generating Unit (non-EGU) industry stationary sources will potentially modify or install new emissions controls and associated monitoring systems to meet the nitrogen oxides (NO_x) emissions limits of this final rule. The burden in this ICR reflects the new monitoring, calibrating, recordkeeping, reporting and testing activities required of covered industrial sources. This information is being collected to assure compliance with the final rule. In accordance with the Clean Air Act Amendments of 1990, any monitoring information to be submitted by sources is a matter of public record. Information received and identified by owners or operators as confidential business information (CBI) and approved as CBI by the EPA, in accordance with 40 CFR chapter I, part 2, subpart B, shall be maintained appropriately (see 40 CFR part 2; 41 FR 36902, September 1, 1976; amended by 43 FR 39999, September 8, 1978; 43 FR 42251, September 28, 1978; 44 FR 17674, March 23, 1979).

Respondents/affected entities: The respondents/affected entities are the owners/operators of certain non-EGU

industry sources in the following industry sectors: furnaces in Glass and Glass Product Manufacturing; boilers and furnaces in Iron and Steel Mills and Ferroalloy Manufacturing; kilns in Cement and Cement Product Manufacturing; reciprocating internal combustion engines in Pipeline Transportation of Natural Gas; and boilers in Metal Ore Mining, Basic Chemical Manufacturing, Petroleum and Coal Products Manufacturing, and Pulp, Paper, and Paperboard Mills; and combustors and incinerators in Solid Waste Combustors and Incinerators.

Respondent's obligation to respond: Voluntary and mandatory. (Sections 110(a) and 301(a) of the Clean Air Act.) All data that is recorded or reported by respondents is required by the final rule, titled "Federal "Good Neighbor Plan" for the 2015 Ozone National Ambient Air Quality Standards."

Estimated number of respondents: 3,328.

Frequency of response: The specific frequency for each information collection activity within the non-EGU ICR is shown at the end of the ICR document in Tables 1 through 18. In general, the frequency varies across the monitoring, recordkeeping, and reporting activities. Some recordkeeping such as work plan preparation is a one-time activity whereas pipeline engine maintenance recordkeeping is conducted quarterly. Reporting frequency is on an annual basis.

Total estimated burden: 11,481 hours (per year). Burden is defined at 5 CFR 1320.3(b).

Total estimated cost: \$3,823,000 (average per year); includes \$2,400,000 annualized capital or operation & maintenance costs.

An agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number. The OMB control numbers for the EPA's regulations in 40 CFR are listed in 40 CFR part 9. When OMB approves this ICR, the Agency will announce that approval in the **Federal Register** and publish a technical amendment to 40 CFR part 9 to display the OMB control number for the approved information collection activities contained in this final rule.

C. Regulatory Flexibility Act (RFA)

I certify that this action will not have a significant economic impact on a substantial number of small entities under the RFA. The small entities subject to the requirements of this action are small businesses, which includes EGUs and non-EGUs and are described in more detail below. In 2026,

the EPA identified a total of 29 small entities affected by the rule. Of these, 2 small entities may experience costs of greater than 1 percent of revenues. In 2026 for EGUs, the EPA identified 19 small entities. The EPA's decision to exclude units smaller than 25 MW capacity from the final rule, and exclusion of uncontrolled units smaller than 100 MW from backstop emissions rates significantly reduced the burden on small entities by reducing the number of affected small entity-owned units. Further, in 2026 for non-EGUs, there are ten small entities, and two small entities are estimated to have a cost-to-sales impact between 1.7 and 2.4 percent of their revenues.

The Agency has not determined that a significant number of small entities potentially affected by the rule will have compliance costs greater than 1 percent of annual revenues during the compliance period. The EPA has concluded that there will be no significant economic impact on a substantial number of small entities (No SISNOSE) for this rule overall. Details of this analysis are presented in Chapter 6 of the *RIA*, which is in the public docket.

D. Unfunded Mandates Reform Act (UMRA)

This action contains no unfunded Federal mandate for State, local, or Tribal governments as described in UMRA, 2 U.S.C. 1531–1538, and does not significantly or uniquely affect small governments. This action imposes no enforceable duty on any State, local, or Tribal government. This action contains a Federal mandate under UMRA, 2 U.S.C. 1531–1538, that may result in expenditures of \$100 million or more in any one year for the private sector. Accordingly, the costs and benefits associated with this action are discussed in section VIII of this preamble and in the *RIA*, which is in the docket for this rule. Additional details are presented in the *RIA*. This action is not subject to the requirements of UMRA section 203 because it contains no regulatory requirements that might significantly or uniquely affect small governments.

E. Executive Order 13132: Federalism

This action does not have federalism implications. It will not have substantial direct effects on the states, on the relationship between the National Government and the states, or on the distribution of power and responsibilities among the various levels of government.

F. Executive Order 13175: Consultation and Coordination With Indian Tribal Governments

This final action has tribal implications. However, it would neither impose substantial direct compliance costs on federally recognized tribal governments, nor preempt tribal law.

The EPA is finalizing a finding that interstate transport of ozone precursor emissions from 23 upwind states (Alabama, Arkansas, California, Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, Minnesota, Mississippi, Missouri, Nevada, New Jersey, New York, Ohio, Oklahoma, Pennsylvania, Texas, Utah, Virginia, West Virginia, and Wisconsin) is significantly contributing to downwind nonattainment or interfering with maintenance of the 2015 ozone NAAQS in other states. The EPA is promulgating FIP requirements to eliminate interstate transport of ozone precursors from these 23 states. Under CAA section 301(d)(4), the EPA is extending FIP requirements to apply in Indian country located within the upwind geography of the final rule, including Indian reservation lands and other areas of Indian country over which the EPA or a tribe has demonstrated that a tribe has jurisdiction. The EPA's determinations in this regard are described further in section III.C.2 of this document, *Application of Rule in Indian Country and Necessary or Appropriate Finding*. The EPA finds that all covered existing and new EGU and non-EGU sources that are located in the "301(d) FIP" areas within the geographic boundaries of the covered states, and which would be subject to this rule if located within areas subject to state CAA planning authority, should be included in this rule. To the EPA's knowledge, only one covered existing EGU or non-EGU source is located within the 301(d) FIP areas: the Bonanza Power Plant, an EGU source, located on the Uintah and Ouray Reservation, geographically located within the borders of Utah. This final action has tribal implication because of the extension of FIP requirements into Indian country and because, in general, tribes have a vested interest in how this final rule would affect air quality.

The EPA hosted an environmental justice webinar on October 26, 2021, that was attended by state regulatory authorities, environmental groups, federally recognized tribes, and small business stakeholders. The EPA issued tribal consultation letters addressed to 574 tribes in February 2022 after the proposed rule was signed. The EPA received no further requests to facilitate

additional tribal consultation for the final rule.

G. Executive Order 13045: Protection of Children From Environmental Health Risks and Safety Risks

The EPA interprets Executive Order 13045 as applying only to those regulatory actions that concern environmental health or safety risks that the EPA has reason to believe may disproportionately affect children, per the definition of “covered regulatory action” in section 2–202 of the Executive order. This action is not subject to Executive Order 13045 because it implements a previously promulgated health-based Federal standard. This action’s health and risk assessments are contained in Chapter 5 and 6 of the *RIA*. The EPA believes that the ozone-related benefits, PM_{2.5}-related benefits, and CO₂-related benefits from this final rule will further improve children’s health. Additionally, the ozone and PM_{2.5} EJ exposure analyses in Chapter 7 of the *RIA* suggests that nationally, children (ages 0–17) will experience at least as great a reduction in ozone and PM_{2.5} exposures as adults (ages 18–64) in 2023 and 2026 under all regulatory alternatives of this rulemaking.

H. Executive Order 13211: Actions Concerning Regulations That Significantly Affect Energy Supply, Distribution or Use

This action is not a “significant energy action” because it is not likely to have a significant adverse effect on the supply, distribution, or use of energy. The EPA has prepared a Statement of Energy Effects for the final regulatory control alternative as follows. The Agency estimates a 1 percent change in retail electricity prices on average across the contiguous U.S. in the 2025 run year, a 4 percent reduction (28 GWh) in coal-fired electricity generation, a 2 percent increase (21 GWh) in natural gas-fired electricity generation, and a 1 percent increase (8 GWh) in renewable electricity generation as a result of this final rule. The EPA projects that utility power sector delivered natural gas prices will change by less than 1 percent in 2025. Details of the estimated energy effects are presented in Chapter 4 of the *RIA*, which is in the public docket.

I. National Technology Transfer and Advancement Act (NTTAA)

This rulemaking does not involve technical standards.

J. Executive Order 12898: Federal Actions To Address Environmental Justice in Minority Populations and Low-Income Populations

Executive Order 12898 (59 FR 7629, February 16, 1994) directs Federal agencies, to the greatest extent practicable and permitted by law, to make environmental justice part of their mission by identifying and addressing, as appropriate, disproportionately high and adverse human health or environmental effects of their programs, policies, and activities on minority populations (people of color and/or indigenous peoples) and low-income populations.

The EPA believes that the human health or environmental conditions that exist prior to this action result in or have the potential to result in disproportionate and adverse human health or environmental effects on people of color, low-income populations and/or Indigenous peoples. The documentation for this decision is contained in section VII of this document, *Environmental Justice Analytical Considerations and Stakeholder Outreach and Engagement*, and in Chapter 7, *Environmental Justice Impacts* of the *RIA*, which is in the public document. Briefly, proximity demographic analyses found larger percentages of Hispanics, African Americans, people below the poverty level, people with less educational attainment, and people linguistically isolated are living within 5 km and 10 km of an affected EGU, compared to national averages. It also finds larger percentages of African Americans, people below the poverty level, and with less educational attainment living within 5 km and 10 km of an affected non-EGU facility. Considering the known limitations of proximity analyses, including the inability to assess policy-specific impacts, we also performed analysis of baseline EJ ozone and PM_{2.5} exposures. Baseline ozone and PM_{2.5} exposure analyses show that certain populations, such as Hispanics, Asians, those linguistically isolated, those less educated, and children may experience disproportionately higher ozone and PM_{2.5} exposures as compared to the national average. American Indians may also experience disproportionately higher ozone concentrations than the reference group.

The EPA believes that this action is not likely to change existing disproportionate and adverse effects on people of color, low-income populations and/or Indigenous peoples. Specifically, we do not find evidence that potential EJ concerns related to ozone or PM_{2.5}

exposures will be meaningfully exacerbated or mitigated in the regulatory alternatives under consideration as compared to the baseline. We infer that baseline disparities in the ozone and PM_{2.5} concentration burdens are likely to persist after implementation of the regulatory action or alternatives under consideration, due to similar modeled concentration reductions across population demographics. Importantly, the action described in this rule is expected to lower ozone and PM_{2.5} in many areas, including in ozone nonattainment areas, and thus mitigate some pre-existing health risks across all populations evaluated.

The EPA additionally identified and addressed environmental justice concerns by providing the public, including those communities disproportionately impacted by the burdens of pollution, opportunities for meaningful engagement with the EPA on this action through outreach activities conducted by the Agency. The information supporting this Executive order review is contained in section VII of this document.

K. Congressional Review Act

This action is subject to the CRA, and the EPA will submit a rule report to each House of the Congress and to the Comptroller General of the United States. Because this action falls within the definition provided by 5 U.S.C. 804(2), the rule’s effective date is consistent with 5 U.S.C. 801(a)(3).

L. Determinations Under CAA Section 307(b)(1) and (d)

Section 307(b)(1) of the CAA governs judicial review of final actions by the EPA. This section provides, in part, that petitions for review must be filed in the D.C. Circuit: (i) when the agency action consists of “nationally applicable regulations promulgated, or final actions taken, by the Administrator,” or (ii) when such action is locally or regionally applicable, but “such action is based on a determination of nationwide scope or effect and if in taking such action the Administrator finds and publishes that such action is based on such a determination.” For locally or regionally applicable final actions, the CAA reserves to the EPA complete discretion whether to invoke the exception in (ii).⁴³⁴

⁴³⁴ In deciding whether to invoke the exception by making and publishing a finding that an action is based on a determination of nationwide scope or effect, the Administrator takes into account a number of policy considerations, including his judgment balancing the benefit of obtaining the D.C.

This rulemaking is “nationally applicable” within the meaning of CAA section 307(b)(1). In this final action, the EPA is applying a uniform legal interpretation and common, nationwide analytical methods with respect to the requirements of CAA section 110(a)(2)(D)(i)(I) concerning interstate transport of pollution (*i.e.*, “good neighbor” requirements) to promulgate FIPs that satisfy these requirements for the 2015 ozone NAAQS. Based on these analyses, the EPA is promulgating FIPs for 23 states located across a wide geographic area in eight of the ten EPA regions and ten Federal judicial circuits. Given that this action addresses implementation of the good neighbor requirements of CAA section 110(a)(2)(D)(i)(I) in a large number of states located across the country, and given the interdependent nature of interstate pollution transport and the common core of knowledge and analysis involved in promulgating these FIPs, this is a “nationally applicable” action within the meaning of CAA section 307(b)(1).

In the alternative, to the extent a court finds this action to be locally or regionally applicable, the Administrator is exercising the complete discretion afforded to him under the CAA to make and publish a finding that this action is based on a determination of “nationwide scope or effect” within the meaning of CAA section 307(b)(1). In this final action, the EPA is interpreting and applying section 110(a)(2)(d)(i)(I) of the CAA for the 2015 ozone NAAQS based on a common core of nationwide policy judgments and technical analysis concerning the interstate transport of pollutants throughout the continental U.S. In particular, the EPA is applying here the same, nationally consistent 4-step framework for assessing good neighbor obligations for the 2015 ozone NAAQS that it has applied in other nationally applicable rulemakings, such as CSAPR, the CSAPR Update, and the Revised CSAPR Update. The EPA is relying on the results from nationwide photochemical grid modeling using a 2016 base year and 2023 projection year as the primary basis for its assessment of air quality conditions and pollution contribution levels at Step 1 and Step 2 of that 4-step framework and applying a nationally uniform approach to the identification of nonattainment and maintenance receptors across the entire

Circuit’s authoritative centralized review versus allowing development of the issue in other contexts and the best use of agency resources.

geographic area covered by this final rule.⁴³⁵

The Administrator finds that this is a matter on which national uniformity in judicial resolution of any petitions for review is desirable, to take advantage of the D.C. Circuit’s administrative law expertise, and to facilitate the orderly development of the basic law under the Act. The Administrator also finds that consolidated review of this action in the D.C. Circuit will avoid piecemeal litigation in the regional circuits, further judicial economy, and eliminate the risk of inconsistent results for different states, and that a nationally consistent approach to the CAA’s mandate concerning interstate transport of ozone pollution constitutes the best use of agency resources. The EPA’s responses to comments on the appropriate venue for petitions for review are contained in section 1.10 of the *RTC* document.

For these reasons, this final action is nationally applicable or, alternatively, the Administrator is exercising the complete discretion afforded to him by the CAA and finds that this final action is based on a determination of nationwide scope or effect for purposes of CAA section 307(b)(1) and is publishing that finding in the **Federal Register**. Under section 307(b)(1) of the CAA, petitions for judicial review of this action must be filed in the United States Court of Appeals for the District of Columbia Circuit by August 4, 2023.

This action is subject to the provisions of section 307(d). CAA section 307(d)(1)(B) provides that section 307(d) applies to, among other things, “the promulgation or revision of an implementation plan by the Administrator under [CAA section 110(c)].” 42 U.S.C. 7407(d)(1)(B). This action, among other things, promulgates new Federal implementation plans pursuant to the authority of section 110(c). To the extent any portion of this final action is not expressly identified under section 307(d)(1)(B), the Administrator determines that the provisions of section 307(d) apply to such final action. *See* CAA section 307(d)(1)(V) (the provisions of section 307(d) apply to “such other actions as the Administrator may determine”).

⁴³⁵ In the report on the 1977 Amendments that revised section 307(b)(1) of the CAA, Congress noted that the Administrator’s determination that the “nationwide scope or effect” exception applies would be appropriate for any action that has a scope or effect beyond a single judicial circuit. *See* H.R. Rep. No. 95–294 at 323, 324, reprinted in 1977 U.S.C.C.A.N. 1402–03.

List of Subjects

40 CFR Part 52

Environmental protection, Administrative practice and procedure, Air pollution control, Incorporation by reference, Intergovernmental relations, Nitrogen oxides, Ozone, Particulate matter, Sulfur dioxide.

40 CFR Part 75

Environmental protection, Administrative practice and procedure, Air pollution control, Continuous emissions monitoring, Electric power plants, Nitrogen oxides, Ozone, Particulate matter, Reporting and recordkeeping requirements, Sulfur dioxide.

40 CFR Part 78

Environmental protection, Administrative practice and procedure, Air pollution control, Electric power plants, Nitrogen oxides, Ozone, Particulate matter, Sulfur dioxide.

40 CFR Part 97

Environmental protection, Administrative practice and procedure, Air pollution control, Electric power plants, Nitrogen oxides, Ozone, Particulate matter, Reporting and recordkeeping requirements, Sulfur dioxide.

Michael S. Regan,
Administrator.

For the reasons stated in the preamble, parts 52, 75, 78, and 97 of title 40 of the Code of Federal Regulations are amended as follows:

PART 52—APPROVAL AND PROMULGATION OF IMPLEMENTATION PLANS

■ 1. The authority citation for part 52 continues to read as follows:

Authority: 42 U.S.C. 7401 *et seq.*

Subpart A—General Provisions

- 2. Amend § 52.38 by:
- a. In paragraph (a)(1), removing “(NO_x), except” and adding in its place “(NO_x) for sources meeting the applicability criteria set forth in subpart AAAAA, except”;
 - b. In paragraph (a)(3) introductory text:
 - i. Removing “(a)(2)(i) or (ii)” and adding in its place “(a)(2)”; and
 - ii. Removing “the State and” and adding in its place “sources in the State and areas of Indian country within the borders of the State subject to the State’s SIP authority for”;
 - c. In paragraph (a)(3)(i), removing “State and” and adding in its place

“State and areas of Indian country within the borders of the State subject to the State’s SIP authority and that”;

■ d. In paragraph (a)(4) introductory text, removing “for the State’s sources, and” and adding in its place “with regard to sources in the State and areas of Indian country within the borders of the State subject to the State’s SIP authority, and”;

■ e. Revising table 1 to paragraph (a)(4)(i)(B);

■ f. In paragraph (a)(4)(ii), removing “deadlines for submission of allocations or auction results under paragraphs (a)(4)(i)(B) and (C)” and adding in its place “deadline for submission of allocations or auction results under paragraph (a)(4)(i)(B)”;

■ g. In paragraph (a)(5) introductory text, removing “State (but not sources in any Indian country within the borders of the State), regulations” and adding in its place “State and areas of Indian country within the borders of the State subject to the State’s SIP authority, regulations”;

■ h. Revising table 2 to paragraph (a)(5)(i)(B);

■ i. In paragraph (a)(5)(iv), removing “Indian country within the borders of the State” and adding in its place “areas of Indian country within the borders of the State not subject to the State’s SIP authority”;

■ j. In paragraph (a)(5)(v), removing “Indian country within the borders of the State, the” and adding in its place “areas of Indian country within the borders of the State not subject to the State’s SIP authority, the”;

■ k. In paragraph (a)(5)(vi), removing “deadlines for submission of allocations or auction results under paragraphs (a)(5)(i)(B) and (C)” and adding in its place “deadline for submission of allocations or auction results under paragraph (a)(5)(i)(B)”;

■ l. Revising paragraphs (a)(6) and (a)(7)(ii);

■ m. Adding paragraph (a)(7)(iii);

■ n. In paragraphs (a)(8)(i) and (ii), removing “the State and” and adding in its place “sources in the State and areas of Indian country within the borders of the State subject to the State’s SIP authority for”;

■ o. In paragraph (a)(8)(iii), removing “State (but not sources in any Indian country within the borders of the State):” and adding in its place “State and areas of Indian country within the borders of the State subject to the State’s SIP authority:”;

■ p. In paragraph (b)(1), removing “(year), except” and adding in its place “(year) for sources meeting the applicability criteria set forth in

subparts BBBBB, EEEEE, and GGGGG, except”;

■ q. Redesignating paragraphs (b)(2)(i) and (ii) as paragraphs (b)(2)(i)(A) and (B), respectively, paragraphs (b)(2)(iii) and (iv) as paragraphs (b)(2)(ii)(A) and (B), respectively, and paragraph (b)(2)(v) as paragraph (b)(2)(iii)(A);

■ r. In newly redesignated paragraph (b)(2)(ii)(A), removing “Alabama, Arkansas, Iowa, Kansas, Mississippi, Missouri, Oklahoma, Tennessee, Texas, and Wisconsin.” and adding in its place “Iowa, Kansas, and Tennessee.”;

■ s. Adding paragraphs (b)(2)(ii)(C) and (b)(2)(iii)(B) and (C);

■ t. In paragraph (b)(3) introductory text:

■ i. Removing “or (ii)”;

■ ii. Removing “the State and” and adding in its place “sources in the State and areas of Indian country within the borders of the State subject to the State’s SIP authority for”;

■ u. In paragraph (b)(3)(i), removing “State and” and adding in its place “State and areas of Indian country within the borders of the State subject to the State’s SIP authority and that”;

■ v. Revising paragraph (b)(4) introductory text;

■ w. Removing and reserving paragraph (b)(4)(i);

■ x. Revising table 3 to paragraph (b)(4)(ii)(B) and paragraphs (b)(4)(iii) and (b)(5) introductory text;

■ y. Removing and reserving paragraph (b)(5)(i);

■ z. Revising table 4 to paragraph (b)(5)(ii)(B);

■ aa. In paragraph (b)(5)(v), removing “Indian country within the borders of the State” and adding in its place “areas of Indian country within the borders of the State not subject to the State’s SIP authority”;

■ bb. In paragraph (b)(5)(vi), removing “Indian country within the borders of the State, the” and adding in its place “areas of Indian country within the borders of the State not subject to the State’s SIP authority, the”;

■ cc. Revising paragraphs (b)(5)(vii), (b)(7) introductory text, (b)(7)(i), and (b)(8) introductory text;

■ dd. Removing and reserving paragraphs (b)(8)(i) and (ii);

■ ee. Revising paragraph (b)(8)(iii)(A), table 5 to paragraph (b)(8)(iii)(B), and paragraphs (b)(8)(iv) and (b)(9) introductory text;

■ ff. Removing and reserving paragraphs (b)(9)(i) and (ii);

■ gg. Revising paragraph (b)(9)(iii)(A) and table 6 to paragraph (b)(9)(iii)(B);

■ hh. In paragraph (b)(9)(vi), removing “Indian country within the borders of the State” and adding in its place “areas of Indian country within the borders of

the State not subject to the State’s SIP authority”;

■ ii. Revising paragraphs (b)(9)(vii) and (viii), (b)(10) introductory text, (b)(10)(i) and (ii), (b)(10)(v)(A) and (B), and (b)(11) introductory text;

■ jj. Removing and reserving paragraphs (b)(11)(i) and (ii);

■ kk. In paragraph (b)(11)(iii) introductory text, removing “§§ 97.1011(a) and (b)(1) and 97.1012(a)” and adding in its place “§ 97.1011(a)(1)”;

■ ll. Revising paragraph (b)(11)(iii)(A);

■ mm. In paragraph (b)(11)(iii)(B):

■ i. Removing “§ 97.1011(a)” and adding in its place “§ 97.1011(a)(1)”;

and

■ ii. Adding “and” after the semicolon;

■ nn. Removing and reserving paragraph (b)(11)(iii)(C);

■ oo. Revising paragraphs (b)(11)(iii)(D), (b)(11)(iv), and (b)(12) introductory text;

■ pp. Removing and reserving paragraphs (b)(12)(i) and (ii);

■ qq. In paragraph (b)(12)(iii) introductory text, removing “§§ 97.1011(a) and (b)(1) and 97.1012(a)” and adding in its place “§ 97.1011(a)(1)”;

■ rr. Revising paragraph (b)(12)(iii)(A);

■ ss. In paragraph (b)(12)(iii)(B):

■ i. Removing “§ 97.1011(a)” and adding in its place “§ 97.1011(a)(1)”;

and

■ ii. Adding “and” after the semicolon;

■ tt. Removing and reserving paragraph (b)(12)(iii)(C);

■ uu. Revising paragraphs (b)(12)(iii)(D), (b)(12)(vi) through (viii), (b)(13) introductory text, and (b)(13)(i);

■ vv. In paragraph (b)(13)(ii), removing “regulations, including any sources made subject to such regulations pursuant to paragraph (b)(9)(ii) or (b)(12)(ii) of this section, the” and adding in its place “regulations the”;

■ ww. In paragraph (b)(14)(i)(F), removing “§ 97.825(b)” and adding in its place “§§ 97.806(c)(2) and (3) and 97.825(b)”;

■ xx. In paragraph (b)(14)(i)(G), removing “§ 97.826(e)” and adding in its place “§ 97.826(f)”;

■ yy. Revising paragraphs (b)(14)(ii) and (iii);

■ zz. In paragraph (b)(15)(i), removing “the State and” and adding in its place “sources in the State and areas of Indian country within the borders of the State subject to the State’s SIP authority for”;

■ aaa. Revising paragraph (b)(15)(ii);

■ bbb. In paragraph (b)(15)(iii), removing “State (but not sources in any Indian country within the borders of the State):” and adding in its place “State and areas of Indian country within the borders of the State subject to the State’s SIP authority:”;

- ccc. In paragraph (b)(16)(i)(A), removing “the State and” and adding in its place “sources in the State and areas of Indian country within the borders of the State subject to the State’s SIP authority for”;
- ddd. Revising paragraphs (b)(16)(i)(B) and (C);
- eee. Redesignating paragraph (b)(16)(ii) as paragraph (b)(16)(ii)(A),

and, in newly redesignated paragraph (b)(16)(ii)(A), removing “(b)(2)(iv)” and adding in its place “(b)(2)(ii)(B)”;

- fff. Adding paragraph (b)(16)(ii)(B); and
- ggg. Revising paragraphs (b)(17)(i) through (iii).

The revisions and additions read as follows:

§ 52.38 What are the requirements of the Federal Implementation Plans (FIPs) for the Cross-State Air Pollution Rule (CSAPR) relating to emissions of nitrogen oxides?

- (a) * * *
- (4) * * *
- (i) * * *
- (B) * * *

TABLE 1 TO PARAGRAPH (a)(4)(i)(B)

Year of the control period for which CSAPR NO _x Annual allowances are allocated or auctioned	Deadline for submission of allocations or auction results to the administrator
2017 or 2018	June 1, 2016.
2019 or 2020	June 1, 2017.
2021 or 2022	June 1, 2018.
2023	June 1, 2019.
2024	June 1, 2020.
2025 or any year thereafter	June 1 of the year before the year of the control period.

- * * * * *
- (5) * * *
- (i) * * *

(B) * * *

TABLE 2 TO PARAGRAPH (a)(5)(i)(B)

Year of the control period for which CSAPR NO _x Annual allowances are allocated or auctioned	Deadline for submission of allocations or auction results to the administrator
2017 or 2018	June 1, 2016.
2019 or 2020	June 1, 2017.
2021 or 2022	June 1, 2018.
2023	June 1, 2019.
2024	June 1, 2020.
2025 or any year thereafter	June 1 of the year before the year of the control period.

* * * * *

(6) *Withdrawal of CSAPR FIP provisions relating to NO_x annual emissions.* Except as provided in paragraph (a)(7) of this section, following promulgation of an approval by the Administrator of a State’s SIP revision as correcting the SIP’s deficiency that is the basis for the CSAPR Federal Implementation Plan set forth in paragraphs (a)(1), (a)(2)(i), and (a)(3) and (4) of this section for sources in the State and Indian country within the borders of the State subject to the State’s SIP authority, the provisions of paragraph (a)(2)(i) of this section will no longer apply to sources in the State and areas of Indian country within the borders of the State subject to the State’s SIP authority, unless the Administrator’s approval of the SIP revision is partial or conditional, and will continue to apply to sources in areas of Indian country within the borders of the State not subject to the State’s SIP authority, provided that if the CSAPR Federal Implementation Plan was promulgated as a partial rather than full remedy for an obligation of the

State to address interstate air pollution, the SIP revision likewise will constitute a partial rather than full remedy for the State’s obligation unless provided otherwise in the Administrator’s approval of the SIP revision.

(7) * * *

(ii) Notwithstanding the provisions of paragraph (a)(6) of this section, if, at the time of any approval of a State’s SIP revision under this section, the Administrator has already started recording any allocations of CSAPR NO_x Annual allowances under subpart AAAAA of part 97 of this chapter to units in the State and areas of Indian country within the borders of the State subject to the State’s SIP authority for a control period in any year, the provisions of subpart AAAAA authorizing the Administrator to complete the allocation and recordation of such allowances to such units for each such control period shall continue to apply, unless provided otherwise by such approval of the State’s SIP revision.

(iii) Notwithstanding any discontinuation pursuant to paragraph

(a)(2)(ii) or (a)(6) of this section of the applicability of subpart AAAAA of part 97 of this chapter to the sources in a State and areas of Indian country within the borders of the State subject to the State’s SIP authority with regard to emissions occurring in any control period, the following provisions shall continue to apply with regard to all CSAPR NO_x Annual allowances at any time allocated for any control period to any source or other entity in the State and areas of Indian country within the borders of the State subject to the State’s SIP authority and shall apply to all entities, wherever located, that at any time held or hold such allowances:

(A) The provisions of § 97.426(c) of this chapter (concerning the transfer of CSAPR NO_x Annual allowances between certain Allowance Management System accounts under common control).

(B) [Reserved]

* * * * *

- (b) * * *
- (2) * * *
- (ii) * * *

(C) The provisions of subpart EEEEE of part 97 of this chapter apply to sources in each of the following States and Indian country located within the borders of such States with regard to emissions occurring in 2017 through 2022 only, except as provided in paragraph (b)(14)(iii) of this section: Alabama, Arkansas, Mississippi, Missouri, Oklahoma, Texas, and Wisconsin.

(iii) * * *

(B) The provisions of subpart GGGGG of part 97 of this chapter apply to sources in each of the following States and Indian country located within the

borders of such States with regard to emissions occurring in 2023 and each subsequent year: Alabama, Arkansas, Mississippi, Missouri, Oklahoma, Texas, and Wisconsin.

(C) The provisions of subpart GGGGG of part 97 of this chapter apply to sources in each of the following States and Indian country located within the borders of such States with regard to emissions occurring on and after August 4, 2023, and in each subsequent year: Minnesota, Nevada, and Utah.

* * * * *

(4) *Abbreviated SIP revisions replacing certain provisions of the*

Federal CSAPR NO_x Ozone Season Group 1 Trading Program. A State listed in paragraph (b)(2)(i)(A) of this section may adopt and include in a SIP revision, and the Administrator will approve, regulations replacing specified provisions of subpart BBBBB of part 97 of this chapter with regard to sources in the State and areas of Indian country within the borders of the State subject to the State's SIP authority, and not substantively replacing any other provisions, as follows:

* * * * *

(ii) * * *
(B) * * *

TABLE 3 TO PARAGRAPH (b)(4)(ii)(B)

Year of the control period for which CSAPR NO _x Ozone Season Group 1 allowances are allocated or auctioned	Deadline for submission of allocations or auction results to the administrator
2017 or 2018	June 1, 2016.
2019 or 2020	June 1, 2017.
2021 or 2022	June 1, 2018.
2023	June 1, 2019.
2024	June 1, 2020.
2025 or any year thereafter	June 1 of the year before the year of the control period.

* * * * *

(iii) Provided that the State must submit a complete SIP revision meeting the requirements of paragraph (b)(4)(ii) of this section by December 1 of the year before the year of the deadline for submission of allocations or auction results under paragraph (b)(4)(ii)(B) of this section applicable to the first control period for which the State wants to make allocations or hold an auction under paragraph (b)(4)(ii) of this section.

(5) *Full SIP revisions adopting State CSAPR NO_x Ozone Season Group 1 Trading Programs.* A State listed in paragraph (b)(2)(i)(A) of this section may adopt and include in a SIP revision, and the Administrator will approve, as correcting the deficiency in the SIP that is the basis for the CSAPR Federal Implementation Plan set forth in paragraphs (b)(1), (b)(2)(i), and (b)(3) and (4) of this section with regard to sources in the State and areas of Indian

country within the borders of the State subject to the State's SIP authority, regulations that are substantively identical to the provisions of the CSAPR NO_x Ozone Season Group 1 Trading Program set forth in §§ 97.502 through 97.535 of this chapter, except that the SIP revision:

* * * * *

(ii) * * *
(B) * * *

TABLE 4 TO PARAGRAPH (b)(5)(ii)(B)

Year of the control period for which CSAPR NO _x Ozone Season group 1 allowances are allocated or auctioned	Deadline for submission of allocations or auction results to the administrator
2017 or 2018	June 1, 2016.
2019 or 2020	June 1, 2017.
2021 or 2022	June 1, 2018.
2023	June 1, 2019.
2024	June 1, 2020.
2025 or any year thereafter	June 1 of the year before the year of the control period.

* * * * *

(vii) Provided that the State must submit a complete SIP revision meeting the requirements of paragraphs (b)(5)(ii) through (v) of this section by December 1 of the year before the year of the deadline for submission of allocations or auction results under paragraph (b)(5)(ii)(B) of this section applicable to the first control period for which the State wants to make allocations or hold an auction under paragraph (b)(5)(ii) of this section.

* * * * *

(7) *State-determined allocations of CSAPR NO_x Ozone Season Group 2 allowances for 2018.* A State listed in paragraph (b)(2)(ii) of this section may adopt and include in a SIP revision, and the Administrator will approve, as CSAPR NO_x Ozone Season Group 2 allowance allocation provisions replacing the provisions in § 97.811(a) of this chapter with regard to sources in the State and areas of Indian country within the borders of the State subject to the State's SIP authority for the control period in 2018, a list of CSAPR

NO_x Ozone Season Group 2 units and the amount of CSAPR NO_x Ozone Season Group 2 allowances allocated to each unit on such list, provided that the list of units and allocations meets the following requirements:

(i) All of the units on the list must be units that are in the State and areas of Indian country within the borders of the State subject to the State's SIP authority and that commenced commercial operation before January 1, 2015;

* * * * *

(8) *Abbreviated SIP revisions replacing certain provisions of the Federal CSAPR NO_x Ozone Season Group 2 Trading Program.* A State listed in paragraph (b)(2)(ii) of this section may adopt and include in a SIP revision, and the Administrator will approve, regulations replacing specified provisions of subpart EEEEE of part 97 of this chapter with regard to sources in the State and areas of Indian country

within the borders of the State subject to the State's SIP authority, and not substantively replacing any other provisions, as follows:

* * * * *

(iii) * * *

(A) Requires the State or the permitting authority to allocate and, if applicable, auction a total amount of CSAPR NO_x Ozone Season Group 2 allowances for any such control period

not exceeding the amount, under §§ 97.810(a) and 97.821 of this chapter for the State and such control period, of the CSAPR NO_x Ozone Season Group 2 trading budget minus the sum of the Indian country new unit set-aside and the amount of any CSAPR NO_x Ozone Season Group 2 allowances already allocated and recorded by the Administrator;

(B) * * *

TABLE 5 TO PARAGRAPH (b)(8)(iii)(B)

Year of the control period for which CSAPR NO _x Ozone Season Group 2 allowances are allocated or auctioned	Deadline for submission of allocations or auction results to the administrator
2019 or 2020	June 1, 2018.
2021 or 2022	June 1, 2019.
2023 or 2024	June 1, 2020.
2025 or any year thereafter	June 1 of the year before the year of the control period.

* * * * *

(iv) Provided that the State must submit a complete SIP revision meeting the requirements of paragraph (b)(8)(iii) of this section by December 1 of the year before the year of the deadline for submission of allocations or auction results under paragraph (b)(8)(iii)(B) of this section applicable to the first control period for which the State wants to make allocations or hold an auction under paragraph (b)(8)(iii) of this section.

(9) *Full SIP revisions adopting State CSAPR NO_x Ozone Season Group 2 Trading Programs.* A State listed in paragraph (b)(2)(ii) of this section may

adopt and include in a SIP revision, and the Administrator will approve, as correcting the deficiency in the SIP that is the basis for the CSAPR Federal Implementation Plan set forth in paragraphs (b)(1), (b)(2)(ii), and (b)(7) and (8) of this section with regard to sources in the State and areas of Indian country within the borders of the State subject to the State's SIP authority, regulations that are substantively identical to the provisions of the CSAPR NO_x Ozone Season Group 2 Trading Program set forth in §§ 97.802 through 97.835 of this chapter, except that the SIP revision:

* * * * *

(iii) * * *

(A) Requires the State or the permitting authority to allocate and, if applicable, auction a total amount of CSAPR NO_x Ozone Season Group 2 allowances for any such control period not exceeding the amount, under §§ 97.810(a) and 97.821 of this chapter for the State and such control period, of the CSAPR NO_x Ozone Season Group 2 trading budget minus the sum of the Indian country new unit set-aside and the amount of any CSAPR NO_x Ozone Season Group 2 allowances already allocated and recorded by the Administrator;

(B) * * *

TABLE 6 TO PARAGRAPH (b)(9)(iii)(B)

Year of the control period for which CSAPR NO _x Ozone Season Group 2 allowances are allocated or auctioned	Deadline for submission of allocations or auction results to the administrator
2019 or 2020	June 1, 2018.
2021 or 2022	June 1, 2019.
2023 or 2024	June 1, 2020.
2025 or any year thereafter	June 1 of the year before the year of the control period.

* * * * *

(vii) Provided that, if and when any covered unit is located in areas of Indian country within the borders of the State not subject to the State's SIP authority, the Administrator may modify his or her approval of the SIP revision to exclude the provisions in §§ 97.802 (definitions of "common designated representative", "common designated representative's assurance level", and "common designated representative's share"), 97.806(c)(2), and 97.825 of this chapter and the portions of other provisions of subpart EEEEE of part 97 of this chapter referencing §§ 97.802, 97.806(c)(2), and

97.825 and may modify any portion of the CSAPR Federal Implementation Plan that is not replaced by the SIP revision to include these provisions; and

(viii) Provided that the State must submit a complete SIP revision meeting the requirements of paragraphs (b)(9)(iii) through (vi) of this section by December 1 of the year before the year of the deadline for submission of allocations or auction results under paragraph (b)(9)(iii)(B) of this section applicable to the first control period for which the State wants to make allocations or hold an auction under paragraph (b)(9)(iii) of this section.

(10) *State-determined allocations of CSAPR NO_x Ozone Season Group 3 allowances for 2024.* A State listed in paragraph (b)(2)(iii) of this section may adopt and include in a SIP revision, and the Administrator will approve, as CSAPR NO_x Ozone Season Group 3 allowance allocation provisions replacing the provisions in § 97.1011(a)(1) of this chapter with regard to sources in the State and areas of Indian country within the borders of the State subject to the State's SIP authority for the control period in 2024, a list of CSAPR NO_x Ozone Season Group 3 units and the amount of CSAPR NO_x Ozone Season Group 3 allowances

allocated to each unit on such list, provided that the list of units and allocations meets the following requirements:

(i) All of the units on the list must be units that are in the State and areas of Indian country within the borders of the State subject to the State's SIP authority and that commenced commercial operation before January 1, 2021;

(ii) The total amount of CSAPR NO_x Ozone Season Group 3 allowance allocations on the list must not exceed the amount, under § 97.1010 of this chapter for the State and the control period in 2024, of the CSAPR NO_x Ozone Season Group 3 trading budget minus the sum of the Indian country existing unit set-aside and the new unit set-aside;

* * * * *
(v) * * *

(A) By August 4, 2023, the State must notify the Administrator electronically in a format specified by the Administrator of the State's intent to submit to the Administrator a complete SIP revision meeting the requirements of paragraphs (b)(10)(i) through (iv) of this section by September 1, 2023; and

(B) The State must submit to the Administrator a complete SIP revision described in paragraph (b)(10)(v)(A) of this section by September 1, 2023.

(11) *Abbreviated SIP revisions replacing certain provisions of the Federal CSAPR NO_x Ozone Season Group 3 Trading Program.* A State listed in paragraph (b)(2)(iii) of this section may adopt and include in a SIP revision, and the Administrator will approve, regulations replacing specified provisions of subpart GGGGG of part 97 of this chapter with regard to sources in the State and areas of Indian country within the borders of the State subject to the State's SIP authority, and not substantively replacing any other provisions, as follows:

* * * * *
(iii) * * *

(A) Requires the State or the permitting authority to allocate and, if applicable, auction a total amount of CSAPR NO_x Ozone Season Group 3 allowances for any such control period not exceeding the amount, under §§ 97.1010 and 97.1021 of this chapter for the State and such control period, of the CSAPR NO_x Ozone Season Group 3 trading budget minus the sum of the Indian country existing unit set-aside, the new unit set-aside, and the amount of any CSAPR NO_x Ozone Season Group 3 allowances already allocated and recorded by the Administrator;

* * * * *

(D) Does not provide for any change, after the submission deadlines in paragraph (b)(11)(iii)(B) of this section, in the allocations submitted to the Administrator by such deadlines and does not provide for any change in any allocation determined and recorded by the Administrator under subpart GGGGG of part 97 of this chapter or § 97.526(d) or § 97.826(d) or (e) of this chapter; and

(iv) Provided that the State must submit a complete SIP revision meeting the requirements of paragraph (b)(11)(iii) of this section by December 1 of the year before the year of the deadline for submission of allocations or auction results under paragraph (b)(11)(iii)(B) of this section applicable to the first control period for which the State wants to make allocations or hold an auction under paragraph (b)(11)(iii) of this section.

(12) *Full SIP revisions adopting State CSAPR NO_x Ozone Season Group 3 Trading Programs.* A State listed in paragraph (b)(2)(iii) of this section may adopt and include in a SIP revision, and the Administrator will approve, as correcting the deficiency in the SIP that is the basis for the CSAPR Federal Implementation Plan set forth in paragraphs (b)(1), (b)(2)(iii), and (b)(10) and (11) of this section with regard to sources in the State and areas of Indian country within the borders of the State subject to the State's SIP authority, regulations that are substantively identical to the provisions of the CSAPR NO_x Ozone Season Group 3 Trading Program set forth in §§ 97.1002 through 97.1035 of this chapter, except that the SIP revision:

* * * * *
(iii) * * *

(A) Requires the State or the permitting authority to allocate and, if applicable, auction a total amount of CSAPR NO_x Ozone Season Group 3 allowances for any such control period not exceeding the amount, under §§ 97.1010 and 97.1021 of this chapter for the State and such control period, of the CSAPR NO_x Ozone Season Group 3 trading budget minus the sum of the Indian country existing unit set-aside, the new unit set-aside, and the amount of any CSAPR NO_x Ozone Season Group 3 allowances already allocated and recorded by the Administrator;

* * * * *

(D) Does not provide for any change, after the submission deadlines in paragraph (b)(12)(iii)(B) of this section, in the allocations submitted to the Administrator by such deadlines and does not provide for any change in any allocation determined and recorded by

the Administrator under subpart GGGGG of part 97 of this chapter or § 97.526(d) or § 97.826(d) or (e) of this chapter;

* * * * *

(vi) Must not include any of the requirements imposed on any unit in areas of Indian country within the borders of the State not subject to the State's SIP authority in the provisions in §§ 97.1002 through 97.1035 of this chapter and must not include the provisions in §§ 97.1011(a)(2), 97.1012, and 97.1021(g) through (j) of this chapter, all of which provisions will continue to apply under any portion of the CSAPR Federal Implementation Plan that is not replaced by the SIP revision;

(vii) Provided that, if before the Administrator's approval of the SIP revision any covered unit is located in areas of Indian country within the borders of the State not subject to the State's SIP authority before the Administrator's approval of the SIP revision, the SIP revision must exclude the provisions in §§ 97.1002 (definitions of "common designated representative", "common designated representative's assurance level", and "common designated representative's share"), 97.1006(c)(2), and 97.1025 of this chapter and the portions of other provisions of subpart GGGGG of part 97 of this chapter referencing §§ 97.1002, 97.1006(c)(2), and 97.1025, and further provided that, if and when after the Administrator's approval of the SIP revision any covered unit is located in areas of Indian country within the borders of the State not subject to the State's SIP authority, the Administrator may modify his or her approval of the SIP revision to exclude these provisions and may modify any portion of the CSAPR Federal Implementation Plan that is not replaced by the SIP revision to include these provisions; and

(viii) Provided that the State must submit a complete SIP revision meeting the requirements of paragraphs (b)(12)(iii) through (vi) of this section by December 1 of the year before the year of the deadline for submission of allocations or auction results under paragraph (b)(12)(iii)(B) of this section applicable to the first control period for which the State wants to make allocations or hold an auction under paragraph (b)(12)(iii) of this section.

(13) *Withdrawal of CSAPR FIP provisions relating to NO_x ozone season emissions; satisfaction of NO_x SIP Call requirements.* Following promulgation of an approval by the Administrator of a State's SIP revision as correcting the SIP's deficiency that is the basis for the

CSAPR Federal Implementation Plan set forth in paragraphs (b)(1), (b)(2)(i), and (b)(3) and (4) of this section, paragraphs (b)(1), (b)(2)(ii), and (b)(7) and (8) of this section, or paragraphs (b)(1), (b)(2)(iii), and (b)(10) and (11) of this section for sources in the State and areas of Indian country within the borders of the State subject to the State's SIP authority—

(i) Except as provided in paragraph (b)(14) of this section, the provisions of paragraph (b)(2)(i), (ii), or (iii) of this section, as applicable, will no longer apply to sources in the State and areas of Indian country within the borders of the State subject to the State's SIP authority, unless the Administrator's approval of the SIP revision is partial or conditional, and will continue to apply to sources in areas of Indian country within the borders of the State not subject to the State's SIP authority, provided that if the CSAPR Federal Implementation Plan was promulgated as a partial rather than full remedy for an obligation of the State to address interstate air pollution, the SIP revision likewise will constitute a partial rather than full remedy for the State's obligation unless provided otherwise in the Administrator's approval of the SIP revision; and

* * * * *

(14) * * *

(ii) Notwithstanding the provisions of paragraph (b)(13)(i) of this section, if, at the time of any approval of a State's SIP revision under this section, the Administrator has already started recording any allocations of CSAPR NO_x Ozone Season Group 1 allowances under subpart BBBBBB of part 97 of this chapter, or allocations of CSAPR NO_x Ozone Season Group 2 allowances under subpart EEEEE of part 97 of this chapter, or allocations of CSAPR NO_x Ozone Season Group 3 allowances under subpart GGGGG of part 97 of this chapter, to units in the State and areas of Indian country within the borders of the State subject to the State's SIP authority for a control period in any year, the provisions of such subpart authorizing the Administrator to complete the allocation and recordation of such allowances to such units for each such control period shall continue to apply, unless provided otherwise by such approval of the State's SIP revision.

(iii) Notwithstanding any discontinuation pursuant to paragraph (b)(2)(i)(B), (b)(2)(ii)(B) or (C), or (b)(13)(i) of this section of the applicability of subpart BBBBBB or EEEEE of part 97 of this chapter to the sources in a State and areas of Indian country within the borders of the State

subject to the State's SIP authority with regard to emissions occurring in any control period, the following provisions shall continue to apply with regard to all CSAPR NO_x Ozone Season Group 1 allowances and CSAPR NO_x Ozone Season Group 2 allowances at any time allocated for any control period to any source or other entity in the State and areas of Indian country within the borders of the State subject to the State's SIP authority and shall apply to all entities, wherever located, that at any time held or hold such allowances:

(A) The provisions of §§ 97.526(c) and 97.826(c) of this chapter (concerning the transfer of CSAPR NO_x Ozone Season Group 1 allowances and CSAPR NO_x Ozone Season Group 2 allowances between certain Allowance Management System accounts under common control);

(B) The provisions of §§ 97.526(d) and 97.826(d) and (e) of this chapter (concerning the conversion of unused CSAPR NO_x Ozone Season Group 1 allowances allocated for specified control periods to different amounts of CSAPR NO_x Ozone Season Group 2 allowances or CSAPR NO_x Ozone Season Group 3 allowances and the conversion of unused CSAPR NO_x Ozone Season Group 2 allowances allocated for specified control periods to different amounts of CSAPR NO_x Ozone Season Group 3 allowances); and

(C) The provisions of § 97.811(d) and (e) of this chapter (concerning the recall of CSAPR NO_x Ozone Season Group 2 allowances equivalent in quantity and usability to all CSAPR NO_x Ozone Season Group 2 allowances allocated for specified control periods and recorded in specified Allowance Management System accounts).

(15) * * *

(ii) For each of the following States, the Administrator has approved a SIP revision under paragraph (b)(4) of this section as replacing the CSAPR NO_x Ozone Season Group 1 allowance allocation provisions in §§ 97.511(a) and (b)(1) and 97.512(a) of this chapter with regard to sources in the State and areas of Indian country within the borders of the State subject to the State's SIP authority for the control period in 2017 or any subsequent year: [none].

* * * * *

(16) * * *

(i) * * *

(B) For each of the following States, the Administrator has approved a SIP revision under paragraph (b)(8) of this section as replacing the CSAPR NO_x Ozone Season Group 2 allowance allocation provisions in §§ 97.811(a) and (b)(1) and 97.812(a) of this chapter with

regard to sources in the State and areas of Indian country within the borders of the State subject to the State's SIP authority for the control period in 2019 or any subsequent year: New York.

(C) For each of the following States, the Administrator has approved a SIP revision under paragraph (b)(9) of this section as correcting the SIP's deficiency that is the basis for the CSAPR Federal Implementation Plan set forth in paragraphs (b)(1), (b)(2)(ii), and (b)(7) and (8) of this section with regard to sources in the State and areas of Indian country within the borders of the State subject to the State's SIP authority: Alabama, Indiana, and Missouri.

(ii) * * *

(B) Notwithstanding any provision of subpart EEEEE of part 97 of this chapter or any State's SIP, with regard to any State listed in paragraph (b)(2)(ii)(C) of this section and any control period that begins after December 31, 2022, the Administrator will not carry out any of the functions set forth for the Administrator in subpart EEEEE of part 97 of this chapter, except §§ 97.811(e) and 97.826(c) and (e) of this chapter, or in any emissions trading program provisions in a State's SIP approved under paragraph (b)(8) or (9) of this section.

(17) * * *

(i) For each of the following States, the Administrator has approved a SIP revision under paragraph (b)(10) of this section as replacing the CSAPR NO_x Ozone Season Group 3 allowance allocation provisions in § 97.1011(a)(1) of this chapter with regard to sources in the State and areas of Indian country within the borders of the State subject to the State's SIP authority for the control period in 2024: [none].

(ii) For each of the following States, the Administrator has approved a SIP revision under paragraph (b)(11) of this section as replacing the CSAPR NO_x Ozone Season Group 3 allowance allocation provisions in § 97.1011(a)(1) of this chapter with regard to sources in the State and areas of Indian country within the borders of the State subject to the State's SIP authority for the control period in 2025 or any subsequent year: [none].

(iii) For each of the following States, the Administrator has approved a SIP revision under paragraph (b)(12) of this section as correcting the SIP's deficiency that is the basis for the CSAPR Federal Implementation Plan set forth in paragraphs (b)(1), (b)(2)(iii), and (b)(10) and (11) of this section with regard to sources in the State and areas of Indian country within the borders of the State subject to the State's SIP authority: [none].

- 3. Amend § 52.39 by:
 - a. In paragraph (a), removing “(SO₂), except” and adding in its place “(SO₂) for sources meeting the applicability criteria set forth in subparts CCCCC and DDDDD, except”;
 - b. In paragraph (d) introductory text, removing “the State and” and adding in its place “sources in the State and areas of Indian country within the borders of the State subject to the State’s SIP authority for”;
 - c. In paragraph (d)(1), removing “State and” and adding in its place “State and areas of Indian country within the borders of the State subject to the State’s SIP authority and that”;
 - d. In paragraph (e) introductory text, removing “for the State’s sources, and” and adding in its place “with regard to sources in the State and areas of Indian country within the borders of the State subject to the State’s SIP authority, and”;
 - e. Revising table 1 to paragraph (e)(1)(ii);
 - f. In paragraph (e)(2), removing “deadlines for submission of allocations or auction results under paragraphs (e)(1)(ii) and (iii)” and adding in its place “deadline for submission of allocations or auction results under paragraph (e)(1)(ii)”;
 - g. In paragraph (f) introductory text, removing “State (but not sources in any Indian country within the borders of the State), regulations” and adding in its place “State and areas of Indian country within the borders of the State subject to the State’s SIP authority, regulations”;
 - h. Revising table 2 to paragraph (f)(1)(ii);
 - i. In paragraph (f)(4), removing “Indian country within the borders of the State” and adding in its place “areas of Indian country within the borders of the State not subject to the State’s SIP authority”;
 - j. In paragraph (f)(5), removing “Indian country within the borders of the State, the” and adding in its place “areas of Indian country within the

- borders of the State not subject to the State’s SIP authority, the”;
- k. In paragraph (f)(6), removing “deadlines for submission of allocations or auction results under paragraphs (f)(1)(ii) and (iii)” and adding in its place “deadline for submission of allocations or auction results under paragraph (f)(1)(ii)”;
- l. In paragraph (g) introductory text:
 - i. Removing “(c)(1) or (2)” and adding in its place “(c)”;
 - ii. Removing “the State and” and adding in its place “sources in the State and areas of Indian country within the borders of the State subject to the State’s SIP authority for”;
 - m. In paragraph (g)(1), removing “State and” and adding in its place “State and areas of Indian country within the borders of the State subject to the State’s SIP authority and that”;
 - n. In paragraph (h) introductory text, removing “for the State’s sources, and” and adding in its place “with regard to sources in the State and areas of Indian country within the borders of the State subject to the State’s SIP authority, and”;
 - o. Revising table 3 to paragraph (h)(1)(ii);
 - p. In paragraph (h)(2), removing “deadlines for submission of allocations or auction results under paragraphs (h)(1)(ii) and (iii)” and adding in its place “deadline for submission of allocations or auction results under paragraph (h)(1)(ii)”;
 - q. In paragraph (i) introductory text, removing “State (but not sources in any Indian country within the borders of the State), regulations” and adding in its place “State and areas of Indian country within the borders of the State subject to the State’s SIP authority, regulations”;
 - r. Revising table 4 to paragraph (i)(1)(ii);
 - s. In paragraph (i)(4), removing “Indian country within the borders of the State” and adding in its place “areas of Indian country within the borders of the State not subject to the State’s SIP authority”;

- t. In paragraph (i)(5), removing “Indian country within the borders of the State, the” and adding in its place “areas of Indian country within the borders of the State not subject to the State’s SIP authority, the”;
- u. In paragraph (i)(6), removing “deadlines for submission of allocations or auction results under paragraphs (i)(1)(ii) and (iii)” and adding in its place “deadline for submission of allocations or auction results under paragraph (i)(1)(ii)”;
- v. Revising paragraphs (j) and (k)(2);
- w. Adding paragraph (k)(3);
- x. In paragraphs (l)(1) and (2), removing “the State and” and adding in its place “sources in the State and areas of Indian country within the borders of the State subject to the State’s SIP authority for”;
- y. In paragraph (l)(3), removing “State (but not sources in any Indian country within the borders of the State):” and adding in its place “State and areas of Indian country within the borders of the State subject to the State’s SIP authority:”;
- z. In paragraphs (m)(1) and (2), removing “the State and” and adding in its place “sources in the State and areas of Indian country within the borders of the State subject to the State’s SIP authority for”; and
- aa. In paragraph (m)(3), removing “State (but not sources in any Indian country within the borders of the State):” and adding in its place “State and areas of Indian country within the borders of the State subject to the State’s SIP authority:”.

The revisions and addition read as follows:

§ 52.39 What are the requirements of the Federal Implementation Plans (FIPs) for the Cross-State Air Pollution Rule (CSAPR) relating to emissions of sulfur dioxide?

- * * * * *
- (e) * * *
- (1) * * *
- (ii) * * *

TABLE 1 TO PARAGRAPH (e)(1)(ii)

Year of the control period for which CSAPR SO ₂ group 1 allowances are allocated or auctioned	Deadline for submission of allocations or auction results to the administrator
2017 or 2018	June 1, 2016.
2019 or 2020	June 1, 2017.
2021 or 2022	June 1, 2018.
2023	June 1, 2019.
2024	June 1, 2020.
2025 or any year thereafter	June 1 of the year before the year of the control period.

* * * * * (ii) * * *
 (f) * * *
 (1) * * *

TABLE 2 TO PARAGRAPH (f)(1)(ii)

Year of the control period for which CSAPR SO ₂ group 1 allowances are allocated or auctioned	Deadline for submission of allocations or auction results to the administrator
2017 or 2018	June 1, 2016.
2019 or 2020	June 1, 2017.
2021 or 2022	June 1, 2018.
2023	June 1, 2019.
2024	June 1, 2020.
2025 or any year thereafter	June 1 of the year before the year of the control period.

* * * * * (ii) * * *
 (h) * * *
 (1) * * *

TABLE 3 TO PARAGRAPH (h)(1)(ii)

Year of the control period for which CSAPR SO ₂ group 2 allowances are allocated or auctioned	Deadline for submission of allocations or auction results to the administrator
2017 or 2018	June 1, 2016.
2019 or 2020	June 1, 2017.
2021 or 2022	June 1, 2018.
2023	June 1, 2019.
2024	June 1, 2020.
2025 or any year thereafter	June 1 of the year before the year of the control period.

* * * * * (ii) * * *
 (i) * * *
 (1) * * *

TABLE 4 TO PARAGRAPH (i)(1)(ii)

Year of the control period for which CSAPR SO ₂ group 2 allowances are allocated or auctioned	Deadline for submission of allocations or auction results to the administrator
2017 or 2018	June 1, 2016.
2019 or 2020	June 1, 2017.
2021 or 2022	June 1, 2018.
2023	June 1, 2019.
2024	June 1, 2020.
2025 or any year thereafter	June 1 of the year before the year of the control period.

* * * * *

(j) *Withdrawal of CSAPR FIP provisions relating to SO₂ emissions.* Except as provided in paragraph (k) of this section, following promulgation of an approval by the Administrator of a State's SIP revision as correcting the SIP's deficiency that is the basis for the CSAPR Federal Implementation Plan set forth in paragraphs (a), (b), (d), and (e) of this section or paragraphs (a), (c)(1), (g), and (h) of this section for sources in the State and Indian country within the borders of the State subject to the State's SIP authority, the provisions of paragraph (b) or (c)(1) of this section, as applicable, will no longer apply to sources in the State and areas of Indian country within the borders of the State subject to the State's SIP authority,

unless the Administrator's approval of the SIP revision is partial or conditional, and will continue to apply to sources in areas of Indian country within the borders of the State not subject to the State's SIP authority, provided that if the CSAPR Federal Implementation Plan was promulgated as a partial rather than full remedy for an obligation of the State to address interstate air pollution, the SIP revision likewise will constitute a partial rather than full remedy for the State's obligation unless provided otherwise in the Administrator's approval of the SIP revision.

(k) * * *
 (2) Notwithstanding the provisions of paragraph (j) of this section, if, at the time of any approval of a State's SIP revision under this section, the

Administrator has already started recording any allocations of CSAPR SO₂ Group 1 allowances under subpart CCCCC of part 97 of this chapter, or allocations of CSAPR SO₂ Group 2 allowances under subpart DDDDD of part 97 of this chapter, to units in the State and areas of Indian country within the borders of the State subject to the State's SIP authority for a control period in any year, the provisions of such subpart authorizing the Administrator to complete the allocation and recordation of such allowances to such units for each such control period shall continue to apply, unless provided otherwise by such approval of the State's SIP revision.

(3) Notwithstanding any discontinuation pursuant to paragraph

(c)(2) or (j) of this section of the applicability of subpart CCCCC or DDDDD of part 97 of this chapter to the sources in a State and areas of Indian country within the borders of the State subject to the State's SIP authority with regard to emissions occurring in any control period, the following provisions shall continue to apply with regard to all CSAPR SO₂ Group 1 allowances and CSAPR SO₂ Group 2 allowances at any time allocated for any control period to any source or other entity in the State and areas of Indian country within the borders of the State subject to the State's SIP authority and shall apply to all entities, wherever located, that at any time held or hold such allowances:

(i) The provisions of §§ 97.626(c) and 97.726(c) of this chapter (concerning the transfer of CSAPR SO₂ Group 1 allowances and CSAPR SO₂ Group 2 allowances between certain Allowance Management System accounts under common control).

(ii) [Reserved]

* * * * *

■ 4. Add §§ 52.40 through 52.46 to subpart A to read as follows:

Sec.

* * * * *

- 52.40 What are the requirements of the Federal Implementation Plans (FIPs) relating to ozone season emissions of nitrogen oxides from sources not subject to the CSAPR ozone season trading program?
- 52.41 What are the requirements of the Federal Implementation Plans (FIPs) relating to ozone season emissions of nitrogen oxides from the Pipeline Transportation of Natural Gas Industry?
- 52.42 What are the requirements of the Federal Implementation Plans (FIPs) relating to ozone season emissions of nitrogen oxides from the Cement and Concrete Product Manufacturing Industry?
- 52.43 What are the requirements of the Federal Implementation Plans (FIPs) relating to ozone season emissions of nitrogen oxides from the Iron and Steel Mills and Ferroalloy Manufacturing Industry?
- 52.44 What are the requirements of the Federal Implementation Plans (FIPs) relating to ozone season emissions of nitrogen oxides from the Glass and Glass Product Manufacturing Industry?
- 52.45 What are the requirements of the Federal Implementation Plans (FIPs) relating to ozone season emissions of nitrogen oxides from the Basic Chemical Manufacturing, Petroleum and Coal Products Manufacturing, the Pulp, Paper, and Paperboard Mills Industries, Metal Ore Mining, and the Iron and Steel and Ferroalloy Manufacturing Industries?
- 52.46 What are the requirements of the Federal Implementation Plans (FIPs) relating to ozone season emissions of

nitrogen oxides from Municipal Waste Combustors?

* * * * *

§ 52.40 What are the requirements of the Federal Implementation Plans (FIPs) relating to ozone season emissions of nitrogen oxides from sources not subject to the CSAPR ozone season trading program?

(a) *Purpose.* This section establishes Federal Implementation Plan requirements for new and existing units in the industries specified in paragraph (b) of this section to eliminate significant contribution to nonattainment, or interference with maintenance, of the 2015 8-hour ozone National Ambient Air Quality Standards in other states pursuant to 42 U.S.C. 7410(a)(2)(D)(i)(I).

(b) *Definitions.* The terms used in this section and §§ 52.41 through § 52.46 are defined as follows:

Calendar year means the period between January 1 and December 31, inclusive, for a given year.

Existing affected unit means any affected unit for which construction commenced before August 4, 2023.

New affected unit means any affected unit for which construction commenced on or after August 4, 2023.

Operator means any person who operates, controls, or supervises an affected unit and shall include, but not be limited to, any holding company, utility system, or plant manager of such affected unit.

Owner means any holder of any portion of the legal or equitable title in an affected unit.

Potential to emit means the maximum capacity of a unit to emit a pollutant under its physical and operational design. Any physical or operational limitation on the capacity of the unit to emit a pollutant, including air pollution control equipment and restrictions on hours of operation or on the type or amount of material combusted, stored, or processed, shall be treated as part of its design only if the limitation or the effect it would have on emissions is federally enforceable. Secondary emissions do not count in determining the potential to emit of a unit.

Rolling average means the weighted average of all data, meeting quality assurance and quality control (QA/QC) requirements in this part or otherwise normalized, collected during the applicable averaging period. The period of a rolling average stipulates the frequency of data averaging and reporting. To demonstrate compliance with an operating parameter a 30-day rolling average period requires calculation of a new average value each operating day and shall include the

average of all the hourly averages of the specific operating parameter. For demonstration of compliance with an emissions limit based on pollutant concentration, a 30-day rolling average is comprised of the average of all the hourly average concentrations over the previous 30 operating days. For demonstration of compliance with an emissions limit based on lbs-pollutant per production unit, the 30-day rolling average is calculated by summing the hourly mass emissions over the previous 30 operating days, then dividing that sum by the total production during the same period.

(c) *General requirements.* (1) The NO_x emissions limitations or emissions control requirements and associated compliance requirements for the following listed source categories not subject to the CSAPR ozone season trading program constitute the Federal Implementation Plan provisions that relate to emissions of NO_x during the ozone season (defined as May 1 through September 30 of a calendar year):

§§ 52.41 for engines in the Pipeline Transportation of Natural Gas Industry, 52.42 for kilns in the Cement and Concrete Product Manufacturing Industry, 52.43 for reheat furnaces in the Iron and Steel Mills and Ferroalloy Manufacturing Industry, 52.44 for furnaces in the Glass and Glass Product Manufacturing Industry, 52.45 for boilers in the Iron and Steel Mills and Ferroalloy Manufacturing, Metal Ore Mining, Basic Chemical Manufacturing, Petroleum and Coal Products Manufacturing, and Pulp, Paper, and Paperboard Mills industries, and 52.46 for Municipal Waste Combustors.

(2) The provisions of this section or § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 apply to affected units located in each of the following States, including Indian country located within the borders of such States, beginning in the 2026 ozone season and in each subsequent ozone season: Arkansas, California, Illinois, Indiana, Kentucky, Louisiana, Maryland, Michigan, Mississippi, Missouri, Nevada, New Jersey, New York, Ohio, Oklahoma, Pennsylvania, Texas, Utah, Virginia, and West Virginia.

(3) The testing, monitoring, recordkeeping, and reporting requirements of this section or § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 only apply during the ozone season, except as otherwise specified in these sections. Additionally, if an owner or operator of an affected unit chooses to conduct a performance or compliance test outside of the ozone season, all recordkeeping, reporting, and notification requirements associated

with that test shall apply, without regard to whether they occur during the ozone season.

(d) *Requests for extension of compliance.* (1) The owner or operator of an existing affected unit under § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 that cannot comply with the applicable requirements in those sections by May 1, 2026, due to circumstances entirely beyond the owner or operator's control, may request an initial compliance extension to a date certain no later than May 1, 2027. The extension request must contain a demonstration of necessity consistent with the requirements of paragraph (d)(3) of this section.

(2) If, after the EPA has granted a request for an initial compliance extension, the source remains unable to comply with the applicable requirements in § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 by the extended compliance date due to circumstances entirely beyond the owner or operator's control, the owner or operator may apply for a second compliance extension to a date certain no later than May 1, 2029. The extension request must contain an updated demonstration of necessity consistent with the requirements of paragraph (d)(3) of this section.

(3) Each request for a compliance extension shall demonstrate that the owner or operator has taken all steps possible to install the controls necessary for compliance with the applicable requirements in § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 by the applicable compliance date and shall:

(i) Identify each affected unit for which the owner or operator is seeking the compliance extension;

(ii) Identify and describe the controls to be installed at each affected unit to comply with the applicable requirements in § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46;

(iii) Identify the circumstances entirely beyond the owner or operator's control that necessitate additional time to install the identified controls;

(iv) Identify the date(s) by which on-site construction, installation of control equipment, and/or process changes will be initiated;

(v) Identify the owner or operator's proposed compliance date. A request for an initial compliance extension under paragraph (d)(1) of this section must specify a proposed compliance date no later than May 1, 2027, and state whether the owner or operator anticipates a need to request a second compliance extension. A request for a second compliance extension under paragraph (d)(2) of this section must

specify a proposed compliance date no later than May 1, 2029, and identify additional actions taken by the owner or operator to ensure that the affected unit(s) will be in compliance with the applicable requirements in this section by that proposed compliance date;

(vi) Include all information obtained from control technology vendors demonstrating that the identified controls cannot be installed by the applicable compliance date;

(vii) Include any and all contract(s) entered into for the installation of the identified controls or an explanation as to why no contract is necessary or obtainable; and

(viii) Include any permit(s) obtained for the installation of the identified controls or, where a required permit has not yet been issued, a copy of the permit application submitted to the permitting authority and a statement from the permitting authority identifying its anticipated timeframe for issuance of such permit(s).

(4) Each request for a compliance extension shall be submitted via the Compliance and Emissions Data Reporting Interface (CEDRI) or analogous electronic submission system provided by the EPA no later than 180 days prior to the applicable compliance date. Until an extension has been granted by the Administrator under this section, the owner or operator of an affected unit shall comply with all applicable requirements of this section and shall remain subject to the May 1, 2026 compliance date or the initial extended compliance date, as applicable. A denial will be effective as of the date of denial.

(5) The owner or operator of an affected unit who has requested a compliance extension under this paragraph (d)(5) and is required to have a title V permit shall apply to have the relevant title V permit revised to incorporate the conditions of the extension of compliance. The conditions of a compliance extension granted under this paragraph (d)(5) will be incorporated into the affected unit's title V permit according to the provisions of an EPA-approved state operating permit program or the Federal title V regulations in 40 CFR part 71, whichever apply.

(6) Based on the information provided in any request made under paragraph (d) of this section or other information, the Administrator may grant an extension of time to comply with applicable requirements in § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 consistent with the provisions of paragraph (d)(1) or (2) of this section. The decision to grant an extension will

be provided by notification via the CEDRI or analogous electronic submission system provided by the EPA and publicly available, and will identify each affected unit covered by the extension; specify the termination date of the extension; and specify any additional conditions that the Administrator deems necessary to ensure timely installation of the necessary controls (e.g., the date(s) by which on-site construction, installation of control equipment, and/or process changes will be initiated).

(7) The Administrator will provide notification via the CEDRI or analogous electronic submission system provided by the EPA to the owner or operator of an affected unit who has requested a compliance extension under this paragraph (d)(7) whether the submitted request is complete, that is, whether the request contains sufficient information to make a determination, within 60 calendar days after receipt of the original request and within 60 calendar days after receipt of any supplementary information.

(8) The Administrator will provide notification via the CEDRI or analogous electronic submission system provided by the EPA, which shall be publicly available, to the owner or operator of a decision to grant or intention to deny a request for a compliance extension within 60 calendar days after providing written notification pursuant to paragraph (d)(7) of this section that the submitted request is complete.

(9) Before denying any request for an extension of compliance, the Administrator will provide notification via the CEDRI or analogous electronic submission system provided by the EPA to the owner or operator in writing of the Administrator's intention to issue the denial, together with:

(i) Notice of the information and findings on which the intended denial is based; and

(ii) Notice of opportunity for the owner or operator to present via the CEDRI or analogous electronic submission system provided by the EPA, within 15 calendar days after he/she is notified of the intended denial, additional information or arguments to the Administrator before further action on the request.

(10) The Administrator's final decision to deny any request for an extension will be provided via the CEDRI or analogous electronic submission system provided by the EPA and publicly available, and will set forth the specific grounds on which the denial is based. The final decision will be made within 60 calendar days after presentation of additional information

or argument (if the request is complete), or within 60 calendar days after the deadline for the submission of additional information or argument under paragraph (d)(9)(ii) of this section, if no such submission is made.

(11) The granting of an extension under this section shall not abrogate the Administrator's authority under section 114 of the Clean Air Act (CAA or the Act).

(e) *Requests for case-by-case emissions limits.* (1) The owner or operator of an existing affected unit under § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 that cannot comply with the applicable requirements in those sections due to technical impossibility or extreme economic hardship may submit to the Administrator, by August 5, 2024, a request for approval of a case-by-case emissions limit. The request shall contain information sufficient for the Administrator to confirm that the affected unit is unable to comply with the applicable emissions limit, due to technical impossibility or extreme economic hardship, and to establish an appropriate alternative case-by-case emissions limit for the affected unit. Until a case-by-case emissions limit has been approved by the Administrator under this section, the owner or operator shall remain subject to all applicable requirements in § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46. A denial will be effective as of the date of denial.

(2) Each request for a case-by-case emissions limit shall include, but not be limited to, the following:

(i) A demonstration that the affected unit cannot achieve the applicable emissions limit with available control technology due to technical impossibility or extreme economic hardship.

(A) A demonstration of technical impossibility shall include:

(1) Uncontrolled NO_x emissions for the affected unit established with a CEMS, or stack tests obtained during steady state operation in accordance with the applicable reference test methods of 40 CFR part 60, appendix A-4, any alternative test method approved by the EPA as of June 5, 2023, under 40 CFR 59.104(f), 60.8(b)(3), 61.13(h)(1)(ii), 63.7(e)(2)(ii)(2), or 65.158(a)(2) and available at the EPA's website (<https://www.epa.gov/emc/broadly-applicable-approved-alternative-test-methods>), or other methods and procedures approved by the EPA through notice-and-comment rulemaking; and

(2) A demonstration that the affected unit cannot meet the applicable

emissions limit even with available control technology, including:

(i) Stack test data or other emissions data for the affected unit; or

(ii) A third-party engineering assessment demonstrating that the affected unit cannot meet the applicable emissions limit with available control technology.

(B) A demonstration of extreme economic hardship shall include at least three vendor estimates of the costs of installing control technology necessary to meet the applicable emissions limit and other information that demonstrates, to the satisfaction of the Administrator, that the cost of complying with the applicable emissions limit would present an extreme economic hardship relative to the costs borne by other comparable sources in the industry.

(ii) An analysis of available control technology options and a proposed case-by-case emissions limit that represents the lowest emissions limitation technically achievable by the affected unit without causing extreme economic hardship relative to the costs borne by other comparable sources in the industry. The owner or operator may propose additional measures to reduce NO_x emissions, such as operational standards or work practice standards.

(iii) Calculations of the NO_x emissions reduction to be achieved through implementation of the proposed case-by-case emissions limit and any additional proposed measures, the difference between this NO_x emissions reduction level and the NO_x emissions reductions that would have occurred if the affected unit complied with the applicable emissions limitations in § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46, and a description of the methodology used for these calculations.

(3) The owner or operator of an affected unit who has requested a case-by-case emissions limit under this paragraph (e)(3) and is required to have a title V permit shall apply to have the relevant title V permit revised to incorporate the case-by-case emissions limit. Any case-by-case emissions limit approved under this paragraph (e)(3) will be incorporated into the affected unit's title V permit according to the provisions of an EPA-approved state operating permit program or the Federal title V regulations in 40 CFR part 71, whichever apply.

(4) Based on the information provided in any request made under this paragraph (e)(4) or other information, the Administrator may approve a case-by-case emissions limit that will apply to an affected unit in lieu of the

applicable emissions limit in § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46. The decision to approve a case-by-case emissions limit will be provided via the CEDRI or analogous electronic submission system provided by the EPA in paragraph (d) of this section and publicly available, and will identify each affected unit covered by the case-by-case emissions limit.

(5) The Administrator will provide notification via the CEDRI or analogous electronic submission system provided by the EPA in paragraph (d) of this section to the owner or operator of an affected unit who has requested a case-by-case emissions limit under this paragraph (e)(5) whether the submitted request is complete, that is, whether the request contains sufficient information to make a determination, within 60 calendar days after receipt of the original request and within 60 calendar days after receipt of any supplementary information.

(6) The Administrator will provide notification via the CEDRI or analogous electronic submission system described by the EPA in paragraph (d) of this section, which shall be publicly available, to the owner or operator of a decision to approve or intention to deny the request within 60 calendar days after providing notification pursuant to paragraph (e)(5) of this section that the submitted request is complete.

(7) Before denying any request for a case-by-case emissions limit, the Administrator will provide notification via the CEDRI or analogous electronic submission system provided by the EPA to the owner or operator in writing of the Administrator's intention to issue the denial, together with:

(i) Notice of the information and findings on which the intended denial is based; and

(ii) Notice of opportunity for the owner or operator to present via the CEDRI or analogous electronic submission system provided by the EPA, within 15 calendar days after he/she is notified of the intended denial, additional information or arguments to the Administrator before further action on the request.

(8) The Administrator's final decision to deny any request for a case-by-case emissions limit will be provided by notification via the CEDRI or analogous electronic submission system provided by the EPA and publicly available, and will set forth the specific grounds on which the denial is based. The final decision will be made within 60 calendar days after presentation of additional information or argument (if the request is complete), or within 60 calendar days after the deadline for the

submission of additional information or argument under paragraph (e)(7)(ii) of this section, if no such submission is made.

(9) The approval of a case-by-case emissions limit under this section shall not abrogate the Administrator's authority under section 114 of the Act.

(f) *Recordkeeping requirements.* (1) The owner or operator of an affected unit subject to the provisions of this section or § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 shall maintain files of all information (including all reports and notifications) required by these sections recorded in a form suitable and readily available for expeditious inspection and review. The files shall be retained for at least 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record. At minimum, the most recent 2 years of data shall be retained on site. The remaining 3 years of data may be retained off site. Such files may be maintained on microfilm, on a computer, on computer floppy disks, on magnetic tape disks, or on microfiche.

(2) Any records required to be maintained by § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 that are submitted electronically via the EPA's Compliance and Emissions Data Reporting Interface (CEDRI) may be maintained in electronic format. This ability to maintain electronic copies does not affect the requirement for facilities to make records, data, and reports available upon request to the EPA as part of an on-site compliance evaluation.

(g) *CEDRI reporting requirements.* (1) You shall submit the results of the performance test following the procedures specified in paragraphs (g)(1)(i) through (iii) of this section:

(i) Data collected using test methods supported by the EPA's Electronic Reporting Tool (ERT) as listed on the EPA's ERT website (<https://www.epa.gov/electronic-reporting-air-emissions/electronic-reporting-tool-ert>) at the time of the test. Submit the results of the performance test to the EPA via the CEDRI or analogous electronic reporting approach provided by the EPA to report data required by § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46, which can be accessed through the EPA's Central Data Exchange (CDX) (<https://cdx.epa.gov/>). The data must be submitted in a file format generated using the EPA's ERT. Alternatively, you may submit an electronic file consistent with the extensible markup language (XML) schema listed on the EPA's ERT website.

(ii) Data collected using test methods that are not supported by the EPA's ERT as listed on the EPA's ERT website at the time of the test. The results of the performance test must be included as an attachment in the ERT or an alternate electronic file consistent with the XML schema listed on the EPA's ERT website. Submit the ERT generated package or alternative file to the EPA via CEDRI.

(iii)(A) The EPA will make all the information submitted through CEDRI available to the public without further notice to you. Do not use CEDRI to submit information you claim as confidential business information (CBI). Although we do not expect persons to assert a claim of CBI, if you wish to assert a CBI claim for some of the information submitted under paragraph (g)(1) or (2) of this section, you should submit a complete file, including information claimed to be CBI, to the EPA.

(B) The file must be generated using the EPA's ERT or an alternate electronic file consistent with the XML schema listed on the EPA's ERT website.

(C) Clearly mark the part or all of the information that you claim to be CBI. Information not marked as CBI may be authorized for public release without prior notice. Information marked as CBI will not be disclosed except in accordance with procedures set forth in 40 CFR part 2.

(D) The preferred method to receive CBI is for it to be transmitted electronically using email attachments, File Transfer Protocol, or other online file sharing services. Electronic submissions must be transmitted directly to the Office of Air Quality Planning and Standards (OAQPS) CBI Office at the email address oaqpscbi@epa.gov, and as described in this paragraph (g), should include clear CBI markings and be flagged to the attention of Lead of 2015 Ozone Transport FIP. If assistance is needed with submitting large electronic files that exceed the file size limit for email attachments, and if you do not have your own file sharing service, please email oaqpscbi@epa.gov to request a file transfer link.

(E) If you cannot transmit the file electronically, you may send CBI information through the postal service to the following address: OAQPS Document Control Officer (C404-02), OAQPS, U.S. Environmental Protection Agency, Research Triangle Park, North Carolina 27711, Attention Lead of 2015 Ozone Transport FIP. The mailed CBI material should be double wrapped and clearly marked. Any CBI markings should not show through the outer envelope.

(F) All CBI claims must be asserted at the time of submission. Anything submitted using CEDRI cannot later be claimed CBI. Furthermore, under CAA section 114(c), emissions data is not entitled to confidential treatment, and the EPA is required to make emissions data available to the public. Thus, emissions data will not be protected as CBI and will be made publicly available.

(G) You must submit the same file submitted to the CBI office with the CBI omitted to the EPA via the EPA's CDX as described in paragraphs (g)(1) and (2) of this section.

(2) Annual reports must be submitted via CEDRI or analogous electronic reporting approach provided by the EPA to report data required by § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46.

(3) If you are required to electronically submit a report through CEDRI in the EPA's CDX, you may assert a claim of EPA system outage for failure to timely comply with that reporting requirement. To assert a claim of EPA system outage, you must meet the requirements outlined in paragraphs (g)(3)(i) through (vii) of this section.

(i) You must have been or will be precluded from accessing CEDRI and submitting a required report within the time prescribed due to an outage of either the EPA's CEDRI or CDX systems.

(ii) The outage must have occurred within the period of time beginning five business days prior to the date that the submission is due.

(iii) The outage may be planned or unplanned.

(iv) You must submit notification to the Administrator in writing as soon as possible following the date you first knew, or through due diligence should have known, that the event may cause or has caused a delay in reporting.

(v) You must provide to the Administrator a written description identifying:

(A) The date(s) and time(s) when CDX or CEDRI was accessed and the system was unavailable;

(B) A rationale for attributing the delay in reporting beyond the regulatory deadline to EPA system outage;

(C) A description of measures taken or to be taken to minimize the delay in reporting; and

(D) The date by which you propose to report, or if you have already met the reporting requirement at the time of the notification, the date you reported.

(vi) The decision to accept the claim of EPA system outage and allow an extension to the reporting deadline is solely within the discretion of the Administrator.

(vii) In any circumstance, the report must be submitted electronically as soon as possible after the outage is resolved.

(4) If you are required to electronically submit a report through CEDRI in the EPA's CDX, you may assert a claim of force majeure for failure to timely comply with that reporting requirement. To assert a claim of force majeure, you must meet the requirements outlined in paragraphs (g)(4)(i) through (v) of this section.

(i) You may submit a claim if a force majeure event is about to occur, occurs, or has occurred or there are lingering effects from such an event within the period of time beginning five business days prior to the date the submission is due. For the purposes of this section, a force majeure event is defined as an event that will be or has been caused by circumstances beyond the control of the affected unit, its contractors, or any entity controlled by the affected unit that prevents you from complying with the requirement to submit a report electronically within the time period prescribed. Examples of such events are acts of nature (e.g., hurricanes, earthquakes, or floods), acts of war or terrorism, or equipment failure or safety hazard beyond the control of the affected unit (e.g., large scale power outage).

(ii) You must submit notification to the Administrator in writing as soon as possible following the date you first knew, or through due diligence should have known, that the event may cause or has caused a delay in reporting.

(iii) You must provide to the Administrator:

(A) A written description of the force majeure event;

(B) A rationale for attributing the delay in reporting beyond the regulatory deadline to the force majeure event;

(C) A description of measures taken or to be taken to minimize the delay in reporting; and

(D) The date by which you propose to report, or if you have already met the reporting requirement at the time of the notification, the date you reported.

(iv) The decision to accept the claim of force majeure and allow an extension to the reporting deadline is solely within the discretion of the Administrator.

(v) In any circumstance, the reporting must occur as soon as possible after the force majeure event occurs.

§ 52.41 What are the requirements of the Federal Implementation Plans (FIPs) relating to ozone season emissions of nitrogen oxides from the Pipeline Transportation of Natural Gas Industry?

(a) *Definitions.* All terms not defined in this paragraph (a) shall have the meaning given to them in the Act and in subpart A of 40 CFR part 60.

Affected unit means an engine meeting the applicability criteria of this section.

Cap means the total amount of NO_x emissions, in tons per day on a 30-day rolling average basis, that is collectively allowed from all of the affected units covered by a Facility-Wide Averaging Plan and is calculated as the sum each affected unit's NO_x emissions at the emissions limit applicable to such unit under paragraph (c) of this section, converted to tons per day in accordance with paragraph (d)(3) of this section.

Emergency engine means any stationary reciprocating internal combustion engine (RICE) that meets all of the criteria in paragraphs (i) and (ii) of this definition. All emergency stationary RICE must comply with the requirements specified in paragraph (b)(1) of this section in order to be considered emergency engines. If the engine does not comply with the requirements specified in paragraph (b)(1), it is not considered an emergency engine under this section.

(i) The stationary engine is operated to provide electrical power or mechanical work during an emergency situation. Examples include stationary RICE used to produce power for critical networks or equipment (including power supplied to portions of a facility) when electric power from the local utility (or the normal power source, if the facility runs on its own power production) is interrupted, or stationary RICE used to pump water in the case of fire or flood, etc.

(ii) The stationary RICE is operated under limited circumstances for purposes other than those identified in paragraph (i) of this definition, as specified in paragraph (b)(1) of this section.

Facility means all of the pollutant-emitting activities which belong to the same industrial grouping, are located on one or more contiguous or adjacent properties, and are under the control of the same person (or persons under common control). Pollutant-emitting activities shall be considered as part of the same industrial grouping if they belong to the same "Major Group" (i.e., which have the same first two digit code as described in the Standard Industrial Classification Manual, 1987). For purposes of this section, a facility may

not extend beyond the 20 states identified in § 52.40(b)(2).

Four stroke means any type of engine which completes the power cycle in two crankshaft revolutions, with intake and compression strokes in the first revolution and power and exhaust strokes in the second revolution.

ISO conditions means 288 Kelvin (15 °C), 60 percent relative humidity, and 101.3 kilopascals pressure.

Lean burn means any two-stroke or four-stroke spark ignited reciprocating internal combustion engine that does not meet the definition of a rich burn engine.

Local Distribution Companies (LDCs) are companies that own or operate distribution pipelines, but not interstate pipelines or intrastate pipelines, that physically deliver natural gas to end users and that are within a single state that are regulated as separate operating companies by State public utility commissions or that operate as independent municipally-owned distribution systems. LDCs do not include pipelines (both interstate and intrastate) delivering natural gas directly to major industrial users and farm taps upstream of the local distribution company inlet.

Local Distribution Company (LDC) custody transfer station means a metering station where the LDC receives a natural gas supply from an upstream supplier, which may be an interstate transmission pipeline or a local natural gas producer, for delivery to customers through the LDC's intrastate transmission or distribution lines.

Nameplate rating means the manufacturer's maximum design capacity in horsepower (hp) at the installation site conditions. Starting from the completion of any physical change in the engine resulting in an increase in the maximum output (in hp) that the engine is capable of producing on a steady state basis and during continuous operation, such increased maximum output shall be as specified by the person conducting the physical change.

Natural gas means a fluid mixture of hydrocarbons (e.g., methane, ethane, or propane) or non-hydrocarbons, composed of at least 70 percent methane by volume or that has a gross calorific value between 35 and 41 megajoules (MJ) per dry standard cubic meter (950 and 1,100 Btu per dry standard cubic foot), that maintains a gaseous state under ISO conditions. Natural gas does not include the following gaseous fuels: Landfill gas, digester gas, refinery gas, sour gas, blast furnace gas, coal-derived gas, producer gas, coke oven gas, or any gaseous fuel produced in a process

which might result in highly variable CO₂ content or heating value.

Natural gas-fired means that greater than or equal to 90% of the engine's heat input, excluding recirculated or recuperated exhaust heat, is derived from the combustion of natural gas.

Natural gas processing plant means any processing site engaged in the extraction of natural gas liquids from field gas, fractionation of mixed natural gas liquids to natural gas products, or both. A Joule-Thompson valve, a dew point depression valve, or an isolated or standalone Joule-Thompson skid is not a natural gas processing plant.

Natural gas production facility means all equipment at a single stationary source directly associated with one or more natural gas wells upstream of the natural gas processing plant. This equipment includes, but is not limited to, equipment used for storage, separation, treating, dehydration, artificial lift, combustion, compression, pumping, metering, monitoring, and flowline.

Operating day means a 24-hour period beginning at 12:00 midnight during which any fuel is combusted at any time in the engine.

Pipeline transportation of natural gas means the movement of natural gas through an interconnected network of compressors and pipeline components, including the compressor and pipeline network used to transport the natural gas from processing plants over a distance (intrastate or interstate) to and from storage facilities, to large natural gas end-users, and prior to delivery to a "local distribution company custody transfer station" (as defined in this section) of an LDC that provides the natural gas to end-users. *Pipeline transportation of natural gas* does not include natural gas production facilities, natural gas processing plants, or the portion of a compressor and pipeline network that is upstream of a natural gas processing plant.

Reciprocating internal combustion engine (RICE) means a reciprocating engine in which power, produced by heat and/or pressure that is developed in the engine combustion chambers by the burning of a mixture of air and fuel, is subsequently converted to mechanical work.

Rich burn means any four-stroke spark ignited reciprocating internal combustion engine where the manufacturer's recommended operating air/fuel ratio divided by the stoichiometric air/fuel ratio at full load conditions is less than or equal to 1.1. Internal combustion engines originally manufactured as rich burn engines but modified with passive emissions control

technology for nitrogen oxides (NO_x) (such as pre-combustion chambers) will be considered lean burn engines. Existing affected unit where there are no manufacturer's recommendations regarding air/fuel ratio will be considered rich burn engines if the excess oxygen content of the exhaust at full load conditions is less than or equal to 2 percent.

Spark ignition means a reciprocating internal combustion engine utilizing a spark plug (or other sparking device) to ignite the air/fuel mixture and with operating characteristics significantly similar to the theoretical Otto combustion cycle.

Stoichiometric means the theoretical air-to-fuel ratio required for complete combustion.

Two stroke means a type of reciprocating internal combustion engine which completes the power cycle in a single crankshaft revolution by combining the intake and compression operations into one stroke (one-half revolution) and the power and exhaust operations into a second stroke. This system requires auxiliary exhaust scavenging of the combustion products and inherently runs lean (excess of air) of stoichiometry.

(b) *Applicability.* You are subject to the requirements under this section if you own or operate a new or existing natural gas-fired spark ignition engine, other than an emergency engine, with a nameplate rating of 1,000 hp or greater that is used for pipeline transportation of natural gas and is located within any of the States listed in § 52.40(c)(2), including Indian country located within the borders of any such State(s).

(1) For purposes of this section, the owner or operator of an emergency stationary RICE must operate the RICE according to the requirements in paragraphs (b)(1)(i) through (iii) of this section to be treated as an emergency stationary RICE. In order for stationary RICE to be treated as an emergency RICE under this subpart, any operation other than emergency operation, maintenance and testing, and operation in non-emergency situations for up to 50 hours per year, as described in paragraphs (b)(1)(i) through (iii), is prohibited. If you do not operate the RICE according to the requirements in paragraphs (b)(1)(i) through (iii), the RICE will not be considered an emergency engine under this section and must meet all requirements for affected units in this section.

(i) There is no time limit on the use of emergency stationary RICE in emergency situations.

(ii) The owner or operator may operate your emergency stationary RICE

for maintenance checks and readiness testing for a maximum of 100 hours per calendar year, provided that the tests are recommended by a Federal, state, or local government agency, the manufacturer, the vendor, or the insurance company associated with the engine. Any operation for non-emergency situations as allowed by paragraph (b)(1)(iii) of this section counts as part of the 100 hours per calendar year allowed by paragraph (b)(1)(ii) of this section. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records confirming that Federal, state, or local standards require maintenance and testing of emergency RICE beyond 100 hours per calendar year. Any approval of a petition for additional hours granted by the Administrator under 40 CFR part 63, subpart ZZZZ, shall constitute approval by the Administrator of the same petition under this paragraph (b)(1)(ii).

(iii) Emergency stationary RICE may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing provided in paragraph (b)(1)(ii) of this section.

(2) If you own or operate a natural gas-fired two stroke lean burn spark ignition engine manufactured after July 1, 2007 that is meeting the applicable emissions limits in 40 CFR part 60, subpart JJJJ, table 1, the engine is not an affected unit under this section and you do not have to comply with the requirements of this section.

(3) If you own or operate a natural gas-fired four stroke lean or rich burn spark ignition engine manufactured after July 1, 2010, that is meeting the applicable emissions limits in 40 CFR part 60, subpart JJJJ, table 1, the engine is not an affected unit under this section and you do not have to comply with the requirements of this section.

(c) *Emissions limitations.* If you are the owner or operator of an affected unit, you must meet the following emissions limitations on a 30-day rolling average basis during the 2026 ozone season and in each ozone season thereafter:

(1) Natural gas-fired four stroke rich burn spark ignition engine: 1.0 grams per hp-hour (g/hp-hr);

(2) Natural gas-fired four stroke lean burn spark ignition engine: 1.5 g/hp-hr; and

(3) Natural gas-fired two stroke lean burn spark ignition engine: 3.0 g/hp-hr.

(d) *Facility-Wide Averaging Plan.* If you are the owner or operator of a facility containing more than one affected unit, you may submit a request via the CEDRI or analogous electronic submission system provided by the EPA to the Administrator for approval of a proposed Facility-Wide Averaging Plan as an alternative means of compliance with the applicable emissions limits in paragraph (c) of this section. Any such request shall be submitted to the Administrator on or before October 1st of the year prior to each emissions averaging year. The Administrator will approve a proposed Facility-Wide Averaging Plan submitted under this paragraph (d) if the Administrator determines that the proposed Facility-Wide Averaging Plan meets the requirements of this paragraph (d), will provide total emissions reductions equivalent to or greater than those achieved by the applicable emissions limits in paragraph (c), and identifies satisfactory means for determining initial and continuous compliance, including appropriate testing, monitoring, recordkeeping, and

reporting requirements. You may only include affected units (*i.e.*, engines meeting the applicability criteria in paragraph (b) of this section) in a Facility-Wide Averaging Plan. Upon EPA approval of a proposed Facility-Wide Averaging Plan, you cannot withdraw any affected unit listed in such plan, and the terms of the plan may not be changed unless approved in writing by the Administrator.

(1) Each request for approval of a proposed Facility-Wide Averaging Plan shall include, but not be limited to:

- (i) The address of the facility;
- (ii) A list of all affected units at the facility that will be covered by the plan, identified by unit identification number, the engine manufacturer's name, and model;
- (iii) For each affected unit, a description of any existing NO_x emissions control technology and the date of installation, and a description of any NO_x emissions control technology to be installed and the projected date of installation;
- (iv) Identification of the emissions cap, calculated in accordance with paragraph (d)(3) of this section, that all affected units covered by the proposed

Facility-Wide Averaging Plan will be subject to during the ozone season, together with all assumptions included in such calculation; and

(iv) Adequate provisions for testing, monitoring, recordkeeping, and reporting for each affected unit.

(2) Upon the Administrator's approval of a proposed Facility-Wide Averaging Plan, the owner or operator of the affected units covered by the Facility-Wide Averaging Plan shall comply with the cap identified in the plan in lieu of the emissions limits in paragraph (c) of this section. You will be in compliance with the cap if the sum of NO_x emissions from all units covered by the Facility-Wide Averaging Plan, in tons per day on a 30-day rolling average basis, is less than or equal to the cap.

(3) The owner or operator will calculate the cap according to equation 1 to this paragraph (d)(3). You will monitor and record daily hours of engine operation for use in calculating the cap on a 30-day rolling average basis. You will base the hours of operation on hour readings from a non-resettable hour meter or an equivalent monitoring device.

Equation 1 to Paragraph (d)(3)

$$\text{Cap (tons per day)} = 907,184.74 \times \sum_{i=1}^N (R_{li} \times DC \times H_i)$$

Where:

H_i = the average daily operating hours based on the highest consecutive 30-day period during the ozone season of the two most recent years preceding the emissions averaging year (hours).

i = each affected unit included in the Cap.

N = number of affected units.

DC = the engine manufacturer's design maximum capacity in horsepower (hp) at the installation site conditions.

R_{li} = the emissions limit for each affected unit from paragraph (c) of this section (grams/hp-hr).

(i) Any affected unit for which less than two years of operating data are available shall not be included in the Facility-Wide Averaging Plan unless the owner or operator extrapolates the available operating data for the affected unit to two years of operating data, for use in calculating the emissions cap in accordance with paragraph (d)(3) of this section.

(ii) [Reserved]

(4) The owner or operator of an affected units covered by an EPA-approved Facility-Wide Averaging Plan will be in violation of the cap if the sum of NO_x emissions from all such units, in

tons per day on a 30-day rolling average basis, exceeds the cap. Each day of noncompliance by each affected unit covered by the Facility-Wide Averaging Plan shall be a violation of the cap until corrective action is taken to achieve compliance.

(e) *Testing and monitoring requirements.* (1) If you are the owner or operator of an affected unit subject to a NO_x emissions limit under paragraph (c) of this section, you must keep a maintenance plan and records of conducted maintenance and must, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions.

(2) If you are the owner or operator of an affected unit and are operating a NO_x continuous emissions monitoring system (CEMS) that monitors NO_x emissions from the affected unit, you may use the CEMS data in lieu of the annual performance tests and parametric monitoring required under this section. You must meet the

following requirements for using CEMS to monitor NO_x emissions:

(i) You shall install, calibrate, maintain, and operate a continuous emissions monitoring system (CEMS) for measuring NO_x emissions and either oxygen (O₂) or carbon dioxide (CO₂).

(ii) The CEMS shall be operated and data recorded during all periods of operation during the ozone season of the affected unit except for CEMS breakdowns and repairs. Data shall be recorded during calibration checks and zero and span adjustments.

(iii) The 1-hour average NO_x emissions rates measured by the CEMS shall be used to calculate the average emissions rates to demonstrate compliance with the applicable emissions limits in this section.

(iv) The procedures under 40 CFR 60.13 shall be followed for installation, evaluation, and operation of the continuous monitoring systems.

(v) When NO_x emissions data are not obtained because of CEMS breakdowns, repairs, calibration checks, and zero and span adjustments, emissions data will be obtained by using standby

monitoring systems, Method 7 of 40 CFR part 60, appendix A-4, Method 7A of 40 CFR part 60, appendix A-4, or other approved reference methods to provide emissions data for a minimum of 75 percent of the operating hours in each affected unit operating day, in at least 22 out of 30 successive operating days.

(3)(i) If you are the owner or operator of a new affected unit, you must conduct an initial performance test within six months of engine startup and conduct subsequent performance tests every twelve months thereafter to demonstrate compliance. If pollution control equipment is installed to comply with a NO_x emissions limit in paragraph (c) of this section, however, the initial performance test shall be conducted within 90 days of such installation.

(ii) If you are the owner or operator of an existing affected unit, you must conduct an initial performance test within six months of becoming subject to an emissions limit under paragraph (c) of this section and conduct subsequent performance tests every twelve months thereafter to demonstrate compliance. If pollution control equipment is installed to comply with a NO_x emissions limit in paragraph (c) of this section, however, the initial performance test shall be conducted within 90 days of such installation.

(iii) If you are the owner or operator of a new or existing affected unit that is only operated during peak demand periods outside of the ozone season and the engine's hours of operation during the ozone season are 50 hours or less, the affected unit is not subject to the testing and monitoring requirements of this paragraph (e)(3)(iii) as long as you record and report your hours of operation during the ozone season in accordance with paragraphs (f) and (g) of this section.

(iv) If you are the owner or operator of an affected unit, you must conduct all performance tests consistent with the requirements of 40 CFR 60.4244 in accordance with the applicable reference test methods identified in table 2 to subpart JJJJ of 40 CFR part 60, any alternative test method approved by the EPA as of June 5, 2023, under 40 CFR 59.104(f), 60.8(b)(3), 61.13(h)(1)(ii), 63.7(e)(2)(ii), or 65.158(a)(2) and available at the EPA's website (<https://www.epa.gov/emc/broadly-applicable-approved-alternative-test-methods>), or other methods and procedures approved by the EPA through notice-and-comment rulemaking. To determine compliance with the NO_x emissions limit in paragraph (c) of this section, the emissions rate shall be calculated in

accordance with the requirements of 40 CFR 60.4244(d).

(4) If you are the owner or operator of an affected unit that has a non-selective catalytic reduction (NSCR) control device to reduce emissions, you must:

(i) Monitor the inlet temperature to the catalyst daily and conduct maintenance if the temperature is not within the observed inlet temperature range from the most recent performance test or the temperatures specified by the manufacturer if no performance test was required by this section; and

(ii) Measure the pressure drop across the catalyst monthly and conduct maintenance if the pressure drop across the catalyst changes by more than 2 inches of water at 100 percent load plus or minus 10 percent from the pressure drop across the catalyst measured during the most recent performance test.

(5) If you are the owner or operator of an affected unit not using an NSCR control device to reduce emissions, you are required to conduct continuous parametric monitoring to assure compliance with the applicable emissions limits according to the requirements in paragraphs (e)(5)(i) through (vi) of this section.

(i) You must prepare a site-specific monitoring plan that includes all of the following monitoring system design, data collection, and quality assurance and quality control elements:

(A) The performance criteria and design specifications for the monitoring system equipment, including the sample interface, detector signal analyzer, and data acquisition and calculations.

(B) Sampling interface (*e.g.*, thermocouple) location such that the monitoring system will provide representative measurements.

(C) Equipment performance evaluations, system accuracy audits, or other audit procedures.

(D) Ongoing operation and maintenance procedures in accordance with the requirements of paragraph (e)(1) of this section.

(E) Ongoing recordkeeping and reporting procedures in accordance with the requirements of paragraphs (f) and (g) of this section.

(ii) You must continuously monitor the selected operating parameters according to the procedures in your site-specific monitoring plan.

(iii) You must collect parametric monitoring data at least once every 15 minutes.

(iv) When measuring temperature range, the temperature sensor must have a minimum tolerance of 2.8 degrees Celsius (5 degrees Fahrenheit) or 1 percent of the measurement range, whichever is larger.

(v) You must conduct performance evaluations, system accuracy audits, or other audit procedures specified in your site-specific monitoring plan at least annually.

(vi) You must conduct a performance evaluation of each parametric monitoring device in accordance with your site-specific monitoring plan.

(6) If you are the owner or operator of an affected unit that is only operated during peak periods outside of the ozone season and your hours of operation during the ozone season are 0, you are not subject to the testing and monitoring requirements of this paragraph (e)(6) so long as you record and report your hours of operation during the ozone season in accordance with paragraphs (f) and (g) of this section.

(f) *Recordkeeping requirements.* If you are the owner or operator of an affected unit, you must keep records of:

(1) Performance tests conducted pursuant to paragraph (e)(2) of this section, including the date, engine settings on the date of the test, and documentation of the methods and results of the testing.

(2) Catalyst monitoring required by paragraph (e)(3) of this section, if applicable, and any actions taken to address monitored values outside the temperature or pressure drop parameters, including the date and a description of actions taken.

(3) Parameters monitored pursuant to the facility's site-specific parametric monitoring plan.

(4) Hours of operation on a daily basis.

(5) Tuning, adjustments, or other combustion process adjustments and the date of the adjustment(s).

(6) For any Facility-Wide Averaging Plan approved by the Administrator under paragraph (d) of this section, daily calculations of total NO_x emissions to demonstrate compliance with the cap during the ozone season. You must use the equation in this paragraph (f)(6) to calculate total NO_x emissions from all affected units covered by the Facility-Wide Averaging Plan, in tons per day on a 30-day rolling average basis, for purposes of determining compliance with the cap during the ozone season. A new 30-day rolling average emissions rate in tpd is calculated for each operating day during the ozone season, using the 30-day rolling average daily operating hours for the preceding 30 operating days.

Equation 2 to Paragraph (f)(6)

$$\sum_{i=1}^N (R_{ai} \times DC \times H_{ai}) \leq Cap \text{ (tons per day)}$$

Where:

H_{ai} = the consecutive 30-day rolling average daily operating hours for the preceding 30 operating days during ozone season (hours).

i = each affected unit.

N = number of affected units.

DC = the engine manufacturer's maximum design capacity in horsepower (hp) at the installation site conditions.

R_{ai} = the actual emissions rate for each affected unit based on the most recent performance test results, (grams/hp-hr).

(g) *Reporting requirements.* (1) If you are the owner or operator of an affected unit, you must submit the results of the performance test or performance evaluation of the CEMS following the procedures specified in § 52.40(g) within 60 days after completing each performance test required by this section.

(2) If you are the owner or operator of an affected unit, you are required to submit excess emissions reports for any excess emissions that occurred during the reporting period. Excess emissions are defined as any calculated 30-day rolling average NO_x emissions rate that exceeds the applicable emissions limit in paragraph (c) of this section. Excess emissions reports must be submitted in PDF format to the EPA via CEDRI or analogous electronic reporting approach provided by the EPA to report data required by this section following the procedures specified in § 52.40(g).

(3) If you are the owner or operator of an affected unit, you must submit an annual report in PDF format to the EPA by January 30th of each year via CEDRI or analogous electronic reporting approach provided by the EPA to report data required by this section. Annual reports shall be submitted following the procedures in paragraph (g) of this section. The report shall contain the following information:

- (i) The name and address of the owner and operator;
- (ii) The address of the subject engine;
- (iii) Longitude and latitude coordinates of the subject engine;
- (iv) Identification of the subject engine;
- (v) Statement of compliance with the applicable emissions limit under paragraph (c) of this section or a Facility-Wide Averaging Plan under paragraph (d) of this section;
- (vi) Statement of compliance regarding the conduct of maintenance and operations in a manner consistent

with good air pollution control practices for minimizing emissions;

(vii) The date and results of the performance test conducted pursuant to paragraph (e) of this section;

(viii) Any records required by paragraph (f) of this section, including records of parametric monitoring data, to demonstrate compliance with the applicable emissions limit under paragraph (c) of this section or a Facility-Wide Averaging Plan under paragraph (d) of this section, if applicable;

(ix) If applicable, a statement documenting any change in the operating characteristics of the subject engine; and

(x) A statement certifying that the information included in the annual report is complete and accurate.

§ 52.42 What are the requirements of the Federal Implementation Plans (FIPs) relating to ozone season emissions of nitrogen oxides from the Cement and Concrete Product Manufacturing Industry?

(a) *Definitions.* All terms not defined in this paragraph (a) shall have the meaning given to them in the Act and in subpart A of 40 CFR part 60.

Affected unit means a cement kiln meeting the applicability criteria of this section.

Cement kiln means an installation, including any associated pre-heater or pre-calciner devices, that produces clinker by heating limestone and other materials to produce Portland cement.

Cement plant means any facility manufacturing cement by either the wet or dry process.

Clinker means the product of a cement kiln from which finished cement is manufactured by milling and grinding.

Operating day means a 24-hour period beginning at 12:00 midnight during which the kiln produces clinker at any time.

(b) *Applicability.* You are subject to the requirements of this section if you own or operate a new or existing cement kiln that emits or has the potential to emit 100 tons per year or more of NO_x on or after August 4, 2023, and is located within any of the States listed in § 52.40(c)(2), including Indian country located within the borders of any such State(s). Any existing cement kiln with a potential to emit of 100 tons per year or more of NO_x on August 4, 2023, will continue to be subject to the

requirements of this section even if that unit later becomes subject to a physical or operational limitation that lowers its potential to emit below 100 tons per year of NO_x .

(c) *Emissions limitations.* If you are the owner or operator of an affected unit, you must meet the following emissions limitations on a 30-day rolling average basis during the 2026 ozone season and in each ozone season thereafter:

- (1) Long wet kilns: 4.0 lb/ton of clinker;
- (2) Long dry kilns: 3.0 lb/ton of clinker;
- (3) Preheater kilns: 3.8 lb/ton of clinker;
- (4) Precalciner kilns: 2.3 lb/ton of clinker; and
- (5) Preheater/Precalciner kilns: 2.8 lb/ton of clinker.

(d) *Testing and monitoring requirements.* (1) If you are the owner or operator of an affected unit you must conduct performance tests, on an annual basis, in accordance with the applicable reference test methods of 40 CFR part 60, appendix A-4, any alternative test method approved by the EPA as of June 5, 2023, under 40 CFR 59.104(f), 60.8(b)(3), 61.13(h)(1)(ii), 63.7(e)(2)(ii), or 65.158(a)(2) and available at the EPA's website (<https://www.epa.gov/emc/broadly-applicable-approved-alternative-test-methods>), or other methods and procedures approved by the EPA through notice-and-comment rulemaking. The annual performance test does not have to be performed during the ozone season. You must calculate and record the 30-operating day rolling average emissions rate of NO_x as the total of all hourly emissions data for a cement kiln in the preceding 30 days, divided by the total tons of clinker produced in that kiln during the same 30-operating day period, using equation 1 to this paragraph (d)(1):

Equation 1 to Paragraph (d)(1)

$$E_{30D} = k \left(\frac{\sum_{i=1}^N C_i Q_i}{P} \right)$$

Where:

E_{30D} = 30 kiln operating day average emissions rate of NO_x , in lbs/ton of clinker.

C_i = Concentration of NO_x for hour i , in ppm.

Q_i = Volumetric flow rate of effluent gas for hour i , where C_i and Q_i are on the same basis (either wet or dry), in scf/hr.

P = 30 days of clinker production during the same Time period as the NO_x emissions measured, in tons.

k = Conversion factor, 1.194×10^{-7} for NO_x, in lb/scf/ppm.

n = Number of kiln operating hours over 30 kiln operating days.

(2) If you are the owner or operator of an affected unit and are operating a NO_x continuous emissions monitoring system (CEMS) that monitors NO_x emissions from the affected unit, you may use the CEMS data in lieu of the annual performance tests and parametric monitoring required under this section. You must meet the following requirements for using CEMS to monitor NO_x emissions:

(i) You shall install, calibrate, maintain, and operate a continuous emissions monitoring system (CEMS) for measuring NO_x emissions and either oxygen (O₂) or carbon dioxide (CO₂).

(ii) The CEMS shall be operated and data recorded during all periods of operation during the ozone season of the affected unit except for CEMS breakdowns and repairs. Data shall be recorded during calibration checks and zero and span adjustments.

(iii) The 1-hour average NO_x emissions rates measured by the CEMS shall be expressed in terms of lbs/ton of clinker and shall be used to calculate the average emissions rates to demonstrate compliance with the applicable emissions limits in this section.

(iv) The procedures under 40 CFR 60.13 shall be followed for installation, evaluation, and operation of the continuous monitoring systems.

(v) When NO_x emissions data are not obtained because of CEMS breakdowns, repairs, calibration checks and zero and span adjustments, emissions data will be obtained by using standby monitoring systems, Method 7 of 40 CFR part 60, appendix A-4, Method 7A of 40 CFR part 60, appendix A-4, or other approved reference methods to provide emissions data for a minimum of 75 percent of the operating hours in each affected unit operating day, in at least 22 out of 30 successive operating days.

(3) If you are the owner or operator of an affected unit not operating NO_x CEMS, you must conduct an initial performance test before the 2026 ozone season to establish appropriate indicator ranges for operating parameters and continuously monitor those operator parameters consistent with the requirements of paragraphs (d)(3)(i) through (v) of this section.

(i) You must monitor and record kiln stack exhaust gas flow rate, hourly clinker production rate or kiln feed rate,

and kiln stack exhaust temperature during the initial performance test and subsequent annual performance tests to demonstrate continuous compliance with your NO_x emissions limits.

(ii) You must determine hourly clinker production by one of two methods:

(A) Install, calibrate, maintain, and operate a permanent weigh scale system to record weight rates of the amount of clinker produced in tons of mass per hour. The system of measuring hourly clinker production must be maintained within ± 5 percent accuracy; or

(B) Install, calibrate, maintain, and operate a permanent weigh scale system to measure and record weight rates of the amount of feed to the kiln in tons of mass per hour. The system of measuring feed must be maintained within ± 5 percent accuracy. Calculate your hourly clinker production rate using a kiln specific feed-to-clinker ratio based on reconciled clinker production rates determined for accounting purposes and recorded feed rates. This ratio should be updated monthly. Note that if this ratio changes at clinker reconciliation, you must use the new ratio going forward, but you do not have to retroactively change clinker production rates previously estimated.

(C) For each kiln operating hour for which you do not have data on clinker production or the amount of feed to the kiln, use the value from the most recent previous hour for which valid data are available.

(D) If you measure clinker production directly, record the daily clinker production rates; if you measure the kiln feed rates and calculate clinker production, record the daily kiln feed and clinker production rates.

(iii) You must use the kiln stack exhaust gas flow rate, hourly kiln production rate or kiln feed rate, and kiln stack exhaust temperature during the initial performance test and subsequent annual performance tests as indicators of NO_x operating parameters to demonstrate continuous compliance and establish site-specific indicator ranges for these operating parameters.

(iv) You must repeat the performance test annually to reassess and adjust the site-specific operating parameter indicator ranges in accordance with the results of the performance test.

(v) You must report and include your ongoing site-specific operating parameter data in the annual reports required under paragraph (e) of this section and semi-annual title V monitoring reports to the relevant permitting authority.

(e) *Recordkeeping requirements.* If you are the owner or operator of an

affected unit, you shall maintain records of the following information for each day the affected unit operates:

(1) Calendar date;

(2) The average hourly NO_x emissions rates measured or predicted;

(3) The 30-day average NO_x emissions rates calculated at the end of each affected unit operating day from the measured or predicted hourly NO_x emissions rates for the preceding 30 operating days;

(4) Identification of the affected unit operating days when the calculated 30-day average NO_x emissions rates are in excess of the applicable site-specific NO_x emissions limit with the reasons for such excess emissions as well as a description of corrective actions taken;

(5) Identification of the affected unit operating days for which pollutant data have not been obtained, including reasons for not obtaining sufficient data and a description of corrective actions taken;

(6) Identification of the times when emissions data have been excluded from the calculation of average emissions rates and the reasons for excluding data;

(7) If a CEMS is used to verify compliance:

(i) Identification of the times when the pollutant concentration exceeded full span of the CEMS;

(ii) Description of any modifications to the CEMS that could affect the ability of the CEMS to comply with Performance Specification 2 or 3 in appendix B to 40 CFR part 60; and

(iii) Results of daily CEMS drift tests and quarterly accuracy assessments as required under Procedure 1 of 40 CFR part 60, appendix F;

(8) Operating parameters required under paragraph (d) of this section to demonstrate compliance during the ozone season;

(9) Each fuel type, usage, and heat content; and

(10) Clinker production rates.

(f) *Reporting requirements.* (1) If you are the owner or operator of an affected unit, you shall submit the results of the performance test or performance evaluation of the CEMS following the procedures specified in § 52.40(g) within 60 days after the date of completing each performance test required by this section.

(2) If you are the owner or operator of an affected unit, you are required to submit excess emissions reports for any excess emissions that occurred during the reporting period. Excess emissions are defined as any calculated 30-day rolling average NO_x emissions rate that exceeds the applicable emissions limit established under paragraph (c) of this section. Excess emissions reports must

be submitted in PDF format to the EPA via CEDRI or analogous electronic reporting approach provided by the EPA to report data required by this section following the procedures specified in § 52.40(g).

(3) If you are the owner or operator of an affected unit, you shall submit an annual report in PDF format to the EPA by January 30th of each year via CEDRI or analogous electronic reporting approach provided by the EPA to report data required by this section. Annual reports shall be submitted following the procedures in § 52.40(g). The report shall include records all records required by paragraph (d) of this section, including record of CEMS data or operating parameters required by paragraph (d) to demonstrate continuous compliance the applicable emissions limits under paragraph (c) of this section.

(g) *Initial notification requirements for existing affected units.* (1) The requirements of this paragraph (g) apply to the owner or operator of an existing affected unit.

(2) The owner or operator of an existing affected unit that emits or has a potential to emit 100 tons per year or greater as of August 4, 2023, shall notify the Administrator via the CEDRI or analogous electronic submission system provided by the EPA that the unit is subject to this section. The notification, which shall be submitted not later than December 4, 2023, shall be submitted in PDF format to the EPA via CEDRI, which can be accessed through the EPA's CDX (<https://cdx.epa.gov/>). The notification shall provide the following information:

(i) The name and address of the owner or operator;

(ii) The address (*i.e.*, physical location) of the affected unit;

(iii) An identification of the relevant standard, or other requirement, that is the basis for the notification and the unit's compliance date; and

(iv) A brief description of the nature, size, design, and method of operation of the facility and an identification of the types of emissions points (units) within the facility subject to the relevant standard.

§ 52.43 What are the requirements of the Federal Implementation Plans (FIPs) relating to ozone season emissions of nitrogen oxides from the Iron and Steel Mills and Ferroalloy Manufacturing Industry?

(a) *Definitions.* All terms not defined in this paragraph (a) shall have the meaning given to them in the Act and in subpart A of 40 CFR part 60.

Affected unit means any reheat furnace meeting the applicability criteria of this section.

Day means a calendar day unless expressly stated to be a business day. In computing any period of time for recordkeeping and reporting purposes where the last day would fall on a Saturday, Sunday, or Federal holiday, the period shall run until the close of business of the next business day.

Low NO_x burner means a burner designed to reduce flame turbulence by the mixing of fuel and air and by establishing fuel-rich zones for initial combustion, thereby reducing the formation of NO_x.

Low-NO_x technology means any post-combustion NO_x control technology capable of reducing NO_x emissions by 40% from baseline emission levels as measured during pre-installation testing.

Operating day means a 24-hour period beginning at 12:00 midnight during which any fuel is combusted at any time in the reheat furnace.

Reheat furnace means a furnace used to heat steel product—including metal ingots, billets, slabs, beams, blooms and other similar products—for the purpose of deformation and rolling.

(b) *Applicability.* The requirements of this section apply to each new or existing reheat furnace at an iron and steel mill or ferroalloy manufacturing facility that directly emits or has the potential to emit 100 tons per year or more of NO_x on or after August 4, 2023, does not have low-NO_x burners installed, and is located within any of the States listed in § 52.40(c)(2), including Indian country located within the borders of any such State(s). Any existing reheat furnace with a potential to emit of 100 tons per year or more of NO_x on August 4, 2023, will continue to be subject to the requirements of this section even if that unit later becomes subject to a physical or operational limitation that lowers its potential to emit below 100 tons per year of NO_x.

(c) *Emissions control requirements.* If you are the owner or operator of an affected unit without low-NO_x burners already installed, you must install and operate low-NO_x burners or equivalent alternative low-NO_x technology designed to achieve at least a 40% reduction from baseline NO_x emissions in accordance with the work plan established pursuant to paragraph (d) of this section. You must meet the emissions limit established under paragraph (d) on a 30-day rolling average basis.

(d) *Work plan requirements.* (1) The owner or operator of each affected unit must submit a work plan for each

affected unit by August 5, 2024. The work plan must be submitted via CEDRI or analogous electronic reporting approach provided by the EPA to report data required by this section following the procedures specified in § 52.40(g). Each work plan must include a description of the affected unit and rated production and energy capacities, identification of the low-NO_x burner or alternative low NO_x technology selected, and the phased construction timeframe by which you will design, install, and consistently operate the device. Each work plan shall also include, where applicable, performance test results obtained no more than five years before August 4, 2023, to be used as baseline emissions testing data providing the basis for required emissions reductions. If no such data exist, then the owner or operator must perform pre-installation testing as described in paragraph (e)(3) of this section.

(2) The owner or operator of an affected unit shall design each low-NO_x burner or alternative low-NO_x technology identified in the work plan to achieve NO_x emission reductions by a minimum of 40% from baseline emission levels measured during performance testing that meets the criteria set forth in paragraph (e)(1) of this section, or during pre-installation testing as described in paragraph (e)(3) of this section. Each low-NO_x burner or alternative low-NO_x technology shall be continuously operated during all production periods according to paragraph (c) of this section.

(3) The owner or operator of an affected unit shall establish an emissions limit in the work plan that the affected unit must comply with in accordance with paragraph (c) of this section.

(4) The EPA's action on work plans:

(i) The Administrator will provide via the CEDRI or analogous electronic submission system provided by the EPA notification to the owner or operator of an affected unit if the submitted work plan is complete, that is, whether the request contains sufficient information to make a determination, within 60 calendar days after receipt of the original work plan and within 60 calendar days after receipt of any supplementary information.

(ii) The Administrator will provide notification via the CEDRI or analogous electronic submission system provided by the EPA, which shall be publicly available, to the owner or operator of a decision to approve or intention to disapprove the work plan within 60 calendar days after providing written notification pursuant to paragraph

(d)(4)(i) of this section that the submitted work plan is complete.

(iii) Before disapproving a work plan, the Administrator will notify the owner or operator via the CEDRI or analogous electronic submission system provided by the EPA of the Administrator's intention to issue the disapproval, together with:

(A) Notice of the information and findings on which the intended disapproval is based; and

(B) Notice of opportunity for the owner or operator to present in writing, within 15 calendar days after he/she is notified of the intended disapproval, additional information or arguments to the Administrator before further action on the work plan.

(iv) The Administrator's final decision to disapprove a work plan will be via the CEDRI or analogous electronic submission system provided by the EPA and publicly available, and will set forth the specific grounds on which the disapproval is based. The final decision will be made within 60 calendar days after presentation of additional information or argument (if the submitted work plan is complete), or within 60 calendar days after the deadline for the submission of additional information or argument under paragraph (d)(5)(iii)(B) of this section, if no such submission is made.

(v) If the Administrator disapproves the submitted work plan for failure to satisfy the requirements of paragraphs (c) and (d)(1) through (3) of this section, or if the owner or operator of an affected unit fails to submit a work plan by August 5, 2024, the owner or operator will be in violation of this section. Each day that the affected unit operates following such disapproval or failure to submit shall constitute a violation.

(e) *Testing and monitoring requirements.* (1) If you are the owner or operator of an affected unit you must conduct performance tests, on an annual basis, in accordance with the applicable reference test methods of 40 CFR part 60, appendix A-4, any alternative test method approved by the EPA as of June 5, 2023, under 40 CFR 59.104(f), 60.8(b)(3), 61.13(h)(1)(ii), 63.7(e)(2)(ii), or 65.158(a)(2) and available at the EPA's website (<https://www.epa.gov/emc/broadly-applicable-approved-alternative-test-methods>), or other methods and procedures approved by the EPA through notice-and-comment rulemaking. The annual performance test does not have to be performed during the ozone season.

(2) If you are the owner or operator of an affected unit and are operating a NO_x continuous emissions monitoring system (CEMS) that monitors NO_x

emissions from the affected unit, you may use the CEMS data in lieu of the annual performance tests and parametric monitoring required under this section. You must meet the following requirements for using CEMS to monitor NO_x emissions:

(i) You shall install, calibrate, maintain, and operate a continuous emissions monitoring system (CEMS) for measuring NO_x emissions and either oxygen (O₂) or carbon dioxide (CO₂).

(ii) The CEMS shall be operated and data recorded during all periods of operation during the ozone season of the affected unit except for CEMS breakdowns and repairs. Data shall be recorded during calibration checks and zero and span adjustments.

(iii) The 1-hour average NO_x emissions rates measured by the CEMS shall be expressed in form of the emissions limit established in the work plan and shall be used to calculate the average emissions rates to demonstrate compliance with the applicable emissions limits established in the work plan.

(iv) The procedures under 40 CFR 60.13 shall be followed for installation, evaluation, and operation of the continuous monitoring systems.

(v) When NO_x emissions data are not obtained because of CEMS breakdowns, repairs, calibration checks and zero and span adjustments, emissions data will be obtained by using standby monitoring systems, Method 7 of 40 CFR part 60, appendix A-4, Method 7A of 40 CFR part 60, appendix A-4, or other approved reference methods to provide emissions data for a minimum of 75 percent of the operating hours in each affected unit operating day, in at least 22 out of 30 successive operating days.

(3) If you are the owner or operator of an affected unit not operating NO_x CEMS, you must conduct an initial performance test before the 2026 ozone season to establish appropriate indicator ranges for operating parameters and continuously monitor those operator parameters consistent with the requirements of paragraphs (e)(3)(i) through (iv) of this section.

(i) You must monitor and record stack exhaust gas flow rate and temperature during the initial performance test and subsequent annual performance tests to demonstrate continuous compliance with your NO_x emissions limits.

(ii) You must use the stack exhaust gas flow rate and temperature during the initial performance test and subsequent annual performance tests to establish a site-specific indicator for these operating parameters.

(iii) You must repeat the performance test annually to reassess and adjust the site-specific operating parameter indicator ranges in accordance with the results of the performance test.

(iv) You must report and include your ongoing site-specific operating parameter data in the annual reports required under paragraph (f) of this section and semi-annual title V monitoring reports to the relevant permitting authority.

(f) *Recordkeeping requirements.* If you are the owner or operator of an affected unit, you shall maintain records of the following information for each day the affected unit operates:

(1) Calendar date;

(2) The average hourly NO_x emissions rates measured or predicted;

(3) The 30-day average NO_x emissions rates calculated at the end of each affected unit operating day from the measured or predicted hourly NO_x emissions rates for the preceding 30 operating days;

(4) Identification of the affected unit operating days when the calculated 30-day average NO_x emissions rates are in excess of the applicable site-specific NO_x emissions limit with the reasons for such excess emissions as well as a description of corrective actions taken;

(5) Identification of the affected unit operating days for which pollutant data have not been obtained, including reasons for not obtaining sufficient data and a description of corrective actions taken;

(6) Identification of the times when emissions data have been excluded from the calculation of average emissions rates and the reasons for excluding data;

(7) If a CEMS is used to verify compliance:

(i) Identification of the times when the pollutant concentration exceeded full span of the CEMS;

(ii) Description of any modifications to the CEMS that could affect the ability of the CEMS to comply with Performance Specification 2 or 3 in appendix B to 40 CFR part 60; and

(iii) Results of daily CEMS drift tests and quarterly accuracy assessments as required under Procedure 1 of 40 CFR part 60, appendix F;

(8) Operating parameters required under paragraph (d) of this section to demonstrate compliance during the ozone season; and

(9) Each fuel type, usage, and heat content.

(g) *Reporting requirements.* (1) If you are the owner or operator of an affected unit, you shall submit a final report via the CEDRI or analogous electronic submission system provided by the EPA, by no later than March 30, 2026,

certifying that installation of each selected control device has been completed. You shall include in the report the dates of final construction and relevant performance testing, where applicable, demonstrating compliance with the selected emission limits pursuant to paragraphs (c) and (d) of this section.

(2) If you are the owner or operator of an affected unit, you must submit the results of the performance test or performance evaluation of the CEMS following the procedures specified in § 52.40(g) within 60 days after the date of completing each performance test required by this section.

(3) If you are the owner or operator of an affected unit, you are required to submit excess emissions reports for any excess emissions that occurred during the reporting period. Excess emissions are defined as any calculated 30-day rolling average NO_x emissions rate that exceeds the applicable emissions limit established under paragraphs (c) and (d) of this section. Excess emissions reports must be submitted in PDF format to the EPA via CEDRI or analogous electronic reporting approach provided by the EPA to report data required by this section following the procedures specified in § 52.40(g).

(4) If you are the owner or operator of an affected unit, you shall submit an annual report in PDF format to the EPA by January 30th of each year via CEDRI or analogous electronic reporting approach provided by the EPA to report data required by this section. Annual reports shall be submitted following the procedures in § 52.40(g). The report shall include records all records required by paragraphs (e) and (f) of this section, including record of CEMS data or operating parameters required by paragraph (e) to demonstrate compliance the applicable emissions limits established under paragraphs (c) and (d) of this section.

(h) *Initial notification requirements for existing affected units.* (1) The requirements of this paragraph (h) apply to the owner or operator of an existing affected unit.

(2) The owner or operator of an existing affected unit that emits or has a potential to emit 100 tons per year or more of NO_x as of August 4, 2023, shall notify the Administrator via the CEDRI or analogous electronic submission system provided by the EPA that the unit is subject to this section. The notification, which shall be submitted not later than December 4, 2023, shall be submitted in PDF format to the EPA via CEDRI, which can be accessed through the EPA's CDX (<https://>

cdx.epa.gov/). The notification shall provide the following information:

(i) The name and address of the owner or operator;

(ii) The address (*i.e.*, physical location) of the affected unit;

(iii) An identification of the relevant standard, or other requirement, that is the basis for the notification and the unit's compliance date; and

(iv) A brief description of the nature, size, design, and method of operation of the facility and an identification of the types of emissions points (units) within the facility subject to the relevant standard.

§ 52.44 What are the requirements of the Federal Implementation Plans (FIPs) relating to ozone season emissions of nitrogen oxides from the Glass and Glass Product Manufacturing Industry?

(a) *Definitions.* All terms not defined in this paragraph (a) shall have the meaning given to them in the Act and in subpart A of 40 CFR part 60.

Affected units means a glass manufacturing furnace meeting the applicability criteria of this section.

Borosilicate recipe means glass product composition of the following approximate ranges of weight proportions: 60 to 80 percent silicon dioxide, 4 to 10 percent total R₂O (*e.g.*, Na₂O and K₂O), 5 to 35 percent boric oxides, and 0 to 13 percent other oxides.

Container glass means glass made of soda-lime recipe, clear or colored, which is pressed and/or blown into bottles, jars, ampoules, and other products listed in Standard Industrial Classification (SIC) 3221 (SIC 3221).

Flat glass means glass made of soda-lime recipe and produced into continuous flat sheets and other products listed in SIC 3211.

Glass melting furnace means a unit comprising a refractory vessel in which raw materials are charged, melted at high temperature, refined, and conditioned to produce molten glass.

The unit includes foundations, superstructure and retaining walls, raw material charger systems, heat exchangers, melter cooling system, exhaust system, refractory brick work, fuel supply and electrical boosting equipment, integral control systems and instrumentation, and appendages for conditioning and distributing molten glass to forming apparatuses. The forming apparatuses, including the float bath used in flat glass manufacturing and flow channels in wool fiberglass and textile fiberglass manufacturing, are not considered part of the glass melting furnace.

Glass produced means the weight of the glass pulled from the glass melting furnace.

Idling means the operation of a glass melting furnace at less than 25% of the permitted production capacity or fuel use capacity as stated in the operating permit.

Lead recipe means glass product composition of the following ranges of weight proportions: 50 to 60 percent silicon dioxide, 18 to 35 percent lead oxides, 5 to 20 percent total R₂O (*e.g.*, Na₂O and K₂O), 0 to 8 percent total R₂O₃ (*e.g.*, Al₂O₃), 0 to 15 percent total RO (*e.g.*, CaO, MgO), other than lead oxide, and 5 to 10 percent other oxides.

Operating day means a 24-hr period beginning at 12:00 midnight during which the furnace combusts fuel at any time but excludes any period of startup, shutdown, or idling during which the affected unit complies with the requirements in paragraphs (d) through (f) of this section, as applicable.

Pressed and blown glass means glass which is pressed, blown, or both, including textile fiberglass, noncontinuous flat glass, noncontainer glass, and other products listed in SIC 3229. It is separated into: Glass of borosilicate recipe, Glass of soda-lime and lead recipes, and Glass of opal, fluoride, and other recipes.

Raw material means minerals, such as silica sand, limestone, and dolomite; inorganic chemical compounds, such as soda ash (sodium carbonate), salt cake (sodium sulfate), and potash (potassium carbonate); metal oxides and other metal-based compounds, such as lead oxide, chromium oxide, and sodium antimonate; metal ores, such as chromite and pyrolusite; and other substances that are intentionally added to a glass manufacturing batch and melted in a glass melting furnace to produce glass. Metals that are naturally-occurring trace constituents or contaminants of other substances are not considered to be raw materials.

Shutdown means the period of time during which a glass melting furnace is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to a cold or ambient temperature as the fuel supply is turned off.

Soda-lime recipe means glass product composition of the following ranges of weight proportions: 60 to 75 percent silicon dioxide, 10 to 17 percent total R₂O (*e.g.*, Na₂O and K₂O), 8 to 20 percent total RO but not to include any PbO (*e.g.*, CaO, and MgO), 0 to 8 percent total R₂O₃ (*e.g.*, Al₂O₃), and 1 to 5 percent other oxides.

Startup means the period of time, after initial construction or a furnace rebuild, during which a glass melting furnace is heated to operating temperatures by the primary furnace

combustion system, and systems and instrumentation are brought to stabilization.

Textile fiberglass means fibrous glass in the form of continuous strands having uniform thickness.

Wool fiberglass means fibrous glass of random texture, including acoustical board and tile (mineral wool), fiberglass insulation, glass wool, insulation (rock wool, fiberglass, slag, and silica minerals), and mineral wool roofing mats.

(b) *Applicability.* You are subject to the requirements under this section if you own or operate a new or existing glass manufacturing furnace that directly emits or has the potential to emit 100 tons per year or more of NO_x on or after August 4, 2023, and is located within any of the States listed in § 52.40(c)(2), including Indian country located within the borders of any such State(s). Any existing glass manufacturing furnace with a potential to emit 100 tons per year or more of NO_x on August 4, 2023, will continue to be subject to the requirements of this section even if that unit later becomes subject to a physical or operational limitation that lowers its potential to emit below 100 tons per year of NO_x.

(c) *Emissions limitations.* If you are the owner or operator of an affected unit, you must meet the emissions limitations in paragraphs (c)(1) and (2) of this section on a 30-day rolling average basis during the 2026 ozone season and in each ozone season thereafter. For the 2026 ozone season, the emissions limitations in paragraphs (c)(1) and (2) do not apply during shutdown and idling if the affected unit complies with the requirements in paragraphs (e) and (f) of this section, as applicable. For the 2027 and subsequent ozone seasons, the emissions limitations in paragraphs (c)(1) and (2) do not apply during startup, shutdown, and idling, if the affected unit complies with the requirements in paragraphs (d) through (f) of this section, as applicable.

(1) Container glass, pressed/blown glass, or fiberglass manufacturing furnace: 4.0 lb/ton of glass; and

(2) Flat glass manufacturing furnace: 7.0 lb/ton of glass.

(d) *Startup requirements.* (1) If you are the owner or operator of an affected unit, you shall submit via the CEDRI or analogous electronic submission system provided by the EPA, no later than 30 days prior to the anticipated date of startup, the following information to assure proper operation of the furnace:

(i) A detailed list of activities to be performed during startup and explanations to support the length of time needed to complete each activity.

(ii) A description of the material process flow rates, system operating parameters, and other information that the owner or operator shall monitor and record during the startup period.

(iii) Identification of the control technologies or strategies to be utilized.

(iv) A description of the physical conditions present during startup periods that prevent the controls from being effective.

(v) A reasonably precise estimate as to when physical conditions will have reached a state that allows for the effective control of emissions.

(2) The length of startup following activation of the primary furnace combustion system may not exceed:

(i) Seventy days for a container, pressed or blown glass furnace;

(ii) Forty days for a fiberglass furnace; and

(iii) One hundred and four days for a flat glass furnace and for all other glass melting furnaces not covered under paragraphs (d)(2)(i) and (ii) of this section.

(3) During the startup period, the owner or operator of an affected unit shall maintain the stoichiometric ratio of the primary furnace combustion system so as not to exceed 5 percent excess oxygen, as calculated from the actual fuel and oxidant flow measurements for combustion in the affected unit.

(4) The owner or operator of an affected unit shall place the emissions control system in operation as soon as technologically feasible during startup to minimize emissions.

(e) *Shutdown requirements.* (1) If you are the owner or operator of an affected unit, you shall submit via the CEDRI or analogous electronic submission system provided by the EPA to the Administrator, no later than 30 days prior to the anticipated date of shutdown, the following information to assure proper operation of the furnace:

(i) A detailed list of activities to be performed during shutdown and explanations to support the length of time needed to complete each activity.

(ii) A description of the material process flow rates, system operating parameters, and other information that the owner or operator shall monitor and record during the shutdown period.

(iii) Identification of the control technologies or strategies to be utilized.

(iv) A description of the physical conditions present during shutdown periods that prevent the controls from being effective.

(v) A reasonably precise estimate as to when physical conditions will have reached a state that allows for the effective control of emissions.

(2) The duration of a shutdown, as measured from the time the furnace operations drop below 25% of the permitted production capacity or fuel use capacity to when all emissions from the furnace cease, may not exceed 20 days.

(3) If you are the owner or operator of an affected unit, you shall operate the emissions control system whenever technologically feasible during shutdown to minimize emissions.

(f) *Idling requirements.* (1) If you are the owner or operator of an affected unit, you shall operate the emissions control system whenever technologically feasible during idling to minimize emissions.

(2) If you are the owner or operator of an affected unit, your NO_x emissions during idling may not exceed the amount calculated using the following equation: Pounds per day emissions limit of NO_x = (Applicable NO_x emissions limit specified in paragraph (c) of this section expressed in pounds per ton of glass produced) × (Furnace permitted production capacity in tons of glass produced per day).

(3) To demonstrate compliance with the alternative daily NO_x emissions limit identified in paragraph (f)(2) of this section during periods of idling, the owners or operators of an affected unit shall maintain records consistent with paragraph (h)(3) of this section.

(g) *Testing and monitoring requirements.* (1) If you own or operate an affected unit subject to the NO_x emissions limits under paragraph (c) of this section you must conduct performance tests, on an annual basis, in accordance with the applicable reference test methods of 40 CFR part 60, appendix A-4, any alternative test method approved by the EPA as of June 5, 2023, under 40 CFR 59.104(f), 60.8(b)(3), 61.13(h)(1)(ii), 63.7(e)(2)(ii), or 65.158(a)(2) and available at the EPA's website (<https://www.epa.gov/emc/broadly-applicable-approved-alternative-test-methods>), or other methods and procedures approved by the EPA through notice-and-comment rulemaking. The annual performance test does not have to be performed during the ozone season. Owners or operators of affected units must calculate and record the 30-day rolling average emissions rate of NO_x as the total of all hourly emissions data for an affected unit in the preceding 30 days, divided by the total tons of glass produced in that affected unit during the same 30-day period. Direct measurement or material balance using good engineering practice shall be used to determine the amount of glass produced during the performance test.

The rate of glass produced is defined as the weight of glass pulled from the affected unit during the performance test divided by the number of hours taken to perform the performance test.

(2) If you are the owner or operator of an affected unit subject to the NO_x emissions limits under paragraph (c)(1) of this section and are operating a NO_x CEMS that monitors NO_x emissions from the affected unit, you may use the CEMS data in lieu of the annual performance tests and parametric monitoring required under this section. You must meet the following requirements for using CEMS to monitor NO_x emissions:

(i) You shall install, calibrate, maintain, and operate a continuous emissions monitoring system (CEMS) for measuring NO_x emissions and either oxygen (O₂) or carbon dioxide (CO₂).

(ii) The CEMS shall be operated and data recorded during all periods of operation during the ozone season of the affected unit except for CEMS breakdowns and repairs. Data shall be recorded during calibration checks and zero and span adjustments.

(iii) The 1-hour average NO_x emissions rates measured by the CEMS shall be expressed in terms of lbs/ton of glass and shall be used to calculate the average emissions rates to demonstrate compliance with the applicable emissions limits in this section.

(iv) The procedures under 40 CFR 60.13 shall be followed for installation, evaluation, and operation of the continuous monitoring systems.

(v) When NO_x emissions data are not obtained because of CEMS breakdowns, repairs, calibration checks and zero and span adjustments, emissions data will be obtained by using standby monitoring systems, Method 7 of 40 CFR part 60, appendix A-4, Method 7A of 40 CFR part 60, appendix A-4, or other approved reference methods to provide emissions data for a minimum of 75 percent of the operating hours in each affected unit operating day, in at least 22 out of 30 successive operating days.

(3) If you are the owner or operator of an affected unit not operating NO_x CEMS, you must conduct an initial performance test before the 2026 ozone season to establish appropriate indicator ranges for operating parameters and continuously monitor those operator parameters consistent with the requirements of paragraphs (g)(3)(i) through (iv) of this section.

(i) You must monitor and record stack exhaust gas flow rate, hourly glass production, and stack exhaust gas temperature during the initial performance test and subsequent annual

performance tests to demonstrate continuous compliance with your NO_x emissions limits.

(ii) You must use the stack exhaust gas flow rate, hourly glass production, and stack exhaust gas temperature during the initial performance test and subsequent annual performance tests as NO_x CEMS indicators to demonstrate continuous compliance and establish a site-specific indicator ranges for these operating parameters.

(iii) You must repeat the performance test annually to reassess and adjust the site-specific operating parameter indicator ranges in accordance with the results of the performance test.

(iv) You must report and include your ongoing site-specific operating parameter data in the annual reports required under paragraph (h) of this section and semi-annual title V monitoring reports to the relevant permitting authority.

(4) If you are the owner or operator of an affected unit seeking to comply with the requirements for startup under paragraph (d) of this section or shutdown under paragraph (e) of this section in lieu of the applicable emissions limit under paragraph (c) of this section, you must monitor material process flow rates, fuel throughput, oxidant flow rate, and the selected system operating parameters in accordance with paragraphs (d)(1)(ii) and (e)(1)(ii) of this section.

(h) *Recordkeeping requirements.* (1) If you are the owner or operator of an affected unit, you shall maintain records of the following information for each day the affected unit operates:

(i) Calendar date;

(ii) The average hourly NO_x emissions rates measured or predicted;

(iii) The 30-day average NO_x emissions rates calculated at the end of each affected unit operating day from the measured or predicted hourly NO_x emissions rates for the preceding 30 operating days;

(iv) Identification of the affected unit operating days when the calculated 30-day average NO_x emissions rates are in excess of the applicable site-specific NO_x emissions limit with the reasons for such excess emissions as well as a description of corrective actions taken;

(v) Identification of the affected unit operating days for which pollutant data have not been obtained, including reasons for not obtaining sufficient data and a description of corrective actions taken;

(vi) Identification of the times when emissions data have been excluded from the calculation of average emissions rates and the reasons for excluding data;

(vii) If a CEMS is used to verify compliance:

(A) Identification of the times when the pollutant concentration exceeded full span of the CEMS;

(B) Description of any modifications to the CEMS that could affect the ability of the CEMS to comply with Performance Specification 2 or 3 in appendix B to 40 CFR part 60; and

(C) Results of daily CEMS drift tests and quarterly accuracy assessments as required under Procedure 1 of 40 CFR part 60, appendix F;

(D) Operating parameters required under paragraph (g) to demonstrate compliance during the ozone season;

(viii) Each fuel type, usage, and heat content; and

(ix) Glass production rate.

(2) If you are the owner or operator of an affected unit, you shall maintain all records necessary to demonstrate compliance with the startup and shutdown requirements in paragraphs (d) and (e) of this section, including but not limited to records of material process flow rates, system operating parameters, the duration of each startup and shutdown period, fuel throughput, oxidant flow rate, and any additional records necessary to determine whether the stoichiometric ratio of the primary furnace combustion system exceeded 5 percent excess oxygen during startup.

(3) If you are the owner or operator of an affected unit, you shall maintain records of daily NO_x emissions in pounds per day for purposes of determining compliance with the applicable emissions limit for idling periods under paragraph (f)(2) of this section. Each owner or operator shall also record the duration of each idling period.

(i) *Reporting requirements.* (1) If you are the owner or operator of an affected unit, you must submit the results of the performance test or performance evaluation of the CEMS following the procedures specified in § 52.40(g) within 60 days after the date of completing each performance test required by this section.

(2) If you are the owner or operator of an affected unit, you are required to submit excess emissions reports for any excess emissions that occurred during the reporting period. Excess emissions are defined as any calculated 30-day rolling average NO_x emissions rate that exceeds the applicable emissions limit in paragraph (c) of this section. Excess emissions reports must be submitted in PDF format to the EPA via CEDRI or analogous electronic reporting approach provided by the EPA to report data required by this section following the procedures specified in § 52.40(g).

(3) If you own or operate an affected unit, you shall submit an annual report in PDF format to the EPA by January 30th of each year via CEDRI or analogous electronic reporting approach provided by the EPA to report data required by this section. Annual reports shall be submitted following the procedures in § 52.40(g). The report shall include records all records required by paragraph (g) of this section, including record of CEMS data or operating parameters to demonstrate continuous compliance the applicable emissions limits under paragraphs (c) of this section.

(j) *Initial notification requirements for existing affected units.* (1) The requirements of this paragraph (j) apply to the owner or operator of an existing affected unit.

(2) The owner or operator of an existing affected unit that emits or has a potential to emit greater than 100 tons per year or greater as of August 4, 2023, shall notify the Administrator via the CEDRI or analogous electronic submission system provided by the EPA that the unit is subject to this section. The notification, which shall be submitted not later than June 23, 2023, shall be submitted in PDF format to the EPA via CEDRI, which can be accessed through the EPA's CDX (<https://cdx.epa.gov/>). The notification shall provide the following information:

(i) The name and address of the owner or operator;

(ii) The address (*i.e.*, physical location) of the affected unit;

(iii) An identification of the relevant standard, or other requirement, that is the basis for the notification and the unit's compliance date; and

(iv) A brief description of the nature, size, design, and method of operation of the facility and an identification of the types of emissions points (units) within the facility subject to the relevant standard.

§ 52.45 What are the requirements of the Federal Implementation Plans (FIPs) relating to ozone season emissions of nitrogen oxides from the Basic Chemical Manufacturing, Petroleum and Coal Products Manufacturing, the Pulp, Paper, and Paperboard Mills Industries, Metal Ore Mining, and the Iron and Steel and Ferroalloy Manufacturing Industries?

(a) *Definitions.* All terms not defined in this paragraph (a) shall have the meaning given to them in the Act and in subpart A of 40 CFR part 60.

Affected unit means an industrial boiler meeting the applicability criteria of this section.

Boiler means an enclosed device using controlled flame combustion and having the primary purpose of

recovering thermal energy in the form of steam or hot water. Controlled flame combustion refers to a steady-state, or near steady-state, process wherein fuel and/or oxidizer feed rates are controlled.

Coal means "coal" as defined in 40 CFR 60.41b.

Distillate oil means "distillate oil" as defined in 40 CFR 60.41b.

Maximum heat input capacity means the ability of a steam generating unit to combust a stated maximum amount of fuel on a steady state basis, as determined by the physical design and characteristics of the steam generating unit.

Natural gas means "natural gas" as defined in 40 CFR 60.41.

Operating day means a 24-hour period between 12:00 midnight and the following midnight during which any fuel is combusted at any time in the steam generating unit. It is not necessary for fuel to be combusted continuously for the entire 24-hour period.

Residual oil means "residual oil" as defined in 40 CFR 60.41c.

(b) *Applicability.* (1) The requirements of this section apply to each new or existing boiler with a design capacity of 100 mmBtu/hr or greater that receives 90% or more of its heat input from coal, residual oil, distillate oil, natural gas, or combinations of these fuels in the previous ozone season, is located at sources that are within the Basic Chemical Manufacturing industry, the Petroleum and Coal Products Manufacturing industry, the Pulp, Paper, and Paperboard industry, the Metal Ore Mining industry, and the Iron and Steel and Ferroalloys Manufacturing industry and which is located within any of the States listed in § 52.40(c)(2), including Indian country located within the borders of any such State(s). The requirements of this section do not apply to an emissions unit that meets the requirements for a low-use exemption as provided in paragraph (b)(2) of this section.

(2) If you are the owner or operator of a boiler meeting the applicability criteria of paragraph (b)(1) of this section that operates less than 10% per year on an hourly basis, based on the three most recent years of use and no more than 20% in any one of the three years, you are exempt from meeting the emissions limits of this section and are only subject to the recordkeeping and reporting requirements of paragraph (f)(2) of this section.

(i) If you are the owner or operator of an affected unit that exceeds the 10% per year hour of operation over three years or the 20% hours of operation per year criteria, you can no longer comply

via the low-use exemption provisions and must meet the applicable emissions limits and other applicable provisions as soon as possible but not later than one year from the date eligibility as a low-use boiler was negated by exceedance of the low-use boiler criteria.

(ii) [Reserved]

(c) *Emissions limitations.* If you are the owner or operator of an affected unit, you must meet the following emissions limitations on a 30-day rolling average basis during the 2026 ozone season and in each ozone season thereafter:

(1) Coal-fired industrial boilers: 0.20 lbs NO_x/mmBtu;

(2) Residual oil-fired industrial boilers: 0.20 lbs NO_x/mmBtu;

(3) Distillate oil-fired industrial boilers: 0.12 lbs NO_x/mmBtu;

(4) Natural gas-fired industrial boilers: 0.08 lbs NO_x/mmBtu; and

(5) Boilers using combinations of fuels listed in paragraphs (c)(1) through (4) of this section: such units shall comply with a NO_x emissions limit derived by summing the products of each fuel's heat input and respective emissions limit and dividing by the sum of the heat input contributed by each fuel.

(d) *Testing and monitoring requirements.* (1) If you are the owner or operator of an affected unit, you shall conduct an initial compliance test as described in 40 CFR 60.8 using the continuous system for monitoring NO_x specified by EPA Test Method 7E of 40 CFR part 60, appendix A-4, to determine compliance with the emissions limits for NO_x identified in paragraph (c) of this section. In lieu of the timing of the compliance test described in 40 CFR 60.8(a), you shall conduct the test within 90 days from the installation of the pollution control equipment used to comply with the NO_x emissions limits in paragraph (c) of this section and no later than May 1, 2026.

(i) For the initial compliance test, you shall monitor NO_x emissions from the affected unit for 30 successive operating days and the 30-day average emissions rate will be used to determine compliance with the NO_x emissions limits in paragraph (c) of this section. You shall calculate the 30-day average emission rate as the average of all hourly emissions data recorded by the monitoring system during the 30-day test period.

(ii) You are not required to conduct an initial compliance test if the affected unit is subject to a pre-existing, federally enforceable requirement to monitor its NO_x emissions using a

CEMS in accordance with 40 CFR 60.13 or 40 CFR part 75.

(2) If you are the owner or operator of an affected unit with a heat input capacity of 250 mmBTU/hr or greater, you are subject to the following monitoring requirements:

(i) You shall install, calibrate, maintain, and operate a continuous emissions monitoring system (CEMS) for measuring NO_x emissions and either oxygen (O₂) or carbon dioxide (CO₂), unless the Administrator has approved a request from you to use an alternative monitoring technique under paragraph (d)(2)(vii) of this section. If you have previously installed a NO_x emissions rate CEMS to meet the requirements of 40 CFR 60.13 or 40 CFR part 75 and continue to meet the ongoing requirements of 40 CFR 60.13 or 40 CFR part 75, that CEMS may be used to meet the monitoring requirements of this section.

(ii) You shall operate the CEMS and record data during all periods of operation during the ozone season of the affected unit except for CEMS breakdowns and repairs. You shall record data during calibration checks and zero and span adjustments.

(iii) You shall express the 1-hour average NO_x emissions rates measured by the CEMS in terms of lbs/mmBtu heat input and shall be used to calculate the average emissions rates under paragraph (c) of this section.

(iv) Following the date on which the initial compliance test is completed, you shall determine compliance with the applicable NO_x emissions limit in paragraph (c) of this section during the ozone season on a continuous basis using a 30-day rolling average emissions rate unless you monitor emissions by means of an alternative monitoring procedure approved pursuant to paragraph (d)(2)(vii) of this section. You shall calculate a new 30-day rolling average emissions rate for each operating day as the average of all the hourly NO_x emissions data for the preceding 30 operating days.

(v) You shall follow the procedures under 40 CFR 60.13 for installation, evaluation, and operation of the continuous monitoring systems. Additionally, you shall use a span value of 1000 ppm NO_x for affected units combusting coal and span value of 500 ppm NO_x for units combusting oil or gas. As an alternative to meeting these span values, you may elect to use the NO_x span values determined according to section 2.1.2 in appendix A to 40 CFR part 75.

(vi) When you are unable to obtain NO_x emissions data because of CEMS breakdowns, repairs, calibration checks

and zero and span adjustments, you will obtain emissions data by using standby monitoring systems, Method 7 of 40 CFR part 60, appendix A-4, Method 7A of 40 CFR part 60, appendix A-4, or other approved reference methods to provide emissions data for a minimum of 75 percent of the operating hours in each affected unit operating day, in at least 22 out of 30 successive operating days.

(vii) You may delay installing a CEMS for NO_x until after the initial performance test has been conducted. If you demonstrate during the performance test that emissions of NO_x are less than 70 percent of the applicable emissions limit in paragraph (c) of this section, you are not required to install a CEMS for measuring NO_x. If you demonstrate your affected unit emits less than 70 percent of the applicable emissions limit chooses to not install a CEMS, you must submit a written request to the Administrator that documents the results of the initial performance test and includes an alternative monitoring procedure that will be used to track compliance with the applicable NO_x emissions limit(s) in paragraph (c) of this section. The Administrator may consider the request and, following public notice and comment, may approve the alternative monitoring procedure with or without revision, or disapprove the request. Upon receipt of a disapproved request, you will have one year to install a CEMS.

(3) If you are the owner or operator of an affected unit with a heat input capacity less than 250 mmBTU/hr, you must monitor NO_x emission via the requirements of paragraph (e)(1) of this section or you must monitor NO_x emissions by conducting an annual test in conjunction with the implementation of a monitoring plan meeting the following requirements:

(i) You must conduct an initial performance test over a minimum of 24 consecutive steam generating unit operating hours at maximum heat input capacity to demonstrate compliance with the NO_x emission standards under paragraph (c) of this section using Method 7, 7A, or 7E of appendix A-4 to 40 CFR part 60, Method 320 of appendix A to 40 CFR part 63, or other approved reference methods.

(ii) You must conduct annual performance tests once per calendar year to demonstrate compliance with the NO_x emission standards under paragraph (c) of this section over a minimum of 3 consecutive steam generating unit operating hours at maximum heat input capacity using Method 7, 7A, or 7E of appendix A-4

to 40 CFR part 60, Method 320 of appendix A to 40 CFR part 63, or other approved reference methods. The annual performance test must be conducted before the affected units operates more than 400 hours in a given year.

(iii) You must develop and comply with a monitoring plan that relates the operational parameters to emissions of the affected unit. The owner or operator of each affected unit shall develop a monitoring plan that identifies the operating conditions of the affected unit to be monitored and the records to be maintained in order to reliably predict NO_x emissions and determine compliance with the applicable emissions limits of this section on a continuous basis. You shall include the following information in the plan:

(A) You shall identify the specific operating parameters to be monitored and the relationship between these operating parameters and the applicable NO_x emission rates. Operating parameters of the affected unit include, but are not limited to, the degree of staged combustion (*i.e.*, the ratio of primary air to secondary and/or tertiary air) and the level of excess air (*i.e.*, flue gas O₂ level).

(B) You shall include the data and information used to identify the relationship between NO_x emission rates and these operating conditions.

(C) *You shall identify:* how these operating parameters, including steam generating unit load, will be monitored on an hourly basis during periods of operation of the affected unit; the quality assurance procedures or practices that will be employed to ensure that the data generated by monitoring these operating parameters will be representative and accurate; and the type and format of the records of these operating parameters, including steam generating unit load, that you will maintain.

(4) You shall submit the monitoring plan to the EPA via the CEDRI reporting system, and request that the relevant permitting agency incorporate the monitoring plan into the facility's title V permit.

(e) *Recordkeeping requirements.* (1) If you are the owner or operator of an affected unit, which is not a low-use boiler, you shall maintain records of the following information for each day the affected unit operates during the ozone season:

(i) Calendar date;

(ii) The average hourly NO_x emissions rates (expressed as lbs NO₂/mmBtu heat input) measured or predicted;

(iii) The 30-day average NO_x emissions rates calculated at the end of

each affected unit operating day from the measured or predicted hourly NO_x emissions rates for the preceding 30 steam generating unit operating days;

(iv) Identification of the affected unit operating days when the calculated 30-day rolling average NO_x emissions rates are in excess of the applicable NO_x emissions limit in paragraph (c) of this section with the reasons for such excess emissions as well as a description of corrective actions taken;

(v) Identification of the affected unit operating days for which pollutant data have not been obtained, including reasons for not obtaining sufficient data and a description of corrective actions taken;

(vi) Identification of the times when emissions data have been excluded from the calculation of average emissions rates and the reasons for excluding data;

(vii) Identification of "F" factor used for calculations, method of determination, and type of fuel combusted;

(viii) Identification of the times when the pollutant concentration exceeded full span of the CEMS;

(ix) Description of any modifications to the CEMS that could affect the ability of the CEMS to comply with Performance Specification 2 or 3 in appendix B to 40 CFR part 60;

(x) Results of daily CEMS drift tests and quarterly accuracy assessments as required under Procedure 1 of 40 CFR part 60, appendix F; and

(xi) The type and amounts of each fuel combusted.

(2) If you are the owner or operator of an affected unit complying as a low-use boiler, you must maintain the following records consistent with the requirements of § 52.40(g):

(i) Identification and location of the boiler;

(ii) Nameplate capacity;

(iii) The fuel or fuels used by the boiler;

(iv) For each operating day, the type and amount of fuel combusted, and the date and total number of hours of operation; and

(v) the annual hours of operation for each of the prior 3 years, and the 3-year average hours of operation.

(f) *Reporting requirements.* (1) If you are the owner or operator of an affected unit, you must submit the results of the performance test or performance evaluation of the CEMS following the procedures specified in § 52.40(g) within 60 days after the date of completing each performance test required by this section.

(2) If you are the owner or operator of an affected unit, you are required to submit excess emissions reports for any

excess emissions that occurred during the reporting period. Excess emissions are defined as any calculated 30-day rolling average NO_x emissions rate, as determined under paragraph (e)(1)(iii) of this section, that exceeds the applicable emissions limit in paragraph (c) of this section. Excess emissions reports must be submitted in PDF format to the EPA via CEDRI or analogous electronic reporting approach provided by the EPA to report data required by this section following the procedures specified in § 52.40(g).

(3) If you are the owner or operator of an affected unit subject to the continuous monitoring requirements for NO_x under paragraph (d) of this section, you shall submit reports containing the information recorded under paragraph (d) of this section as described in paragraph (e)(1) of this section. You shall submit compliance reports for continuous monitoring in PDF format to the EPA via CEDRI or analogous electronic reporting approach provided by the EPA to report data required by this section following the procedures specified in § 52.40(g).

(4) If you are the owner or operator of an affected unit, you shall submit an annual report in PDF format to the EPA by January 30th of each year via CEDRI or analogous electronic reporting approach provided by the EPA to report data required by this section. Annual reports shall be submitted following the procedures in § 52.40(g).

§ 52.46 What are the requirements of the Federal Implementation Plans (FIPs) relating to ozone season emissions of nitrogen oxides from Municipal Waste Combustors?

(a) *Definitions.* All terms not defined in this paragraph (a) shall have the meaning given them in the Act and in subpart A of 40 CFR part 60.

Affected unit means a municipal waste combustor meeting the applicability criteria of this section.

Chief facility operator means the person in direct charge and control of the operation of a municipal waste combustor and who is responsible for daily onsite supervision, technical direction, management, and overall performance of the facility.

Mass burn refractory municipal waste combustor means a field-erected combustor that combusts municipal solid waste in a refractory wall furnace. Unless otherwise specified, this includes combustors with a cylindrical rotary refractory wall furnace.

Mass burn rotary waterwall municipal waste combustor means a field-erected combustor that combusts municipal solid waste in a cylindrical rotary

waterwall furnace or on a tumbling-tile grate.

Mass burn waterwall municipal waste combustor means a field-erected combustor that combusts municipal solid waste in a waterwall furnace.

Municipal waste combustor, MWC, or municipal waste combustor unit means:

(i) Means any setting or equipment that combusts solid, liquid, or gasified MSW including, but not limited to, field-erected incinerators (with or without heat recovery), modular incinerators (starved-air or excess-air), boilers (*i.e.*, steam-generating units), furnaces (whether suspension-fired, grate-fired, mass-fired, air curtain incinerators, or fluidized bed-fired), and pyrolysis/combustion units. Municipal waste combustors do not include pyrolysis/combustion units located at plastics/rubber recycling units. Municipal waste combustors do not include internal combustion engines, gas turbines, or other combustion devices that combust landfill gases collected by landfill gas collection systems.

(ii) The boundaries of a MWC are defined as follows. The MWC unit includes, but is not limited to, the MSW fuel feed system, grate system, flue gas system, bottom ash system, and the combustor water system. The MWC boundary starts at the MSW pit or hopper and extends through:

(A) The combustor flue gas system, which ends immediately following the heat recovery equipment or, if there is no heat recovery equipment, immediately following the combustion chamber;

(B) The combustor bottom ash system, which ends at the truck loading station or similar ash handling equipment that transfer the ash to final disposal, including all ash handling systems that are connected to the bottom ash handling system; and

(C) The combustor water system, which starts at the feed water pump and ends at the piping exiting the steam drum or superheater.

(iii) The MWC unit does not include air pollution control equipment, the stack, water treatment equipment, or the turbine generator set.

Municipal waste combustor unit capacity means the maximum charging rate of a municipal waste combustor unit expressed in tons per day of municipal solid waste combusted, calculated according to the procedures under paragraph (e)(4) of this section.

Shift supervisor means the person who is in direct charge and control of the operation of a municipal waste combustor and who is responsible for onsite supervision, technical direction,

management, and overall performance of the facility during an assigned shift.

(b) *Applicability.* The requirements of this section apply to each new or existing municipal waste combustor unit with a combustion capacity greater than 250 tons per day (225 megagrams per day) of municipal solid waste and which is located within any of the States listed in § 52.40(c)(2), including Indian country located within the borders of any such State(s).

(c) *Emissions limitations.* If you are the owner or operator of an affected unit, you must meet the following emissions limitations at all times, except during startup and shutdown, on a 30-day rolling average basis during the 2026 ozone season and in each ozone season thereafter:

(1) 110 ppmvd at 7 percent oxygen on a 24-hour block averaging period; and

(2) 105 ppmvd at 7 percent oxygen on a 30-day rolling averaging period.

(d) *Startup and shutdown requirements.* If you are the owner or operator of an affected unit, you must comply with the following requirements during startup and shutdown:

(1) During periods of startup and shutdown, you shall meet the following emissions limits at stack oxygen content:

(i) 110 ppmvd at stack oxygen content on a 24-hour block averaging period; and

(ii) 105 ppmvd at stack oxygen content on a 30-day rolling averaging period.

(2) Duration of startup and shutdown, periods are limited to 3 hours per occurrence.

(3) The startup period commences when the affected unit begins the continuous burning of municipal solid waste and does not include any warmup period when the affected unit is combusting fossil fuel or other nonmunicipal solid waste fuel, and no municipal solid waste is being fed to the combustor.

(4) Continuous burning is the continuous, semicontinuous, or batch feeding of municipal solid waste for purposes of waste disposal, energy production, or providing heat to the combustion system in preparation for waste disposal or energy production. The use of municipal solid waste solely to provide thermal protection of the grate or hearth during the startup period when municipal solid waste is not being fed to the grate is not considered to be continuous burning.

(5) The owner and operator of an affected unit shall minimize NO_x emissions by operating and optimizing the use of all installed pollution control technology and combustion controls

consistent with the technological limitations, manufacturers' specifications, good engineering and maintenance practices, and good air pollution control practices for minimizing emissions (as defined in 40 CFR 60.11(d)) for such equipment and the unit at all times the unit is in operation.

(e) *Testing and monitoring requirements.* (1) If you are the owner or operator of an affected unit, you shall install, calibrate, maintain, and operate a continuous emissions monitoring system (CEMS) for measuring the oxygen or carbon dioxide content of the flue gas at each location where NO_x are monitored and record the output of the system. You shall comply with the following test procedures and test methods:

(i) You shall use a span value of 25 percent oxygen for the oxygen monitor or 20 percent carbon dioxide for the carbon dioxide monitor;

(ii) You shall install, evaluate, and operate the CEMS in accordance with 40 CFR 60.13;

(iii) You shall complete the initial performance evaluation no later than 180 days after the date of initial startup of the affected unit, as specified under 40 CFR 60.8;

(iv) You shall operate the monitor in conformance with Performance Specification 3 in 40 CFR part 60, appendix B, except for section 2.3 (relative accuracy requirement);

(v) You shall operate the monitor in accordance with the quality assurance procedures of 40 CFR part 60, appendix F, except for section 5.1.1 (relative accuracy test audit); and

(vi) If you select carbon dioxide for use in diluent corrections, you shall establish the relationship between oxygen and carbon dioxide levels during the initial performance test according to the following procedures and methods:

(A) This relationship may be reestablished during performance compliance tests; and

(B) You shall submit the relationship between carbon dioxide and oxygen concentrations to the EPA as part of the initial performance test report and as part of the annual test report if the relationship is reestablished during the annual performance test.

(2) If you are the owner or operator of an affected unit, you shall use the following procedures and test methods to determine compliance with the NO_x emission limits in paragraph (c) of this section:

(i) If you are not already operating a CEMS in accordance with 40 CFR 60.13, you shall conduct an initial

performance test for nitrogen oxides consistent with 40 CFR 60.8.

(ii) You shall install and operate the NO_x CEMS according to Performance Specification 2 in 40 CFR part 60, appendix B, and shall follow the requirements of 40 CFR 60.58b(h)(10).

(iii) Quarterly accuracy determinations and daily calibration drift tests for the CEMS shall be performed in accordance with Procedure 1 in 40 CFR part 60, appendix F.

(iv) When NO_x continuous emissions data are not obtained because of CEMS breakdowns, repairs, calibration checks, and zero and span adjustments, emissions data shall be obtained using other monitoring systems as approved by the EPA or EPA Reference Method 19 in 40 CFR part 60, appendix A-7, to provide, as necessary, valid emissions data for a minimum of 90 percent of the hours per calendar quarter and 95 percent of the hours per calendar year the unit is operated and combusting municipal solid waste.

(v) You shall use EPA Reference Method 19, section 4.1, in 40 CFR part 60, appendix A-7, for determining the daily arithmetic average NO_x emissions concentration.

(A) You may request that compliance with the NO_x emissions limit be determined using carbon dioxide measurements corrected to an equivalent of 7 percent oxygen. The relationship between oxygen and carbon dioxide levels for the affected unit shall be established as specified in paragraph (e)(1)(vi) of this section.

(B) [Reserved]

(vi) At a minimum, you shall obtain valid CEMS hourly averages for 90 percent of the operating hours per calendar quarter and for 95 percent of the operating hours per calendar year that the affected unit is combusting municipal solid waste:

(A) At least 2 data points per hour shall be used to calculate each 1-hour arithmetic average.

(B) Each NO_x 1-hour arithmetic average shall be corrected to 7 percent oxygen on an hourly basis using the 1-hour arithmetic average of the oxygen (or carbon dioxide) continuous emissions monitoring system data.

(vii) The 1-hour arithmetic averages section shall be expressed in parts per million by volume (dry basis) and used to calculate the 24-hour daily arithmetic average concentrations. The 1-hour arithmetic averages shall be calculated using the data points required under 40 CFR 60.13(e)(2).

(viii) All valid CEMS data must be used in calculating emissions averages even if the minimum CEMS data

requirements of paragraph (e)(2)(iv) of this section are not met.

(ix) The procedures under 40 CFR 60.13 shall be followed for installation, evaluation, and operation of the CEMS. The initial performance evaluation shall be completed no later than 180 days after the date of initial startup of the municipal waste combustor unit.

(3) If you are the owner or operator of an affected unit, you must determine compliance with the startup and shutdown requirements of paragraph (d) of this section by following the requirements in paragraphs (e)(3)(i) and (ii) of this section:

(i) You can measure CEMS data at stack oxygen content. You can dismiss or exclude CEMS data from compliance calculations, but you shall record and report CEMS data in accordance with the provisions of 40 CFR 60.59b(d)(7).

(ii) You shall determine compliance with the NO_x mass loading emissions limitation for periods of startup and shutdown by calculating the 24-hour average of all hourly average NO_x emissions concentrations from continuous emissions monitoring systems.

(A) You shall perform this calculations using stack flow rates derived from flow monitors, for all the hours during the 3-hour startup or shutdown period and the remaining 21 hours of the 24-hour period.

(B) [Reserved]

(4) If you are the owner or operator of an affected unit, you shall calculate municipal waste combustor unit capacity using the following procedures:

(i) For municipal waste combustor units capable of combusting municipal solid waste continuously for a 24-hour period, municipal waste combustor unit capacity shall be calculated based on 24 hours of operation at the maximum charging rate. The maximum charging rate shall be determined as specified in paragraphs (e)(4)(i)(A) and (B) of this section as applicable.

(A) For combustors that are designed based on heat capacity, the maximum charging rate shall be calculated based on the maximum design heat input capacity of the unit and a heating value of 12,800 kilojoules per kilogram for combustors firing refuse-derived fuel and a heating value of 10,500 kilojoules per kilogram for combustors firing municipal solid waste that is not refuse-derived fuel.

(B) For combustors that are not designed based on heat capacity, the maximum charging rate shall be the maximum design charging rate.

(ii) For batch feed municipal waste combustor units, municipal waste combustor unit capacity shall be

calculated as the maximum design amount of municipal solid waste that can be charged per batch multiplied by the maximum number of batches that could be processed in a 24-hour period. The maximum number of batches that could be processed in a 24-hour period is calculated as 24 hours divided by the design number of hours required to process one batch of municipal solid waste, and may include fractional batches (e.g., if one batch requires 16 hours, then 24/16, or 1.5 batches, could be combusted in a 24-hour period). For batch combustors that are designed based on heat capacity, the design heating value of 12,800 kilojoules per kilogram for combustors firing refuse-derived fuel and a heating value of 10,500 kilojoules per kilogram for combustors firing municipal solid waste that is not refuse-derived fuel shall be used in calculating the municipal waste combustor unit capacity in megagrams per day of municipal solid waste.

(f) *Recordkeeping requirements.* If you are the owner or operator of an affected unit, you shall maintain records of the following information, as applicable, for each affected unit consistent with the requirements of § 52.40(g).

(1) The calendar date of each record.

(2) The emissions concentrations and parameters measured using continuous monitoring systems.

(i) All 1-hour average NO_x emissions concentrations.

(ii) The average concentrations and percent reductions, as applicable, including all 24-hour daily arithmetic average NO_x emissions concentrations.

(3) Identification of the calendar dates and times (hours) for which valid hourly NO_x emissions, including reasons for not obtaining the data and a description of corrective actions taken.

(4) Identification of each occurrence that NO_x emissions data, or operational data (i.e., unit load) have been excluded from the calculation of average emissions concentrations or parameters, and the reasons for excluding the data.

(5) The results of daily drift tests and quarterly accuracy determinations for CEMS, as required under 40 CFR part 60, appendix F, Procedure 1.

(6) The following records:

(i) Records showing the names of the municipal waste combustor chief facility operator, shift supervisors, and control room operators who have been provisionally certified by the American Society of Mechanical Engineers or an equivalent State-approved certification program as required by 40 CFR 60.54b(a) including the dates of initial and renewal certifications and documentation of current certification;

(ii) Records showing the names of the municipal waste combustor chief facility operator, shift supervisors, and control room operators who have been fully certified by the American Society of Mechanical Engineers or an equivalent State-approved certification program as required by 40 CFR 60.54b(b) including the dates of initial and renewal certifications and documentation of current certification;

(iii) Records showing the names of the municipal waste combustor chief facility operator, shift supervisors, and control room operators who have completed the EPA municipal waste combustor operator training course or a State-approved equivalent course as required by 40 CFR 60.54b(d) including documentation of training completion; and

(iv) Records of when a certified operator is temporarily off site. Include two main items:

(A) If the certified chief facility operator and certified shift supervisor are off site for more than 12 hours, but for 2 weeks or less, and no other certified operator is on site, record the dates that the certified chief facility operator and certified shift supervisor were off site.

(B) When all certified chief facility operators and certified shift supervisors are off site for more than 2 weeks and no other certified operator is on site, keep records of four items:

(1) Time of day that all certified persons are off site.

(2) The conditions that cause those people to be off site.

(3) The corrective actions taken by the owner or operator of the affected unit to ensure a certified chief facility operator or certified shift supervisor is on site as soon as practicable.

(4) Copies of the reports submitted every 4 weeks that summarize the actions taken by the owner or operator of the affected unit to ensure that a certified chief facility operator or certified shift supervisor will be on site as soon as practicable.

(7) Records showing the names of persons who have completed a review of the operating manual as required by 40 CFR 60.54b(f) including the date of the initial review and subsequent annual reviews.

(8) Records of steps taken to minimize emissions during startup and shutdown as required by paragraph (d)(5) of this section.

(g) *Reporting requirements.* (1) If you are the owner or operator of an affected unit, you must submit the results of the performance test or performance evaluation of the CEMS following the procedures specified in § 52.40(g)

within 60 days after the date of completing each performance test required by this section.

(2) If you are the owner or operator of an affected unit, you shall submit an annual report in PDF format to the EPA by January 30th of each year via CEDRI or analogous electronic reporting approach provided by the EPA to report data required by this section. Annual reports shall be submitted following the procedures in § 52.40(g). The report shall include all information required by paragraph (e) of this section, including CEMS data to demonstrate compliance with the applicable emissions limits under paragraph (c) of this section.

Subpart B—Alabama

■ 5. Amend § 52.54 by revising paragraphs (b)(2) and (3) and adding paragraphs (b)(4) and (5) to read as follows:

§ 52.54 Interstate pollutant transport provisions; What are the FIP requirements for decreases in emissions of nitrogen oxides?

* * * * *

(b) * * *

(2) The owner and operator of each source and each unit located in the State of Alabama and Indian country within the borders of the State and for which requirements are set forth under the CSAPR NO_x Ozone Season Group 2 Trading Program in subpart EEEEE of part 97 of this chapter must comply with such requirements with regard to emissions occurring in 2017 through 2022. The obligation to comply with such requirements with regard to sources and units in the State and areas of Indian country within the borders of the State subject to the State's SIP authority will be eliminated by the promulgation of an approval by the Administrator of a revision to Alabama's State Implementation Plan (SIP) as correcting the SIP's deficiency that is the basis for the CSAPR Federal Implementation Plan (FIP) under § 52.38(b)(1) and (b)(2)(ii) for those sources and units, except to the extent the Administrator's approval is partial or conditional. The obligation to comply with such requirements with regard to sources and units located in areas of Indian country within the borders of the State not subject to the State's SIP authority will not be eliminated by the promulgation of an approval by the Administrator of a revision to Alabama's SIP.

(3) The owner and operator of each source and each unit located in the State of Alabama and Indian country within the borders of the State and for which

requirements are set forth under the CSAPR NO_x Ozone Season Group 3 Trading Program in subpart GGGGG of part 97 of this chapter must comply with such requirements with regard to emissions occurring in 2023 and each subsequent year. The obligation to comply with such requirements with regard to sources and units in the State and areas of Indian country within the borders of the State subject to the State's SIP authority will be eliminated by the promulgation of an approval by the Administrator of a revision to Alabama's State Implementation Plan (SIP) as correcting the SIP's deficiency that is the basis for the CSAPR Federal Implementation Plan (FIP) under § 52.38(b)(1) and (b)(2)(iii) for those sources and units, except to the extent the Administrator's approval is partial or conditional. The obligation to comply with such requirements with regard to sources and units located in areas of Indian country within the borders of the State not subject to the State's SIP authority will not be eliminated by the promulgation of an approval by the Administrator of a revision to Alabama's SIP.

(4) Notwithstanding the provisions of paragraphs (b)(2) and (3) of this section, if, at the time of the approval of Alabama's SIP revision described in paragraph (b)(2) or (3) of this section, the Administrator has already started recording any allocations of CSAPR NO_x Ozone Season Group 2 allowances or CSAPR NO_x Ozone Season Group 3 allowances under subpart EEEEE or GGGGG, respectively, of part 97 of this chapter to units in the State and areas of Indian country within the borders of the State subject to the State's SIP authority for a control period in any year, the provisions of such subpart authorizing the Administrator to complete the allocation and recordation of such allowances to such units for each such control period shall continue to apply, unless provided otherwise by such approval of the State's SIP revision.

(5) Notwithstanding the provisions of paragraph (b)(2) of this section, after 2022 the provisions of § 97.826(c) of this chapter (concerning the transfer of CSAPR NO_x Ozone Season Group 2 allowances between certain accounts under common control), the provisions of § 97.826(e) of this chapter (concerning the conversion of amounts of unused CSAPR NO_x Ozone Season Group 2 allowances allocated for control periods before 2023 to different amounts of CSAPR NO_x Ozone Season Group 3 allowances), and the provisions of § 97.811(e) of this chapter (concerning the recall of CSAPR NO_x Ozone Season

Group 2 allowances equivalent in quantity and usability to all such allowances allocated to units in the State and Indian country within the borders of the State for control periods after 2022) shall continue to apply.

Subpart E—Arkansas

■ 6. Amend § 52.184 by:

- a. Redesignating paragraphs (a) through (c) as paragraphs (a)(1) through (3);
- b. In newly redesignated paragraph (a)(2):
- i. Removing “2017 and each subsequent year” and adding in its place “2017 through 2022”; and
- ii. Removing the second sentence;
- c. Revising newly redesignated paragraph (a)(3); and
- d. Adding paragraphs (a)(4) and (5) and (b).

The revision and additions read as follows:

§ 52.184 Interstate pollutant transport provisions; What are the FIP requirements for decreases in emissions of nitrogen oxides?

(a) * * *

(3) The owner and operator of each source and each unit located in the State of Arkansas and for which requirements are set forth under the CSAPR NO_x Ozone Season Group 3 Trading Program in subpart GGGGG of part 97 of this chapter must comply with such requirements with regard to emissions occurring in 2023 and each subsequent year. The obligation to comply with such requirements will be eliminated by the promulgation of an approval by the Administrator of a revision to Arkansas' State Implementation Plan (SIP) as correcting the SIP's deficiency that is the basis for the CSAPR Federal Implementation Plan (FIP) under § 52.38(b)(1) and (b)(2)(iii), except to the extent the Administrator's approval is partial or conditional.

(4) Notwithstanding the provisions of paragraph (a)(3) of this section, if, at the time of the approval of Arkansas' SIP revision described in paragraph (a)(3) of this section, the Administrator has already started recording any allocations of CSAPR NO_x Ozone Season Group 3 allowances under subpart GGGGG of part 97 of this chapter to units in the State for a control period in any year, the provisions of subpart GGGGG of part 97 of this chapter authorizing the Administrator to complete the allocation and recordation of CSAPR NO_x Ozone Season Group 3 allowances to such units for each such control period shall continue to apply, unless provided otherwise by such approval of the State's SIP revision.

(5) Notwithstanding the provisions of paragraph (a)(2) of this section, after 2022 the provisions of § 97.826(c) of this chapter (concerning the transfer of CSAPR NO_x Ozone Season Group 2 allowances between certain accounts under common control), the provisions of § 97.826(e) of this chapter (concerning the conversion of amounts of unused CSAPR NO_x Ozone Season Group 2 allowances allocated for control periods before 2023 to different amounts of CSAPR NO_x Ozone Season Group 3 allowances), and the provisions of § 97.811(e) of this chapter (concerning the recall of CSAPR NO_x Ozone Season Group 2 allowances equivalent in quantity and usability to all such allowances allocated to units in the State for control periods after 2022) shall continue to apply.

(b) The owner and operator of each source located in the State of Arkansas and for which requirements are set forth in § 52.40 and § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 must comply with such requirements with regard to emissions occurring in 2026 and each subsequent year.

Subpart F—California

■ 7. Add § 52.284 to read as follows:

§ 52.284 Interstate pollutant transport provisions; What are the FIP requirements for decreases in emissions of nitrogen oxides?

The owner and operator of each source located in the State of California and Indian country within the borders of the State and for which requirements are set forth in § 52.40 and § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 must comply with such requirements with regard to emissions occurring in 2026 and each subsequent year.

Subpart O—Illinois

■ 8. Amend § 52.731 by:

- a. In paragraph (b)(3), removing “(b)(2)(v), except” and adding in its place “(b)(2)(iii), except”; and
- b. Adding paragraph (c).

The addition reads as follows:

§ 52.731 Interstate pollutant transport provisions; What are the FIP requirements for decreases in emissions of nitrogen oxides?

* * * * *

(c) The owner and operator of each source located in the State of Illinois and for which requirements are set forth in § 52.40 and § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 must comply with such requirements with regard to emissions occurring in 2026 and each subsequent year.

Subpart P—Indiana

■ 9. Amend § 52.789 by:

- a. In paragraph (b)(2), removing “(b)(2)(iv), except” and adding in its place “(b)(2)(ii), except”;
- b. In paragraph (b)(3), removing “(b)(2)(v), except” and adding in its place “(b)(2)(iii), except”; and
- c. Adding paragraph (c).

The addition reads as follows:

§ 52.789 Interstate pollutant transport provisions; What are the FIP requirements for decreases in emissions of nitrogen oxides?

* * * * *

(c) The owner and operator of each source located in the State of Indiana and for which requirements are set forth in § 52.40 and § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 must comply with such requirements with regard to emissions occurring in 2026 and each subsequent year.

Subpart S—Kentucky

■ 10. Amend § 52.940 by:

- a. In paragraph (b)(3), removing “(b)(2)(v), except” and adding in its place “(b)(2)(iii), except”; and
- b. Adding paragraph (c).

The addition reads as follows:

§ 52.940 Interstate pollutant transport provisions; What are the FIP requirements for decreases in emissions of nitrogen oxides?

* * * * *

(c) The owner and operator of each source located in the State of Kentucky and for which requirements are set forth in § 52.40 and § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 must comply with such requirements with regard to emissions occurring in 2026 and each subsequent year.

Subpart T—Louisiana

■ 11. Amend § 52.984 by:

- a. In paragraph (d)(3), revising the second and third sentences;
- b. Revising paragraph (d)(4);
- c. In paragraph (d)(5), adding “and Indian country within the borders of the State” after “in the State”; and
- d. Adding paragraph (e).

The revision and addition read as follows:

§ 52.984 Interstate pollutant transport provisions; What are the FIP requirements for decreases in emissions of nitrogen oxides?

* * * * *

(d) * * *
(3) * * * The obligation to comply with such requirements with regard to sources and units in the State and areas

of Indian country within the borders of the State subject to the State’s SIP authority will be eliminated by the promulgation of an approval by the Administrator of a revision to Louisiana’s State Implementation Plan (SIP) as correcting the SIP’s deficiency that is the basis for the CSAPR Federal Implementation Plan (FIP) under § 52.38(b)(1) and (b)(2)(iii) for those sources and units, except to the extent the Administrator’s approval is partial or conditional. The obligation to comply with such requirements with regard to sources and units located in areas of Indian country within the borders of the State not subject to the State’s SIP authority will not be eliminated by the promulgation of an approval by the Administrator of a revision to Louisiana’s SIP.

(4) Notwithstanding the provisions of paragraph (d)(3) of this section, if, at the time of the approval of Louisiana’s SIP revision described in paragraph (d)(3) of this section, the Administrator has already started recording any allocations of CSAPR NO_x Ozone Season Group 3 allowances under subpart GGGGG of part 97 of this chapter to units in the State and areas of Indian country within the borders of the State subject to the State’s SIP authority for a control period in any year, the provisions of subpart GGGGG of part 97 of this chapter authorizing the Administrator to complete the allocation and recordation of CSAPR NO_x Ozone Season Group 3 allowances to such units for each such control period shall continue to apply, unless provided otherwise by such approval of the State’s SIP revision.

* * * * *

(e) The owner and operator of each source located in the State of Louisiana and Indian country within the borders of the State and for which requirements are set forth in § 52.40 and § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 must comply with such requirements with regard to emissions occurring in 2026 and each subsequent year.

Subpart V—Maryland

■ 12. Amend § 52.1084 by:

- a. In paragraph (b)(3), removing “(b)(2)(v), except” and adding in its place “(b)(2)(iii), except”; and
- b. Adding paragraph (c).

The addition reads as follows:

§ 52.1084 Interstate pollutant transport provisions; What are the FIP requirements for decreases in emissions of nitrogen oxides?

* * * * *

(c) The owner and operator of each source located in the State of Maryland

and for which requirements are set forth in § 52.40 and § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 must comply with such requirements with regard to emissions occurring in 2026 and each subsequent year.

Subpart X—Michigan

- 13. Amend § 52.1186 by:
 - a. In paragraph (e)(3), revising the second and third sentences;
 - b. Revising paragraph (e)(4);
 - c. In paragraph (e)(5), adding “and Indian country within the borders of the State” after “in the State”; and
 - d. Adding paragraph (f).

The revision and addition read as follows:

§ 52.1186 Interstate pollutant transport provisions; What are the FIP requirements for decreases in emissions of nitrogen oxides?

* * * * *

(e) * * *

(3) * * * The obligation to comply with such requirements with regard to sources and units in the State and areas of Indian country within the borders of the State subject to the State’s SIP authority will be eliminated by the promulgation of an approval by the Administrator of a revision to Michigan’s State Implementation Plan (SIP) as correcting the SIP’s deficiency that is the basis for the CSAPR Federal Implementation Plan (FIP) under § 52.38(b)(1) and (b)(2)(iii) for those sources and units, except to the extent the Administrator’s approval is partial or conditional. The obligation to comply with such requirements with regard to sources and units located in areas of Indian country within the borders of the State not subject to the State’s SIP authority will not be eliminated by the promulgation of an approval by the Administrator of a revision to Michigan’s SIP.

(4) Notwithstanding the provisions of paragraph (e)(3) of this section, if, at the time of the approval of Michigan’s SIP revision described in paragraph (e)(3) of this section, the Administrator has already started recording any allocations of CSAPR NO_x Ozone Season Group 3 allowances under subpart GGGGG of part 97 of this chapter to units in the State and areas of Indian country within the borders of the State subject to the State’s SIP authority for a control period in any year, the provisions of subpart GGGGG of part 97 of this chapter authorizing the Administrator to complete the allocation and recordation of CSAPR NO_x Ozone Season Group 3 allowances to such units for each such control period shall continue to apply,

unless provided otherwise by such approval of the State’s SIP revision.

* * * * *

(f) The owner and operator of each source located in the State of Michigan and Indian country within the borders of the State and for which requirements are set forth in § 52.40 and § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 must comply with such requirements with regard to emissions occurring in 2026 and each subsequent year.

Subpart Y—Minnesota

- 14. Amend § 52.1240 by adding paragraph (d) to read as follows:

§ 52.1240 Interstate pollutant transport provisions; What are the FIP requirements for decreases in emissions of nitrogen oxides?

* * * * *

(d)(1) The owner and operator of each source and each unit located in the State of Minnesota and Indian country within the borders of the State and for which requirements are set forth under the CSAPR NO_x Ozone Season Group 3 Trading Program in subpart GGGGG of part 97 of this chapter must comply with such requirements with regard to emissions occurring in 2023 and each subsequent year. The obligation to comply with such requirements with regard to sources and units in the State and areas of Indian country within the borders of the State subject to the State’s SIP authority will be eliminated by the promulgation of an approval by the Administrator of a revision to Minnesota’s State Implementation Plan (SIP) as correcting the SIP’s deficiency that is the basis for the CSAPR Federal Implementation Plan (FIP) under § 52.38(b)(1) and (b)(2)(iii) for those sources and units, except to the extent the Administrator’s approval is partial or conditional. The obligation to comply with such requirements with regard to sources and units located in areas of Indian country within the borders of the State not subject to the State’s SIP authority will not be eliminated by the promulgation of an approval by the Administrator of a revision to Minnesota’s SIP.

(2) Notwithstanding the provisions of paragraph (d)(1) of this section, if, at the time of the approval of Minnesota’s SIP revision described in paragraph (d)(1) of this section, the Administrator has already started recording any allocations of CSAPR NO_x Ozone Season Group 3 allowances under subpart GGGGG of part 97 of this chapter to units in the State and areas of Indian country within the borders of the State subject to the

State’s SIP authority for a control period in any year, the provisions of subpart GGGGG of part 97 of this chapter authorizing the Administrator to complete the allocation and recordation of CSAPR NO_x Ozone Season Group 3 allowances to such units for each such control period shall continue to apply, unless provided otherwise by such approval of the State’s SIP revision.

Subpart Z—Mississippi

- 15. Amend § 52.1284 by:
 - a. Redesignating paragraphs (a) through (c) as paragraphs (a)(1) through (3);
 - b. In newly redesignated paragraph (a)(2):
 - i. Removing “2017 and each subsequent year” and adding in its place “2017 through 2022”; and
 - ii. Removing the second and third sentences;
 - c. Revising newly redesignated paragraph (a)(3); and
 - d. Adding paragraphs (a)(4) and (5) and (b).

The revision and additions read as follows:

§ 52.1284 Interstate pollutant transport provisions; What are the FIP requirements for decreases in emissions of nitrogen oxides?

(a) * * *

(3) The owner and operator of each source and each unit located in the State of Mississippi and Indian country within the borders of the State and for which requirements are set forth under the CSAPR NO_x Ozone Season Group 3 Trading Program in subpart GGGGG of part 97 of this chapter must comply with such requirements with regard to emissions occurring in 2023 and each subsequent year. The obligation to comply with such requirements with regard to sources and units in the State and areas of Indian country within the borders of the State subject to the State’s SIP authority will be eliminated by the promulgation of an approval by the Administrator of a revision to Mississippi’s State Implementation Plan (SIP) as correcting the SIP’s deficiency that is the basis for the CSAPR Federal Implementation Plan (FIP) under § 52.38(b)(1) and (b)(2)(iii) for those sources and units, except to the extent the Administrator’s approval is partial or conditional. The obligation to comply with such requirements with regard to sources and units located in areas of Indian country within the borders of the State not subject to the State’s SIP authority will not be eliminated by the promulgation of an approval by the Administrator of a revision to Mississippi’s SIP.

(4) Notwithstanding the provisions of paragraph (a)(3) of this section, if, at the time of the approval of Mississippi's SIP revision described in paragraph (a)(3) of this section, the Administrator has already started recording any allocations of CSAPR NO_x Ozone Season Group 3 allowances under subpart GGGGG of part 97 of this chapter to units in the State and areas of Indian country within the borders of the State subject to the State's SIP authority for a control period in any year, the provisions of subpart GGGGG of part 97 of this chapter authorizing the Administrator to complete the allocation and recordation of CSAPR NO_x Ozone Season Group 3 allowances to such units for each such control period shall continue to apply, unless provided otherwise by such approval of the State's SIP revision.

(5) Notwithstanding the provisions of paragraph (a)(2) of this section, after 2022 the provisions of § 97.826(c) of this chapter (concerning the transfer of CSAPR NO_x Ozone Season Group 2 allowances between certain accounts under common control), the provisions of § 97.826(e) of this chapter (concerning the conversion of amounts of unused CSAPR NO_x Ozone Season Group 2 allowances allocated for control periods before 2023 to different amounts of CSAPR NO_x Ozone Season Group 3 allowances), and the provisions of § 97.811(e) of this chapter (concerning the recall of CSAPR NO_x Ozone Season Group 2 allowances equivalent in quantity and usability to all such allowances allocated to units in the State and Indian country within the borders of the State for control periods after 2022) shall continue to apply.

(b) The owner and operator of each source located in the State of Mississippi and Indian country within the borders of the State and for which requirements are set forth in § 52.40 and § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 must comply with such requirements with regard to emissions occurring in 2026 and each subsequent year.

Subpart AA—Missouri

■ 16. Amend § 52.1326 by revising paragraph (b)(2) and (3) and adding paragraphs (b)(4) and (5) and (c) to read as follows:

§ 52.1326 Interstate pollutant transport provisions; What are the FIP requirements for decreases in emissions of nitrogen oxides?

* * * * *

(b) * * *

(2) The owner and operator of each source and each unit located in the State of Missouri and for which requirements

are set forth under the CSAPR NO_x Ozone Season Group 2 Trading Program in subpart EEEEE of part 97 of this chapter must comply with such requirements with regard to emissions occurring in 2017 through 2022. The obligation to comply with such requirements will be eliminated by the promulgation of an approval by the Administrator of a revision to Missouri's State Implementation Plan (SIP) as correcting the SIP's deficiency that is the basis for the CSAPR Federal Implementation Plan (FIP) under § 52.38(b)(1) and (b)(2)(ii), except to the extent the Administrator's approval is partial or conditional.

(3) The owner and operator of each source and each unit located in the State of Missouri and for which requirements are set forth under the CSAPR NO_x Ozone Season Group 3 Trading Program in subpart GGGGG of part 97 of this chapter must comply with such requirements with regard to emissions occurring in 2023 and each subsequent year. The obligation to comply with such requirements will be eliminated by the promulgation of an approval by the Administrator of a revision to Missouri's State Implementation Plan (SIP) as correcting the SIP's deficiency that is the basis for the CSAPR Federal Implementation Plan (FIP) under § 52.38(b)(1) and (b)(2)(iii), except to the extent the Administrator's approval is partial or conditional.

(4) Notwithstanding the provisions of paragraphs (b)(2) and (3) of this section, if, at the time of the approval of Missouri's SIP revision described in paragraph (b)(2) or (3) of this section, the Administrator has already started recording any allocations of CSAPR NO_x Ozone Season Group 2 allowances or CSAPR NO_x Ozone Season Group 3 allowances under subpart EEEEE or GGGGG, respectively, of part 97 of this chapter to units in the State for a control period in any year, the provisions of such subpart authorizing the Administrator to complete the allocation and recordation of such allowances to such units for each such control period shall continue to apply, unless provided otherwise by such approval of the State's SIP revision.

(5) Notwithstanding the provisions of paragraph (b)(2) of this section, after 2022 the provisions of § 97.826(c) of this chapter (concerning the transfer of CSAPR NO_x Ozone Season Group 2 allowances between certain accounts under common control), the provisions of § 97.826(e) of this chapter (concerning the conversion of amounts of unused CSAPR NO_x Ozone Season Group 2 allowances allocated for control periods before 2023 to different amounts

of CSAPR NO_x Ozone Season Group 3 allowances), and the provisions of § 97.811(e) of this chapter (concerning the recall of CSAPR NO_x Ozone Season Group 2 allowances equivalent in quantity and usability to all such allowances allocated to units in the State for control periods after 2022) shall continue to apply.

(c) The owner and operator of each source located in the State of Missouri and for which requirements are set forth in § 52.40 and § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 must comply with such requirements with regard to emissions occurring in 2026 and each subsequent year.

Subpart DD—Nevada

■ 17. Add § 52.1492 to read as follows:

§ 52.1492 Interstate pollutant transport provisions; What are the FIP requirements for decreases in emissions of nitrogen oxides?

(a)(1) The owner and operator of each source and each unit located in the State of Nevada and Indian country within the borders of the State and for which requirements are set forth under the CSAPR NO_x Ozone Season Group 3 Trading Program in subpart GGGGG of part 97 of this chapter must comply with such requirements with regard to emissions occurring in 2023 and each subsequent year. The obligation to comply with such requirements with regard to sources and units in the State and areas of Indian country within the borders of the State subject to the State's SIP authority will be eliminated by the promulgation of an approval by the Administrator of a revision to Nevada's State Implementation Plan (SIP) as correcting the SIP's deficiency that is the basis for the CSAPR Federal Implementation Plan (FIP) under § 52.38(b)(1) and (b)(2)(iii) for those sources and units, except to the extent the Administrator's approval is partial or conditional. The obligation to comply with such requirements with regard to sources and units located in areas of Indian country within the borders of the State not subject to the State's SIP authority will not be eliminated by the promulgation of an approval by the Administrator of a revision to Nevada's SIP.

(2) Notwithstanding the provisions of paragraph (a)(1) of this section, if, at the time of the approval of Nevada's SIP revision described in paragraph (a)(1) of this section, the Administrator has already started recording any allocations of CSAPR NO_x Ozone Season Group 3 allowances under subpart GGGGG of part 97 of this chapter to units in the State and areas of Indian country within

the borders of the State subject to the State's SIP authority for a control period in any year, the provisions of subpart GGGGG of part 97 of this chapter authorizing the Administrator to complete the allocation and recordation of CSAPR NO_x Ozone Season Group 3 allowances to such units for each such control period shall continue to apply, unless provided otherwise by such approval of the State's SIP revision.

(b) The owner and operator of each source located in the State of Nevada and Indian country within the borders of the State and for which requirements are set forth in § 52.40 and § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 must comply with such requirements with regard to emissions occurring in 2026 and each subsequent year.

Subpart FF—New Jersey

- 18. Amend § 52.1584 by:
 - a. In paragraph (e)(3), removing “(b)(2)(v), except” and adding in its place “(b)(2)(iii), except”; and
 - b. Adding paragraph (f).

The addition reads as follows:

§ 52.1584 Interstate pollutant transport provisions; What are the FIP requirements for decreases in emissions of nitrogen oxides?

* * * * *

(f) The owner and operator of each source located in the State of New Jersey and for which requirements are set forth in § 52.40 and § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 must comply with such requirements with regard to emissions occurring in 2026 and each subsequent year.

Subpart HH—New York

- 19. Amend § 52.1684 by:
 - a. In paragraph (b)(3), revising the second and third sentences;
 - b. Revising paragraph (b)(4);
 - c. In paragraph (b)(5), adding “and Indian country within the borders of the State” after “in the State”; and
 - d. Adding paragraph (c).

The revision and addition read as follows:

§ 52.1684 Interstate pollutant transport provisions; What are the FIP requirements for decreases in emissions of nitrogen oxides?

* * * * *

(b) * * *
 (3) * * * The obligation to comply with such requirements with regard to sources and units in the State and areas of Indian country within the borders of the State subject to the State's SIP authority will be eliminated by the

promulgation of an approval by the Administrator of a revision to New York's State Implementation Plan (SIP) as correcting the SIP's deficiency that is the basis for the CSAPR Federal Implementation Plan (FIP) under § 52.38(b)(1) and (b)(2)(iii) for those sources and units, except to the extent the Administrator's approval is partial or conditional. The obligation to comply with such requirements with regard to sources and units located in areas of Indian country within the borders of the State not subject to the State's SIP authority will not be eliminated by the promulgation of an approval by the Administrator of a revision to New York's SIP.

(4) Notwithstanding the provisions of paragraph (b)(3) of this section, if, at the time of the approval of New York's SIP revision described in paragraph (b)(3) of this section, the Administrator has already started recording any allocations of CSAPR NO_x Ozone Season Group 3 allowances under subpart GGGGG of part 97 of this chapter to units in the State and areas of Indian country within the borders of the State subject to the State's SIP authority for a control period in any year, the provisions of subpart GGGGG of part 97 of this chapter authorizing the Administrator to complete the allocation and recordation of CSAPR NO_x Ozone Season Group 3 allowances to such units for each such control period shall continue to apply, unless provided otherwise by such approval of the State's SIP revision.

(c) The owner and operator of each source located in the State of New York and Indian country within the borders of the State and for which requirements are set forth in § 52.40 and § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 must comply with such requirements with regard to emissions occurring in 2026 and each subsequent year.

Subpart KK—Ohio

- 20. Amend § 52.1882 by:
 - a. In paragraph (b)(3), removing “(b)(2)(v), except” and adding in its place “(b)(2)(iii), except”; and
 - b. Adding paragraph (c).

The addition reads as follows:

§ 52.1882 Interstate pollutant transport provisions; What are the FIP requirements for decreases in emissions of nitrogen oxides?

* * * * *

(c) The owner and operator of each source located in the State of Ohio and for which requirements are set forth in § 52.40 and § 52.41, § 52.42, § 52.43,

§ 52.44, § 52.45, or § 52.46 must comply with such requirements with regard to emissions occurring in 2026 and each subsequent year.

Subpart LL—Oklahoma

- 21. Amend § 52.1930 by:
 - a. Redesignating paragraphs (a) through (c) as paragraphs (a)(1) through (3);
 - b. In newly redesignated paragraph (a)(2):
 - i. Removing “2017 and each subsequent year” and adding in its place “2017 through 2022”; and
 - ii. Removing the second and third sentences;
 - c. Revising newly redesignated paragraph (a)(3); and
 - d. Adding paragraphs (a)(4) and (5) and (b).

The revision and additions read as follows:

§ 52.1930 Interstate pollutant transport provisions; What are the FIP requirements for decreases in emissions of nitrogen oxides?

(a) * * *

(3) The owner and operator of each source and each unit located in the State of Oklahoma and Indian country within the borders of the State and for which requirements are set forth under the CSAPR NO_x Ozone Season Group 3 Trading Program in subpart GGGGG of part 97 of this chapter must comply with such requirements with regard to emissions occurring in 2023 and each subsequent year. The obligation to comply with such requirements with regard to sources and units in the State and areas of Indian country within the borders of the State subject to the State's SIP authority will be eliminated by the promulgation of an approval by the Administrator of a revision to Oklahoma's State Implementation Plan (SIP) as correcting the SIP's deficiency that is the basis for the CSAPR Federal Implementation Plan (FIP) under § 52.38(b)(1) and (b)(2)(iii) for those sources and units, except to the extent the Administrator's approval is partial or conditional. The obligation to comply with such requirements with regard to sources and units located in areas of Indian country within the borders of the State not subject to the State's SIP authority will not be eliminated by the promulgation of an approval by the Administrator of a revision to Oklahoma's SIP.

(4) Notwithstanding the provisions of paragraph (a)(3) of this section, if, at the time of the approval of Oklahoma's SIP revision described in paragraph (a)(3) of this section, the Administrator has already started recording any allocations

of CSAPR NO_x Ozone Season Group 3 allowances under subpart GGGGG of part 97 of this chapter to units in the State and areas of Indian country within the borders of the State subject to the State's SIP authority for a control period in any year, the provisions of subpart GGGGG of part 97 of this chapter authorizing the Administrator to complete the allocation and recordation of CSAPR NO_x Ozone Season Group 3 allowances to such units for each such control period shall continue to apply, unless provided otherwise by such approval of the State's SIP revision.

(5) Notwithstanding the provisions of paragraph (a)(2) of this section, after 2022 the provisions of § 97.826(c) of this chapter (concerning the transfer of CSAPR NO_x Ozone Season Group 2 allowances between certain accounts under common control), the provisions of § 97.826(e) of this chapter (concerning the conversion of amounts of unused CSAPR NO_x Ozone Season Group 2 allowances allocated for control periods before 2023 to different amounts of CSAPR NO_x Ozone Season Group 3 allowances), and the provisions of § 97.811(e) of this chapter (concerning the recall of CSAPR NO_x Ozone Season Group 2 allowances equivalent in quantity and usability to all such allowances allocated to units in the State and Indian country within the borders of the State for control periods after 2022) shall continue to apply.

(b) The owner and operator of each source located in the State of Oklahoma and Indian country within the borders of the State and for which requirements are set forth in § 52.40 and § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 must comply with such requirements with regard to emissions occurring in 2026 and each subsequent year.

Subpart NN—Pennsylvania

- 22. Amend § 52.2040 by:
 - a. In paragraph (b)(3), removing “(b)(2)(v), except” and adding in its place “(b)(2)(iii), except”; and
 - b. Adding paragraph (c).
- The addition reads as follows:

§ 52.2040 Interstate pollutant transport provisions; What are the FIP requirements for decreases in emissions of nitrogen oxides?

* * * * *

(c) The owner and operator of each source located in the State of Pennsylvania and for which requirements are set forth in § 52.40 and § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 must comply with such requirements with regard to emissions

occurring in 2026 and each subsequent year.

Subpart SS—Texas

- 23. Amend § 52.2283 by:
 - a. In paragraph (d)(2):
 - i. Removing “2017 and each subsequent year” and adding in its place “2017 through 2022”; and
 - ii. Removing the second and third sentences;
 - b. Revising paragraph (d)(3); and
 - c. Adding paragraphs (d)(4) and (5) and (e).

The revision and additions read as follows:

§ 52.2283 Interstate pollutant transport provisions; What are the FIP requirements for decreases in emissions of nitrogen oxides?

* * * * *

(d) * * *
(3) The owner and operator of each source and each unit located in the State of Texas and Indian country within the borders of the State and for which requirements are set forth under the CSAPR NO_x Ozone Season Group 3 Trading Program in subpart GGGGG of part 97 of this chapter must comply with such requirements with regard to emissions occurring in 2023 and each subsequent year. The obligation to comply with such requirements with regard to sources and units in the State and areas of Indian country within the borders of the State subject to the State's SIP authority will be eliminated by the promulgation of an approval by the Administrator of a revision to Texas' State Implementation Plan (SIP) as correcting the SIP's deficiency that is the basis for the CSAPR Federal Implementation Plan (FIP) under § 52.38(b)(1) and (b)(2)(iii) for those sources and units, except to the extent the Administrator's approval is partial or conditional. The obligation to comply with such requirements with regard to sources and units located in areas of Indian country within the borders of the State not subject to the State's SIP authority will not be eliminated by the promulgation of an approval by the Administrator of a revision to Texas' SIP.

(4) Notwithstanding the provisions of paragraph (d)(3) of this section, if, at the time of the approval of Texas' SIP revision described in paragraph (d)(3) of this section, the Administrator has already started recording any allocations of CSAPR NO_x Ozone Season Group 3 allowances under subpart GGGGG of part 97 of this chapter to units in the State and areas of Indian country within the borders of the State subject to the State's SIP authority for a control period

in any year, the provisions of subpart GGGGG of part 97 of this chapter authorizing the Administrator to complete the allocation and recordation of CSAPR NO_x Ozone Season Group 3 allowances to such units for each such control period shall continue to apply, unless provided otherwise by such approval of the State's SIP revision.

(5) Notwithstanding the provisions of paragraph (d)(2) of this section, after 2022 the provisions of § 97.826(c) of this chapter (concerning the transfer of CSAPR NO_x Ozone Season Group 2 allowances between certain accounts under common control), the provisions of § 97.826(e) of this chapter (concerning the conversion of amounts of unused CSAPR NO_x Ozone Season Group 2 allowances allocated for control periods before 2023 to different amounts of CSAPR NO_x Ozone Season Group 3 allowances), and the provisions of § 97.811(e) of this chapter (concerning the recall of CSAPR NO_x Ozone Season Group 2 allowances equivalent in quantity and usability to all such allowances allocated to units in the State and Indian country within the borders of the State for control periods after 2022) shall continue to apply.

(e) The owner and operator of each source located in the State of Texas and Indian country within the borders of the State and for which requirements are set forth in § 52.40 and § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 must comply with such requirements with regard to emissions occurring in 2026 and each subsequent year.

Subpart TT—Utah

- 24. Add § 52.2356 to read as follows:

§ 52.2356 Interstate pollutant transport provisions; What are the FIP requirements for decreases in emissions of nitrogen oxides?

(a)(1) The owner and operator of each source and each unit located in the State of Utah and Indian country within the borders of the State and for which requirements are set forth under the CSAPR NO_x Ozone Season Group 3 Trading Program in subpart GGGGG of part 97 of this chapter must comply with such requirements with regard to emissions occurring in 2023 and each subsequent year. The obligation to comply with such requirements with regard to sources and units in the State and areas of Indian country within the borders of the State subject to the State's SIP authority will be eliminated by the promulgation of an approval by the Administrator of a revision to Utah's State Implementation Plan (SIP) as correcting the SIP's deficiency that is the basis for the CSAPR Federal

Implementation Plan (FIP) under § 52.38(b)(1) and (b)(2)(iii) for those sources and units, except to the extent the Administrator's approval is partial or conditional. The obligation to comply with such requirements with regard to sources and units located in areas of Indian country within the borders of the State not subject to the State's SIP authority will not be eliminated by the promulgation of an approval by the Administrator of a revision to Utah's SIP.

(2) Notwithstanding the provisions of paragraph (a)(1) of this section, if, at the time of the approval of Utah's SIP revision described in paragraph (a)(1) of this section, the Administrator has already started recording any allocations of CSAPR NO_x Ozone Season Group 3 allowances under subpart GGGGG of part 97 of this chapter to units in the State and areas of Indian country within the borders of the State subject to the State's SIP authority for a control period in any year, the provisions of subpart GGGGG of part 97 of this chapter authorizing the Administrator to complete the allocation and recordation of CSAPR NO_x Ozone Season Group 3 allowances to such units for each such control period shall continue to apply, unless provided otherwise by such approval of the State's SIP revision.

(b) The owner and operator of each source located in the State of Utah and Indian country within the borders of the State and for which requirements are set forth in § 52.40 and § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 must comply with such requirements with regard to emissions occurring in 2026 and each subsequent year.

Subpart VV—Virginia

- 25. Amend § 52.2440 by:
 - a. In paragraph (b)(3), removing “(b)(2)(v), except” and adding in its place “(b)(2)(iii), except”; and
 - b. Adding paragraph (c).

The addition reads as follows:

§ 52.2440 Interstate pollutant transport provisions; What are the FIP requirements for decreases in emissions of nitrogen oxides?

* * * * *

(c) The owner and operator of each source located in the State of Virginia and for which requirements are set forth in § 52.40 and § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 must comply with such requirements with regard to emissions occurring in 2026 and each subsequent year.

Subpart XX—West Virginia

- 26. Amend § 52.2540 by:

- a. In paragraph (b)(3), removing “(b)(2)(v), except” and adding in its place “(b)(2)(iii), except”; and
- b. Adding paragraph (c).

The addition reads as follows:

§ 52.2540 Interstate pollutant transport provisions; What are the FIP requirements for decreases in emissions of nitrogen oxides?

* * * * *

(c) The owner and operator of each source located in the State of West Virginia and for which requirements are set forth in § 52.40 and § 52.41, § 52.42, § 52.43, § 52.44, § 52.45, or § 52.46 must comply with such requirements with regard to emissions occurring in 2026 and each subsequent year.

Subpart YY—Wisconsin

- 27. Amend § 52.2587 by:
 - a. In paragraph (e)(2):
 - i. Removing “2017 and each subsequent year” and adding in its place “2017 through 2022”; and
 - ii. Removing the second and third sentences;
 - b. Revising paragraph (e)(3); and
 - c. Adding paragraphs (e)(4) and (5).

The revision and additions read as follows:

§ 52.2587 Interstate pollutant transport provisions; What are the FIP requirements for decreases in emissions of nitrogen oxides?

* * * * *

(e) * * *

(3) The owner and operator of each source and each unit located in the State of Wisconsin and Indian country within the borders of the State and for which requirements are set forth under the CSAPR NO_x Ozone Season Group 3 Trading Program in subpart GGGGG of part 97 of this chapter must comply with such requirements with regard to emissions occurring in 2023 and each subsequent year. The obligation to comply with such requirements with regard to sources and units in the State and areas of Indian country within the borders of the State subject to the State's SIP authority will be eliminated by the promulgation of an approval by the Administrator of a revision to Wisconsin's State Implementation Plan (SIP) as correcting the SIP's deficiency that is the basis for the CSAPR Federal Implementation Plan (FIP) under § 52.38(b)(1) and (b)(2)(iii) for those sources and units, except to the extent the Administrator's approval is partial or conditional. The obligation to comply with such requirements with regard to sources and units located in areas of Indian country within the borders of the State not subject to the State's SIP

authority will not be eliminated by the promulgation of an approval by the Administrator of a revision to Wisconsin's SIP.

(4) Notwithstanding the provisions of paragraph (e)(3) of this section, if, at the time of the approval of Wisconsin's SIP revision described in paragraph (e)(3) of this section, the Administrator has already started recording any allocations of CSAPR NO_x Ozone Season Group 3 allowances under subpart GGGGG of part 97 of this chapter to units in the State and areas of Indian country within the borders of the State subject to the State's SIP authority for a control period in any year, the provisions of subpart GGGGG of part 97 of this chapter authorizing the Administrator to complete the allocation and recordation of CSAPR NO_x Ozone Season Group 3 allowances to such units for each such control period shall continue to apply, unless provided otherwise by such approval of the State's SIP revision.

(5) Notwithstanding the provisions of paragraph (e)(2) of this section, after 2022 the provisions of § 97.826(c) of this chapter (concerning the transfer of CSAPR NO_x Ozone Season Group 2 allowances between certain accounts under common control), the provisions of § 97.826(e) of this chapter (concerning the conversion of amounts of unused CSAPR NO_x Ozone Season Group 2 allowances allocated for control periods before 2023 to different amounts of CSAPR NO_x Ozone Season Group 3 allowances), and the provisions of § 97.811(e) of this chapter (concerning the recall of CSAPR NO_x Ozone Season Group 2 allowances equivalent in quantity and usability to all such allowances allocated to units in the State and Indian country within the borders of the State for control periods after 2022) shall continue to apply.

PART 75—CONTINUOUS EMISSION MONITORING

- 28. The authority citation for part 75 is revised to read as follows:

Authority: 42 U.S.C. 7401–7671q and 7651k note.

Subpart H—NO_x Mass Emissions Provisions

- 29. Amend § 75.72 by:
 - a. In paragraph (c)(3), removing “appendix B of this part” and adding in its place “appendix B to this part”;
 - b. In paragraph (e)(1)(ii), removing “heat input from” and adding in its place “heat input rate to”;
 - c. In paragraph (e)(2), removing “appendix D of this part” and adding in its place “appendix D to this part”; and

- d. Adding paragraph (f).
The addition reads as follows:

§ 75.72 Determination of NO_x mass emissions for common stack and multiple stack configurations.

* * * * *

(f) *Procedures for apportioning hourly NO_x mass emission rate to the unit level.* If the owner or operator of a unit determining hourly NO_x mass emission rate at a common stack under this section is subject to a State or Federal NO_x mass emissions reduction program under subpart GGGGG of part 97 of this chapter or under a state implementation plan approved pursuant to § 52.38(b)(12) of this chapter, then on and after January 1, 2024, the owner or operator shall apportion the hourly NO_x mass emissions rate at the common stack to each unit using the common stack based on the ratio of the hourly heat input rate for each such unit to the total hourly heat input rate for all such units, in conjunction with the appropriate unit and stack operating times, according to the procedures in section 8.5.3 of appendix F to this part.

* * * * *

- 30. Amend § 75.73 by:
 - a. Revising paragraph (a)(3);
 - b. In paragraph (c)(1), removing “NO_x emissions” and adding in its place “NO_x emissions”;
 - c. Adding a heading to paragraph (c)(2);
 - d. Revising paragraphs (c)(3) and (f)(1) introductory text;
 - e. Removing and reserving paragraph (f)(1)(i)(B);
 - f. In paragraph (f)(1)(ii)(G), removing “appendix D;” and adding in its place “appendix D to this part;”;
 - g. Adding paragraphs (f)(1)(ix) and (x);
 - h. Adding a heading to paragraph (f)(2); and
 - i. Revising paragraph (f)(4).

The revisions and additions read as follows:

§ 75.73 Recordkeeping and reporting.

(a) * * *

(3) For each hour when the unit is operating, NO_x mass emission rate, calculated in accordance with section 8 of appendix F to this part.

* * * * *

(c) * * *

(2) *Monitoring plan updates.* * * *

(3) *Contents of the monitoring plan.*

Each monitoring plan shall contain the information in § 75.53(g)(1) in electronic format and the information in § 75.53(g)(2) in hardcopy format. In addition, to the extent applicable, each monitoring plan shall contain the information in § 75.53(h)(1)(i) and (h)(2)(i) in electronic format and the

information in § 75.53(h)(1)(ii) and (h)(2)(ii) in hardcopy format. For units using the low mass emissions excepted methodology under § 75.19, the monitoring plan shall include the additional information in § 75.53(h)(4)(i) and (ii). The monitoring plan also shall include a seasonal controls indicator and an ozone season fuel-switching flag.

* * * * *

(f) * * *

(1) *Electronic submission.* The designated representative for an affected unit shall electronically report the data and information in this paragraph (f)(1) and in paragraphs (f)(2) and (3) of this section to the Administrator quarterly, unless the unit has been placed in long-term cold storage (as defined in § 72.2 of this chapter). Each electronic report must be submitted to the Administrator within 30 days following the end of each calendar quarter. Each electronic report shall include the information provided in paragraphs (f)(1)(i) through (x) of this section and shall also include the date of report generation. A unit placed into long-term cold storage is exempted from submitting quarterly reports beginning with the calendar quarter following the quarter in which the unit is placed into long-term cold storage, provided that the owner or operator shall submit quarterly reports for the unit beginning with the data from the quarter in which the unit recommences operation (where the initial quarterly report contains hourly data beginning with the first hour of recommenced operation of the unit).

* * * * *

(ix) On and after January 1, 2024, for a unit subject to subpart GGGGG of part 97 of this chapter or a state implementation plan approved under § 52.38(b)(12) of this chapter and determining NO_x mass emission rate at a common stack, apportioned hourly NO_x mass emission rate for the unit, lb/hr.

(x) On and after January 1, 2024, for a unit that is subject to subpart GGGGG of part 97 of this chapter or a state implementation plan approved under § 52.38(b)(12) of this chapter, that lists coal or a solid coal-derived fuel as a fuel in the unit’s monitoring plan under § 75.53 for any portion of the ozone season in the year for which data are being reported, that serves a generator of 100 MW or larger nameplate capacity, and that is not a circulating fluidized bed boiler, provided that through December 31, 2029, the requirements under this paragraph (f)(1)(x) shall apply to a unit in a given calendar year only if the unit also was equipped with selective catalytic reduction controls on

or before September 30 of the previous year:

(A) Daily NO_x emissions (lbs) for each day of the reporting period;

(B) Daily heat input (mmBtu) for each day of the reporting period;

(C) Daily average NO_x emission rate (lb/mmBtu, rounded to the nearest thousandth) for each day of the reporting period;

(D) Daily NO_x emissions (lbs) exceeding the applicable backstop daily NO_x emission rate for each day of the reporting period;

(E) Cumulative NO_x emissions (tons, rounded to the nearest tenth) exceeding the applicable backstop daily NO_x emission rate during the ozone season; and

(F) Cumulative NO_x emissions (tons, rounded to the nearest tenth) exceeding the applicable backstop daily NO_x emission rate during the ozone season by more than 50 tons, calculated as the remainder of the amount calculated under paragraph (f)(1)(x)(E) of this section minus 50, but not less than zero.

(2) *Verification of identification codes and formulas.* * * *

(4) *Electronic format, method of submission, and explanatory information.* The designated representative shall comply with all of the quarterly reporting requirements in § 75.64(d), (f), and (g).

- 31. Revise § 75.75 to read as follows:

§ 75.75 Additional ozone season calculation procedures.

(a) The owner or operator of a unit that is required to calculate daily or ozone season heat input shall do so by summing the unit’s hourly heat input determined according to the procedures in this part for all hours in which the unit operated during the day or ozone season.

(b) The owner or operator of a unit that is required to determine daily or ozone season NO_x emission rate (in lbs/mmBtu) shall do so by dividing daily or ozone season NO_x mass emissions (in lbs) determined in accordance with this subpart, by daily or ozone season heat input determined in accordance with paragraph (a) of this section.

- 32. Amend appendix F to part 75 by:

- a. Adding section 5.3.3;

- b. In section 8.1.2, revising the introductory text preceding Equation F–25;

- c. In section 8.4, revising the introductory text, paragraph (a) introductory text (preceding Equation F–27), and paragraph (b) introductory text (preceding Equation F–27a) and adding paragraph (c);

- d. In section 8.5.2, removing “the hourly NO_x mass emissions at each

unit” and adding in its place “hourly NO_x mass emissions at the common stack”; and

■ e. Adding section 8.5.3.

The additions and revisions read as follows:

Appendix F to Part 75—Conversion Procedures

* * * * *

5. Procedures for Heat Input

* * * * *

5.3 Heat Input Summation (for Heat Input Determined Using a Flow Monitor and Diluent Monitor)

* * * * *

5.3.3 Calculate total daily heat input for a unit using a flow monitor and diluent monitor to calculate heat input, using the following equation:

$$HI_d = \sum_{h=1}^{24} HI_h t_h$$

(Eq. F-18c)

Where:

HI_d = Total heat input for a unit for the day, mmBtu.

HI_h = Heat input rate for the unit for hour “h” from Equation F-15, F-16, F-17, F-18, F-21a, or F-21b to this appendix, mmBtu/hr.

t_h = Unit operating time, fraction of the hour (0.00 to 1.00, in equal increments from one hundredth to one quarter of an hour, at the option of the owner or operator).

h = Designation of a particular hour.

* * * * *

8. Procedures for NO_x Mass Emissions

* * * * *

8.1.2 If NO_x emission rate is measured at a common stack and heat input rate is measured at the unit level, calculate the hourly heat input rate at the common stack according to the following formula:

* * * * *

8.4 Use the following equations to calculate daily, quarterly, cumulative ozone season, and cumulative year-to-date NO_x mass emissions:

(a) When hourly NO_x mass emissions are reported in lb., use Eq. F-27 to this appendix

to calculate quarterly, cumulative ozone season, and cumulative year-to-date NO_x mass emissions in tons.

* * * * *

(b) When hourly NO_x mass emission rate is reported in lb/hr, use Eq. F-27a to this appendix to calculate quarterly, cumulative ozone season, and cumulative year-to-date NO_x mass emissions in tons.

* * * * *

(c) To calculate daily NO_x mass emissions for a unit in pounds, use Eq. F-27b to this appendix.

$$M_{(NOX)_d} = \sum_{h=1}^{24} E_{(NOX)_h} t_h$$

(Eq. F-27b)

Where:

M_{(NOX)_d} = NO_x mass emissions for a unit for the day, pounds.

E_{(NOX)_h} = NO_x mass emission rate for the unit for hour “h” from Equation F-24a, F-26a, F-26b, or F-28, lb/hr.

t_h = Unit operating time, fraction of the hour (0.00 to 1.00, in equal increments from one hundredth to one quarter of an hour, at the option of the owner or operator).

h = Designation of a particular hour.

* * * * *

8.5.3 Where applicable, the owner or operator of a unit that determines hourly NO_x mass emission rate at a common stack shall apportion hourly NO_x mass emissions rate to the units using the common stack based on the hourly heat input rate, using Equation F-28 to this appendix:

$$E_{(NOX)_i} = E_{(NOX)CS} \left(\frac{t_{CS}}{t_i} \right) \left[\frac{HI_i t_i}{\sum_{i=1}^n HI_i t_i} \right]$$

(Eq. F-28)

Where:

E_{(NOX)_i} = Apportioned NO_x mass emission rate for the hour for unit “i”, lb/hr.

E_{(NOX)CS} = NO_x mass emission rate for the hour at the common stack, lb/hr.

HI_i = Heat input rate for the hour for unit “i,” from Equation F-15, F-16, F-17, F-18, F-21a, or F-21b to this appendix, mmBtu/hr.

t_i = Operating time for unit “i”, fraction of the hour (0.00 to 1.00, in equal increments from one hundredth to one

quarter of an hour, at the option of the owner or operator).

t_{CS} = Common stack operating time, fraction of the hour (0.00 to 1.00, in equal increments from one hundredth to one quarter of an hour, at the option of the owner or operator).

n = Number of units using the common stack.

i = Designation of a particular unit.

* * * * *

PART 78—APPEAL PROCEDURES

■ 33. The authority citation for part 78 continues to read as follows:

Authority: 42 U.S.C. 7401–7671q.

■ 34. Amend § 78.1 by:

■ a. In paragraphs (b)(13)(i), (b)(14)(i), (b)(15)(i), (b)(16)(i), and (b)(17)(i), removing “decision on the” and adding in its place “calculation of an”;

- b. In paragraph (b)(17)(viii), adding “or (e)” after “§ 97.826(d)”;
- c. In paragraph (b)(17)(ix), adding “or (e)” after “§ 97.811(d)”;
- d. In paragraph (b)(18)(i), removing “decision on the” and adding in its place “calculation of an”; and
- e. Revising paragraph (b)(19).
The revision reads as follows:

§ 78.1 Purpose and scope.

* * * * *

(b) * * *

(19) Under subpart GGGGG of part 97 of this chapter:

- (i) The calculation of a dynamic trading budget under § 97.1010(a)(4) of this chapter.
- (ii) The calculation of an allocation of CSAPR NO_x Ozone Season Group 3 allowances under § 97.1011 or § 97.1012 of this chapter.
- (iii) The decision on the transfer of CSAPR NO_x Ozone Season Group 3 allowances under § 97.1023 of this chapter.
- (iv) The decision on the deduction of CSAPR NO_x Ozone Season Group 3 allowances under § 97.1024, § 97.1025, or § 97.1026(d) of this chapter.
- (v) The correction of an error in an Allowance Management System account under § 97.1027 of this chapter.
- (vi) The adjustment of information in a submission and the decision on the deduction and transfer of CSAPR NO_x Ozone Season Group 3 allowances based on the information as adjusted under § 97.1028 of this chapter.
- (vii) The finalization of control period emissions data, including retroactive adjustment based on audit.
- (viii) The approval or disapproval of a petition under § 97.1035 of this chapter.

* * * * *

PART 97—FEDERAL NO_x BUDGET TRADING PROGRAM, CAIR NO_x AND SO₂ TRADING PROGRAMS, CSAPR NO_x AND SO₂ TRADING PROGRAMS, AND TEXAS SO₂ TRADING PROGRAM

- 35. The authority citation for part 97 continues to read as follows:

Authority: 42 U.S.C. 7401, 7403, 7410, 7426, 7491, 7601, and 7651, *et seq.*

Subpart AAAAA—CSAPR NO_x Annual Trading Program

§ 97.402 [Amended]

- 36. Amend § 97.402 by:
 - a. In the definition of “CSAPR NO_x Ozone Season Group 1 Trading Program”, removing “(b)(2)(i) and (ii), and” and adding in its place “(b)(2)(i), and”;
 - b. In the definition of “CSAPR NO_x Ozone Season Group 2 Trading

Program”, removing “(b)(2)(iii) and (iv), and” and adding in its place “(b)(2)(ii), and”;

- c. In the definition of “CSAPR NO_x Ozone Season Group 3 Trading Program”, removing “(b)(2)(v), and” and adding in its place “(b)(2)(iii), and”.

§ 97.411 [Amended]

- 37. Amend § 97.411 by:

- a. In paragraphs (b)(1)(i)(A) and (B), removing “State, in accordance” and adding in its place “State and areas of Indian country within the borders of the State subject to the State’s SIP authority, in accordance”;
- b. In paragraphs (b)(2)(i)(A) and (B), removing “Indian country within the borders of a State, in accordance” and adding in its place “areas of Indian country within the borders of a State not subject to the State’s SIP authority, in accordance”.

§ 97.412 [Amended]

- 38. Amend § 97.412 by:

- a. In paragraph (a) introductory text, removing “State, the Administrator” and adding in its place “State and areas of Indian country within the borders of the State subject to the State’s SIP authority, the Administrator”;
- b. In paragraphs (a)(3)(iii) and (a)(5), adding “and areas of Indian country within the borders of the State subject to the State’s SIP authority” after “in the State”;
- c. In paragraph (a)(10), removing “State, is allocated” and adding in its place “State and areas of Indian country within the borders of the State subject to the State’s SIP authority, is allocated”;
- d. In paragraph (b) introductory text, removing “Indian country within the borders of each State, the Administrator” and adding in its place “areas of Indian country within the borders of each State not subject to the State’s SIP authority, the Administrator”;
- e. In paragraph (b)(5), removing “Indian country within the borders of the State” and adding in its place “areas of Indian country within the borders of the State not subject to the State’s SIP authority”.

§ 97.426 [Amended]

- 39. In § 97.426, amend paragraph (c) by:
 - a. Removing “set forth in” and adding in its place “established under”;
 - b. Removing “State (or Indian)” and adding in its place “State (and Indian)”.

Subpart BBBBB—CSAPR NO_x Ozone Season Group 1 Trading Program

§ 97.502 [Amended]

- 40. Amend § 97.502 by:
 - a. In the definition of “CSAPR NO_x Ozone Season Group 1 Trading Program”, removing “(b)(2)(i) and (ii), and” and adding in its place “(b)(2)(i), and”;
 - b. In the definition of “CSAPR NO_x Ozone Season Group 2 Trading Program”, removing “(b)(2)(iii) and (iv), and” and adding in its place “(b)(2)(ii), and”;
 - c. In the definition of “CSAPR NO_x Ozone Season Group 3 allowance”:
 - i. Adding “or (e)” after “§ 97.826(d)”;
 - ii. Adding “or less” after “one ton”;
 - d. In the definition of “CSAPR NO_x Ozone Season Group 3 Trading Program”, removing “(b)(2)(v), and” and adding in its place “(b)(2)(iii), and”;
 - e. In the definition of “State”, removing “(b)(2)(i) and (ii), and” and adding in its place “(b)(2)(i), and”.

§ 97.511 [Amended]

- 41. Amend § 97.511 by:
 - a. In paragraphs (b)(1)(i)(A) and (B), removing “State, in accordance” and adding in its place “State and areas of Indian country within the borders of the State subject to the State’s SIP authority, in accordance”;
 - b. In paragraphs (b)(2)(i)(A) and (B), removing “Indian country within the borders of a State, in accordance” and adding in its place “areas of Indian country within the borders of a State not subject to the State’s SIP authority, in accordance”.

§ 97.512 [Amended]

- 42. Amend § 97.512 by:
 - a. In paragraph (a) introductory text, removing “State, the Administrator” and adding in its place “State and areas of Indian country within the borders of the State subject to the State’s SIP authority, the Administrator”;
 - b. In paragraphs (a)(3)(iii) and (a)(5), adding “and areas of Indian country within the borders of the State subject to the State’s SIP authority” after “in the State”;
 - c. In paragraph (a)(10), removing “State, is allocated” and adding in its place “State and areas of Indian country within the borders of the State subject to the State’s SIP authority, is allocated”;
 - d. In paragraph (b) introductory text, removing “Indian country within the borders of each State, the Administrator” and adding in its place “areas of Indian country within the borders of each State not subject to the

State's SIP authority, the Administrator"; and

■ e. In paragraph (b)(5), removing "Indian country within the borders of the State" and adding in its place "areas of Indian country within the borders of the State not subject to the State's SIP authority".

■ 43. Amend § 97.526 by:

■ a. In paragraph (c):

■ i. Removing "set forth in" and adding in its place "established under"; and

■ ii. Removing "State (or Indian" and adding in its place "State (and Indian";

■ b. In paragraph (d)(1) introductory text, removing "§ 52.38(b)(2)(i) of this chapter (or" and adding in its place "§ 52.38(b)(2)(i)(A) of this chapter (and";

■ c. In paragraph (d)(1)(ii), removing "except a State listed in § 52.38(b)(2)(i)" and adding in its place "listed in § 52.38(b)(2)(ii)";

■ d. In paragraph (d)(1)(iv), removing "§ 52.38(b)(2)(iii) or (iv) of this chapter (or" and adding in its place "§ 52.38(b)(2)(ii) of this chapter (and";

■ e. Revising paragraph (d)(2)(i);

■ f. In paragraph (d)(2)(ii), removing "§ 52.38(b)(2)(v) of this chapter (or" and adding in its place "§ 52.38(b)(2)(iii)(A) of this chapter (and";

■ g. Adding paragraph (d)(2)(iii);

■ h. In paragraph (e)(1), removing "§ 52.38(b)(2)(ii) of this chapter (or Indian" and adding in its place "§ 52.38(b)(2)(i)(B) of this chapter (and Indian";

■ i. In paragraph (e)(2), removing "§ 52.38(b)(2)(iv) of this chapter (or" and adding in its place "§ 52.38(b)(2)(ii)(B) of this chapter (and"; and

■ j. Adding paragraph (e)(3).

The revisions and additions read as follows:

§ 97.526 Banking and conversion.

* * * * *

(d) * * *

(2)(i) Except as provided in paragraphs (d)(2)(ii) and (iii) of this section, after the Administrator has carried out the procedures set forth in paragraph (d)(1) of this section, upon any determination that would otherwise result in the initial recordation of a given number of CSAPR NO_x Ozone Season Group 1 allowances in the compliance account for a source in a State listed in § 52.38(b)(2)(ii) of this chapter (and Indian country within the borders of such a State), the Administrator will not record such CSAPR NO_x Ozone Season Group 1 allowances but instead will allocate and record in such account an amount of CSAPR NO_x Ozone Season Group 2 allowances for the control period in

2017 computed as the quotient, rounded up to the nearest allowance, of such given number of CSAPR NO_x Ozone Season Group 1 allowances divided by the conversion factor determined under paragraph (d)(1)(ii) of this section.

* * * * *

(iii) After the Administrator has carried out the procedures set forth in paragraph (d)(1) of this section and § 97.826(e)(1), upon any determination that would otherwise result in the initial recordation of a given number of CSAPR NO_x Ozone Season Group 1 allowances in the compliance account for a source in a State listed in § 52.38(b)(2)(iii)(B) of this chapter (and Indian country within the borders of such a State), the Administrator will not record such CSAPR NO_x Ozone Season Group 1 allowances but instead will allocate and record in such account an amount of CSAPR NO_x Ozone Season Group 3 allowances for the control period in 2023 computed as the quotient, rounded up to the nearest allowance, of such given number of CSAPR NO_x Ozone Season Group 1 allowances divided by the conversion factor determined under paragraph (d)(1)(ii) of this section and further divided by the conversion factor determined under § 97.826(e)(1)(ii).

(e) * * *

(3) After the Administrator has carried out the procedures set forth in paragraph (d)(1) of this section and § 97.826(e)(1), the owner or operator of a CSAPR NO_x Ozone Season Group 1 source in a State listed in § 52.38(b)(2)(ii)(C) of this chapter (and Indian country within the borders of such a State) may satisfy a requirement to hold a given number of CSAPR NO_x Ozone Season Group 1 allowances for the control period in 2015 or 2016 by holding instead, in a general account established for this sole purpose, an amount of CSAPR NO_x Ozone Season Group 3 allowances for the control period in 2023 (or any later control period for which the allowance transfer deadline defined in § 97.1002 has passed) computed as the quotient, rounded up to the nearest allowance, of such given number of CSAPR NO_x Ozone Season Group 1 allowances divided by the conversion factor determined under paragraph (d)(1)(ii) of this section and further divided by the conversion factor determined under § 97.826(e)(1)(ii).

Subpart CCCCC—CSAPR SO₂ Group 1 Trading Program

§ 97.602 [Amended]

■ 44. Amend § 97.602 by:

■ a. In the definition of "CSAPR NO_x Ozone Season Group 1 Trading

Program", removing "(b)(2)(i) and (ii), and" and adding in its place "(b)(2)(i), and";

■ b. In the definition of "CSAPR NO_x Ozone Season Group 2 Trading Program", removing "(b)(2)(iii) and (iv), and" and adding in its place "(b)(2)(ii), and"; and

■ c. In the definition of "CSAPR NO_x Ozone Season Group 3 Trading Program", removing "(b)(2)(v), and" and adding in its place "(b)(2)(iii), and".

§ 97.611 [Amended]

■ 45. Amend § 97.611 by:

■ a. In paragraphs (b)(1)(i)(A) and (B), removing "State, in accordance" and adding in its place "State and areas of Indian country within the borders of the State subject to the State's SIP authority, in accordance"; and

■ b. In paragraphs (b)(2)(i)(A) and (B), removing "Indian country within the borders of a State, in accordance" and adding in its place "areas of Indian country within the borders of a State not subject to the State's SIP authority, in accordance".

§ 97.612 [Amended]

■ 46. Amend § 97.612 by:

■ a. In paragraph (a) introductory text, removing "State, the Administrator" and adding in its place "State and areas of Indian country within the borders of the State subject to the State's SIP authority, the Administrator";

■ b. In paragraphs (a)(3)(iii) and (a)(5), adding "and areas of Indian country within the borders of the State subject to the State's SIP authority" after "in the State";

■ c. In paragraph (a)(10), removing "State, is allocated" and adding in its place "State and areas of Indian country within the borders of the State subject to the State's SIP authority, is allocated";

■ d. In paragraph (b) introductory text, removing "Indian country within the borders of each State, the Administrator" and adding in its place "areas of Indian country within the borders of each State not subject to the State's SIP authority, the Administrator"; and

■ e. In paragraph (b)(5), removing "Indian country within the borders of the State" and adding in its place "areas of Indian country within the borders of the State not subject to the State's SIP authority".

§ 97.626 [Amended]

■ 47. In § 97.626, amend paragraph (c) by:

■ a. Removing "set forth in" and adding in its place "established under"; and

■ b. Removing “State (or Indian” and adding in its place “State (and Indian”.

Subpart DDDDD—CSAPR SO₂ Group 2 Trading Program

■ 48. Amend § 97.702 by:

- a. In the definition of “Alternate designated representative”, removing “or CSAPR NO_x Ozone Season Group 2 Trading Program, then” and adding in its place “CSAPR NO_x Ozone Season Group 2 Trading Program, or CSAPR NO_x Ozone Season Group 3 Trading Program, then”;
- b. In the definition of “CSAPR NO_x Ozone Season Group 1 Trading Program”, removing “(b)(2)(i) and (ii), and” and adding in its place “(b)(2)(i), and”;
- c. In the definition of “CSAPR NO_x Ozone Season Group 2 Trading Program”, removing “(b)(2)(iii) and (iv), and” and adding in its place “(b)(2)(ii), and”;
- d. Adding in alphabetical order a definition for “CSAPR NO_x Ozone Season Group 3 Trading Program”; and
- e. In the definition of “Designated representative”, removing “or CSAPR NO_x Ozone Season Group 2 Trading Program, then” and adding in its place “CSAPR NO_x Ozone Season Group 2 Trading Program, or CSAPR NO_x Ozone Season Group 3 Trading Program, then”.

The addition reads as follows:

§ 97.702 Definitions.

* * * * *

CSAPR NO_x Ozone Season Group 3 Trading Program means a multi-state NO_x air pollution control and emission reduction program established in accordance with subpart GGGGG of this part and § 52.38(b)(1), (b)(2)(iii), and (b)(10) through (14) and (17) of this chapter (including such a program that is revised in a SIP revision approved by the Administrator under § 52.38(b)(10) or (11) of this chapter or that is established in a SIP revision approved by the Administrator under § 52.38(b)(12) of this chapter), as a means of mitigating interstate transport of ozone and NO_x.

* * * * *

§ 97.711 [Amended]

- 49. Amend § 97.711 by:
- a. In paragraphs (b)(1)(i)(A) and (B), removing “State, in accordance” and adding in its place “State and areas of Indian country within the borders of the State subject to the State’s SIP authority, in accordance”; and
- b. In paragraphs (b)(2)(i)(A) and (B), removing “Indian country within the borders of a State, in accordance” and adding in its place “areas of Indian

country within the borders of a State not subject to the State’s SIP authority, in accordance”.

§ 97.712 [Amended]

- 50. Amend § 97.712 by:
- a. In paragraph (a) introductory text, removing “State, the Administrator” and adding in its place “State and areas of Indian country within the borders of the State subject to the State’s SIP authority, the Administrator”;
- b. In paragraphs (a)(3)(iii) and (a)(5), adding “and areas of Indian country within the borders of the State subject to the State’s SIP authority” after “in the State”;
- c. In paragraph (a)(10), removing “State, is allocated” and adding in its place “State and areas of Indian country within the borders of the State subject to the State’s SIP authority, is allocated”;
- d. In paragraph (b) introductory text, removing “Indian country within the borders of each State, the Administrator” and adding in its place “areas of Indian country within the borders of each State not subject to the State’s SIP authority, the Administrator”; and
- e. In paragraph (b)(5), removing “Indian country within the borders of the State” and adding in its place “areas of Indian country within the borders of the State not subject to the State’s SIP authority”.

§ 97.726 [Amended]

- 51. In § 97.726, amend paragraph (c) by:
- a. Removing “set forth in” and adding in its place “established under”; and
- b. Removing “State (or Indian” and adding in its place “State (and Indian”.

§ 97.734 [Amended]

- 52. In § 97.734, amend paragraph (d)(3) by removing “or CSAPR NO_x Ozone Season Group 2 Trading Program, quarterly” and adding in its place “CSAPR NO_x Ozone Season Group 2 Trading Program, or CSAPR NO_x Ozone Season Group 3 Trading Program, quarterly”.

Subpart EEEEE—CSAPR NO_x Ozone Season Group 2 Trading Program

- 53. Amend § 97.802 by:
- a. In the definition of “Assurance account”, removing “base CSAPR” and adding in its place “CSAPR”;
- b. Removing the definitions for “Base CSAPR NO_x Ozone Season Group 2 source” and “Base CSAPR NO_x Ozone Season Group 2 unit”;
- c. In the definition of “Common designated representative”, removing

“base CSAPR” and adding in its place “CSAPR”;

- d. In the definition of “Common designated representative’s assurance level”, revising paragraph (1);
- e. In the definition of “Common designated representative’s share”, removing “base CSAPR” and adding in its place “CSAPR” each time it appears;
- f. In the definition of “CSAPR NO_x Ozone Season Group 2 Trading Program”, removing “(b)(2)(iii) and (iv), and” and adding in its place “(b)(2)(ii), and”;
- g. In the definition of “CSAPR NO_x Ozone Season Group 3 allowance”;
- i. Adding “or (e)” after “§ 97.826(d)”;
- and
- ii. Adding “or less” after “one ton”;
- h. In the definition of “CSAPR NO_x Ozone Season Group 3 Trading Program”, removing “(b)(2)(v), and” and adding in its place “(b)(2)(iii), and”;
- i. In the definition of “State”, removing “(b)(2)(iii) and (iv), and” and adding in its place “(b)(2)(ii), and”.

The revision reads as follows:

§ 97.802 Definitions.

* * * * *

Common designated representative’s assurance level * * *

(1) The amount (rounded to the nearest allowance) equal to the sum of the total amount of CSAPR NO_x Ozone Season Group 2 allowances allocated for such control period to the group of one or more CSAPR NO_x Ozone Season Group 2 units in such State (and such Indian country) having the common designated representative for such control period and the total amount of CSAPR NO_x Ozone Season Group 2 allowances purchased by an owner or operator of such CSAPR NO_x Ozone Season Group 2 units in an auction for such control period and submitted by the State or the permitting authority to the Administrator for recordation in the compliance accounts for such CSAPR NO_x Ozone Season Group 2 units in accordance with the CSAPR NO_x Ozone Season Group 2 allowance auction provisions in a SIP revision approved by the Administrator under § 52.38(b)(8) or (9) of this chapter, multiplied by the sum of the State NO_x Ozone Season Group 2 trading budget under § 97.810(a) and the State’s variability limit under § 97.810(b) for such control period, and divided by such State NO_x Ozone Season Group 2 trading budget;

* * * * *

§ 97.806 [Amended]

- 54. Amend § 97.806 by:
- a. In paragraphs (c)(2)(i) introductory text, (c)(2)(i)(B), and (c)(2)(iii) and (iv),

removing “base CSAPR” and adding in its place “CSAPR” each time it appears;

- b. In paragraph (c)(3)(i), removing “paragraph (c)(1)” and adding in its place “paragraphs (c)(1) and (2)”; and
- c. Removing and reserving paragraph (c)(3)(ii).

§ 97.810 [Amended]

- 55. In § 97.810, amend paragraphs (a)(1)(i) through (iii), (a)(2)(i) and (ii), (a)(12)(i) through (iii), (a)(13)(i) and (ii), (a)(17)(i) through (iii), (a)(20)(i) through (iii), (a)(23)(i) through (iii), and (b)(1), (2), (12), (13), (17), (20), and (23) by removing “and thereafter” and adding in its place “through 2022”.

- 56. Amend § 97.811 by:

- a. In paragraphs (b)(1)(i)(A) and (B), removing “State, in accordance” and adding in its place “State and areas of Indian country within the borders of the State subject to the State’s SIP authority, in accordance”;

- b. In paragraphs (b)(2)(i)(A) and (B), removing “Indian country within the borders of a State, in accordance” and adding in its place “areas of Indian country within the borders of a State not subject to the State’s SIP authority, in accordance”;

- c. In paragraph (d)(1), removing “§ 52.38(b)(2)(iv) of this chapter (or” and adding in its place “§ 52.38(b)(2)(ii)(B) of this chapter (and”;

- d. Adding paragraph (e).

The addition reads as follows:

§ 97.811 Timing requirements for CSAPR NO_x Ozone Season Group 2 allowance allocations.

* * * * *

(e) *Recall of CSAPR NO_x Ozone Season Group 2 allowances allocated for control periods after 2022.* (1) Notwithstanding any other provision of this subpart, part 52 of this chapter, or any SIP revision approved under § 52.38(b) of this chapter, the provisions of this paragraph (e)(1) and paragraphs (e)(2) through (7) of this section shall apply with regard to each CSAPR NO_x Ozone Season Group 2 allowance that was allocated for a control period after 2022 to any unit (including a permanently retired unit qualifying for an exemption under § 97.805) in a State listed in § 52.38(b)(2)(ii)(C) of this chapter (and Indian country within the borders of such a State) and that was initially recorded in the compliance account for the source that includes the unit, whether such CSAPR NO_x Ozone Season Group 2 allowance was allocated pursuant to this subpart or pursuant to a SIP revision approved under § 52.38(b) of this chapter and whether such CSAPR NO_x Ozone Season Group 2

allowance remains in such compliance account or has been transferred to another Allowance Management System account.

(2)(i) For each CSAPR NO_x Ozone Season Group 2 allowance described in paragraph (e)(1) of this section that was allocated for a given control period and initially recorded in a given source’s compliance account, one CSAPR NO_x Ozone Season Group 2 allowance that was allocated for the same or an earlier control period and initially recorded in the same or any other Allowance Management System account must be surrendered in accordance with the procedures in paragraphs (e)(3) and (4) of this section.

(ii)(A) The surrender requirement under paragraph (e)(2)(i) of this section corresponding to each CSAPR NO_x Ozone Season Group 2 allowance described in paragraph (e)(1) of this section initially recorded in a given source’s compliance account shall apply to such source’s current owners and operators, except as provided in paragraph (e)(2)(ii)(B) of this section.

(B) If the owners and operators of a given source as of a given date assumed ownership and operational control of the source through a transaction that did not also provide rights to direct the use or transfer of a given CSAPR NO_x Ozone Season Group 2 allowance described in paragraph (e)(1) of this section with regard to such source (whether recordation of such CSAPR NO_x Ozone Season Group 2 allowance in the source’s compliance account occurred before such transaction or was anticipated to occur after such transaction), then the surrender requirement under paragraph (e)(2)(i) of this section corresponding to such CSAPR NO_x Ozone Season Group 2 allowance shall apply to the most recent former owners and operators of the source before the occurrence of such a transaction.

(C) The Administrator will not adjudicate any private legal dispute among the owners and operators of a source or among the former owners and operators of a source, including any disputes relating to the requirements to surrender CSAPR NO_x Ozone Season Group 2 allowances for the source under paragraph (e)(2)(i) of this section.

(3)(i) As soon as practicable on or after August 4, 2023, the Administrator will send a notification to the designated representative for each source described in paragraph (e)(1) of this section identifying the amounts of CSAPR NO_x Ozone Season Group 2 allowances allocated for each control period after 2022 and recorded in the source’s compliance account and the

corresponding surrender requirements for the source under paragraph (e)(2)(i) of this section.

(ii) As soon as practicable on or after August 21, 2023, the Administrator will deduct from the compliance account for each source described in paragraph (e)(1) of this section CSAPR NO_x Ozone Season Group 2 allowances eligible to satisfy the surrender requirements for the source under paragraph (e)(2)(i) of this section until all such surrender requirements for the source are satisfied or until no more CSAPR NO_x Ozone Season Group 2 allowances eligible to satisfy such surrender requirements remain in such compliance account.

(iii) As soon as practicable after completion of the deductions under paragraph (e)(3)(ii) of this section, the Administrator will identify for each source described in paragraph (e)(1) of this section the amounts, if any, of CSAPR NO_x Ozone Season Group 2 allowances allocated for each control period after 2022 and recorded in the source’s compliance account for which the corresponding surrender requirements under paragraph (e)(2)(i) of this section have not been satisfied and will send a notification concerning such identified amounts to the designated representative for the source.

(iv) With regard to each source for which unsatisfied surrender requirements under paragraph (e)(2)(i) of this section remain after the deductions under paragraph (e)(3)(ii) of this section:

(A) Except as provided in paragraph (e)(3)(iv)(B) of this section, not later than September 15, 2023, the owners and operators of the source shall hold sufficient CSAPR NO_x Ozone Season Group 2 allowances eligible to satisfy such unsatisfied surrender requirements under paragraph (e)(2)(i) of this section in the source’s compliance account.

(B) With regard to any portion of such unsatisfied surrender requirements that apply to former owners and operators of the source pursuant to paragraph (e)(2)(ii)(B) of this section, not later than September 15, 2023, such former owners and operators shall hold sufficient CSAPR NO_x Ozone Season Group 2 allowances eligible to satisfy such portion of the unsatisfied surrender requirements under paragraph (e)(2)(i) of this section either in the source’s compliance account or in another Allowance Management System account identified to the Administrator on or before such date in a submission by the authorized account representative for such account.

(C) As soon as practicable on or after September 15, 2023, the Administrator will deduct from the Allowance

Management System account identified in accordance with paragraph (e)(3)(iv)(A) or (B) of this section CSAPR NO_x Ozone Season Group 2 allowances eligible to satisfy the surrender requirements for the source under paragraph (e)(2)(i) of this section until all such surrender requirements for the source are satisfied or until no more CSAPR NO_x Ozone Season Group 2 allowances eligible to satisfy such surrender requirements remain in such account.

(v) When making deductions under paragraph (e)(3)(ii) or (iv) of this section to address the surrender requirements under paragraph (e)(2)(i) of this section for a given source:

(A) The Administrator will make deductions to address any surrender requirements with regard to first the 2023 control period and then the 2024 control period.

(B) When making deductions to address the surrender requirements with regard to a given control period, the Administrator will first deduct CSAPR NO_x Ozone Season Group 2 allowances allocated for such given control period and will then deduct CSAPR NO_x Ozone Season Group 2 allowances allocated for each successively earlier control period in sequence.

(C) When deducting CSAPR NO_x Ozone Season Group 2 allowances allocated for a given control period from a given Allowance Management System account, the Administrator will first deduct CSAPR NO_x Ozone Season Group 2 allowances initially recorded in the account under § 97.821 (if the account is a compliance account) in the order of recordation and will then deduct CSAPR NO_x Ozone Season Group 2 allowances recorded in the account under § 97.526(d) or § 97.823 in the order of recordation.

(4)(i) To the extent the surrender requirements under paragraph (e)(2)(i) of this section corresponding to any CSAPR NO_x Ozone Season Group 2 allowances allocated for a control period after 2022 and initially recorded in a given source's compliance account have not been fully satisfied through the deductions under paragraph (e)(3) of this section, as soon as practicable on or after November 15, 2023, the Administrator will deduct such initially recorded CSAPR NO_x Ozone Season Group 2 allowances from any Allowance Management System accounts in which such CSAPR NO_x Ozone Season Group 2 allowances are held, making such deductions in any order determined by the Administrator, until all such surrender requirements for such source have been satisfied or until all such CSAPR NO_x Ozone

Season Group 2 allowances have been deducted, except as provided in paragraph (e)(4)(ii) of this section.

(ii) If no person with an ownership interest in a given CSAPR NO_x Ozone Season Group 2 allowance as of April 30, 2022, was an owner or operator of the source in whose compliance account such CSAPR NO_x Ozone Season Group 2 allowance was initially recorded, was a direct or indirect parent or subsidiary of an owner or operator of such source, or was directly or indirectly under common ownership with an owner or operator of such source, the Administrator will not deduct such CSAPR NO_x Ozone Season Group 2 allowance under paragraph (e)(4)(i) of this section. For purposes of this paragraph (e)(4)(ii), each owner or operator of a source shall be deemed to be a person with an ownership interest in any CSAPR NO_x Ozone Season Group 2 allowance held in that source's compliance account. The limitation established by this paragraph (e)(4)(ii) on the deductibility of certain CSAPR NO_x Ozone Season Group 2 allowances under paragraph (e)(4)(i) of this section shall not be construed as a waiver of the surrender requirements under paragraph (e)(2)(i) of this section corresponding to such CSAPR NO_x Ozone Season Group 2 allowances.

(iii) Not less than 45 days before the planned date for any deductions under paragraph (e)(4)(i) of this section, the Administrator will send a notification to the authorized account representative for the Allowance Management System account from which such deductions will be made identifying the CSAPR NO_x Ozone Season Group 2 allowances to be deducted and the data upon which the Administrator has relied and specifying a process for submission of any objections to such data. Any objections must be submitted to the Administrator not later than 15 days before the planned date for such deductions as indicated in such notification.

(5) To the extent the surrender requirements under paragraph (e)(2)(i) of this section corresponding to any CSAPR NO_x Ozone Season Group 2 allowances allocated for a control period after 2022 and initially recorded in a given source's compliance account have not been fully satisfied through the deductions under paragraphs (e)(3) and (4) of this section:

(i) The persons identified in accordance with paragraph (e)(2)(ii) of this section with regard to such source and each such CSAPR NO_x Ozone Season Group 2 allowance shall pay any fine, penalty, or assessment or comply

with any other remedy imposed under the Clean Air Act; and

(ii) Each such CSAPR NO_x Ozone Season Group 2 allowance, and each day in such control period, shall constitute a separate violation of this subpart and the Clean Air Act.

(6) The Administrator will record in the appropriate Allowance Management System accounts all deductions of CSAPR NO_x Ozone Season Group 2 allowances under paragraphs (e)(3) and (4) of this section.

(7)(i) Each submission, objection, or other written communication from a designated representative, authorized account representative, or other person to the Administrator under paragraph (e)(2), (3), or (4) of this section shall be sent electronically to the email address *CSAPR@epa.gov*. Each such communication from a designated representative must contain the certification statement set forth in § 97.814(a), and each such communication from the authorized account representative for a general account must contain the certification statement set forth in § 97.820(c)(2)(ii).

(ii) Each notification from the Administrator to a designated representative or authorized account representative under paragraph (e)(3) or (4) of this section will be sent electronically to the email address most recently received by the Administrator for such representative. In any such notification, the Administrator may provide information by means of a reference to a publicly accessible website where the information is available.

§ 97.812 [Amended]

- 57. Amend § 97.812 by:
 - a. In paragraph (a) introductory text, removing "State, the Administrator" and adding in its place "State and areas of Indian country within the borders of the State subject to the State's SIP authority, the Administrator";
 - b. In paragraphs (a)(3)(iii) and (a)(5), adding "and areas of Indian country within the borders of the State subject to the State's SIP authority" after "in the State";
 - c. In paragraph (a)(10), removing "State, is allocated" and adding in its place "State and areas of Indian country within the borders of the State subject to the State's SIP authority, is allocated";
 - d. In paragraph (b) introductory text, removing "Indian country within the borders of each State, the Administrator" and adding in its place "areas of Indian country within the borders of each State not subject to the

State's SIP authority, the Administrator"; and

■ e. In paragraph (b)(5), removing "Indian country within the borders of the State" and adding in its place "areas of Indian country within the borders of the State not subject to the State's SIP authority".

§ 97.825 [Amended]

■ 58. In § 97.825, amend paragraphs (a) introductory text, (a)(2), (b)(1)(i), (b)(1)(ii)(A) and (B), (b)(3), (b)(4)(i), (b)(5), (b)(6)(i), (b)(6)(iii) introductory text, and (b)(6)(iii)(A) and (B) by removing "base CSAPR" and adding in its place "CSAPR" each time it appears.

■ 59. Amend § 97.826 by:

■ a. In paragraph (b), removing "(c) or (d)" and adding in its place "(c), (d), or (e)";

■ b. In paragraph (c):

■ i. Removing "set forth in" and adding in its place "established under"; and

■ ii. Removing "State (or Indian" and adding in its place "State (and Indian";

■ c. In paragraphs (d)(1)(i)(A) and (B), removing "§ 52.38(b)(2)(iv)" and adding in its place "§ 52.38(b)(2)(ii)(B)";

■ d. Revising paragraph (d)(1)(i)(C);

■ e. In paragraph (d)(1)(ii) introductory text, removing "§ 52.38(b)(2)(v)" and adding in its place "§ 52.38(b)(2)(iii)(A)";

■ f. In paragraphs (d)(2)(i) and (d)(3), removing "§ 52.38(b)(2)(v) of this chapter (or" and adding in its place "§ 52.38(b)(2)(iii)(A) of this chapter (and";

■ g. Redesignating paragraph (e) as paragraph (f) and adding a new paragraph (e); and

■ h. Revising newly redesignated paragraphs (f)(1) and (2).

The revisions and additions read as follows:

§ 97.826 Banking and conversion.

* * * * *

(d) * * *

(1) * * *

(i) * * *

(C) The full-season CSAPR NO_x Ozone Season Group 3 allowance bank target, computed as the sum for all States listed in § 52.38(b)(2)(iii)(A) of this chapter of the variability limits under § 97.1010(e) for such States for the control period in 2022.

* * * * *

(e) Notwithstanding any other provision of this subpart, part 52 of this chapter, or any SIP revision approved under § 52.38(b)(8) or (9) of this chapter:

(1) By September 18, 2023, the Administrator will temporarily suspend acceptance of CSAPR NO_x Ozone Season Group 2 allowance transfers

submitted under § 97.822 and, before resuming acceptance of such transfers, will take the following actions with regard to every general account and every compliance account except a compliance account for a CSAPR NO_x Ozone Season Group 2 source in a State listed in § 52.38(b)(2)(ii)(A) of this chapter (and Indian country within the borders of such a State):

(i) The Administrator will deduct all CSAPR NO_x Ozone Season Group 2 allowances allocated for the control periods in 2017 through 2022 from each such account.

(ii) The Administrator will determine a conversion factor equal to the greater of 1.0000 or the quotient, expressed to four decimal places, of—

(A) The sum of all CSAPR NO_x Ozone Season Group 2 allowances deducted from all such accounts under paragraph (e)(1)(i) of this section; divided by

(B) The product of the sum of the variability limits for the control period in 2024 under § 97.1010(e) for all States listed in § 52.38(b)(2)(iii)(B) and (C) of this chapter multiplied by a fraction whose numerator is the number of days from August 4, 2023 through September 30, 2023, inclusive, and whose denominator is 153.

(iii) The Administrator will allocate and record in each such account an amount of CSAPR NO_x Ozone Season Group 3 allowances for the control period in 2023 computed as the quotient, rounded up to the nearest allowance, of the number of CSAPR NO_x Ozone Season Group 2 allowances deducted from such account under paragraph (e)(1)(i) of this section divided by the conversion factor determined under paragraph (e)(1)(ii) of this section, except as provided in paragraph (e)(1)(iv) or (v) of this section.

(iv) Where, pursuant to paragraph (e)(1)(i) of this section, the Administrator deducts CSAPR NO_x Ozone Season Group 2 allowances from the compliance account for a source in a State not listed in § 52.38(b)(2)(iii) of this chapter (and Indian country within the borders of such a State), the Administrator will not record CSAPR NO_x Ozone Season Group 3 allowances in that compliance account but instead will allocate and record the amount of CSAPR NO_x Ozone Season Group 3 allowances for the control period in 2023 computed for such source in accordance with paragraph (e)(1)(iii) of this section in a general account identified by the designated representative for such source, provided that if the designated representative fails to identify such a general account in a submission to the Administrator by September 18, 2023, the Administrator

may record such CSAPR NO_x Ozone Season Group 3 allowances in a general account identified or established by the Administrator with the designated representative as the authorized account representative and with the owners and operators of such source (as indicated on the certificate of representation for the source) as the persons represented by the authorized account representative.

(v)(A) In computing any amounts of CSAPR NO_x Ozone Season Group 3 allowances to be allocated to and recorded in general accounts under paragraph (e)(1)(iii) of this section, the Administrator may group multiple general accounts whose ownership interests are held by the same or related persons or entities and treat the group of accounts as a single account for purposes of such computation.

(B) Following a computation for a group of general accounts in accordance with paragraph (e)(1)(v)(A) of this section, the Administrator will allocate to and record in each individual account in such group a proportional share of the quantity of CSAPR NO_x Ozone Season Group 3 allowances computed for such group, basing such shares on the respective quantities of CSAPR NO_x Ozone Season Group 2 allowances removed from such individual accounts under paragraph (e)(1)(i) of this section.

(C) In determining the proportional shares under paragraph (e)(1)(v)(B) of this section, the Administrator may employ any reasonable adjustment methodology to truncate or round each such share up or down to a whole number and to cause the total of such whole numbers to equal the amount of CSAPR NO_x Ozone Season Group 3 allowances computed for such group of accounts in accordance with paragraph (e)(1)(v)(A) of this section, even where such adjustments cause the numbers of CSAPR NO_x Ozone Season Group 3 allowances allocated to some individual accounts to equal zero.

(2) After the Administrator has carried out the procedures set forth in paragraph (e)(1) of this section, upon any determination that would otherwise result in the initial recordation of a given number of CSAPR NO_x Ozone Season Group 2 allowances in the compliance account for a source in a State listed in § 52.38(b)(2)(iii)(B) of this chapter (and Indian country within the borders of such a State), the Administrator will not record such CSAPR NO_x Ozone Season Group 2 allowances but instead will allocate and record in such account an amount of CSAPR NO_x Ozone Season Group 3 allowances for the control period in

2023 computed as the quotient, rounded up to the nearest allowance, of such given number of CSAPR NO_x Ozone Season Group 2 allowances divided by the conversion factor determined under paragraph (e)(1)(ii) of this section.

(f) * * *

(1) After the Administrator has carried out the procedures set forth in paragraph (d)(1) of this section, the owner or operator of a CSAPR NO_x Ozone Season Group 2 source in a State listed in § 52.38(b)(2)(ii)(B) of this chapter (and Indian country within the borders of such a State) may satisfy a requirement to hold a given number of CSAPR NO_x Ozone Season Group 2 allowances for a control period in 2017 through 2020 by holding instead, in a general account established for this sole purpose, an amount of CSAPR NO_x Ozone Season Group 3 allowances for the control period in 2021 (or any later control period for which the allowance transfer deadline defined in § 97.1002 has passed) computed as the quotient, rounded up to the nearest allowance, of such given number of CSAPR NO_x Ozone Season Group 2 allowances divided by the conversion factor determined under paragraph (d)(1)(i)(D) of this section.

(2) After the Administrator has carried out the procedures set forth in paragraph (e)(1) of this section, the owner or operator of a CSAPR NO_x Ozone Season Group 2 source in a State listed in § 52.38(b)(2)(ii)(C) of this chapter (and Indian country within the borders of such a State) may satisfy a requirement to hold a given number of CSAPR NO_x Ozone Season Group 2 allowances for a control period in 2017 through 2022 by holding instead, in a general account established for this sole purpose, an amount of CSAPR NO_x Ozone Season Group 3 allowances for the control period in 2023 (or any later control period for which the allowance transfer deadline defined in § 97.1002 has passed) computed as the quotient, rounded up to the nearest allowance, of such given number of CSAPR NO_x Ozone Season Group 2 allowances divided by the conversion factor determined under paragraph (e)(1)(ii) of this section.

Subpart FFFFF—Texas SO₂ Trading Program

■ 60. Amend § 97.902 by:

■ a. In the definition of “Alternate designated representative”, removing “Program or CSAPR NO_x Ozone Season Group 2 Trading Program, then” and adding in its place “Program, CSAPR NO_x Ozone Season Group 2 Trading

Program, or CSAPR NO_x Ozone Season Group 3 Trading Program, then”;

■ b. In the definition of “CSAPR NO_x Ozone Season Group 2 Trading Program”, removing “(b)(2)(iii) and (iv), and” and adding in its place “(b)(2)(ii), and”;

■ c. Adding in alphabetical order a definition for “CSAPR NO_x Ozone Season Group 3 Trading Program”; and

■ d. In the definition of “Designated representative”, removing “Program or CSAPR NO_x Ozone Season Group 2 Trading Program, then” and adding in its place “Program, CSAPR NO_x Ozone Season Group 2 Trading Program, or CSAPR NO_x Ozone Season Group 3 Trading Program, then”.

The addition reads as follows:

§ 97.902 Definitions.

* * * * *

CSAPR NO_x Ozone Season Group 3 Trading Program means a multi-state NO_x air pollution control and emission reduction program established in accordance with subpart GGGGG of this part and § 52.38(b)(1), (b)(2)(iii), and (b)(10) through (14) and (17) of this chapter (including such a program that is revised in a SIP revision approved by the Administrator under § 52.38(b)(10) or (11) of this chapter or that is established in a SIP revision approved by the Administrator under § 52.38(b)(12) of this chapter), as a means of mitigating interstate transport of ozone and NO_x.

* * * * *

§ 97.934 [Amended]

■ 61. In § 97.934, amend paragraph (d)(3) by removing “Program or CSAPR NO_x Ozone Season Group 2 Trading Program, quarterly” and adding in its place “Program, CSAPR NO_x Ozone Season Group 2 Trading Program, or CSAPR NO_x Ozone Season Group 3 Trading Program, quarterly”.

Subpart GGGGG—CSAPR NO_x Ozone Season Group 3 Trading Program

■ 62. Amend § 97.1002 by:

■ a. Revising the definition of “Allocate or allocation”;

■ b. In the definition of “Allowance transfer deadline”, adding “primary” before “emissions limitation”;

■ c. In the definition of “Alternate designated representative”, removing “or CSAPR SO₂ Group 1 Trading Program, then” and adding in its place “CSAPR SO₂ Group 1 Trading Program, or CSAPR SO₂ Group 2 Trading Program, then”;

■ d. In the definition of “Assurance account”, removing “base CSAPR” and adding in its place “CSAPR”;

■ e. Adding in alphabetical order a definition for “Backstop daily NO_x emissions rate”;

■ f. Removing the definitions for “Base CSAPR NO_x Ozone Season Group 3 source” and “Base CSAPR NO_x Ozone Season Group 3 unit”;

■ g. Adding in alphabetical order a definition for “Coal-derived fuel”;

■ h. In the definition of “Common designated representative”, removing “base CSAPR” and adding in its place “CSAPR”;

■ i. Revising the definition of “Common designated representative’s assurance level”;

■ j. In the definition of “Common designated representative’s share”, removing “base CSAPR” and adding in its place “CSAPR” each time it appears;

■ k. In the definition of “Compliance account”, adding “primary” before “emissions limitation”;

■ l. Adding in alphabetical order a definition for “CSAPR NO_x Ozone Season Group 1 Trading Program”;

■ m. In the definition of “CSAPR NO_x Ozone Season Group 2 Trading Program”, removing “(b)(2)(iii) and (iv), and” and adding in its place “(b)(2)(ii), and”;

■ n. In the definition of “CSAPR NO_x Ozone Season Group 3 allowance”:

■ i. Adding “or (e)” after “§ 97.826(d)”;

and

■ ii. Adding “or less” after “one ton”;

■ o. In the definitions of “CSAPR NO_x Ozone Season Group 3 allowance deduction” and “CSAPR NO_x Ozone Season Group 3 emissions limitation”, adding “primary” before “emissions limitation”;

■ p. Adding in alphabetical order a definition for “CSAPR NO_x Ozone Season Group 3 secondary emissions limitation”;

■ q. In the definition of “CSAPR NO_x Ozone Season Group 3 Trading Program”, removing “(b)(2)(v), and” and adding in its place “(b)(2)(iii), and”;

■ r. Adding in alphabetical order a definition for “CSAPR SO₂ Group 2 Trading Program”;

■ s. In the definition of “Designated representative”, removing “or CSAPR SO₂ Group 1 Trading Program, then”

and adding in its place “CSAPR SO₂ Group 1 Trading Program, or CSAPR SO₂ Group 2 Trading Program, then”.

■ t. In the definition of “Excess emissions”, adding “primary” before “emissions limitation”;

■ u. Adding in alphabetical order a definition for “Historical control period”;

and

■ v. In the definition of “State”, removing “(b)(2)(v), and” and adding in its place “(b)(2)(iii), and”.

The revisions and additions read as follows:

§ 97.1002 Definitions.

* * * * *

Allocate or allocation means, with regard to CSAPR NO_x Ozone Season Group 3 allowances, the determination by the Administrator, State, or permitting authority, in accordance with this subpart, §§ 97.526(d) and 97.826(d) and (e), and any SIP revision submitted by the State and approved by the Administrator under § 52.38(b)(10), (11), or (12) of this chapter, of the amount of such CSAPR NO_x Ozone Season Group 3 allowances to be initially credited, at no cost to the recipient, to:

- (1) A CSAPR NO_x Ozone Season Group 3 unit;
- (2) A new unit set-aside;
- (3) An Indian country new unit set-aside;
- (4) An Indian country existing unit set-aside; or
- (5) An entity not listed in paragraphs (1) through (4) of this definition;
- (6) Provided that, if the Administrator, State, or permitting authority initially credits, to a CSAPR NO_x Ozone Season Group 3 unit qualifying for an initial credit, a credit in the amount of zero CSAPR NO_x Ozone Season Group 3 allowances, the CSAPR NO_x Ozone Season Group 3 unit will be treated as being allocated an amount (*i.e.*, zero) of CSAPR NO_x Ozone Season Group 3 allowances.

* * * * *

Backstop daily NO_x emissions rate means a NO_x emissions rate used in the determination of the CSAPR NO_x Ozone Season Group 3 primary emissions limitation for a CSAPR NO_x Ozone Season Group 3 source in accordance with § 97.1024(b).

* * * * *

Coal-derived fuel means any fuel, whether in a solid, liquid, or gaseous state, produced by the mechanical, thermal, or chemical processing of coal.

* * * * *

Common designated representative's assurance level means, with regard to a specific common designated representative and a State (and Indian country within the borders of such State) and control period in a given year for which the State assurance level is exceeded as described in § 97.1006(c)(2)(iii):

- (1) The amount (rounded to the nearest allowance) equal to the sum of the total amount of CSAPR NO_x Ozone Season Group 3 allowances allocated for such control period to the group of one or more CSAPR NO_x Ozone Season Group 3 units in such State (and such Indian country) having the common designated representative for such control period and the total amount of

CSAPR NO_x Ozone Season Group 3 allowances purchased by an owner or operator of such CSAPR NO_x Ozone Season Group 3 units in an auction for such control period and submitted by the State or the permitting authority to the Administrator for recordation in the compliance accounts for such CSAPR NO_x Ozone Season Group 3 units in accordance with the CSAPR NO_x Ozone Season Group 3 allowance auction provisions in a SIP revision approved by the Administrator under § 52.38(b)(11) or (12) of this chapter, multiplied by the sum of the State NO_x Ozone Season Group 3 trading budget under § 97.1010(a) and the State's variability limit under § 97.1010(e) for such control period, and divided by such State NO_x Ozone Season Group 3 trading budget;

(2) Provided that the allocations of CSAPR NO_x Ozone Season Group 3 allowances for any control period taken into account for purposes of this definition shall exclude any CSAPR NO_x Ozone Season Group 3 allowances allocated for such control period under § 97.526(d) or § 97.826(d) or (e).

* * * * *

CSAPR NO_x Ozone Season Group 1 Trading Program means a multi-state NO_x air pollution control and emission reduction program established in accordance with subpart BBBBB of this part and § 52.38(b)(1), (b)(2)(i), and (b)(3) through (5) and (13) through (15) of this chapter (including such a program that is revised in a SIP revision approved by the Administrator under § 52.38(b)(3) or (4) of this chapter or that is established in a SIP revision approved by the Administrator under § 52.38(b)(5) of this chapter), as a means of mitigating interstate transport of ozone and NO_x.

* * * * *

CSAPR NO_x Ozone Season Group 3 secondary emissions limitation means, for a CSAPR NO_x Ozone Season Group 3 unit to which such a limitation applies under § 97.1025(c)(1) for a control period in a given year, the tonnage of NO_x emissions calculated for the unit in accordance with § 97.1025(c)(2) for such control period.

* * * * *

CSAPR SO₂ Group 2 Trading Program means a multi-state SO₂ air pollution control and emission reduction program established in accordance with subpart DDDDD of this part and § 52.39(a), (c), (g) through (k), and (m) of this chapter (including such a program that is revised in a SIP revision approved by the Administrator under § 52.39(g) or (h) of this chapter or that is established in a SIP revision approved by the Administrator under § 52.39(i) of this chapter), as a means of mitigating

interstate transport of fine particulates and SO₂.

* * * * *

Historical control period means, for a unit as of a given calendar year, the period starting May 1 of a previous calendar year and ending September 30 of that previous calendar year, inclusive, without regard to whether the unit was subject to requirements under the CSAPR NO_x Ozone Season Group 3 Trading Program during such period.

* * * * *

- 63. Amend § 97.1006 by:
 - a. Revising paragraph (b)(2), paragraph (c)(1) heading, paragraph (c)(1)(i), and paragraph (c)(1)(ii) introductory text;
 - b. Adding paragraphs (c)(1)(iii) and (iv);
 - c. In paragraphs (c)(2)(i) introductory text and (c)(2)(i)(B), removing “base CSAPR” and adding in its place “CSAPR” each time it appears;
 - d. Revising paragraph (c)(2)(iii);
 - e. In paragraph (c)(2)(iv), removing “base CSAPR” and adding in its place “CSAPR” each time it appears;
 - f. Revising paragraph (c)(3); and
 - g. In paragraph (c)(6) introductory text, adding “or less” after “one ton”.

The revisions and additions read as follows:

§ 97.1006 Standard requirements.

* * * * *

(b) * * *

(2) The emissions and heat input data determined in accordance with §§ 97.1030 through 97.1035 shall be used to calculate allocations of CSAPR NO_x Ozone Season Group 3 allowances under §§ 97.1011 and 97.1012 and to determine compliance with the CSAPR NO_x Ozone Season Group 3 primary and secondary emissions limitations and assurance provisions under paragraph (c) of this section, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with §§ 97.1030 through 97.1035 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.

(c) * * *

(1) *CSAPR NO_x Ozone Season Group 3 primary and secondary emissions limitations*—(i) *Primary emissions limitation*. As of the allowance transfer deadline for a control period in a given year, the owners and operators of each CSAPR NO_x Ozone Season Group 3 source and each CSAPR NO_x Ozone

Season Group 3 unit at the source shall hold, in the source's compliance account, CSAPR NO_x Ozone Season Group 3 allowances available for deduction for such control period under § 97.1024(a) in an amount not less than the amount determined under § 97.1024(b), comprising the sum of—

(A) The tons of total NO_x emissions for such control period from all CSAPR NO_x Ozone Season Group 3 units at the source; plus

(B) Two times the excess, if any, over 50 tons of the sum, for all CSAPR NO_x Ozone Season Group 3 units at the source and all calendar days of the control period, of any NO_x emissions from such a unit on any calendar day of the control period exceeding the NO_x emissions that would have occurred on that calendar day if the unit had combusted the same daily heat input and emitted at any backstop daily NO_x emissions rate applicable to the unit for that control period.

(ii) *Exceedances of primary emissions limitation.* If total NO_x emissions during a control period in a given year from the CSAPR NO_x Ozone Season Group 3 units at a CSAPR NO_x Ozone Season Group 3 source are in excess of the CSAPR NO_x Ozone Season Group 3 primary emissions limitation set forth in paragraph (c)(1)(i) of this section, then:

* * * * *

(iii) *Secondary emissions limitation.* The owner or operator of a CSAPR NO_x Ozone Season Group 3 unit subject to an emissions limitation under § 97.1025(c)(1) shall not discharge, or allow to be discharged, emissions of NO_x to the atmosphere during a control period in excess of the tonnage amount

calculated in accordance with § 97.1025(c)(2).

(iv) *Exceedances of secondary emissions limitation.* If total NO_x emissions during a control period in a given year from a CSAPR NO_x Ozone Season Group 3 unit are in excess of the amount of a CSAPR NO_x Ozone Season Group 3 secondary emissions limitation applicable to the unit for the control period under paragraph (c)(1)(iii) of this section, then the owners and operators of the unit and the source at which the unit is located shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation of this subpart and the Clean Air Act.

(2) * * *

(iii) Total NO_x emissions from all CSAPR NO_x Ozone Season Group 3 units at CSAPR NO_x Ozone Season Group 3 sources in a State (and Indian country within the borders of such State) during a control period in a given year exceed the State assurance level if such total NO_x emissions exceed the sum, for such control period, of the State NO_x Ozone Season Group 3 trading budget under § 97.1010(a) and the State's variability limit under § 97.1010(e).

* * * * *

(3) *Compliance periods.* (i) A CSAPR NO_x Ozone Season Group 3 unit shall be subject to the requirements under paragraphs (c)(1)(i) and (ii) and (c)(2) of this section for the control period starting on the later of the applicable date in paragraph (c)(3)(i)(A), (B), or (C)

of this section or the deadline for meeting the unit's monitor certification requirements under § 97.1030(b) and for each control period thereafter:

(A) May 1, 2021, for a unit in a State (and Indian country within the borders of such State) listed in § 52.38(b)(2)(iii)(A) of this chapter;

(B) May 1, 2023, for a unit in a State (and Indian country within the borders of such State) listed in § 52.38(b)(2)(iii)(B) of this chapter; or

(C) August 4, 2023, for a unit in a State (and Indian country within the borders of such State) listed in § 52.38(b)(2)(iii)(C) of this chapter.

(ii) A CSAPR NO_x Ozone Season Group 3 unit shall be subject to the requirements under paragraphs (c)(1)(iii) and (iv) of this section for the control period starting on the later of May 1, 2024, or the deadline for meeting the unit's monitor certification requirements under § 97.1030(b) and for each control period thereafter.

* * * * *

■ 64. Revise § 97.1010 to read as follows:

§ 97.1010 State NO_x Ozone Season Group 3 trading budgets, set-asides, and variability limits.

(a) *State NO_x Ozone Season Group 3 trading budgets.* (1)(i) The State NO_x Ozone Season Group 3 trading budgets for allocations of CSAPR NO_x Ozone Season Group 3 allowances for the control periods in 2021 through 2025 shall be as indicated in table 1 to this paragraph (a)(1)(i), subject to prorating for the control period in 2023 as provided in paragraph (a)(1)(ii) of this section:

TABLE 1 TO PARAGRAPH (a)(1)(i)—STATE NO_x OZONE SEASON GROUP 3 TRADING BUDGETS BY CONTROL PERIOD, 2021–2025

[Tons]

State	2021	2022	Portion of 2023 control period before August 4, 2023, before prorating	Portion of 2023 control period on and after August 4, 2023, before prorating	2024	2025
Alabama			13,211	6,379	6,489	6,489
Arkansas			9,210	8,927	8,927	8,927
Illinois	11,223	9,102	8,179	7,474	7,325	7,325
Indiana	17,004	12,582	12,553	12,440	11,413	11,413
Kentucky	17,542	14,051	14,051	13,601	12,999	12,472
Louisiana	16,291	14,818	14,818	9,363	9,363	9,107
Maryland	2,397	1,266	1,266	1,206	1,206	1,206
Michigan	14,384	12,290	9,975	10,727	10,275	10,275
Minnesota				5,504	4,058	4,058
Mississippi			6,315	6,210	5,058	5,037
Missouri			15,780	12,598	11,116	11,116
Nevada				2,368	2,589	2,545
New Jersey	1,565	1,253	1,253	773	773	773
New York	4,079	3,416	3,421	3,912	3,912	3,912
Ohio	13,481	9,773	9,773	9,110	7,929	7,929
Oklahoma			11,641	10,271	9,384	9,376

TABLE 1 TO PARAGRAPH (a)(1)(i)—STATE NO_x OZONE SEASON GROUP 3 TRADING BUDGETS BY CONTROL PERIOD, 2021–2025—Continued
[Tons]

State	2021	2022	Portion of 2023 control period before August 4, 2023, before prorating	Portion of 2023 control period on and after August 4, 2023, before prorating	2024	2025
Pennsylvania	12,071	8,373	8,373	8,138	8,138	8,138
Texas			52,301	40,134	40,134	38,542
Utah				15,755	15,917	15,917
Virginia	6,331	3,897	3,980	3,143	2,756	2,756
West Virginia	15,062	12,884	12,884	13,791	11,958	11,958
Wisconsin			7,915	6,295	6,295	5,988

(ii) For the control period in 2023, the State NO_x Ozone Season Group 3 trading budget for each State shall be calculated as the sum, rounded to the nearest allowance, of the following prorated amounts:

(A) The product of the non-prorated trading budget for the portion of the 2023 control period before August 4, 2023, shown for the State in table 1 to paragraph (a)(1)(i) of this section (or zero if table 1 to paragraph (a)(1)(i) shows no amount for such portion of the

2023 control period for the State) multiplied by a fraction whose numerator is the number of days from May 1, 2023, through the day before August 4, 2023, inclusive, and whose denominator is 153; plus

(B) The product of the non-prorated trading budget for the portion of the 2023 control period on and after August 4, 2023, shown for the State in table 1 to paragraph (a)(1)(i) of this section multiplied by a fraction whose numerator is the number of days from

August 4, 2023, through September 30, 2023, inclusive, and whose denominator is 153.

(2)(i) The State NO_x Ozone Season Group 3 trading budget for each State and each control period in 2026 through 2029 shall be the preset trading budget indicated for the State and control period in table 2 to this paragraph (a)(2)(i), except as provided in paragraph (a)(2)(ii) of this section.

TABLE 2 TO PARAGRAPH (a)(2)(i)—PRESET TRADING BUDGETS BY CONTROL PERIOD, 2026–2029
[Tons]

State	2026	2027	2028	2029
Alabama	6,339	6,236	6,236	5,105
Arkansas	6,365	4,031	4,031	3,582
Illinois	5,889	5,363	4,555	4,050
Indiana	8,363	8,135	7,280	5,808
Kentucky	9,697	7,908	7,837	7,392
Louisiana	6,370	3,792	3,792	3,639
Maryland	842	842	842	842
Michigan	6,743	5,691	5,691	4,656
Minnesota	4,058	2,905	2,905	2,578
Mississippi	3,484	2,084	1,752	1,752
Missouri	9,248	7,329	7,329	7,329
Nevada	1,142	1,113	1,113	880
New Jersey	773	773	773	773
New York	3,650	3,388	3,388	3,388
Ohio	7,929	7,929	6,911	6,409
Oklahoma	6,631	3,917	3,917	3,917
Pennsylvania	7,512	7,158	7,158	4,828
Texas	31,123	23,009	21,623	20,635
Utah	6,258	2,593	2,593	2,593
Virginia	2,565	2,373	2,373	1,951
West Virginia	10,818	9,678	9,678	9,678
Wisconsin	4,990	3,416	3,416	3,416

(ii) If the preset trading budget indicated for a given State and control period in table 2 to paragraph (a)(2)(i) of this section is less than the dynamic trading budget for the State and control period referenced in the applicable notice promulgated under paragraph (a)(4)(v)(C) of this section, then the State NO_x Ozone Season Group 3 trading

budget for the State and control period shall be the dynamic trading budget for the State and control period referenced in the applicable notice promulgated under paragraph (a)(4)(v)(C) of this section.

(3) The State NO_x Ozone Season Group 3 trading budget for each State and each control period in 2030 and

thereafter shall be the dynamic trading budget for the State and control period referenced in the applicable notice promulgated under paragraph (a)(4)(v)(C) of this section.

(4) The Administrator will calculate the dynamic trading budget for each State and each control period in 2026

and thereafter in the year before the year of the control period as follows:

(i) The Administrator will include a unit in a State (and Indian country within the borders of the State) in the calculation of the State's dynamic trading budget for a control period if—

(A) To the best of the Administrator's knowledge, the unit qualifies as a CSAPR NO_x Ozone Season Group 3 unit under § 97.1004, without regard to whether the unit has permanently retired, provided that including a unit in the calculation of a dynamic trading budget does not constitute a determination that the unit is a CSAPR NO_x Ozone Season Group 3 unit, and not including a unit in the calculation of a dynamic trading budget does not constitute a determination that the unit is not a CSAPR NO_x Ozone Season Group 3 unit;

(B) The unit's deadline for certification of monitoring systems under § 97.1030(b) is on or before May 1 of the year two years before the year of the control period for which the dynamic trading budget is being calculated; and

(C) The owner or operator reported heat input greater than zero for the unit in accordance with part 75 of this chapter for the historical control period in the year two years before the year of the control period for which the dynamic trading budget is being calculated.

(ii) For each unit identified for inclusion in the calculation of the State's dynamic trading budget for a control period under paragraph (a)(4)(i) of this section, the Administrator will calculate the heat input amount in mmBtu to be used in the budget calculation as follows:

(A) For each such unit, the Administrator will determine the following unit-level amounts:

(1) The total heat input amounts reported in accordance with part 75 of this chapter for the unit for the historical control periods in the years two, three, four, five, and six years before the year of the control period for which the dynamic trading budget is being calculated, except any historical control period that commenced before the unit's first deadline under any regulatory program to begin recording and reporting heat input in accordance with part 75 of this chapter; and

(2) The average of the three highest unit-level total heat input amounts identified for the unit under paragraph (a)(4)(iv)(A)(1) of this section or, if fewer than three non-zero amounts are identified for the unit, the average of all such non-zero total heat input amounts.

(B) For the State, the Administrator will determine the following state-level amounts:

(1) The sum for all units in the State meeting the criterion under paragraph (a)(4)(i)(A) of this section, without regard to whether such units also meet the criteria under paragraphs (a)(4)(i)(B) and (C) of this section, of the total heat input amounts reported in accordance with part 75 of this chapter for the historical control periods in the years two, three, and four years before the year of the control period for which the dynamic trading budget is being calculated, provided that for the historical control periods in 2022 and 2023, the total reported heat input amounts for Nevada and Utah as otherwise determined under this paragraph (a)(4)(ii)(B)(1) shall be increased by 13,489,332 mmBtu for Nevada and by 1,888,174 mmBtu for Utah;

(2) The average of the three state-level total heat input amounts calculated for the State under paragraph (a)(4)(ii)(B)(1) of this section; and

(3) The sum for all units identified for inclusion in the calculation of the State's dynamic trading budget for the control period under paragraph (a)(4)(i) of this section of the unit-level average heat input amounts calculated under paragraph (a)(4)(ii)(A)(2) of this section.

(C) The heat input amount for a unit used in the calculation of the State's dynamic trading budget shall be the product of the unit-level average total heat input amount calculated for the unit under paragraph (a)(4)(ii)(A)(2) of this section multiplied by a fraction whose numerator is the state-level average total heat input amount calculated under paragraph (a)(4)(ii)(B)(2) of this section and whose denominator is the state-level sum of the unit-level average heat input amounts calculated under paragraph (a)(4)(ii)(B)(3) of this section.

(iii) For each unit identified for inclusion in the calculation of the State's dynamic trading budget for a control period under paragraph (a)(4)(i) of this section, the Administrator will identify the NO_x emissions rate in lb/mmBtu to be used in the calculation as follows:

(A) For a unit listed in the document entitled "Unit-Specific Ozone Season NO_x Emissions Rates for Dynamic Budget Calculations" posted at www.regulations.gov in docket EPA-HQ-OAR-2021-0668, the NO_x emissions rate used in the calculation for the control period shall be the NO_x emissions rate shown for the unit and control period in that document.

(B) For a unit not listed in the document referenced in paragraph (a)(4)(iii)(A) of this section, the NO_x emissions rate used in the calculation for the control period shall be identified according to the type of unit and the type of fuel combusted by the unit during the control period beginning May 1 on or immediately after the unit's deadline for certification of monitoring systems under § 97.1030(b) as follows:

(1) 0.011 lb/mmBtu, for a simple cycle combustion turbine or a combined cycle combustion turbine other than an integrated coal gasification combined cycle unit;

(2) 0.030 lb/mmBtu, for a boiler combusting only fuel oil or gaseous fuel (other than coal-derived fuel) during such control period; or

(3) 0.050 lb/mmBtu, for a boiler combusting any amount of coal or coal-derived fuel during such control period or any other unit not covered by paragraph (a)(4)(iii)(B)(1) or (2) of this section.

(iv) The Administrator will calculate the State's dynamic trading budget for the control period as the sum (converted to tons at a conversion factor of 2,000 lb/ton and rounded to the nearest ton), for all units identified for inclusion in the calculation under paragraph (a)(4)(i) of this section, of the product for each such unit of the heat input amount in mmBtu calculated for the unit under paragraph (a)(4)(ii) of this section multiplied by the NO_x emissions rate in lb/mmBtu identified for the unit under paragraph (a)(4)(iii) of this section.

(v)(A) By March 1, 2025 and March 1 of each year thereafter, the Administrator will calculate the dynamic trading budget for each State, in accordance with paragraphs (a)(4)(i) through (iv) of this section and §§ 97.1006(b)(2) and 97.1030 through 97.1035, for the control period in the year after the year of the applicable calculation deadline under this paragraph (a)(4)(v)(A) and will promulgate a notice of data availability of the results of the calculations.

(B) For each notice of data availability required in paragraph (a)(4)(v)(A) of this section, the Administrator will provide an opportunity for submission of objections to the calculations referenced in such notice. Objections shall be submitted by the deadline specified in such notice and shall be limited to addressing whether the calculations (including the identification of the units included in the calculations) are in accordance with the provisions referenced in paragraph (a)(4)(v)(A) of this section.

(C) The Administrator will adjust the calculations to the extent necessary to

ensure that they are in accordance with the provisions referenced in paragraph (a)(4)(v)(A) of this section. By May 1 immediately after the promulgation of each notice of data availability required in paragraph (a)(4)(v)(A) of this section, the Administrator will promulgate a notice of data availability of the results of the calculations incorporating any adjustments that the Administrator determines to be necessary and the reasons for accepting or rejecting any objections submitted in accordance with paragraph (a)(4)(v)(B) of this section.

(b) *Indian country existing unit set-asides for the control periods in 2023 and thereafter.* The Indian country existing unit set-aside for allocations of CSAPR NO_x Ozone Season Group 3 allowances for each State for each control period in 2023 and thereafter shall be calculated as the sum of all allowance allocations to units in areas of Indian country within the borders of the State not subject to the State's SIP authority as provided in the applicable notice of data availability for the control period referenced in § 97.1011(a)(2).

(c) *New unit set-asides.* (1) The new unit set-asides for allocations of CSAPR NO_x Ozone Season Group 3 allowances for the control periods in 2021 and 2022 for each State with CSAPR NO_x Ozone Season Group 3 trading budgets for such control periods shall be as indicated in table 3 to this paragraph (c)(1):

TABLE 3 TO PARAGRAPH (c)(1)—NEW UNIT SET-ASIDES BY CONTROL PERIOD [2021–2022 (tons)]

State	2021	2022
Illinois	265	265
Indiana	262	254
Kentucky	309	283
Louisiana	430	430
Maryland	135	115
Michigan	500	482
New Jersey	27	27
New York	168	168
Ohio	291	290
Pennsylvania	335	339
Virginia	185	161
West Virginia	266	261

(2) The new unit set-aside for allocations of CSAPR NO_x Ozone Season Group 3 allowances for each State for each control period in 2023 and thereafter shall be calculated as the product (rounded to the nearest allowance) of the State NO_x Ozone Season Group 3 trading budget for the State and control period established in

accordance with paragraph (a) of this section multiplied by—

- (i) 0.09, for Nevada for the control periods in 2023 through 2025;
- (ii) 0.06, for Ohio for the control periods in 2023 through 2025;
- (iii) 0.05, for each State other than Nevada and Ohio for the control periods in 2023 through 2025; or
- (iv) 0.05, for each State for each control period in 2026 and thereafter.

(d) *Indian country new unit set-asides for the control periods in 2021 and 2022.* The Indian country new unit set-asides for allocations of CSAPR NO_x Ozone Season Group 3 allowances for the control periods in 2021 and 2022 for each State with CSAPR NO_x Ozone Season Group 3 trading budgets for such control periods shall be as indicated in table 4 to this paragraph (d):

TABLE 4 TO PARAGRAPH (d)—INDIAN COUNTRY NEW UNIT SET-ASIDES BY CONTROL PERIOD [2021–2022 (tons)]

State	2021	2022
Illinois
Indiana
Kentucky
Louisiana	15	15
Maryland
Michigan	13	12
New Jersey
New York	3	3
Ohio
Pennsylvania
Virginia
West Virginia

(e) *Variability limits.* (1) The variability limits for the State NO_x Ozone Season Group 3 trading budgets for the control periods in 2021 and 2022 for each State with such trading budgets for such control periods shall be as indicated in table 5 to this paragraph (e)(1).

TABLE 5 TO PARAGRAPH (e)(1)—VARIABILITY LIMITS BY CONTROL PERIOD [2021–2022 (tons)]

State	2021	2022
Illinois	2,356	1,911
Indiana	3,571	2,642
Kentucky	3,684	2,951
Louisiana	3,421	3,112
Maryland	504	266
Michigan	3,021	2,581
New Jersey	329	263
New York	856	717

TABLE 5 TO PARAGRAPH (e)(1)—VARIABILITY LIMITS BY CONTROL PERIOD—Continued [2021–2022 (tons)]

State	2021	2022
Ohio	2,831	2,052
Pennsylvania	2,535	1,758
Virginia	1,329	818
West Virginia	3,163	2,706

(2) The variability limit for the State NO_x Ozone Season Group 3 trading budget for each State for each control period in 2023 and thereafter shall be calculated as the product (rounded to the nearest ton) of the State NO_x Ozone Season Group 3 trading budget for the State and control period established in accordance with paragraph (a) of this section multiplied by the greater of—

- (i) 0.21; or
- (ii) Any excess over 1.00 of the quotient (rounded to two decimal places) of—

(A) The sum for all CSAPR NO_x Ozone Season Group 3 units in the State and Indian country within the borders of the State of the total heat input reported for the control period in mmBtu, provided that, for purposes of this paragraph (e)(2)(ii)(A), the 2023 control period for all States shall be deemed to be the period from May 1, 2023 through September 30, 2023, inclusive; divided by

(B) The state-level total heat input amount used in the calculation of the State NO_x Ozone Season Group 3 trading budget for the State and control period in mmBtu, as identified in accordance with paragraph (e)(3) of this section.

(3) For purposes of paragraph (e)(2)(ii)(B) of this section, the state-level total heat input amount used in the calculation of a State NO_x Ozone Season Group 3 trading budget for a given control period shall be identified as follows:

- (i) For a control period in 2023 through 2025, and for a control period in 2026 through 2029 if the State NO_x Ozone Season Group 3 trading budget for the State and control period under paragraph (a)(2) of this section is the preset trading budget set forth for the State and control period in table 2 to paragraph (a)(2)(i) of this section, the state-level total heat input amounts shall be as indicated in table 6 to this paragraph (e)(3)(i).

TABLE 6 TO PARAGRAPH (e)(3)(i)—STATE-LEVEL TOTAL HEAT INPUT USED IN CALCULATIONS OF PRESET TRADING BUDGETS BY CONTROL PERIOD [2023–2029 (mmBtu)]

State	2023	2024	2025	2026	2027	2028	2029
Alabama	313,037,541	333,030,691	333,030,691	330,396,046	328,650,653	328,650,653	307,987,882
Arkansas	192,843,561	192,843,561	192,843,561	190,921,052	190,921,052	190,921,052	190,921,052
Illinois	274,005,935	286,568,112	286,568,112	253,219,463	253,219,463	214,086,655	193,900,867
Indiana	356,047,916	330,175,944	330,175,944	302,245,332	302,245,332	277,218,546	236,611,101
Kentucky	301,161,750	301,161,750	295,857,697	295,857,697	295,857,697	293,016,485	274,595,978
Louisiana	280,592,592	280,592,592	278,766,253	278,461,807	277,262,840	277,262,840	277,262,840
Maryland	70,725,007	70,725,007	70,725,007	70,725,007	70,725,007	70,725,007	70,725,007
Michigan	313,846,533	299,124,688	299,124,688	258,225,107	258,225,107	258,225,107	222,314,181
Minnesota	128,893,685	107,821,236	107,821,236	107,821,236	93,890,928	93,890,928	85,707,385
Mississippi	192,978,295	189,415,018	189,279,160	189,279,160	189,279,160	176,004,820	176,004,820
Missouri	284,308,851	249,153,661	249,153,661	249,153,661	248,413,545	248,413,545	248,413,545
Nevada	103,489,785	116,979,117	114,729,782	105,018,415	100,193,805	100,193,805	96,378,269
New Jersey	112,233,231	112,233,231	112,233,231	112,233,231	112,233,231	112,233,231	112,233,231
New York	242,853,661	242,853,661	242,853,661	242,853,661	242,853,661	242,853,661	242,853,661
Ohio	412,292,609	386,560,212	386,560,212	386,560,212	386,560,212	358,992,155	342,075,946
Oklahoma	212,903,386	211,187,283	211,165,691	211,145,820	196,160,642	196,160,642	196,160,642
Pennsylvania	550,993,363	550,993,363	550,993,363	550,993,363	550,993,363	550,993,363	487,590,728
Texas	1,395,116,925	1,395,116,925	1,389,251,813	1,389,251,813	1,356,192,532	1,320,040,162	1,280,014,875
Utah	164,519,648	166,407,822	166,407,822	127,217,396	127,217,396	127,217,396	127,217,396
Virginia	202,953,791	194,015,719	194,015,719	194,015,719	194,015,719	194,015,719	186,848,587
West Virginia	306,845,495	273,151,957	273,151,957	273,151,957	273,151,957	273,151,957	273,151,957
Wisconsin	220,794,282	220,792,155	213,038,308	185,469,476	151,343,287	151,343,287	151,343,287

(ii) For a control period in 2026 through 2029 if the State NO_x Ozone Season Group 3 trading budget for the State and control period under paragraph (a)(2) of this section is the dynamic trading budget for the State and control period referenced in the applicable notice promulgated under paragraph (a)(4)(v)(C) of this section, and for a control period in 2030 and thereafter, the state-level total heat input amount shall be the amount for the State and control period calculated under paragraph (a)(4)(ii)(B)(2) of this section.

(f) *Relationship of trading budgets, set-asides, and variability limits.* Each State NO_x Ozone Season Group 3 trading budget in this section includes any tons in an Indian country existing unit set-aside, a new unit set-aside, or an Indian country new unit set-aside but does not include any tons in a variability limit.

■ 65. Amend § 97.1011 by revising the section heading and paragraphs (a), (b), paragraph (c) heading, and paragraphs (c)(1) and (5) to read as follows:

§ 97.1011 CSAPR NO_x Ozone Season Group 3 allowance allocations to existing units.

(a) *Allocations to existing units in general.* (1) For the control periods in 2021 and each year thereafter, CSAPR NO_x Ozone Season Group 3 allowances will be allocated to units in each State and areas of Indian country within the borders of the State subject to the State’s SIP authority as provided in notices of data availability issued by the Administrator. Starting with the control period in 2026, the notices of data availability will be the notices issued

under paragraph (b)(11)(iii) of this section.

(2) For the control periods in 2023 and each year thereafter, CSAPR NO_x Ozone Season Group 3 allowances will be allocated to units in areas of Indian country within the borders of each State not subject to the State’s SIP authority as provided in notices of data availability issued by the Administrator. Starting with the control period in 2026, the notices of data availability will be the notices issued under paragraph (b)(11)(iii) of this section.

(3) Providing an allocation to a unit in a notice of data availability does not constitute a determination that the unit is a CSAPR NO_x Ozone Season Group 3 unit, and not providing an allocation to a unit in such notice does not constitute a determination that the unit is not a CSAPR NO_x Ozone Season Group 3 unit.

(b) *Calculation of default allocations to existing units for control periods in 2026 and thereafter.* For each control period in 2026 and thereafter, and for the CSAPR NO_x Ozone Season Group 3 units in each State and areas of Indian country within the borders of the State, the Administrator will calculate default allocations of CSAPR NO_x Ozone Season Group 3 allowances to the CSAPR NO_x Ozone Season Group 3 units as follows:

(1) For each State and control period, the total amount of CSAPR NO_x Ozone Season Group 3 allowances for which the Administrator will calculate default allocations shall be the remainder of the State NO_x Ozone Season Group 3 trading budget for the control period under § 97.1010(a) minus the new unit

set-aside for the control period under § 97.1010(c).

(2) The Administrator will calculate a default allocation of CSAPR NO_x Ozone Season Group 3 allowances for each CSAPR NO_x Ozone Season Group 3 unit in the State and Indian country within the borders of the State meeting the following criteria:

(i) To the best of the Administrator’s knowledge, the unit qualifies as a CSAPR NO_x Ozone Season Group 3 unit under § 97.1004, without regard to whether the unit has permanently retired;

(ii) The unit’s deadline for certification of monitoring systems under § 97.1030(b) is on or before May 1 of the year two years before the year of the control period for which the allowances are being allocated; and

(iii) The owner or operator reported heat input greater than zero for the unit in accordance with part 75 of this chapter for the historical control period in the year two years before the year of the control period for which the allowances are being allocated.

(3) For each CSAPR NO_x Ozone Season Group 3 unit for which a default allocation is being calculated for a control period, the Administrator will calculate an average heat input amount to be used in the allocation calculations as follows:

(i) The Administrator will identify the total heat input amounts reported for the unit in accordance with part 75 of this chapter for the historical control periods in the years two, three, four, five, and six years before the year of the control period for which the allowances are being allocated, except any

historical control period that commenced before the unit's first deadline under any regulatory program to begin recording and reporting heat input in accordance with part 75 of this chapter.

(ii) The average heat input amount used in the allocation calculations shall be the average of the three highest total heat input amounts identified for the unit under paragraph (b)(3)(i) of this section or, if fewer than three non-zero amounts are identified for the unit, the average of all such non-zero total heat input amounts.

(4) For each CSAPR NO_x Ozone Season Group 3 unit for which a default allocation is being calculated for a control period, the Administrator will calculate a tentative maximum allocation amount to be used in the allocation calculations as follows:

(i) The Administrator will identify the total NO_x emissions amounts reported for the unit in accordance with part 75 of this chapter for the historical control periods in the years two, three, four, five, and six years before the year of the control period for which the allowances are being allocated.

(ii) The tentative maximum allocation amount used in the allocation calculations shall be the highest of the total NO_x emissions amounts identified for the unit under paragraph (b)(4)(i) of this section or, if less, any applicable amount calculated under paragraph (b)(4)(iii) of this section.

(iii)(A) The tentative maximum allocation amount under paragraph (b)(4)(ii) of this section for a unit described in paragraph (b)(4)(iii)(B) or (C) of this section may not exceed a maximum controlled baseline calculated as the product (converted to tons at a conversion factor of 2,000 lb/ton and rounded to the nearest ton) of the highest total heat input amount identified for the unit under paragraph (b)(3)(i) of this section in mmBtu multiplied by a NO_x emissions rate of 0.08 lb/mmBtu.

(B) For the control period in 2026, a maximum controlled baseline under paragraph (b)(4)(iii)(A) of this section shall apply to any unit that combusted any coal or solid coal-derived fuel during the historical control period for which the unit's heat input was most recently reported, that serves a generator with nameplate capacity of 100 MW or more, and that is equipped with selective catalytic reduction controls, except a circulating fluidized bed boiler.

(C) For each control period in 2027 and thereafter, a maximum controlled baseline under paragraph (b)(4)(iii)(A) of this section shall apply to any unit that combusted any coal or solid coal-

derived fuel during the historical control period for which the unit's heat input was most recently reported and that serves a generator with nameplate capacity of 100 MW or more, except a circulating fluidized bed boiler.

(5) The Administrator will calculate the initial unrounded default allocations for each CSAPR NO_x Ozone Season Group 3 unit according to the procedure in paragraph (b)(6) of this section and will recalculate the unrounded default allocations according to the procedures in paragraph (b)(7) or (8) of this section, as applicable, iterating the recalculations as necessary until the total of the unrounded default allocations to all eligible units equals the amount of allowances determined for the State under paragraph (b)(1) of this section.

(6) The Administrator will calculate the initial unrounded default allocations to CSAPR NO_x Ozone Season Group 3 units as follows:

(i) The Administrator will calculate the sum, for all units determined under paragraph (b)(2) of this section to be eligible to receive default allocations, of the units' average heat input amounts determined under paragraph (b)(3)(ii) of this section.

(ii) For each unit determined under paragraph (b)(2) of this section to be eligible to receive a default allocation, the Administrator will calculate the unit's unrounded default allocation as the lesser of—

(A) The product of the total amount of allowances determined for the State and control period under paragraph (b)(1) of this section multiplied by a fraction whose numerator is the unit's average heat input amount determined under paragraph (b)(3)(ii) of this section and whose denominator is the sum determined under paragraph (b)(6)(i) of this section; and

(B) The unit's tentative maximum allocation amount determined under paragraph (b)(4)(ii) of this section.

(iii) If the sum of the unrounded default allocations determined under paragraph (b)(6)(ii) of this section is less than the total amount of allowances determined for the State and control period under paragraph (b)(1) of this section, the Administrator will follow the procedures in paragraph (b)(7) or (8) of this section, as applicable.

(iv) If the sum of the unrounded default allocations determined under paragraph (b)(6)(ii) of this section equals the total amount of allowances determined for the State and control period under paragraph (b)(1) of this section, the Administrator will determine the rounded default allocations according to the procedures

in paragraphs (b)(9) and (10) of this section.

(7) If the unrounded default allocation determined in the previous round of the calculation procedure for at least one CSAPR NO_x Ozone Season Group 3 unit is less than the unit's tentative maximum allocation amount determined under paragraph (b)(4)(ii) of this section, the Administrator will recalculate the unrounded default allocations as follows:

(i) The Administrator will calculate the additional pool of allowances to be allocated as the remainder of the total amount of allowances determined for the State and control period under paragraph (b)(1) of this section minus the sum of the unrounded default allocations from the previous round of the calculation procedure for all units determined under paragraph (b)(2) of this section to be eligible to receive default allocations.

(ii) The Administrator will calculate the sum, for all units whose unrounded default allocations determined in the previous round of the calculation procedure were less than the respective units' tentative maximum allocation amounts determined under paragraph (b)(4)(ii) of this section, of the units' average heat input amounts determined under paragraph (b)(3)(ii) of this section.

(iii) For each unit whose unrounded default allocation determined in the previous round of the calculation procedure was less than the unit's tentative maximum allocation amount determined under paragraph (b)(4)(ii) of this section, the Administrator will recalculate the unit's unrounded default allocation as the lesser of—

(A) The sum of the unit's unrounded default allocation determined in the previous round of the calculation procedure plus the product of the additional pool of allowances determined under paragraph (b)(7)(i) of this section multiplied by a fraction whose numerator is the unit's average heat input amount determined under paragraph (b)(3)(ii) of this section and whose denominator is the sum determined under paragraph (b)(7)(ii) of this section; and

(B) The unit's tentative maximum allocation amount determined under paragraph (b)(4)(ii) of this section.

(iv) Except as provided in paragraph (b)(7)(iii) of this section, a unit's unrounded default allocation shall equal the amount determined in the previous round of the calculation procedure.

(v) If the sum of the unrounded default allocations determined under paragraphs (b)(7)(iii) and (iv) of this section is less than the total amount of

allowances determined for the State and control period under paragraph (b)(1) of this section, the Administrator will iterate the procedures in paragraph (b)(7) of this section or follow the procedures in paragraph (b)(8) of this section, as applicable.

(vi) If the sum of the unrounded default allocations determined under paragraphs (b)(7)(iii) and (iv) of this section equals the total amount of allowances determined for the State and control period under paragraph (b)(1) of this section, the Administrator will determine the rounded default allocations according to the procedures in paragraphs (b)(9) and (10) of this section.

(8) If the unrounded default allocation determined in the previous round of the calculation procedure for every CSAPR NO_x Ozone Season Group 3 unit equals the unit's tentative maximum allocation amount determined under paragraph (b)(4)(ii) of this section, the Administrator will recalculate the unrounded default allocations as follows:

(i) The Administrator will calculate the additional pool of allowances to be allocated as the remainder of the total amount of allowances determined for the State and control period under paragraph (b)(1) of this section minus the sum of the unrounded default allocations from the previous round of the calculation procedure for all units determined under paragraph (b)(2) of this section to be eligible to receive default allocations.

(ii) The Administrator will recalculate the unrounded default allocation for each eligible unit as the sum of—

(A) The unit's unrounded default allocation as determined in the previous round of the calculation procedure; plus

(B) The product of the additional pool of allowances determined under paragraph (b)(8)(i) of this section multiplied by a fraction whose numerator is the unit's average heat input amount determined under paragraph (b)(3)(ii) of this section and whose denominator is the sum determined under paragraph (b)(6)(i) of this section.

(9) The Administrator will round the default allocation for each eligible unit determined under paragraph (b)(6), (7), or (8) of this section to the nearest allowance and make any adjustments required under paragraph (b)(10) of this section.

(10) If the sum of the default allocations after rounding under paragraph (b)(9) of this section does not equal the total amount of allowances determined for the State and control period under paragraph (b)(1) of this

section, the Administrator will adjust the default allocations as follows. The Administrator will list the CSAPR NO_x Ozone Season Group 3 units in descending order based on such units' allocation amounts under paragraph (b)(9) of this section and, in cases of equal allocation amounts, in alphabetical order of the relevant sources' names and numerical order of the relevant units' identification numbers, and will adjust each unit's allocation amount upward or downward by one CSAPR NO_x Ozone Season Group 3 allowance (but not below zero) in the order in which the units are listed, and will repeat this adjustment process as necessary, until the total of the adjusted default allocations equals the total amount of allowances determined for the State and control period under paragraph (b)(1) of this section.

(11)(i) By March 1, 2025 and March 1 of each year thereafter, the Administrator will calculate the default allocation of CSAPR NO_x Ozone Season Group 3 allowances to each CSAPR NO_x Ozone Season Group 3 unit in a State and Indian country within the borders of the State, in accordance with paragraphs (b)(1) through (10) of this section and §§ 97.1006(b)(2) and 97.1030 through 97.1035, for the control period in the year after the year of the applicable calculation deadline under this paragraph (b)(11)(i) and will promulgate a notice of data availability of the results of the calculations.

(ii) For each notice of data availability required in paragraph (b)(11)(i) of this section, the Administrator will provide an opportunity for submission of objections to the calculations referenced in such notice. Objections shall be submitted by the deadline specified in such notice and shall be limited to addressing whether the calculations (including the identification of the CSAPR NO_x Ozone Season Group 3 units) are in accordance with the provisions referenced in paragraph (b)(11)(i) of this section.

(iii) The Administrator will adjust the calculations to the extent necessary to ensure that they are in accordance with the provisions referenced in paragraph (b)(11)(i) of this section. By May 1 immediately after the promulgation of each notice of data availability required in paragraph (b)(11)(i) of this section, the Administrator will promulgate a notice of data availability of the results of the calculations incorporating any adjustments that the Administrator determines to be necessary and the reasons for accepting or rejecting any objections submitted in accordance with paragraph (b)(11)(ii) of this section.

(c) *Incorrect allocations of CSAPR NO_x Ozone Season Group 3 allowances to existing units.* (1) For each control period in 2021 and thereafter, if the Administrator determines that CSAPR NO_x Ozone Season Group 3 allowances were allocated for the control period to a recipient covered by the provisions of paragraph (c)(1)(i), (ii), or (iii) of this section, then the Administrator will notify the designated representative of the recipient and will act in accordance with the procedures set forth in paragraphs (c)(2) through (5) of this section:

(i) The recipient is not actually a CSAPR NO_x Ozone Season Group 3 unit under § 97.1004 as of the first day of the control period and is allocated CSAPR NO_x Ozone Season Group 3 allowances for such control period under paragraph (a)(1) or (2) of this section;

(ii) The recipient is not actually a CSAPR NO_x Ozone Season Group 3 unit under § 97.1004 as of the first day of the control period and is allocated CSAPR NO_x Ozone Season Group 3 allowances for such control period under a provision of a SIP revision approved under § 52.38(b)(10), (11), or (12) of this chapter that the SIP revision provides should be allocated only to recipients that are CSAPR NO_x Ozone Season Group 3 units as of the first day of such control period; or

(iii) The recipient is not located as of the first day of the control period in the State (and Indian country within the borders of the State) from whose NO_x Ozone Season Group 3 trading budget CSAPR NO_x Ozone Season Group 3 allowances were allocated to the recipient for such control period under paragraph (a)(1) or (2) of this section or under a provision of a SIP revision approved under § 52.38(b)(10), (11), or (12) of this chapter.

* * * * *

(5) With regard to any CSAPR NO_x Ozone Season Group 3 allowances that are not recorded, or that are deducted as an incorrect allocation, in accordance with paragraphs (c)(2) and (3) of this section:

(i) If the non-recording decision under paragraph (c)(2) of this section or the deduction under paragraph (c)(3) of this section occurs on or before May 1, 2024, the Administrator will transfer the CSAPR NO_x Ozone Season Group 3 allowances to the new unit set-aside for 2021, 2022, or 2023 for the State from whose NO_x Ozone Season Group 3 trading budget the CSAPR NO_x Ozone Season Group 3 allowances were allocated.

(ii) If the non-recording decision under paragraph (c)(2) of this section or

the deduction under paragraph (c)(3) of this section occurs after May 1, 2024, and on or before May 1 of the year following the year of the control period for which the CSAPR NO_x Ozone Season Group 3 allowances were allocated, the Administrator will transfer the CSAPR NO_x Ozone Season Group 3 allowances to the new unit set-aside for such control period for the State from whose NO_x Ozone Season Group 3 trading budget the CSAPR NO_x Ozone Season Group 3 allowances were allocated.

(iii) If the non-recording decision under paragraph (c)(2) of this section or the deduction under paragraph (c)(3) of this section occurs after May 1, 2024, and after May 1 of the year following the year of the control period for which the CSAPR NO_x Ozone Season Group 3 allowances were allocated, the Administrator will transfer the CSAPR NO_x Ozone Season Group 3 allowances to a surrender account.

■ 66. Amend § 97.1012 by:

■ a. Revising paragraphs (a)

introductory text and (a)(1)(i) and (ii);

■ b. Removing paragraphs (a)(1)(iii) and (iv);

■ c. Revising paragraphs (a)(2) and (a)(3)(i);

■ d. In paragraph (a)(3)(ii), adding “and” after the semicolon;

■ e. Revising paragraph (a)(3)(iii);

■ f. Removing paragraph (a)(3)(iv);

■ g. Revising paragraph (a)(4)(i);

■ h. Redesignating paragraph (a)(4)(ii) as paragraph (a)(4)(iii) and adding a new paragraph (a)(4)(ii);

■ i. Revising paragraphs (a)(5) and (10);

■ j. In paragraph (a)(11), removing “§ 97.1011(b)(1)(i), (ii), and (v), of” and adding in its place “paragraph (a)(13) of this section, of”;

■ k. Adding paragraph (a)(13);

■ l. Revising paragraphs (b) introductory text and (b)(1) and (2);

■ m. In paragraph (b)(5), removing “Indian country within the borders of the State” and adding in its place “areas of Indian country within the borders of the State not subject to the State’s SIP authority”;

■ n. Revising paragraph (b)(10);

■ o. In paragraph (b)(11), removing “§ 97.1011(b)(2)(i), (ii), and (v), of” and adding in its place “paragraph (b)(13) of this section, of”;

■ p. Adding paragraphs (b)(13) and (c).

The revisions and additions read as follows:

§ 97.1012 CSAPR NO_x Ozone Season Group 3 allowance allocations to new units.

(a) *Allocations from new unit set-asides.* For each control period in 2021 and thereafter for a State listed in § 52.38(b)(2)(iii)(A) of this chapter, or

2023 and thereafter for a State listed in § 52.38(b)(2)(iii)(B) or (C) of this chapter, and for the CSAPR NO_x Ozone Season Group 3 units in each State and areas of Indian country within the borders of the State (except, for the control periods in 2021 and 2022, areas of Indian country within the borders of the State not subject to the State’s SIP authority), the Administrator will allocate CSAPR NO_x Ozone Season Group 3 allowances to the CSAPR NO_x Ozone Season Group 3 units as follows:

(1) * * *

(i) CSAPR NO_x Ozone Season Group 3 units that are not allocated an amount of CSAPR NO_x Ozone Season Group 3 allowances for such control period in the applicable notice of data availability referenced in § 97.1011(a)(1) or (2) and that have deadlines for certification of monitoring systems under § 97.1030(b) not later than September 30 of the year of the control period; or

(ii) CSAPR NO_x Ozone Season Group 3 units whose allocation of an amount of CSAPR NO_x Ozone Season Group 3 allowances for such control period in the applicable notice of data availability referenced in § 97.1011(a)(1) or (2) is covered by § 97.1011(c)(2) or (3).

(2) The Administrator will establish a separate new unit set-aside for the State for each such control period. Each such new unit set-aside will be allocated CSAPR NO_x Ozone Season Group 3 allowances in an amount equal to the applicable amount of tons of NO_x emissions as set forth in § 97.1010(c) and will be allocated additional CSAPR NO_x Ozone Season Group 3 allowances (if any) in accordance with § 97.1011(c)(5) and paragraphs (b)(10) and (c)(5) of this section.

(3) * * *

(i) The control period in 2021, for a State listed in § 52.38(b)(2)(iii)(A) of this chapter, or the control period in 2023, for a State listed in § 52.38(b)(2)(iii)(B) or (C) of this chapter;

* * * * *

(iii) For a unit described in paragraph (a)(1)(ii) of this section, the first control period in which the CSAPR NO_x Ozone Season Group 3 unit operates in the State and Indian country within the borders of the State (except, for the control periods in 2021 and 2022, areas of Indian country within the borders of the State not subject to the State’s SIP authority) after operating in another jurisdiction and for which the unit is not already allocated one or more CSAPR NO_x Ozone Season Group 3 allowances.

(4)(i) The allocation to each CSAPR NO_x Ozone Season Group 3 unit described in paragraphs (a)(1)(i) through

(iii) of this section and for each control period described in paragraph (a)(3) of this section will be an amount equal to the unit’s total tons of NO_x emissions during the control period or, if less, any applicable amount calculated under paragraph (a)(4)(ii) of this section.

(ii)(A) The allocation under paragraph (a)(4)(i) of this section to a unit described in paragraph (a)(4)(ii)(B) or (C) of this section may not exceed a maximum controlled baseline calculated as the product (converted to tons at a conversion factor of 2,000 lb/ton and rounded to the nearest ton) of the unit’s total heat input during the control period in mmBtu multiplied by a NO_x emissions rate of 0.08 lb/mmBtu.

(B) For a control period in 2024 through 2026, a maximum controlled baseline under paragraph (a)(4)(ii)(A) of this section shall apply to any unit combusting any coal or solid coal-derived fuel during the control period, serving a generator with nameplate capacity of 100 MW or more, and equipped with selective catalytic reduction controls on or before September 30 of the preceding control period, except a circulating fluidized bed boiler.

(C) For a control period in 2027 and thereafter, a maximum controlled baseline under paragraph (a)(4)(ii)(A) of this section shall apply to any unit combusting any coal or solid coal-derived fuel during the control period and serving a generator with nameplate capacity of 100 MW or more, except a circulating fluidized bed boiler.

* * * * *

(5) The Administrator will calculate the sum of the allocation amounts of CSAPR NO_x Ozone Season Group 3 allowances determined for all such CSAPR NO_x Ozone Season Group 3 units under paragraph (a)(4)(i) of this section in the State and Indian country within the borders of the State (except, for the control periods in 2021 and 2022, areas of Indian country within the borders of the State not subject to the State’s SIP authority) for such control period.

* * * * *

(10)(i) For a control period in 2021 or 2022, if, after completion of the procedures under paragraphs (a)(2) through (7) and (12) of this section for a control period, any unallocated CSAPR NO_x Ozone Season Group 3 allowances remain in the new unit set-aside for the State for such control period, the Administrator will allocate to each CSAPR NO_x Ozone Season Group 3 unit that is in the State and areas of Indian country within the borders of the State subject to the State’s

SIP authority and is allocated an amount of CSAPR NO_x Ozone Season Group 3 allowances for the control period in the applicable notice of data availability referenced in § 97.1011(a)(1) an amount of CSAPR NO_x Ozone Season Group 3 allowances equal to the following: The total amount of such remaining unallocated CSAPR NO_x Ozone Season Group 3 allowances in such new unit set-aside, multiplied by the unit's allocation under § 97.1011(a)(1) for such control period, divided by the remainder of the amount of tons in the applicable State NO_x Ozone Season Group 3 trading budget minus the sum of the amounts of tons in such new unit set-aside and the Indian country new unit set-aside for the State for such control period, and rounded to the nearest allowance.

(ii) For a control period in 2023 or thereafter, if, after completion of the procedures under paragraphs (a)(2) through (7) and (12) of this section for a control period, any unallocated CSAPR NO_x Ozone Season Group 3 allowances remain in the new unit set-aside for the State for such control period, the Administrator will allocate to each CSAPR NO_x Ozone Season Group 3 unit that is in the State and Indian country within the borders of the State and is allocated an amount of CSAPR NO_x Ozone Season Group 3 allowances for the control period by the Administrator in the applicable notice of data availability referenced in § 97.1011(a)(1) or (2), or under a provision of a SIP revision approved under § 52.38(b)(10), (11), or (12) of this chapter, an amount of CSAPR NO_x Ozone Season Group 3 allowances equal to the following: The total amount of such remaining unallocated CSAPR NO_x Ozone Season Group 3 allowances in such new unit set-aside, multiplied by the unit's allocation under § 97.1011(a)(1) or (2) or a provision of a SIP revision approved under § 52.38(b)(10), (11), or (12) of this chapter for such control period, divided by the remainder of the amount of tons in the applicable State NO_x Ozone Season Group 3 trading budget minus the amount of tons in such new unit set-aside for the State for such control period, and rounded to the nearest allowance.

* * * * *

(13)(i) By March 1, 2022, and March 1 of each year thereafter, the Administrator will calculate the CSAPR NO_x Ozone Season Group 3 allowance allocation to each CSAPR NO_x Ozone Season Group 3 unit in a State and Indian country within the borders of the State (except, for the control periods in

2021 and 2022, areas of Indian country within the State not subject to the State's SIP authority), in accordance with paragraphs (a)(2) through (7), (10), and (12) of this section and §§ 97.1006(b)(2) and 97.1030 through 97.1035, for the control period in the year before the year of the applicable calculation deadline under this paragraph (a)(13)(i) and will promulgate a notice of data availability of the results of the calculations.

(ii) For each notice of data availability required in paragraph (a)(13)(i) of this section, the Administrator will provide an opportunity for submission of objections to the calculations referenced in such notice. Objections shall be submitted by the deadline specified in such notice and shall be limited to addressing whether the calculations (including the identification of the CSAPR NO_x Ozone Season Group 3 units) are in accordance with the provisions referenced in paragraph (a)(13)(i) of this section.

(iii) The Administrator will adjust the calculations to the extent necessary to ensure that they are in accordance with the provisions referenced in paragraph (a)(13)(i) of this section. By May 1 immediately after the promulgation of each notice of data availability required in paragraph (a)(13)(i) of this section, the Administrator will promulgate a notice of data availability of the results of the calculations incorporating any adjustments that the Administrator determines to be necessary and the reasons for accepting or rejecting any objections submitted in accordance with paragraph (a)(13)(ii) of this section.

(b) *Allocations from Indian country new unit set-asides.* For the control periods in 2021 and 2022, for a State listed in § 52.38(b)(2)(iii)(A) of this chapter, and for the CSAPR NO_x Ozone Season Group 3 units in areas of Indian country within the borders of each such State not subject to the State's SIP authority, the Administrator will allocate CSAPR NO_x Ozone Season Group 3 allowances to the CSAPR NO_x Ozone Season Group 3 units as follows:

(1) The CSAPR NO_x Ozone Season Group 3 allowances will be allocated to CSAPR NO_x Ozone Season Group 3 units that are not allocated an amount of CSAPR NO_x Ozone Season Group 3 allowances for such control period in the applicable notice of data availability referenced in § 97.1011(a)(1) and that have deadlines for certification of monitoring systems under § 97.1030(b) not later than September 30 of the year of the control period, except as provided in paragraph (b)(10) of this section.

(2) The Administrator will establish a separate Indian country new unit set-

aside for the State for each such control period. Each such Indian country new unit set-aside will be allocated CSAPR NO_x Ozone Season Group 3 allowances in an amount equal to the applicable amount of tons of NO_x emissions as set forth in § 97.1010(d) and will be allocated additional CSAPR NO_x Ozone Season Group 3 allowances (if any) in accordance with paragraph (c)(5) of this section.

* * * * *

(10) If, after completion of the procedures under paragraphs (b)(2) through (7) and (12) of this section for a control period, any unallocated CSAPR NO_x Ozone Season Group 3 allowances remain in the Indian country new unit set-aside for the State for such control period, the Administrator will transfer such unallocated CSAPR NO_x Ozone Season Group 3 allowances to the new unit set-aside for the State for such control period.

* * * * *

(13)(i) By March 1, 2022, and March 1, 2023, the Administrator will calculate the CSAPR NO_x Ozone Season Group 3 allowance allocation to each CSAPR NO_x Ozone Season Group 3 unit in areas of Indian country within the borders of a State not subject to the State's SIP authority, in accordance with paragraphs (b)(2) through (7), (10), and (12) of this section and §§ 97.1006(b)(2) and 97.1030 through 97.1035, for the control period in the year before the year of the applicable calculation deadline under this paragraph (b)(13)(i) and will promulgate a notice of data availability of the results of the calculations.

(ii) For each notice of data availability required in paragraph (b)(13)(i) of this section, the Administrator will provide an opportunity for submission of objections to the calculations referenced in such notice. Objections shall be submitted by the deadline specified in such notice and shall be limited to addressing whether the calculations (including the identification of the CSAPR NO_x Ozone Season Group 3 units) are in accordance with the provisions referenced in paragraph (b)(13)(i) of this section.

(iii) The Administrator will adjust the calculations to the extent necessary to ensure that they are in accordance with the provisions referenced in paragraph (b)(13)(i) of this section. By May 1 immediately after the promulgation of each notice of data availability required in paragraph (b)(13)(i) of this section, the Administrator will promulgate a notice of data availability of the results of the calculations incorporating any adjustments that the Administrator

determines to be necessary and the reasons for accepting or rejecting any objections submitted in accordance with paragraph (b)(13)(ii) of this section.

(c) *Incorrect allocations of CSAPR NO_x Ozone Season Group 3 allowances to new units.* (1) For each control period in 2021 and thereafter, if the Administrator determines that CSAPR NO_x Ozone Season Group 3 allowances were allocated for the control period under paragraphs (a)(2) through (7) and (12) of this section or paragraphs (b)(2) through (7) and (12) of this section to a recipient that is not actually a CSAPR NO_x Ozone Season Group 3 unit under § 97.1004 as of the first day of such control period, then the Administrator will notify the designated representative of the recipient and will act in accordance with the procedures set forth in paragraphs (c)(2) through (5) of this section.

(2) Except as provided in paragraph (c)(3) or (4) of this section, the Administrator will not record such CSAPR NO_x Ozone Season Group 3 allowances under § 97.1021.

(3) If the Administrator already recorded such CSAPR NO_x Ozone Season Group 3 allowances under § 97.1021 and if the Administrator makes the determination under paragraph (c)(1) of this section before making deductions for the source that includes such recipient under § 97.1024(b) for such control period, then the Administrator will deduct from the account in which such CSAPR NO_x Ozone Season Group 3 allowances were recorded an amount of CSAPR NO_x Ozone Season Group 3 allowances allocated for the same or a prior control period equal to the amount of such already recorded CSAPR NO_x Ozone Season Group 3 allowances. The authorized account representative shall ensure that there are sufficient CSAPR NO_x Ozone Season Group 3 allowances in such account for completion of the deduction.

(4) If the Administrator already recorded such CSAPR NO_x Ozone Season Group 3 allowances under § 97.1021 and if the Administrator makes the determination under paragraph (c)(1) of this section after making deductions for the source that includes such recipient under § 97.1024(b) for such control period, then the Administrator will not make any deduction to take account of such already recorded CSAPR NO_x Ozone Season Group 3 allowances.

(5) With regard to any CSAPR NO_x Ozone Season Group 3 allowances that are not recorded, or that are deducted as an incorrect allocation, in accordance

with paragraphs (c)(2) and (3) of this section:

(i) If the non-recordation decision under paragraph (c)(2) of this section or the deduction under paragraph (c)(3) of this section occurs on or before May 1, 2023, the Administrator will transfer the CSAPR NO_x Ozone Season Group 3 allowances to the new unit set-aside, in the case of allowances allocated under paragraph (a) of this section, or the Indian country new unit set-aside, in the case of allowances allocated under paragraph (b) of this section, for the control period in 2021 or 2022 for the State from whose NO_x Ozone Season Group 3 trading budget the CSAPR NO_x Ozone Season Group 3 allowances were allocated.

(ii) If the non-recordation decision under paragraph (c)(2) of this section or the deduction under paragraph (c)(3) of this section occurs after May 1, 2023, and on or before May 1, 2024, the Administrator will transfer the CSAPR NO_x Ozone Season Group 3 allowances to the new unit set-aside for the control period in 2023 for the State from whose NO_x Ozone Season Group 3 trading budget the CSAPR NO_x Ozone Season Group 3 allowances were allocated.

(iii) If the non-recordation decision under paragraph (c)(2) of this section or the deduction under paragraph (c)(3) of this section occurs after May 1, 2024, the Administrator will transfer the CSAPR NO_x Ozone Season Group 3 allowances to a surrender account.

■ 67. Amend § 97.1021 by:

- a. In paragraph (a), removing “§ 97.1011(a)” and adding in its place “§ 97.1011(a)(1)”;
- b. Revising paragraph (b);
- c. Removing and reserving paragraph (c);
- d. Adding paragraphs (d) and (e);
- e. In paragraph (f), removing “§ 97.1011(a), or” and adding in its place “§ 97.1011(a)(1), or”;
- f. Redesignating paragraphs (g) and (h) as paragraphs (i) and (j), respectively, and adding new paragraphs (g) and (h);
- g. Revising newly redesignated paragraph (i);
- h. In newly redesignated paragraph (j), removing “and May 1 of each year thereafter, the” and adding in its place “, and May 1, 2023, the”; and
- i. In paragraph (m), adding “or (e)” after “§ 97.811(d)” each time it appears.

The revisions and addition read as follows:

§ 97.1021 Recordation of CSAPR NO_x Ozone Season Group 3 allowance allocations and auction results.

* * * * *

(b) By July 29, 2021, the Administrator will record in each

CSAPR NO_x Ozone Season Group 3 source's compliance account the CSAPR NO_x Ozone Season Group 3 allowances allocated to the CSAPR NO_x Ozone Season Group 3 units at the source in accordance with § 97.1011(a)(1) for the control period in 2022.

* * * * *

(d) By September 5, 2023, the Administrator will record in each CSAPR NO_x Ozone Season Group 3 source's compliance account the CSAPR NO_x Ozone Season Group 3 allowances allocated to the CSAPR NO_x Ozone Season Group 3 units at the source in accordance with § 97.1011(a)(1) for the control period in 2023.

(e) By September 5, 2023, the Administrator will record in each CSAPR NO_x Ozone Season Group 3 source's compliance account the CSAPR NO_x Ozone Season Group 3 allowances allocated to the CSAPR NO_x Ozone Season Group 3 units at the source in accordance with § 97.1011(a)(1) for the control period in 2024, unless the State in which the source is located notifies the Administrator in writing by August 4, 2023, of the State's intent to submit to the Administrator a complete SIP revision by September 1, 2023, meeting the requirements of § 52.38(b)(10)(i) through (iv) of this chapter.

(1) If, by September 1, 2023, the State does not submit to the Administrator such complete SIP revision, the Administrator will record by September 15, 2023, in each CSAPR NO_x Ozone Season Group 3 source's compliance account the CSAPR NO_x Ozone Season Group 3 allowances allocated to the CSAPR NO_x Ozone Season Group 3 units at the source in accordance with § 97.1011(a)(1) for the control period in 2024.

(2) If the State submits to the Administrator by September 1, 2023, and the Administrator approves by March 1, 2024, such complete SIP revision, the Administrator will record by March 1, 2024, in each CSAPR NO_x Ozone Season Group 3 source's compliance account the CSAPR NO_x Ozone Season Group 3 allowances allocated to the CSAPR NO_x Ozone Season Group 3 units at the source as provided in such approved, complete SIP revision for the control period in 2024.

(3) If the State submits to the Administrator by September 1, 2023, and the Administrator does not approve by March 1, 2024, such complete SIP revision, the Administrator will record by March 1, 2024, in each CSAPR NO_x Ozone Season Group 3 source's compliance account the CSAPR NO_x Ozone Season Group 3 allowances

allocated to the CSAPR NO_x Ozone Season Group 3 units at the source in accordance with § 97.1011(a)(1) for the control period in 2024.

* * * * *

(g) By September 5, 2023, the Administrator will record in each CSAPR NO_x Ozone Season Group 3 source's compliance account the CSAPR NO_x Ozone Season Group 3 allowances allocated to the CSAPR NO_x Ozone Season Group 3 units at the source in accordance with § 97.1011(a)(2) for the control periods in 2023 and 2024.

(h) By July 1, 2024, and July 1 of each year thereafter, the Administrator will record in each CSAPR NO_x Ozone Season Group 3 source's compliance account the CSAPR NO_x Ozone Season Group 3 allowances allocated to the CSAPR NO_x Ozone Season Group 3 units at the source in accordance with § 97.1011(a)(2) for the control period in the year after the year of the applicable recordation deadline under this paragraph (h).

(i) By May 1, 2022, and May 1 of each year thereafter, the Administrator will record in each CSAPR NO_x Ozone Season Group 3 source's compliance account the CSAPR NO_x Ozone Season Group 3 allowances allocated to the CSAPR NO_x Ozone Season Group 3 units at the source in accordance with § 97.1012(a) for the control period in the year before the year of the applicable recordation deadline under this paragraph (i).

* * * * *

- 68. Amend § 97.1024 by:
 - a. Revising the section heading;
 - b. In paragraphs (a) introductory text and (b) introductory text, adding "primary" before "emissions limitation";
 - c. Revising paragraph (b)(1);
 - d. Adding paragraph (b)(3); and
 - e. In paragraph (c)(2)(ii), adding "or (e)" after "§ 97.826(d)".

The revisions and addition read as follows:

§ 97.1024 Compliance with CSAPR NO_x Ozone Season Group 3 primary emissions limitation; backstop daily NO_x emissions rate.

* * * * *

(b) * * *

(1) Until the amount of CSAPR NO_x Ozone Season Group 3 allowances deducted equals the sum of:

(i) The number of tons of total NO_x emissions from all CSAPR NO_x Ozone Season Group 3 units at the source for such control period; plus

(ii) Two times the excess, if any, over 50 tons of the sum (converted to tons at a conversion factor of 2,000 lb/ton and rounded to the nearest ton), for all

calendar days in the control period and all CSAPR NO_x Ozone Season Group 3 units at the source to which the backstop daily NO_x emissions rate applies for the control period under paragraph (b)(3) of this section, of any amount by which a unit's NO_x emissions for a given calendar day in pounds exceed the product in pounds of the unit's total heat input in mmBtu for that calendar day multiplied by 0.14 lb/mmBtu; or

* * * * *

(3) The backstop daily NO_x emissions rate of 0.14 lb/mmBtu applies as follows:

(i) For each control period in 2024 through 2029, the backstop daily NO_x emissions rate shall apply to each CSAPR NO_x Ozone Season Group 3 unit combusting any coal or solid coal-derived fuel during the control period, serving a generator with nameplate capacity of 100 MW or more, and equipped with selective catalytic reduction controls on or before September 30 of the preceding control period, except a circulating fluidized bed boiler.

(ii) For each control in 2030 and thereafter, the backstop daily NO_x emissions rate shall apply to each CSAPR NO_x Ozone Season Group 3 unit combusting any coal or solid coal-derived fuel during the control period and serving a generator with nameplate capacity of 100 MW or more, except a circulating fluidized bed boiler.

* * * * *

- 69. Amend § 97.1025 by:
 - a. Revising the section heading;
 - b. In paragraphs (a) introductory text, (a)(2), (b)(1)(i), (b)(1)(ii)(A) and (B), (b)(3), (b)(4)(i), (b)(5), (b)(6)(i), (b)(6)(iii) introductory text, and (b)(6)(iii)(A) and (B), removing "base CSAPR" and adding in its place "CSAPR" each time it appears; and
 - c. Adding paragraph (c).

The revision and addition read as follows:

§ 97.1025 Compliance with CSAPR NO_x Ozone Season Group 3 assurance provisions; CSAPR NO_x Ozone Season Group 3 secondary emissions limitation.

* * * * *

(c) *CSAPR NO_x Ozone Season Group 3 secondary emissions limitation.* (1) The owner or operator of a CSAPR NO_x Ozone Season Group 3 unit equipped with selective catalytic reduction controls or selective non-catalytic reduction controls shall not discharge, or allow to be discharged, emissions of NO_x to the atmosphere during a control period in excess of the tonnage amount calculated in accordance with paragraph (c)(2) of this section, provided that the

emissions limitation established under this paragraph (c)(1) shall apply to a unit for a control period only if:

(i) The unit is included for the control period in a group of CSAPR NO_x Ozone Season Group 3 units at CSAPR NO_x Ozone Season Group 3 sources in a State (and Indian country within the borders of such State) having a common designated representative and the owners and operators of such units and sources are subject to a requirement for such control period to hold one or more CSAPR NO_x Ozone Season Group 3 allowances under § 97.1006(c)(2)(i) and paragraph (b) of this section with respect to such group; and

(ii) The unit was required to report NO_x emissions and heat input data for all or portions of at least 367 operating hours during the control period and all or portions of at least 367 operating hours during at least one historical control period under the CSAPR NO_x Ozone Season Group 1 Trading Program, CSAPR NO_x Ozone Season Group 2 Trading Program, or CSAPR NO_x Ozone Season Group 3 Trading Program.

(2) The amount of the emissions limitation applicable to a CSAPR NO_x Ozone Season Group 3 unit for a control period under paragraph (c)(1) of this section, in tons of NO_x, shall be calculated as the sum of 50 plus the product (converted to tons at a conversion factor of 2,000 lb/ton and rounded to the nearest ton) of multiplying—

(i) The total heat input in mmBtu reported for the unit for the control period in accordance with §§ 97.1030 through 97.1035; and

(ii) A NO_x emission rate of 0.10 lb/mmBtu or, if higher, the product of 1.25 times the lowest seasonal average NO_x emission rate in lb/mmBtu achieved by the unit in any historical control period for which the unit was required to report NO_x emissions and heat input data for all or portions of at least 367 operating hours under the CSAPR NO_x Ozone Season Group 1 Trading Program, CSAPR NO_x Ozone Season Group 2 Trading Program, or CSAPR NO_x Ozone Season Group 3 Trading Program, where the unit's seasonal average NO_x emission rate for each such historical control period shall be calculated from such reported data as the quotient (converted to lb/mmBtu at a conversion factor of 2,000 lb/ton, and rounded to the nearest 0.0001 lb/mmBtu) of the unit's total NO_x emissions in tons for the historical control period divided by the unit's total heat input in mmBtu for the historical control period.

- 70. Amend § 97.1026 by:

- a. Revising the section heading and paragraph (b);
- b. In paragraph (c):
- i. Removing “set forth in” and adding in its place “established under”; and
- ii. Removing “State (or Indian” and adding in its place “State (and Indian”;
- c. Adding paragraph (d).

The revision and addition read as follows:

§ 97.1026 Banking; bank recalibration.

* * * * *

(b) Any CSAPR NO_x Ozone Season Group 3 allowance that is held in a compliance account or a general account will remain in such account unless and until the CSAPR NO_x Ozone Season Group 3 allowance is deducted or transferred under § 97.1011(c), § 97.1012(c), § 97.1023, § 97.1024, § 97.1025, § 97.1027, or § 97.1028 or paragraph (c) or (d) of this section.

* * * * *

(d) Before the allowance transfer deadline for each control period in 2024 and thereafter, the Administrator will deduct amounts of CSAPR NO_x Ozone Season Group 3 allowances issued for the control periods in previous years exceeding the CSAPR NO_x Ozone Season Group 3 allowance bank ceiling target for the control period in accordance with paragraphs (d)(1) through (4) of this section.

(1) As soon as practicable on or after August 1, 2024, and August 1 of each year thereafter, the Administrator will temporarily suspend acceptance of CSAPR NO_x Ozone Season Group 3 allowance transfers submitted under § 97.1022 and, before resuming acceptance of such transfers, will take the actions in paragraphs (d)(2) through (4) of this section.

(2) The Administrator will determine each of the following values:

(i) The total amount of CSAPR NO_x Ozone Season Group 3 allowances issued for control periods in years before the year of the deadline under paragraph (d)(1) of this section and held in all compliance and general accounts.

(ii) The CSAPR NO_x Ozone Season Group 3 allowance bank ceiling target for the control period in the year of the deadline under paragraph (d)(1) of this section, calculated as the product, rounded to the nearest allowance, of the sum for all States listed in § 52.38(b)(2)(iii) of this chapter of the State NO_x Ozone Season Group 3 trading budgets under § 97.1010(a) for such States for such control period multiplied by—

(A) 0.210, for a control period in 2024 through 2029; or

(B) 0.105, for a control period in 2030 and thereafter.

(3) If the total amount of CSAPR NO_x Ozone Season Group 3 allowances determined under paragraph (d)(2)(i) of this section exceeds the CSAPR NO_x Ozone Season Group 3 allowance bank ceiling target determined under paragraph (d)(2)(ii) of this section, then for each compliance account or general account holding CSAPR NO_x Ozone Season Group 3 allowances issued for control periods in years before the year of the deadline under paragraph (d)(1) of this section, the Administrator will:

(i) Determine the total amount of CSAPR NO_x Ozone Season Group 3 allowances issued for control periods in years before the year of the deadline under paragraph (d)(1) of this section and held in the account.

(ii) Determine the account's share of the CSAPR NO_x Ozone Season Group 3 allowance bank ceiling target for the control period, calculated as the product, rounded up to the nearest allowance, of the CSAPR NO_x Ozone Season Group 3 allowance bank ceiling target determined under paragraph (d)(2)(ii) of this section multiplied by a fraction whose numerator is the total amount of CSAPR NO_x Ozone Season Group 3 allowances held in the account determined under paragraph (d)(3)(i) of this section and whose denominator is the total amount of CSAPR NO_x Ozone Season Group 3 allowances held in all compliance and general accounts determined under paragraph (d)(2)(i) of this section.

(iii) Deduct an amount of CSAPR NO_x Ozone Season Group 3 allowances issued for control periods in years before the year of the deadline under paragraph (d)(1) of this section equal to any positive remainder of the total amount of CSAPR NO_x Ozone Season Group 3 allowances held in the account determined under paragraph (d)(3)(i) of this section minus the account's share of the CSAPR NO_x Ozone Season Group 3 allowance bank ceiling target for the control period determined under paragraph (d)(3)(ii) of this section. The allowances will be deducted on a first-in, first-out basis in the order set forth in § 97.1024(c)(2)(i) and (ii).

(iv) Record the deductions under paragraph (d)(3)(iii) of this section in the account.

(4)(i) In computing any amounts of CSAPR NO_x Ozone Season Group 3 allowances to be deducted from general accounts under paragraph (d)(3) of this section, the Administrator may group multiple general accounts whose ownership interests are held by the same or related persons or entities and treat the group of accounts as a single

account for purposes of such computation.

(ii) Following a computation for a group of general accounts in accordance with paragraph (d)(4)(i) of this section, the Administrator will deduct from and record in each individual account in such group a proportional share of the quantity of CSAPR NO_x Ozone Season Group 3 allowances computed for such group, basing such shares on the respective quantities of CSAPR NO_x Ozone Season Group 3 allowances determined for such individual accounts under paragraph (d)(3)(i) of this section.

(iii) In determining the proportional shares under paragraph (d)(4)(ii) of this section, the Administrator may employ any reasonable adjustment methodology to truncate or round each such share up or down to a whole number and to cause the total of such whole numbers to equal the amount of CSAPR NO_x Ozone Season Group 3 allowances computed for such group of accounts in accordance with paragraph (d)(4)(i) of this section, even where such adjustments cause the numbers of CSAPR NO_x Ozone Season Group 3 allowances remaining in some individual accounts following the deductions to equal zero.

■ 71. Amend § 97.1030 by:

■ a. Revising paragraph (b)(1); and

■ b. In paragraph (b)(3), removing “(b)(2)” and adding in its place “(b)(1) or (2)” each time it appears.

The revision reads as follows:

§ 97.1030 General monitoring, recordkeeping, and reporting requirements.

* * * * *

(b) * * *

(1)(i) May 1, 2021, for a unit in a State (and Indian country within the borders of such State) listed in § 52.38(b)(2)(iii)(A) of this chapter;

(ii) May 1, 2023, for a unit in a State (and Indian country within the borders of such State) listed in § 52.38(b)(2)(iii)(B) of this chapter;

(iii) August 4, 2023, for a unit in a State (and Indian country within the borders of such State) listed in § 52.38(b)(2)(iii)(C) of this chapter, where the unit is required to report NO_x mass emissions data or NO_x emissions rate data according to 40 CFR part 75 to address other regulatory requirements; or

(iv) January 31, 2024, for a unit in a State (and Indian country within the borders of such State) listed in § 52.38(b)(2)(iii)(C) of this chapter, where the unit is not required to report NO_x mass emissions data or NO_x emissions rate data according to 40 CFR

part 75 to address other regulatory requirements.

* * * * *

■ 72. Amend § 97.1034 by:

- a. Revising paragraph (d)(2)(i); and
- b. In paragraph (d)(4), removing “or CSAPR SO₂ Group 1 Trading Program, quarterly” and adding in its place “CSAPR SO₂ Group 1 Trading Program, or CSAPR SO₂ Group 2 Trading Program, quarterly”.

The revision reads as follows:

§ 97.1034 Recordkeeping and reporting.

* * * * *

(d) * * *

(2) * * *

(i)(A) The calendar quarter covering May 1, 2021, through June 30, 2021, for a unit in a State (and Indian country within the borders of such State) listed in § 52.38(b)(2)(iii)(A) of this chapter;

(B) The calendar quarter covering May 1, 2023, through June 30, 2023, for a unit in a State (and Indian country

within the borders of such State) listed in § 52.38(b)(2)(iii)(B) of this chapter; or

(C) The calendar quarter covering August 4, 2023, through June 30, 2023, for a unit in a State (and Indian country within the borders of such State) listed in § 52.38(b)(2)(iii)(C) of this chapter;

* * * * *

[FR Doc. 2023-05744 Filed 6-2-23; 8:45 am]

BILLING CODE 6560-50-P

until modified or rescinded in accordance with act July 14, 1955, as amended by Pub. L. 95-95 [this chapter], see section 406(b) of Pub. L. 95-95, set out as an Effective Date of 1977 Amendment note under section 7401 of this title.

§ 7406. Interstate air quality agencies; program cost limitations

For the purpose of developing implementation plans for any interstate air quality control region designated pursuant to section 7407 of this title or of implementing section 7506a of this title (relating to control of interstate air pollution) or section 7511c of this title (relating to control of interstate ozone pollution), the Administrator is authorized to pay, for two years, up to 100 per centum of the air quality planning program costs of any commission established under section 7506a of this title (relating to control of interstate air pollution) or section 7511c of this title (relating to control of interstate ozone pollution) or any agency designated by the Governors of the affected States, which agency shall be capable of recommending to the Governors plans for implementation of national primary and secondary ambient air quality standards and shall include representation from the States and appropriate political subdivisions within the air quality control region. After the initial two-year period the Administrator is authorized to make grants to such agency or such commission in an amount up to three-fifths of the air quality implementation program costs of such agency or commission.

(July 14, 1955, ch. 360, title I, § 106, as added Pub. L. 90-148, § 2, Nov. 21, 1967, 81 Stat. 490; amended Pub. L. 91-604, § 3(c), Dec. 31, 1970, 84 Stat. 1677; Pub. L. 101-549, title I, § 102(f)(2), title VIII, § 802(f), Nov. 15, 1990, 104 Stat. 2420, 2688.)

Editorial Notes

CODIFICATION

Section was formerly classified to section 1857c-1 of this title.

PRIOR PROVISIONS

A prior section 106 of act July 14, 1955, was renumbered section 117 by Pub. L. 91-604 and is classified to section 7417 of this title.

AMENDMENTS

1990—Pub. L. 101-549, § 102(f)(2)(A), inserted “or of implementing section 7506a of this title (relating to control of interstate air pollution) or section 7511c of this title (relating to control of interstate ozone pollution)” after “section 7407 of this title”.

Pub. L. 101-549, § 102(f)(2)(B), which directed insertion of “any commission established under section 7506a of this title (relating to control of interstate air pollution) or section 7511c of this title (relating to control of interstate ozone pollution) or” after “program costs of”, was executed by making the insertion after that phrase the first place it appeared to reflect the probable intent of Congress.

Pub. L. 101-549, § 102(f)(2)(C), which directed insertion of “or such commission” after “such agency” in last sentence, was executed by making insertion after “such agency” the first place it appeared in the last sentence to reflect the probable intent of Congress.

Pub. L. 101-549, §§ 102(f)(2)(D), 802(f), substituted “three-fifths of the air quality implementation program costs of such agency or commission” for “three-fourths of the air quality planning program costs of such agency”.

1970—Pub. L. 91-604 struck out designation “(a)”, substituted provisions authorizing Federal grants for the purpose of developing implementation plans and provisions requiring the designated State agency to be capable of recommending plans for implementation of national primary and secondary ambient air quality standards, for provisions authorizing Federal grants for the purpose of expediting the establishment of air quality standards and provisions requiring the designated State agency to be capable of recommending standards of air quality and plans for implementation thereof, respectively, and struck out subsec. (b) which authorized establishment of air quality planning commissions.

§ 7407. Air quality control regions

(a) Responsibility of each State for air quality; submission of implementation plan

Each State shall have the primary responsibility for assuring air quality within the entire geographic area comprising such State by submitting an implementation plan for such State which will specify the manner in which national primary and secondary ambient air quality standards will be achieved and maintained within each air quality control region in such State.

(b) Designated regions

For purposes of developing and carrying out implementation plans under section 7410 of this title—

(1) an air quality control region designated under this section before December 31, 1970, or a region designated after such date under subsection (c), shall be an air quality control region; and

(2) the portion of such State which is not part of any such designated region shall be an air quality control region, but such portion may be subdivided by the State into two or more air quality control regions with the approval of the Administrator.

(c) Authority of Administrator to designate regions; notification of Governors of affected States

The Administrator shall, within 90 days after December 31, 1970, after consultation with appropriate State and local authorities, designate as an air quality control region any interstate area or major intrastate area which he deems necessary or appropriate for the attainment and maintenance of ambient air quality standards. The Administrator shall immediately notify the Governors of the affected States of any designation made under this subsection.

(d) Designations

(1) Designations generally

(A) Submission by Governors of initial designations following promulgation of new or revised standards

By such date as the Administrator may reasonably require, but not later than 1 year after promulgation of a new or revised national ambient air quality standard for any pollutant under section 7409 of this title, the Governor of each State shall (and at any other time the Governor of a State deems appropriate the Governor may) submit to the Administrator a list of all areas (or portions thereof) in the State, designating as—

(i) nonattainment, any area that does not meet (or that contributes to ambient

air quality in a nearby area that does not meet) the national primary or secondary ambient air quality standard for the pollutant,

(ii) attainment, any area (other than an area identified in clause (i)) that meets the national primary or secondary ambient air quality standard for the pollutant, or

(iii) unclassifiable, any area that cannot be classified on the basis of available information as meeting or not meeting the national primary or secondary ambient air quality standard for the pollutant.

The Administrator may not require the Governor to submit the required list sooner than 120 days after promulgating a new or revised national ambient air quality standard.

(B) Promulgation by EPA of designations

(i) Upon promulgation or revision of a national ambient air quality standard, the Administrator shall promulgate the designations of all areas (or portions thereof) submitted under subparagraph (A) as expeditiously as practicable, but in no case later than 2 years from the date of promulgation of the new or revised national ambient air quality standard. Such period may be extended for up to one year in the event the Administrator has insufficient information to promulgate the designations.

(ii) In making the promulgations required under clause (i), the Administrator may make such modifications as the Administrator deems necessary to the designations of the areas (or portions thereof) submitted under subparagraph (A) (including to the boundaries of such areas or portions thereof). Whenever the Administrator intends to make a modification, the Administrator shall notify the State and provide such State with an opportunity to demonstrate why any proposed modification is inappropriate. The Administrator shall give such notification no later than 120 days before the date the Administrator promulgates the designation, including any modification thereto. If the Governor fails to submit the list in whole or in part, as required under subparagraph (A), the Administrator shall promulgate the designation that the Administrator deems appropriate for any area (or portion thereof) not designated by the State.

(iii) If the Governor of any State, on the Governor's own motion, under subparagraph (A), submits a list of areas (or portions thereof) in the State designated as non-attainment, attainment, or unclassifiable, the Administrator shall act on such designations in accordance with the procedures under paragraph (3) (relating to redesignation).

(iv) A designation for an area (or portion thereof) made pursuant to this subsection shall remain in effect until the area (or portion thereof) is redesignated pursuant to paragraph (3) or (4).

(C) Designations by operation of law

(i) Any area designated with respect to any air pollutant under the provisions of para-

graph (1)(A), (B), or (C) of this subsection (as in effect immediately before November 15, 1990) is designated, by operation of law, as a nonattainment area for such pollutant within the meaning of subparagraph (A)(i).

(ii) Any area designated with respect to any air pollutant under the provisions of paragraph (1)(E) (as in effect immediately before November 15, 1990) is designated by operation of law, as an attainment area for such pollutant within the meaning of subparagraph (A)(ii).

(iii) Any area designated with respect to any air pollutant under the provisions of paragraph (1)(D) (as in effect immediately before November 15, 1990) is designated, by operation of law, as an unclassifiable area for such pollutant within the meaning of subparagraph (A)(iii).

(2) Publication of designations and redesignations

(A) The Administrator shall publish a notice in the Federal Register promulgating any designation under paragraph (1) or (5), or announcing any designation under paragraph (4), or promulgating any redesignation under paragraph (3).

(B) Promulgation or announcement of a designation under paragraph (1), (4) or (5) shall not be subject to the provisions of sections 553 through 557 of title 5 (relating to notice and comment), except nothing herein shall be construed as precluding such public notice and comment whenever possible.

(3) Redesignation

(A) Subject to the requirements of subparagraph (E), and on the basis of air quality data, planning and control considerations, or any other air quality-related considerations the Administrator deems appropriate, the Administrator may at any time notify the Governor of any State that available information indicates that the designation of any area or portion of an area within the State or interstate area should be revised. In issuing such notification, which shall be public, to the Governor, the Administrator shall provide such information as the Administrator may have available explaining the basis for the notice.

(B) No later than 120 days after receiving a notification under subparagraph (A), the Governor shall submit to the Administrator such redesignation, if any, of the appropriate area (or areas) or portion thereof within the State or interstate area, as the Governor considers appropriate.

(C) No later than 120 days after the date described in subparagraph (B) (or paragraph (1)(B)(iii)), the Administrator shall promulgate the redesignation, if any, of the area or portion thereof, submitted by the Governor in accordance with subparagraph (B), making such modifications as the Administrator may deem necessary, in the same manner and under the same procedure as is applicable under clause (ii) of paragraph (1)(B), except that the phrase "60 days" shall be substituted for the phrase "120 days" in that clause. If the Governor does not submit, in accordance with subparagraph (B), a redesignation for an area

(or portion thereof) identified by the Administrator under subparagraph (A), the Administrator shall promulgate such redesignation, if any, that the Administrator deems appropriate.

(D) The Governor of any State may, on the Governor's own motion, submit to the Administrator a revised designation of any area or portion thereof within the State. Within 18 months of receipt of a complete State redesignation submittal, the Administrator shall approve or deny such redesignation. The submission of a redesignation by a Governor shall not affect the effectiveness or enforceability of the applicable implementation plan for the State.

(E) The Administrator may not promulgate a redesignation of a nonattainment area (or portion thereof) to attainment unless—

(i) the Administrator determines that the area has attained the national ambient air quality standard;

(ii) the Administrator has fully approved the applicable implementation plan for the area under section 7410(k) of this title;

(iii) the Administrator determines that the improvement in air quality is due to permanent and enforceable reductions in emissions resulting from implementation of the applicable implementation plan and applicable Federal air pollutant control regulations and other permanent and enforceable reductions;

(iv) the Administrator has fully approved a maintenance plan for the area as meeting the requirements of section 7505a of this title; and

(v) the State containing such area has met all requirements applicable to the area under section 7410 of this title and part D.

(F) The Administrator shall not promulgate any redesignation of any area (or portion thereof) from nonattainment to unclassifiable.

(4) Nonattainment designations for ozone, carbon monoxide and particulate matter (PM-10)

(A) Ozone and carbon monoxide

(i) Within 120 days after November 15, 1990, each Governor of each State shall submit to the Administrator a list that designates, affirms or reaffirms the designation of, or redesignates (as the case may be), all areas (or portions thereof) of the Governor's State as attainment, nonattainment, or unclassifiable with respect to the national ambient air quality standards for ozone and carbon monoxide.

(ii) No later than 120 days after the date the Governor is required to submit the list of areas (or portions thereof) required under clause (i) of this subparagraph, the Administrator shall promulgate such designations, making such modifications as the Administrator may deem necessary, in the same manner, and under the same procedure, as is applicable under clause (ii) of paragraph (1)(B), except that the phrase "60 days" shall be substituted for the phrase "120 days" in that clause. If the Governor does not submit, in accordance with clause (i) of this subparagraph, a designation for an area (or portion

thereof), the Administrator shall promulgate the designation that the Administrator deems appropriate.

(iii) No nonattainment area may be redesignated as an attainment area under this subparagraph.

(iv) Notwithstanding paragraph (1)(C)(ii) of this subsection, if an ozone or carbon monoxide nonattainment area located within a metropolitan statistical area or consolidated metropolitan statistical area (as established by the Bureau of the Census) is classified under part D of this subchapter as a Serious, Severe, or Extreme Area, the boundaries of such area are hereby revised (on the date 45 days after such classification) by operation of law to include the entire metropolitan statistical area or consolidated metropolitan statistical area, as the case may be, unless within such 45-day period the Governor (in consultation with State and local air pollution control agencies) notifies the Administrator that additional time is necessary to evaluate the application of clause (v). Whenever a Governor has submitted such a notice to the Administrator, such boundary revision shall occur on the later of the date 8 months after such classification or 14 months after November 15, 1990, unless the Governor makes the finding referred to in clause (v), and the Administrator concurs in such finding, within such period. Except as otherwise provided in this paragraph, a boundary revision under this clause or clause (v) shall apply for purposes of any State implementation plan revision required to be submitted after November 15, 1990.

(v) Whenever the Governor of a State has submitted a notice under clause (iv), the Governor, in consultation with State and local air pollution control agencies, shall undertake a study to evaluate whether the entire metropolitan statistical area or consolidated metropolitan statistical area should be included within the nonattainment area. Whenever a Governor finds and demonstrates to the satisfaction of the Administrator, and the Administrator concurs in such finding, that with respect to a portion of a metropolitan statistical area or consolidated metropolitan statistical area, sources in the portion do not contribute significantly to violation of the national ambient air quality standard, the Administrator shall approve the Governor's request to exclude such portion from the nonattainment area. In making such finding, the Governor and the Administrator shall consider factors such as population density, traffic congestion, commercial development, industrial development, meteorological conditions, and pollution transport.

(B) PM-10 designations

By operation of law, until redesignation by the Administrator pursuant to paragraph (3)—

(i) each area identified in 52 Federal Register 29383 (Aug. 7, 1987) as a Group I area (except to the extent that such identification was modified by the Administrator

before November 15, 1990) is designated nonattainment for PM-10;

(ii) any area containing a site for which air quality monitoring data show a violation of the national ambient air quality standard for PM-10 before January 1, 1989 (as determined under part 50, appendix K of title 40 of the Code of Federal Regulations) is hereby designated nonattainment for PM-10; and

(iii) each area not described in clause (i) or (ii) is hereby designated unclassifiable for PM-10.

Any designation for particulate matter (measured in terms of total suspended particulates) that the Administrator promulgated pursuant to this subsection (as in effect immediately before November 15, 1990) shall remain in effect for purposes of implementing the maximum allowable increases in concentrations of particulate matter (measured in terms of total suspended particulates) pursuant to section 7473(b) of this title, until the Administrator determines that such designation is no longer necessary for that purpose.

(5) Designations for lead

The Administrator may, in the Administrator's discretion at any time the Administrator deems appropriate, require a State to designate areas (or portions thereof) with respect to the national ambient air quality standard for lead in effect as of November 15, 1990, in accordance with the procedures under subparagraphs (A) and (B) of paragraph (1), except that in applying subparagraph (B)(i) of paragraph (1) the phrase "2 years from the date of promulgation of the new or revised national ambient air quality standard" shall be replaced by the phrase "1 year from the date the Administrator notifies the State of the requirement to designate areas with respect to the standard for lead".

(6) Designations

(A) Submission

Notwithstanding any other provision of law, not later than February 15, 2004, the Governor of each State shall submit designations referred to in paragraph (1) for the July 1997 PM_{2.5} national ambient air quality standards for each area within the State, based on air quality monitoring data collected in accordance with any applicable Federal reference methods for the relevant areas.

(B) Promulgation

Notwithstanding any other provision of law, not later than December 31, 2004, the Administrator shall, consistent with paragraph (1), promulgate the designations referred to in subparagraph (A) for each area of each State for the July 1997 PM_{2.5} national ambient air quality standards.

(7) Implementation plan for regional haze

(A) In general

Notwithstanding any other provision of law, not later than 3 years after the date on

which the Administrator promulgates the designations referred to in paragraph (6)(B) for a State, the State shall submit, for the entire State, the State implementation plan revisions to meet the requirements promulgated by the Administrator under section 7492(e)(1) of this title (referred to in this paragraph as "regional haze requirements").

(B) No preclusion of other provisions

Nothing in this paragraph precludes the implementation of the agreements and recommendations stemming from the Grand Canyon Visibility Transport Commission Report dated June 1996, including the submission of State implementation plan revisions by the States of Arizona, California, Colorado, Idaho, Nevada, New Mexico, Oregon, Utah, or Wyoming by December 31, 2003, for implementation of regional haze requirements applicable to those States.

(e) Redesignation of air quality control regions

(1) Except as otherwise provided in paragraph (2), the Governor of each State is authorized, with the approval of the Administrator, to redesignate from time to time the air quality control regions within such State for purposes of efficient and effective air quality management. Upon such redesignation, the list under subsection (d) shall be modified accordingly.

(2) In the case of an air quality control region in a State, or part of such region, which the Administrator finds may significantly affect air pollution concentrations in another State, the Governor of the State in which such region, or part of a region, is located may redesignate from time to time the boundaries of so much of such air quality control region as is located within such State only with the approval of the Administrator and with the consent of all Governors of all States which the Administrator determines may be significantly affected.

(3) No compliance date extension granted under section 7413(d)(5)¹ of this title (relating to coal conversion) shall cease to be effective by reason of the regional limitation provided in section 7413(d)(5)¹ of this title if the violation of such limitation is due solely to a redesignation of a region under this subsection.

(July 14, 1955, ch. 360, title I, § 107, as added Pub. L. 91-604, § 4(a), Dec. 31, 1970, 84 Stat. 1678; amended Pub. L. 95-95, title I, § 103, Aug. 7, 1977, 91 Stat. 687; Pub. L. 101-549, title I, § 101(a), Nov. 15, 1990, 104 Stat. 2399; Pub. L. 108-199, div. G, title IV, § 425(a), Jan. 23, 2004, 118 Stat. 417.)

Editorial Notes

REFERENCES IN TEXT

Section 7413 of this title, referred to in subsec. (e)(3), was amended generally by Pub. L. 101-549, title VII, § 701, Nov. 15, 1990, 104 Stat. 2672, and, as so amended, subsec. (d) of section 7413 no longer relates to final compliance orders.

CODIFICATION

Section was formerly classified to section 1857c-2 of this title.

¹ See References in Text note below.

PRIOR PROVISIONS

A prior section 107 of act July 14, 1955, as added Nov. 21, 1967, Pub. L. 90-148, § 2, 81 Stat. 490, related to air quality control regions and was classified to section 1857c-2 of this title, prior to repeal by Pub. L. 91-604.

Another prior section 107 of act July 14, 1955, as added Dec. 17, 1963, Pub. L. 88-206, § 1, 77 Stat. 399, was renumbered section 111 by Pub. L. 90-148 and is classified to section 7411 of this title.

AMENDMENTS

2004—Subsec. (d)(6), (7). Pub. L. 108-199 added pars. (6) and (7).

1990—Subsec. (d). Pub. L. 101-549 amended subsec. (d) generally, substituting present provisions for provisions which required States to submit lists of regions not in compliance on Aug. 7, 1977, with certain air quality standards to be submitted to the Administrator, and which authorized States to revise and resubmit such lists from time to time.

1977—Subsecs. (d), (e). Pub. L. 95-95 added subsecs. (d) and (e).

Statutory Notes and Related Subsidiaries

EFFECTIVE DATE OF 1977 AMENDMENT

Amendment by Pub. L. 95-95 effective Aug. 7, 1977, except as otherwise expressly provided, see section 406(d) of Pub. L. 95-95, set out as a note under section 7401 of this title.

OZONE AND PARTICULATE MATTER STANDARDS

Pub. L. 108-199, div. G, title IV, § 425(b), Jan. 23, 2004, 118 Stat. 417, provided that: "Except as provided in paragraphs (6) and (7) of section 107(d) of the Clean Air Act [subsec. (d)(6), (7) of this section] (as added by subsection (a)), section 6101, subsections (a) and (b) of section 6102, and section 6103 of the Transportation Equity Act for the 21st Century [Pub. L. 105-178] (42 U.S.C. 7407 note; 112 Stat. 463), as in effect on the day before the date of enactment of this Act [Jan. 23, 2004], shall remain in effect."

Pub. L. 105-178, title VI, June 9, 1998, 112 Stat. 463, as amended by Pub. L. 109-59, title VI, § 6012(a), Aug. 10, 2005, 119 Stat. 1882, provided that:

"SEC. 6101. FINDINGS AND PURPOSE.

"(a) The Congress finds that—

"(1) there is a lack of air quality monitoring data for fine particle levels, measured as PM_{2.5}, in the United States and the States should receive full funding for the monitoring efforts;

"(2) such data would provide a basis for designating areas as attainment or nonattainment for any PM_{2.5} national ambient air quality standards pursuant to the standards promulgated in July 1997;

"(3) the President of the United States directed the Administrator of the Environmental Protection Agency (referred to in this title as the 'Administrator') in a memorandum dated July 16, 1997, to complete the next periodic review of the particulate matter national ambient air quality standards by July 2002 in order to determine 'whether to revise or maintain the standards';

"(4) the Administrator has stated that 3 years of air quality monitoring data for fine particle levels, measured as PM_{2.5} and performed in accordance with any applicable Federal reference methods, is appropriate for designating areas as attainment or nonattainment pursuant to the July 1997 promulgated standards; and

"(5) the Administrator has acknowledged that in drawing boundaries for attainment and nonattainment areas for the July 1997 ozone national air quality standards, Governors would benefit from considering implementation guidance from EPA on drawing area boundaries.

"(b) The purposes of this title are—

"(1) to ensure that 3 years of air quality monitoring data regarding fine particle levels are gathered for

use in the determination of area attainment or nonattainment designations respecting any PM_{2.5} national ambient air quality standards;

"(2) to ensure that the Governors have adequate time to consider implementation guidance from EPA on drawing area boundaries prior to submitting area designations respecting the July 1997 ozone national ambient air quality standards;

"(3) to ensure that the schedule for implementation of the July 1997 revisions of the ambient air quality standards for particulate matter and the schedule for the Environmental Protection Agency's visibility regulations related to regional haze are consistent with the timetable for implementation of such particulate matter standards as set forth in the President's Implementation Memorandum dated July 16, 1997.

"SEC. 6102. PARTICULATE MATTER MONITORING PROGRAM.

"(a) Through grants under section 103 of the Clean Air Act [42 U.S.C. 7403] the Administrator of the Environmental Protection Agency shall use appropriated funds no later than fiscal year 2000 to fund 100 percent of the cost of the establishment, purchase, operation and maintenance of a PM_{2.5} monitoring network necessary to implement the national ambient air quality standards for PM_{2.5} under section 109 of the Clean Air Act [42 U.S.C. 7409]. This implementation shall not result in a diversion or reprogramming of funds from other Federal, State or local Clean Air Act activities. Any funds previously diverted or reprogrammed from section 105 Clean Air Act [42 U.S.C. 7405] grants for PM_{2.5} monitors must be restored to State or local air programs in fiscal year 1999.

"(b) EPA and the States, consistent with their respective authorities under the Clean Air Act [42 U.S.C. 7401 et seq.], shall ensure that the national network (designated in subsection (a)) which consists of the PM_{2.5} monitors necessary to implement the national ambient air quality standards is established by December 31, 1999.

"(c)(1) The Governors shall be required to submit designations referred to in section 107(d)(1) of the Clean Air Act [42 U.S.C. 7407(d)(1)] for each area following promulgation of the July 1997 PM_{2.5} national ambient air quality standard within 1 year after receipt of 3 years of air quality monitoring data performed in accordance with any applicable Federal reference methods for the relevant areas. Only data from the monitoring network designated in subsection (a) and other Federal reference method PM_{2.5} monitors shall be considered for such designations. Nothing in the previous sentence shall be construed as affecting the Governor's authority to designate an area initially as nonattainment, and the Administrator's authority to promulgate the designation of an area as nonattainment, under section 107(d)(1) of the Clean Air Act, based on its contribution to ambient air quality in a nearby nonattainment area.

"(2) For any area designated as nonattainment for the July 1997 PM_{2.5} national ambient air quality standard in accordance with the schedule set forth in this section, notwithstanding the time limit prescribed in paragraph (2) of section 169B(e) of the Clean Air Act [42 U.S.C. 7492(e)(2)], the Administrator shall require State implementation plan revisions referred to in such paragraph (2) to be submitted at the same time as State implementation plan revisions referred to in section 172 of the Clean Air Act [42 U.S.C. 7502] implementing the revised national ambient air quality standard for fine particulate matter are required to be submitted. For any area designated as attainment or unclassifiable for such standard, the Administrator shall require the State implementation plan revisions referred to in such paragraph (2) to be submitted 1 year after the area has been so designated. The preceding provisions of this paragraph shall not preclude the implementation of the agreements and recommendations set forth in the Grand Canyon Visibility Transport Commission Report dated June 1996.

“(d) The Administrator shall promulgate the designations referred to in section 107(d)(1) of the Clean Air Act [42 U.S.C. 7407(d)(1)] for each area following promulgation of the July 1997 PM_{2.5} national ambient air quality standard by the earlier of 1 year after the initial designations required under subsection (c)(1) are required to be submitted or December 31, 2005.

“(e) FIELD STUDY.—Not later than 2 years after the date of enactment of the SAFETEA-LU [Aug. 10, 2005], the Administrator shall—

“(1) conduct a field study of the ability of the PM_{2.5} Federal Reference Method to differentiate those particles that are larger than 2.5 micrometers in diameter;

“(2) develop a Federal reference method to measure directly particles that are larger than 2.5 micrometers in diameter without reliance on subtracting from coarse particle measurements those particles that are equal to or smaller than 2.5 micrometers in diameter;

“(3) develop a method of measuring the composition of coarse particles; and

“(4) submit a report on the study and responsibilities of the Administrator under paragraphs (1) through (3) to—

“(A) the Committee on Energy and Commerce of the House of Representatives; and

“(B) the Committee on Environment and Public Works of the Senate.

“SEC. 6103. OZONE DESIGNATION REQUIREMENTS.

“(a) The Governors shall be required to submit the designations referred to in section 107(d)(1) of the Clean Air Act [42 U.S.C. 7407(d)(1)] within 2 years following the promulgation of the July 1997 ozone national ambient air quality standards.

“(b) The Administrator shall promulgate final designations no later than 1 year after the designations required under subsection (a) are required to be submitted.

“SEC. 6104. ADDITIONAL PROVISIONS.

“Nothing in sections 6101 through 6103 shall be construed by the Administrator of Environmental Protection Agency or any court, State, or person to affect any pending litigation or to be a ratification of the ozone or PM_{2.5} standards.”

PENDING ACTIONS AND PROCEEDINGS

Suits, actions, and other proceedings lawfully commenced by or against the Administrator or any other officer or employee of the United States in his official capacity or in relation to the discharge of his official duties under act July 14, 1955, the Clean Air Act, as in effect immediately prior to the enactment of Pub. L. 95-95 [Aug. 7, 1977], not to abate by reason of the taking effect of Pub. L. 95-95, see section 406(a) of Pub. L. 95-95, set out as an Effective Date of 1977 Amendment note under section 7401 of this title.

MODIFICATION OR RESCISSION OF RULES, REGULATIONS, ORDERS, DETERMINATIONS, CONTRACTS, CERTIFICATIONS, AUTHORIZATIONS, DELEGATIONS, AND OTHER ACTIONS

All rules, regulations, orders, determinations, contracts, certifications, authorizations, delegations, or other actions duly issued, made, or taken by or pursuant to act July 14, 1955, the Clean Air Act, as in effect immediately prior to the date of enactment of Pub. L. 95-95 [Aug. 7, 1977] to continue in full force and effect until modified or rescinded in accordance with act July 14, 1955, as amended by Pub. L. 95-95 [this chapter], see section 406(b) of Pub. L. 95-95, set out as an Effective Date of 1977 Amendment note under section 7401 of this title.

§ 7408. Air quality criteria and control techniques

(a) Air pollutant list; publication and revision by Administrator; issuance of air quality criteria for air pollutants

(1) For the purpose of establishing national primary and secondary ambient air quality standards, the Administrator shall within 30 days after December 31, 1970, publish, and shall from time to time thereafter revise, a list which includes each air pollutant—

(A) emissions of which, in his judgment, cause or contribute to air pollution which may reasonably be anticipated to endanger public health or welfare;

(B) the presence of which in the ambient air results from numerous or diverse mobile or stationary sources; and

(C) for which air quality criteria had not been issued before December 31, 1970 but for which he plans to issue air quality criteria under this section.

(2) The Administrator shall issue air quality criteria for an air pollutant within 12 months after he has included such pollutant in a list under paragraph (1). Air quality criteria for an air pollutant shall accurately reflect the latest scientific knowledge useful in indicating the kind and extent of all identifiable effects on public health or welfare which may be expected from the presence of such pollutant in the ambient air, in varying quantities. The criteria for an air pollutant, to the extent practicable, shall include information on—

(A) those variable factors (including atmospheric conditions) which of themselves or in combination with other factors may alter the effects on public health or welfare of such air pollutant;

(B) the types of air pollutants which, when present in the atmosphere, may interact with such pollutant to produce an adverse effect on public health or welfare; and

(C) any known or anticipated adverse effects on welfare.

(b) Issuance by Administrator of information on air pollution control techniques; standing consulting committees for air pollutants; establishment; membership

(1) Simultaneously with the issuance of criteria under subsection (a), the Administrator shall, after consultation with appropriate advisory committees and Federal departments and agencies, issue to the States and appropriate air pollution control agencies information on air pollution control techniques, which information shall include data relating to the cost of installation and operation, energy requirements, emission reduction benefits, and environmental impact of the emission control technology. Such information shall include such data as are available on available technology and alternative methods of prevention and control of air pollution. Such information shall also include data on alternative fuels, processes, and operating methods which will result in elimination or significant reduction of emissions.

(2) In order to assist in the development of information on pollution control techniques, the

“(d) The Administrator shall promulgate the designations referred to in section 107(d)(1) of the Clean Air Act [42 U.S.C. 7407(d)(1)] for each area following promulgation of the July 1997 PM_{2.5} national ambient air quality standard by the earlier of 1 year after the initial designations required under subsection (c)(1) are required to be submitted or December 31, 2005.

“(e) FIELD STUDY.—Not later than 2 years after the date of enactment of the SAFETEA-LU [Aug. 10, 2005], the Administrator shall—

“(1) conduct a field study of the ability of the PM_{2.5} Federal Reference Method to differentiate those particles that are larger than 2.5 micrometers in diameter;

“(2) develop a Federal reference method to measure directly particles that are larger than 2.5 micrometers in diameter without reliance on subtracting from coarse particle measurements those particles that are equal to or smaller than 2.5 micrometers in diameter;

“(3) develop a method of measuring the composition of coarse particles; and

“(4) submit a report on the study and responsibilities of the Administrator under paragraphs (1) through (3) to—

“(A) the Committee on Energy and Commerce of the House of Representatives; and

“(B) the Committee on Environment and Public Works of the Senate.

“SEC. 6103. OZONE DESIGNATION REQUIREMENTS.

“(a) The Governors shall be required to submit the designations referred to in section 107(d)(1) of the Clean Air Act [42 U.S.C. 7407(d)(1)] within 2 years following the promulgation of the July 1997 ozone national ambient air quality standards.

“(b) The Administrator shall promulgate final designations no later than 1 year after the designations required under subsection (a) are required to be submitted.

“SEC. 6104. ADDITIONAL PROVISIONS.

“Nothing in sections 6101 through 6103 shall be construed by the Administrator of Environmental Protection Agency or any court, State, or person to affect any pending litigation or to be a ratification of the ozone or PM_{2.5} standards.”

PENDING ACTIONS AND PROCEEDINGS

Suits, actions, and other proceedings lawfully commenced by or against the Administrator or any other officer or employee of the United States in his official capacity or in relation to the discharge of his official duties under act July 14, 1955, the Clean Air Act, as in effect immediately prior to the enactment of Pub. L. 95-95 [Aug. 7, 1977], not to abate by reason of the taking effect of Pub. L. 95-95, see section 406(a) of Pub. L. 95-95, set out as an Effective Date of 1977 Amendment note under section 7401 of this title.

MODIFICATION OR RESCISSION OF RULES, REGULATIONS, ORDERS, DETERMINATIONS, CONTRACTS, CERTIFICATIONS, AUTHORIZATIONS, DELEGATIONS, AND OTHER ACTIONS

All rules, regulations, orders, determinations, contracts, certifications, authorizations, delegations, or other actions duly issued, made, or taken by or pursuant to act July 14, 1955, the Clean Air Act, as in effect immediately prior to the date of enactment of Pub. L. 95-95 [Aug. 7, 1977] to continue in full force and effect until modified or rescinded in accordance with act July 14, 1955, as amended by Pub. L. 95-95 [this chapter], see section 406(b) of Pub. L. 95-95, set out as an Effective Date of 1977 Amendment note under section 7401 of this title.

§ 7408. Air quality criteria and control techniques

(a) Air pollutant list; publication and revision by Administrator; issuance of air quality criteria for air pollutants

(1) For the purpose of establishing national primary and secondary ambient air quality standards, the Administrator shall within 30 days after December 31, 1970, publish, and shall from time to time thereafter revise, a list which includes each air pollutant—

(A) emissions of which, in his judgment, cause or contribute to air pollution which may reasonably be anticipated to endanger public health or welfare;

(B) the presence of which in the ambient air results from numerous or diverse mobile or stationary sources; and

(C) for which air quality criteria had not been issued before December 31, 1970 but for which he plans to issue air quality criteria under this section.

(2) The Administrator shall issue air quality criteria for an air pollutant within 12 months after he has included such pollutant in a list under paragraph (1). Air quality criteria for an air pollutant shall accurately reflect the latest scientific knowledge useful in indicating the kind and extent of all identifiable effects on public health or welfare which may be expected from the presence of such pollutant in the ambient air, in varying quantities. The criteria for an air pollutant, to the extent practicable, shall include information on—

(A) those variable factors (including atmospheric conditions) which of themselves or in combination with other factors may alter the effects on public health or welfare of such air pollutant;

(B) the types of air pollutants which, when present in the atmosphere, may interact with such pollutant to produce an adverse effect on public health or welfare; and

(C) any known or anticipated adverse effects on welfare.

(b) Issuance by Administrator of information on air pollution control techniques; standing consulting committees for air pollutants; establishment; membership

(1) Simultaneously with the issuance of criteria under subsection (a), the Administrator shall, after consultation with appropriate advisory committees and Federal departments and agencies, issue to the States and appropriate air pollution control agencies information on air pollution control techniques, which information shall include data relating to the cost of installation and operation, energy requirements, emission reduction benefits, and environmental impact of the emission control technology. Such information shall include such data as are available on available technology and alternative methods of prevention and control of air pollution. Such information shall also include data on alternative fuels, processes, and operating methods which will result in elimination or significant reduction of emissions.

(2) In order to assist in the development of information on pollution control techniques, the

Administrator may establish a standing consulting committee for each air pollutant included in a list published pursuant to subsection (a)(1), which shall be comprised of technically qualified individuals representative of State and local governments, industry, and the academic community. Each such committee shall submit, as appropriate, to the Administrator information related to that required by paragraph (1).

(c) Review, modification, and reissuance of criteria or information

The Administrator shall from time to time review, and, as appropriate, modify, and reissue any criteria or information on control techniques issued pursuant to this section. Not later than six months after August 7, 1977, the Administrator shall revise and reissue criteria relating to concentrations of NO₂ over such period (not more than three hours) as he deems appropriate. Such criteria shall include a discussion of nitric and nitrous acids, nitrites, nitrates, nitrosamines, and other carcinogenic and potentially carcinogenic derivatives of oxides of nitrogen.

(d) Publication in Federal Register; availability of copies for general public

The issuance of air quality criteria and information on air pollution control techniques shall be announced in the Federal Register and copies shall be made available to the general public.

(e) Transportation planning and guidelines

The Administrator shall, after consultation with the Secretary of Transportation, and after providing public notice and opportunity for comment, and with State and local officials, within nine months after November 15, 1990,¹ and periodically thereafter as necessary to maintain a continuous transportation-air quality planning process, update the June 1978 Transportation-Air Quality Planning Guidelines and publish guidance on the development and implementation of transportation and other measures necessary to demonstrate and maintain attainment of national ambient air quality standards. Such guidelines shall include information on—

- (1) methods to identify and evaluate alternative planning and control activities;
- (2) methods of reviewing plans on a regular basis as conditions change or new information is presented;
- (3) identification of funds and other resources necessary to implement the plan, including interagency agreements on providing such funds and resources;
- (4) methods to assure participation by the public in all phases of the planning process; and
- (5) such other methods as the Administrator determines necessary to carry out a continuous planning process.

(f) Information regarding processes, procedures, and methods to reduce or control pollutants in transportation; reduction of mobile source related pollutants; reduction of impact on public health

(1) The Administrator shall publish and make available to appropriate Federal, State, and

local environmental and transportation agencies not later than one year after November 15, 1990, and from time to time thereafter—

(A) information prepared, as appropriate, in consultation with the Secretary of Transportation, and after providing public notice and opportunity for comment, regarding the formulation and emission reduction potential of transportation control measures related to criteria pollutants and their precursors, including, but not limited to—

- (i) programs for improved public transit;
- (ii) restriction of certain roads or lanes to, or construction of such roads or lanes for use by, passenger buses or high occupancy vehicles;
- (iii) employer-based transportation management plans, including incentives;
- (iv) trip-reduction ordinances;
- (v) traffic flow improvement programs that achieve emission reductions;
- (vi) fringe and transportation corridor parking facilities serving multiple occupancy vehicle programs or transit service;
- (vii) programs to limit or restrict vehicle use in downtown areas or other areas of emission concentration particularly during periods of peak use;
- (viii) programs for the provision of all forms of high-occupancy, shared-ride services;
- (ix) programs to limit portions of road surfaces or certain sections of the metropolitan area to the use of non-motorized vehicles or pedestrian use, both as to time and place;
- (x) programs for secure bicycle storage facilities and other facilities, including bicycle lanes, for the convenience and protection of bicyclists, in both public and private areas;
- (xi) programs to control extended idling of vehicles;
- (xii) programs to reduce motor vehicle emissions, consistent with subchapter II, which are caused by extreme cold start conditions;
- (xiii) employer-sponsored programs to permit flexible work schedules;
- (xiv) programs and ordinances to facilitate non-automobile travel, provision and utilization of mass transit, and to generally reduce the need for single-occupant vehicle travel, as part of transportation planning and development efforts of a locality, including programs and ordinances applicable to new shopping centers, special events, and other centers of vehicle activity;
- (xv) programs for new construction and major reconstructions of paths, tracks or areas solely for the use by pedestrian or other non-motorized means of transportation when economically feasible and in the public interest. For purposes of this clause, the Administrator shall also consult with the Secretary of the Interior; and
- (xvi) program to encourage the voluntary removal from use and the marketplace of pre-1980 model year light duty vehicles and pre-1980 model light duty trucks.²

¹ See Codification note below.

² So in original. The period probably should be a semicolon.

(B) information on additional methods or strategies that will contribute to the reduction of mobile source related pollutants during periods in which any primary ambient air quality standard will be exceeded and during episodes for which an air pollution alert, warning, or emergency has been declared;

(C) information on other measures which may be employed to reduce the impact on public health or protect the health of sensitive or susceptible individuals or groups; and

(D) information on the extent to which any process, procedure, or method to reduce or control such air pollutant may cause an increase in the emissions or formation of any other pollutant.

(2) In publishing such information the Administrator shall also include an assessment of—

(A) the relative effectiveness of such processes, procedures, and methods;

(B) the potential effect of such processes, procedures, and methods on transportation systems and the provision of transportation services; and

(C) the environmental, energy, and economic impact of such processes, procedures, and methods.

(g) Assessment of risks to ecosystems

The Administrator may assess the risks to ecosystems from exposure to criteria air pollutants (as identified by the Administrator in the Administrator's sole discretion).

(h) RACT/BACT/LAER clearinghouse

The Administrator shall make information regarding emission control technology available to the States and to the general public through a central database. Such information shall include all control technology information received pursuant to State plan provisions requiring permits for sources, including operating permits for existing sources.

(July 14, 1955, ch. 360, title I, § 108, as added Pub. L. 91-604, § 4(a), Dec. 31, 1970, 84 Stat. 1678; amended Pub. L. 95-95, title I, §§ 104, 105, title IV, § 401(a), Aug. 7, 1977, 91 Stat. 689, 790; Pub. L. 101-549, title I, §§ 108(a)-(c), (o), 111, Nov. 15, 1990, 104 Stat. 2465, 2466, 2469, 2470; Pub. L. 105-362, title XV, § 1501(b), Nov. 10, 1998, 112 Stat. 3294.)

Editorial Notes

CODIFICATION

November 15, 1990, referred to in subsec. (e), was in the original "enactment of the Clean Air Act Amendments of 1989", and was translated as meaning the date of the enactment of Pub. L. 101-549, popularly known as the Clean Air Act Amendments of 1990, to reflect the probable intent of Congress.

Section was formerly classified to section 1857c-3 of this title.

PRIOR PROVISIONS

A prior section 108 of act July 14, 1955, was renumbered section 115 by Pub. L. 91-604 and is classified to section 7415 of this title.

AMENDMENTS

1998—Subsec. (f)(3), (4). Pub. L. 105-362 struck out par. (3), which required reports by the Secretary of Transportation and the Administrator to be submitted to

Congress by Jan. 1, 1993, and every 3 years thereafter, reviewing and analyzing existing State and local air quality related transportation programs, evaluating achievement of goals, and recommending changes to existing programs, and par. (4), which required that in each report after the first report the Secretary of Transportation include a description of the actions taken to implement the changes recommended in the preceding report.

1990—Subsec. (e). Pub. L. 101-549, § 108(a), inserted first sentence and struck out former first sentence which read as follows: "The Administrator shall, after consultation with the Secretary of Transportation and the Secretary of Housing and Urban Development and State and local officials and within 180 days after August 7, 1977, and from time to time thereafter, publish guidelines on the basic program elements for the planning process assisted under section 7505 of this title."

Subsec. (f)(1). Pub. L. 101-549, § 108(b), in introductory provisions, substituted present provisions for provisions relating to Federal agencies, States, and air pollution control agencies within either 6 months or one year after Aug. 7, 1977.

Subsec. (f)(1)(A). Pub. L. 101-549, § 108(b), substituted present provisions for provisions relating to information prepared in cooperation with Secretary of Transportation, regarding processes, procedures, and methods to reduce certain pollutants.

Subsec. (f)(3), (4). Pub. L. 101-549, § 111, added pars. (3) and (4).

Subsec. (g). Pub. L. 101-549, § 108(o), added subsec. (g).

Subsec. (h). Pub. L. 101-549, § 108(c), added subsec. (h).

1977—Subsec. (a)(1)(A). Pub. L. 95-95, § 401(a), substituted "emissions of which, in his judgment, cause or contribute to air pollution which may reasonably be anticipated to endanger public health or welfare" for "which in his judgment has an adverse effect on public health or welfare".

Subsec. (b)(1). Pub. L. 95-95, § 104(a), substituted "cost of installation and operation, energy requirements, emission reduction benefits, and environmental impact of the emission control technology" for "technology and costs of emission control".

Subsec. (c). Pub. L. 95-95, § 104(b), inserted provision directing the Administrator, not later than six months after Aug. 7, 1977, to revise and reissue criteria relating to concentrations of NO₂ over such period (not more than three hours) as he deems appropriate, with the criteria to include a discussion of nitric and nitrous acids, nitrites, nitrates, nitrosamines, and other carcinogenic and potentially carcinogenic derivatives of oxides of nitrogen.

Subsecs. (e), (f). Pub. L. 95-95, § 105, added subsecs. (e) and (f).

Statutory Notes and Related Subsidiaries

EFFECTIVE DATE OF 1977 AMENDMENT

Amendment by Pub. L. 95-95 effective Aug. 7, 1977, except as otherwise expressly provided, see section 406(d) of Pub. L. 95-95, set out as a note under section 7401 of this title.

MODIFICATION OR RESCISSION OF RULES, REGULATIONS, ORDERS, DETERMINATIONS, CONTRACTS, CERTIFICATIONS, AUTHORIZATIONS, DELEGATIONS, AND OTHER ACTIONS

All rules, regulations, orders, determinations, contracts, certifications, authorizations, delegations, or other actions duly issued, made, or taken by or pursuant to act July 14, 1955, the Clean Air Act, as in effect immediately prior to the date of enactment of Pub. L. 95-95 [Aug. 7, 1977] to continue in full force and effect until modified or rescinded in accordance with act July 14, 1955, as amended by Pub. L. 95-95 [this chapter], see section 406(b) of Pub. L. 95-95, set out as an Effective Date of 1977 Amendment note under section 7401 of this title.

§ 7409. National primary and secondary ambient air quality standards

(a) Promulgation

(1) The Administrator—

(A) within 30 days after December 31, 1970, shall publish proposed regulations prescribing a national primary ambient air quality standard and a national secondary ambient air quality standard for each air pollutant for which air quality criteria have been issued prior to such date; and

(B) after a reasonable time for interested persons to submit written comments thereon (but no later than 90 days after the initial publication of such proposed standards) shall by regulation promulgate such proposed national primary and secondary ambient air quality standards with such modifications as he deems appropriate.

(2) With respect to any air pollutant for which air quality criteria are issued after December 31, 1970, the Administrator shall publish, simultaneously with the issuance of such criteria and information, proposed national primary and secondary ambient air quality standards for any such pollutant. The procedure provided for in paragraph (1)(B) of this subsection shall apply to the promulgation of such standards.

(b) Protection of public health and welfare

(1) National primary ambient air quality standards, prescribed under subsection (a) shall be ambient air quality standards the attainment and maintenance of which in the judgment of the Administrator, based on such criteria and allowing an adequate margin of safety, are requisite to protect the public health. Such primary standards may be revised in the same manner as promulgated.

(2) Any national secondary ambient air quality standard prescribed under subsection (a) shall specify a level of air quality the attainment and maintenance of which in the judgment of the Administrator, based on such criteria, is requisite to protect the public welfare from any known or anticipated adverse effects associated with the presence of such air pollutant in the ambient air. Such secondary standards may be revised in the same manner as promulgated.

(c) National primary ambient air quality standard for nitrogen dioxide

The Administrator shall, not later than one year after August 7, 1977, promulgate a national primary ambient air quality standard for NO₂ concentrations over a period of not more than 3 hours unless, based on the criteria issued under section 7408(c) of this title, he finds that there is no significant evidence that such a standard for such a period is requisite to protect public health.

(d) Review and revision of criteria and standards; independent scientific review committee; appointment; advisory functions

(1) Not later than December 31, 1980, and at five-year intervals thereafter, the Administrator shall complete a thorough review of the criteria published under section 7408 of this title and the national ambient air quality standards promulgated under this section and shall make such re-

visions in such criteria and standards and promulgate such new standards as may be appropriate in accordance with section 7408 of this title and subsection (b) of this section. The Administrator may review and revise criteria or promulgate new standards earlier or more frequently than required under this paragraph.

(2)(A) The Administrator shall appoint an independent scientific review committee composed of seven members including at least one member of the National Academy of Sciences, one physician, and one person representing State air pollution control agencies.

(B) Not later than January 1, 1980, and at five-year intervals thereafter, the committee referred to in subparagraph (A) shall complete a review of the criteria published under section 7408 of this title and the national primary and secondary ambient air quality standards promulgated under this section and shall recommend to the Administrator any new national ambient air quality standards and revisions of existing criteria and standards as may be appropriate under section 7408 of this title and subsection (b) of this section.

(C) Such committee shall also (i) advise the Administrator of areas in which additional knowledge is required to appraise the adequacy and basis of existing, new, or revised national ambient air quality standards, (ii) describe the research efforts necessary to provide the required information, (iii) advise the Administrator on the relative contribution to air pollution concentrations of natural as well as anthropogenic activity, and (iv) advise the Administrator of any adverse public health, welfare, social, economic, or energy effects which may result from various strategies for attainment and maintenance of such national ambient air quality standards.

(July 14, 1955, ch. 360, title I, §109, as added Pub. L. 91-604, §4(a), Dec. 31, 1970, 84 Stat. 1679; amended Pub. L. 95-95, title I, §106, Aug. 7, 1977, 91 Stat. 691.)

Editorial Notes

CODIFICATION

Section was formerly classified to section 1857c-4 of this title.

PRIOR PROVISIONS

A prior section 109 of act July 14, 1955, was renumbered section 116 by Pub. L. 91-604 and is classified to section 7416 of this title.

AMENDMENTS

1977—Subsec. (c). Pub. L. 95-95, §106(b), added subsec. (c).

Subsec. (d). Pub. L. 95-95, §106(a), added subsec. (d).

Statutory Notes and Related Subsidiaries

EFFECTIVE DATE OF 1977 AMENDMENT

Amendment by Pub. L. 95-95 effective Aug. 7, 1977, except as otherwise expressly provided, see section 406(d) of Pub. L. 95-95, set out as a note under section 7401 of this title.

MODIFICATION OR RESCISSION OF RULES, REGULATIONS, ORDERS, DETERMINATIONS, CONTRACTS, CERTIFICATIONS, AUTHORIZATIONS, DELEGATIONS, AND OTHER ACTIONS

All rules, regulations, orders, determinations, contracts, certifications, authorizations, delegations, or

§ 7409. National primary and secondary ambient air quality standards

(a) Promulgation

(1) The Administrator—

(A) within 30 days after December 31, 1970, shall publish proposed regulations prescribing a national primary ambient air quality standard and a national secondary ambient air quality standard for each air pollutant for which air quality criteria have been issued prior to such date; and

(B) after a reasonable time for interested persons to submit written comments thereon (but no later than 90 days after the initial publication of such proposed standards) shall by regulation promulgate such proposed national primary and secondary ambient air quality standards with such modifications as he deems appropriate.

(2) With respect to any air pollutant for which air quality criteria are issued after December 31, 1970, the Administrator shall publish, simultaneously with the issuance of such criteria and information, proposed national primary and secondary ambient air quality standards for any such pollutant. The procedure provided for in paragraph (1)(B) of this subsection shall apply to the promulgation of such standards.

(b) Protection of public health and welfare

(1) National primary ambient air quality standards, prescribed under subsection (a) shall be ambient air quality standards the attainment and maintenance of which in the judgment of the Administrator, based on such criteria and allowing an adequate margin of safety, are requisite to protect the public health. Such primary standards may be revised in the same manner as promulgated.

(2) Any national secondary ambient air quality standard prescribed under subsection (a) shall specify a level of air quality the attainment and maintenance of which in the judgment of the Administrator, based on such criteria, is requisite to protect the public welfare from any known or anticipated adverse effects associated with the presence of such air pollutant in the ambient air. Such secondary standards may be revised in the same manner as promulgated.

(c) National primary ambient air quality standard for nitrogen dioxide

The Administrator shall, not later than one year after August 7, 1977, promulgate a national primary ambient air quality standard for NO₂ concentrations over a period of not more than 3 hours unless, based on the criteria issued under section 7408(c) of this title, he finds that there is no significant evidence that such a standard for such a period is requisite to protect public health.

(d) Review and revision of criteria and standards; independent scientific review committee; appointment; advisory functions

(1) Not later than December 31, 1980, and at five-year intervals thereafter, the Administrator shall complete a thorough review of the criteria published under section 7408 of this title and the national ambient air quality standards promulgated under this section and shall make such re-

visions in such criteria and standards and promulgate such new standards as may be appropriate in accordance with section 7408 of this title and subsection (b) of this section. The Administrator may review and revise criteria or promulgate new standards earlier or more frequently than required under this paragraph.

(2)(A) The Administrator shall appoint an independent scientific review committee composed of seven members including at least one member of the National Academy of Sciences, one physician, and one person representing State air pollution control agencies.

(B) Not later than January 1, 1980, and at five-year intervals thereafter, the committee referred to in subparagraph (A) shall complete a review of the criteria published under section 7408 of this title and the national primary and secondary ambient air quality standards promulgated under this section and shall recommend to the Administrator any new national ambient air quality standards and revisions of existing criteria and standards as may be appropriate under section 7408 of this title and subsection (b) of this section.

(C) Such committee shall also (i) advise the Administrator of areas in which additional knowledge is required to appraise the adequacy and basis of existing, new, or revised national ambient air quality standards, (ii) describe the research efforts necessary to provide the required information, (iii) advise the Administrator on the relative contribution to air pollution concentrations of natural as well as anthropogenic activity, and (iv) advise the Administrator of any adverse public health, welfare, social, economic, or energy effects which may result from various strategies for attainment and maintenance of such national ambient air quality standards.

(July 14, 1955, ch. 360, title I, §109, as added Pub. L. 91-604, §4(a), Dec. 31, 1970, 84 Stat. 1679; amended Pub. L. 95-95, title I, §106, Aug. 7, 1977, 91 Stat. 691.)

Editorial Notes

CODIFICATION

Section was formerly classified to section 1857c-4 of this title.

PRIOR PROVISIONS

A prior section 109 of act July 14, 1955, was renumbered section 116 by Pub. L. 91-604 and is classified to section 7416 of this title.

AMENDMENTS

1977—Subsec. (c). Pub. L. 95-95, §106(b), added subsec. (c).

Subsec. (d). Pub. L. 95-95, §106(a), added subsec. (d).

Statutory Notes and Related Subsidiaries

EFFECTIVE DATE OF 1977 AMENDMENT

Amendment by Pub. L. 95-95 effective Aug. 7, 1977, except as otherwise expressly provided, see section 406(d) of Pub. L. 95-95, set out as a note under section 7401 of this title.

MODIFICATION OR RESCISSION OF RULES, REGULATIONS, ORDERS, DETERMINATIONS, CONTRACTS, CERTIFICATIONS, AUTHORIZATIONS, DELEGATIONS, AND OTHER ACTIONS

All rules, regulations, orders, determinations, contracts, certifications, authorizations, delegations, or

other actions duly issued, made, or taken by or pursuant to act July 14, 1955, the Clean Air Act, as in effect immediately prior to the date of enactment of Pub. L. 95-95 [Aug. 7, 1977] to continue in full force and effect until modified or rescinded in accordance with act July 14, 1955, as amended by Pub. L. 95-95 [this chapter], see section 406(b) of Pub. L. 95-95, set out as an Effective Date of 1977 Amendment note under section 7401 of this title.

TERMINATION OF ADVISORY COMMITTEES

Advisory committees established after Jan. 5, 1973, to terminate not later than the expiration of the 2-year period beginning on the date of their establishment, unless, in the case of a committee established by the President or an officer of the Federal Government, such committee is renewed by appropriate action prior to the expiration of such 2-year period, or in the case of a committee established by the Congress, its duration is otherwise provided for by law. See section 14 of Pub. L. 92-463, Oct. 6, 1972, 86 Stat. 776, set out in the Appendix to Title 5, Government Organization and Employees.

ROLE OF SECONDARY STANDARDS

Pub. L. 101-549, title VIII, §817, Nov. 15, 1990, 104 Stat. 2697, provided that:

“(a) REPORT.—The Administrator shall request the National Academy of Sciences to prepare a report to the Congress on the role of national secondary ambient air quality standards in protecting welfare and the environment. The report shall:

“(1) include information on the effects on welfare and the environment which are caused by ambient concentrations of pollutants listed pursuant to section 108 [42 U.S.C. 7408] and other pollutants which may be listed;

“(2) estimate welfare and environmental costs incurred as a result of such effects;

“(3) examine the role of secondary standards and the State implementation planning process in preventing such effects;

“(4) determine ambient concentrations of each such pollutant which would be adequate to protect welfare and the environment from such effects;

“(5) estimate the costs and other impacts of meeting secondary standards; and

“(6) consider other means consistent with the goals and objectives of the Clean Air Act [42 U.S.C. 7401 et seq.] which may be more effective than secondary standards in preventing or mitigating such effects.

“(b) SUBMISSION TO CONGRESS; COMMENTS; AUTHORIZATION.—(1) The report shall be transmitted to the Congress not later than 3 years after the date of enactment of the Clean Air Act Amendments of 1990 [Nov. 15, 1990].

“(2) At least 90 days before issuing a report the Administrator shall provide an opportunity for public comment on the proposed report. The Administrator shall include in the final report a summary of the comments received on the proposed report.

“(3) There are authorized to be appropriated such sums as are necessary to carry out this section.”

§ 7410. State implementation plans for national primary and secondary ambient air quality standards

(a) Adoption of plan by State; submission to Administrator; content of plan; revision; new sources; indirect source review program; supplemental or intermittent control systems

(1) Each State shall, after reasonable notice and public hearings, adopt and submit to the Administrator, within 3 years (or such shorter period as the Administrator may prescribe) after the promulgation of a national primary ambient air quality standard (or any revision thereof) under section 7409 of this title for any air pollut-

ant, a plan which provides for implementation, maintenance, and enforcement of such primary standard in each air quality control region (or portion thereof) within such State. In addition, such State shall adopt and submit to the Administrator (either as a part of a plan submitted under the preceding sentence or separately) within 3 years (or such shorter period as the Administrator may prescribe) after the promulgation of a national ambient air quality secondary standard (or revision thereof), a plan which provides for implementation, maintenance, and enforcement of such secondary standard in each air quality control region (or portion thereof) within such State. Unless a separate public hearing is provided, each State shall consider its plan implementing such secondary standard at the hearing required by the first sentence of this paragraph.

(2) Each implementation plan submitted by a State under this chapter shall be adopted by the State after reasonable notice and public hearing. Each such plan shall—

(A) include enforceable emission limitations and other control measures, means, or techniques (including economic incentives such as fees, marketable permits, and auctions of emissions rights), as well as schedules and timetables for compliance, as may be necessary or appropriate to meet the applicable requirements of this chapter;

(B) provide for establishment and operation of appropriate devices, methods, systems, and procedures necessary to—

(i) monitor, compile, and analyze data on ambient air quality, and

(ii) upon request, make such data available to the Administrator;

(C) include a program to provide for the enforcement of the measures described in subparagraph (A), and regulation of the modification and construction of any stationary source within the areas covered by the plan as necessary to assure that national ambient air quality standards are achieved, including a permit program as required in parts C and D;

(D) contain adequate provisions—

(i) prohibiting, consistent with the provisions of this subchapter, any source or other type of emissions activity within the State from emitting any air pollutant in amounts which will—

(I) contribute significantly to nonattainment in, or interfere with maintenance by, any other State with respect to any such national primary or secondary ambient air quality standard, or

(II) interfere with measures required to be included in the applicable implementation plan for any other State under part C to prevent significant deterioration of air quality or to protect visibility,

(ii) insuring compliance with the applicable requirements of sections 7426 and 7415 of this title (relating to interstate and international pollution abatement);

(E) provide (i) necessary assurances that the State (or, except where the Administrator deems inappropriate, the general purpose local government or governments, or a regional

other actions duly issued, made, or taken by or pursuant to act July 14, 1955, the Clean Air Act, as in effect immediately prior to the date of enactment of Pub. L. 95-95 [Aug. 7, 1977] to continue in full force and effect until modified or rescinded in accordance with act July 14, 1955, as amended by Pub. L. 95-95 [this chapter], see section 406(b) of Pub. L. 95-95, set out as an Effective Date of 1977 Amendment note under section 7401 of this title.

TERMINATION OF ADVISORY COMMITTEES

Advisory committees established after Jan. 5, 1973, to terminate not later than the expiration of the 2-year period beginning on the date of their establishment, unless, in the case of a committee established by the President or an officer of the Federal Government, such committee is renewed by appropriate action prior to the expiration of such 2-year period, or in the case of a committee established by the Congress, its duration is otherwise provided for by law. See section 14 of Pub. L. 92-463, Oct. 6, 1972, 86 Stat. 776, set out in the Appendix to Title 5, Government Organization and Employees.

ROLE OF SECONDARY STANDARDS

Pub. L. 101-549, title VIII, §817, Nov. 15, 1990, 104 Stat. 2697, provided that:

“(a) REPORT.—The Administrator shall request the National Academy of Sciences to prepare a report to the Congress on the role of national secondary ambient air quality standards in protecting welfare and the environment. The report shall:

“(1) include information on the effects on welfare and the environment which are caused by ambient concentrations of pollutants listed pursuant to section 108 [42 U.S.C. 7408] and other pollutants which may be listed;

“(2) estimate welfare and environmental costs incurred as a result of such effects;

“(3) examine the role of secondary standards and the State implementation planning process in preventing such effects;

“(4) determine ambient concentrations of each such pollutant which would be adequate to protect welfare and the environment from such effects;

“(5) estimate the costs and other impacts of meeting secondary standards; and

“(6) consider other means consistent with the goals and objectives of the Clean Air Act [42 U.S.C. 7401 et seq.] which may be more effective than secondary standards in preventing or mitigating such effects.

“(b) SUBMISSION TO CONGRESS; COMMENTS; AUTHORIZATION.—(1) The report shall be transmitted to the Congress not later than 3 years after the date of enactment of the Clean Air Act Amendments of 1990 [Nov. 15, 1990].

“(2) At least 90 days before issuing a report the Administrator shall provide an opportunity for public comment on the proposed report. The Administrator shall include in the final report a summary of the comments received on the proposed report.

“(3) There are authorized to be appropriated such sums as are necessary to carry out this section.”

§ 7410. State implementation plans for national primary and secondary ambient air quality standards

(a) Adoption of plan by State; submission to Administrator; content of plan; revision; new sources; indirect source review program; supplemental or intermittent control systems

(1) Each State shall, after reasonable notice and public hearings, adopt and submit to the Administrator, within 3 years (or such shorter period as the Administrator may prescribe) after the promulgation of a national primary ambient air quality standard (or any revision thereof) under section 7409 of this title for any air pollut-

ant, a plan which provides for implementation, maintenance, and enforcement of such primary standard in each air quality control region (or portion thereof) within such State. In addition, such State shall adopt and submit to the Administrator (either as a part of a plan submitted under the preceding sentence or separately) within 3 years (or such shorter period as the Administrator may prescribe) after the promulgation of a national ambient air quality secondary standard (or revision thereof), a plan which provides for implementation, maintenance, and enforcement of such secondary standard in each air quality control region (or portion thereof) within such State. Unless a separate public hearing is provided, each State shall consider its plan implementing such secondary standard at the hearing required by the first sentence of this paragraph.

(2) Each implementation plan submitted by a State under this chapter shall be adopted by the State after reasonable notice and public hearing. Each such plan shall—

(A) include enforceable emission limitations and other control measures, means, or techniques (including economic incentives such as fees, marketable permits, and auctions of emissions rights), as well as schedules and timetables for compliance, as may be necessary or appropriate to meet the applicable requirements of this chapter;

(B) provide for establishment and operation of appropriate devices, methods, systems, and procedures necessary to—

(i) monitor, compile, and analyze data on ambient air quality, and

(ii) upon request, make such data available to the Administrator;

(C) include a program to provide for the enforcement of the measures described in subparagraph (A), and regulation of the modification and construction of any stationary source within the areas covered by the plan as necessary to assure that national ambient air quality standards are achieved, including a permit program as required in parts C and D;

(D) contain adequate provisions—

(i) prohibiting, consistent with the provisions of this subchapter, any source or other type of emissions activity within the State from emitting any air pollutant in amounts which will—

(I) contribute significantly to nonattainment in, or interfere with maintenance by, any other State with respect to any such national primary or secondary ambient air quality standard, or

(II) interfere with measures required to be included in the applicable implementation plan for any other State under part C to prevent significant deterioration of air quality or to protect visibility,

(ii) insuring compliance with the applicable requirements of sections 7426 and 7415 of this title (relating to interstate and international pollution abatement);

(E) provide (i) necessary assurances that the State (or, except where the Administrator deems inappropriate, the general purpose local government or governments, or a regional

agency designated by the State or general purpose local governments for such purpose) will have adequate personnel, funding, and authority under State (and, as appropriate, local) law to carry out such implementation plan (and is not prohibited by any provision of Federal or State law from carrying out such implementation plan or portion thereof), (ii) requirements that the State comply with the requirements respecting State boards under section 7428 of this title, and (iii) necessary assurances that, where the State has relied on a local or regional government, agency, or instrumentality for the implementation of any plan provision, the State has responsibility for ensuring adequate implementation of such plan provision;

(F) require, as may be prescribed by the Administrator—

(i) the installation, maintenance, and replacement of equipment, and the implementation of other necessary steps, by owners or operators of stationary sources to monitor emissions from such sources,

(ii) periodic reports on the nature and amounts of emissions and emissions-related data from such sources, and

(iii) correlation of such reports by the State agency with any emission limitations or standards established pursuant to this chapter, which reports shall be available at reasonable times for public inspection;

(G) provide for authority comparable to that in section 7603 of this title and adequate contingency plans to implement such authority;

(H) provide for revision of such plan—

(i) from time to time as may be necessary to take account of revisions of such national primary or secondary ambient air quality standard or the availability of improved or more expeditious methods of attaining such standard, and

(ii) except as provided in paragraph (3)(C), whenever the Administrator finds on the basis of information available to the Administrator that the plan is substantially inadequate to attain the national ambient air quality standard which it implements or to otherwise comply with any additional requirements established under this chapter;

(I) in the case of a plan or plan revision for an area designated as a nonattainment area, meet the applicable requirements of part D (relating to nonattainment areas);

(J) meet the applicable requirements of section 7421 of this title (relating to consultation), section 7427 of this title (relating to public notification), and part C (relating to prevention of significant deterioration of air quality and visibility protection);

(K) provide for—

(i) the performance of such air quality modeling as the Administrator may prescribe for the purpose of predicting the effect on ambient air quality of any emissions of any air pollutant for which the Administrator has established a national ambient air quality standard, and

(ii) the submission, upon request, of data related to such air quality modeling to the Administrator;

(L) require the owner or operator of each major stationary source to pay to the permitting authority, as a condition of any permit required under this chapter, a fee sufficient to cover—

(i) the reasonable costs of reviewing and acting upon any application for such a permit, and

(ii) if the owner or operator receives a permit for such source, the reasonable costs of implementing and enforcing the terms and conditions of any such permit (not including any court costs or other costs associated with any enforcement action),

until such fee requirement is superseded with respect to such sources by the Administrator's approval of a fee program under subchapter V; and

(M) provide for consultation and participation by local political subdivisions affected by the plan.

(3)(A) Repealed. Pub. L. 101-549, title I, § 101(d)(1), Nov. 15, 1990, 104 Stat. 2409.

(B) As soon as practicable, the Administrator shall, consistent with the purposes of this chapter and the Energy Supply and Environmental Coordination Act of 1974 [15 U.S.C. 791 et seq.], review each State's applicable implementation plans and report to the State on whether such plans can be revised in relation to fuel burning stationary sources (or persons supplying fuel to such sources) without interfering with the attainment and maintenance of any national ambient air quality standard within the period permitted in this section. If the Administrator determines that any such plan can be revised, he shall notify the State that a plan revision may be submitted by the State. Any plan revision which is submitted by the State shall, after public notice and opportunity for public hearing, be approved by the Administrator if the revision relates only to fuel burning stationary sources (or persons supplying fuel to such sources), and the plan as revised complies with paragraph (2) of this subsection. The Administrator shall approve or disapprove any revision no later than three months after its submission.

(C) Neither the State, in the case of a plan (or portion thereof) approved under this subsection, nor the Administrator, in the case of a plan (or portion thereof) promulgated under subsection (c), shall be required to revise an applicable implementation plan because one or more exemptions under section 7418 of this title (relating to Federal facilities), enforcement orders under section 7413(d)¹ of this title, suspensions under subsection (f) or (g) (relating to temporary energy or economic authority), orders under section 7419 of this title (relating to primary nonferrous smelters), or extensions of compliance in decrees entered under section 7413(e)¹ of this title (relating to iron- and steel-producing operations) have been granted, if such plan would have met the requirements of this section if no such exemptions, orders, or extensions had been granted.

(4) Repealed. Pub. L. 101-549, title I, § 101(d)(2), Nov. 15, 1990, 104 Stat. 2409.

¹ See References in Text note below.

(5)(A)(i) Any State may include in a State implementation plan, but the Administrator may not require as a condition of approval of such plan under this section, any indirect source review program. The Administrator may approve and enforce, as part of an applicable implementation plan, an indirect source review program which the State chooses to adopt and submit as part of its plan.

(ii) Except as provided in subparagraph (B), no plan promulgated by the Administrator shall include any indirect source review program for any air quality control region, or portion thereof.

(iii) Any State may revise an applicable implementation plan approved under this subsection to suspend or revoke any such program included in such plan, provided that such plan meets the requirements of this section.

(B) The Administrator shall have the authority to promulgate, implement and enforce regulations under subsection (c) respecting indirect source review programs which apply only to federally assisted highways, airports, and other major federally assisted indirect sources and federally owned or operated indirect sources.

(C) For purposes of this paragraph, the term "indirect source" means a facility, building, structure, installation, real property, road, or highway which attracts, or may attract, mobile sources of pollution. Such term includes parking lots, parking garages, and other facilities subject to any measure for management of parking supply (within the meaning of subsection (c)(2)(D)(ii)), including regulation of existing off-street parking but such term does not include new or existing on-street parking. Direct emissions sources or facilities at, within, or associated with, any indirect source shall not be deemed indirect sources for the purpose of this paragraph.

(D) For purposes of this paragraph the term "indirect source review program" means the facility-by-facility review of indirect sources of air pollution, including such measures as are necessary to assure, or assist in assuring, that a new or modified indirect source will not attract mobile sources of air pollution, the emissions from which would cause or contribute to air pollution concentrations—

(i) exceeding any national primary ambient air quality standard for a mobile source-related air pollutant after the primary standard attainment date, or

(ii) preventing maintenance of any such standard after such date.

(E) For purposes of this paragraph and paragraph (2)(B), the term "transportation control measure" does not include any measure which is an "indirect source review program".

(6) No State plan shall be treated as meeting the requirements of this section unless such plan provides that in the case of any source which uses a supplemental, or intermittent control system for purposes of meeting the requirements of an order under section 7413(d)¹ of this title or section 7419 of this title (relating to primary nonferrous smelter orders), the owner or operator of such source may not temporarily reduce the pay of any employee by reason of the use of such supplemental or intermittent or other dispersion dependent control system.

(b) Extension of period for submission of plans

The Administrator may, wherever he determines necessary, extend the period for submission of any plan or portion thereof which implements a national secondary ambient air quality standard for a period not to exceed 18 months from the date otherwise required for submission of such plan.

(c) Preparation and publication by Administrator of proposed regulations setting forth implementation plan; transportation regulations study and report; parking surcharge; suspension authority; plan implementation

(1) The Administrator shall promulgate a Federal implementation plan at any time within 2 years after the Administrator—

(A) finds that a State has failed to make a required submission or finds that the plan or plan revision submitted by the State does not satisfy the minimum criteria established under subsection (k)(1)(A), or

(B) disapproves a State implementation plan submission in whole or in part,

unless the State corrects the deficiency, and the Administrator approves the plan or plan revision, before the Administrator promulgates such Federal implementation plan.

(2)(A) Repealed. Pub. L. 101-549, title I, § 101(d)(3)(A), Nov. 15, 1990, 104 Stat. 2409.

(B) No parking surcharge regulation may be required by the Administrator under paragraph (1) of this subsection as a part of an applicable implementation plan. All parking surcharge regulations previously required by the Administrator shall be void upon June 22, 1974. This subparagraph shall not prevent the Administrator from approving parking surcharges if they are adopted and submitted by a State as part of an applicable implementation plan. The Administrator may not condition approval of any implementation plan submitted by a State on such plan's including a parking surcharge regulation.

(C) Repealed. Pub. L. 101-549, title I, § 101(d)(3)(B), Nov. 15, 1990, 104 Stat. 2409.

(D) For purposes of this paragraph—

(i) The term "parking surcharge regulation" means a regulation imposing or requiring the imposition of any tax, surcharge, fee, or other charge on parking spaces, or any other area used for the temporary storage of motor vehicles.

(ii) The term "management of parking supply" shall include any requirement providing that any new facility containing a given number of parking spaces shall receive a permit or other prior approval, issuance of which is to be conditioned on air quality considerations.

(iii) The term "preferential bus/carpool lane" shall include any requirement for the setting aside of one or more lanes of a street or highway on a permanent or temporary basis for the exclusive use of buses or carpools, or both.

(E) No standard, plan, or requirement, relating to management of parking supply or preferential bus/carpool lanes shall be promulgated after June 22, 1974, by the Administrator pursuant to this section, unless such promulgation has been subjected to at least one public hearing

which has been held in the area affected and for which reasonable notice has been given in such area. If substantial changes are made following public hearings, one or more additional hearings shall be held in such area after such notice.

(3) Upon application of the chief executive officer of any general purpose unit of local government, if the Administrator determines that such unit has adequate authority under State or local law, the Administrator may delegate to such unit the authority to implement and enforce within the jurisdiction of such unit any part of a plan promulgated under this subsection. Nothing in this paragraph shall prevent the Administrator from implementing or enforcing any applicable provision of a plan promulgated under this subsection.

(4) Repealed. Pub. L. 101-549, title I, § 101(d)(3)(C), Nov. 15, 1990, 104 Stat. 2409.

(5)(A) Any measure in an applicable implementation plan which requires a toll or other charge for the use of a bridge located entirely within one city shall be eliminated from such plan by the Administrator upon application by the Governor of the State, which application shall include a certification by the Governor that he will revise such plan in accordance with subparagraph (B).

(B) In the case of any applicable implementation plan with respect to which a measure has been eliminated under subparagraph (A), such plan shall, not later than one year after August 7, 1977, be revised to include comprehensive measures to:

(i) establish, expand, or improve public transportation measures to meet basic transportation needs, as expeditiously as is practicable; and

(ii) implement transportation control measures necessary to attain and maintain national ambient air quality standards,

and such revised plan shall, for the purpose of implementing such comprehensive public transportation measures, include requirements to use (insofar as is necessary) Federal grants, State or local funds, or any combination of such grants and funds as may be consistent with the terms of the legislation providing such grants and funds. Such measures shall, as a substitute for the tolls or charges eliminated under subparagraph (A), provide for emissions reductions equivalent to the reductions which may reasonably be expected to be achieved through the use of the tolls or charges eliminated.

(C) Any revision of an implementation plan for purposes of meeting the requirements of subparagraph (B) shall be submitted in coordination with any plan revision required under part D.

(d), (e) Repealed. Pub. L. 101-549, title I, § 101(d)(4), (5), Nov. 15, 1990, 104 Stat. 2409

(f) National or regional energy emergencies; determination by President

(1) Upon application by the owner or operator of a fuel burning stationary source, and after notice and opportunity for public hearing, the Governor of the State in which such source is located may petition the President to determine that a national or regional energy emergency exists of such severity that—

(A) a temporary suspension of any part of the applicable implementation plan or of any requirement under section 7651j of this title (concerning excess emissions penalties or offsets) may be necessary, and

(B) other means of responding to the energy emergency may be inadequate.

Such determination shall not be delegable by the President to any other person. If the President determines that a national or regional energy emergency of such severity exists, a temporary emergency suspension of any part of an applicable implementation plan or of any requirement under section 7651j of this title (concerning excess emissions penalties or offsets) adopted by the State may be issued by the Governor of any State covered by the President's determination under the condition specified in paragraph (2) and may take effect immediately.

(2) A temporary emergency suspension under this subsection shall be issued to a source only if the Governor of such State finds that—

(A) there exists in the vicinity of such source a temporary energy emergency involving high levels of unemployment or loss of necessary energy supplies for residential dwellings; and

(B) such unemployment or loss can be totally or partially alleviated by such emergency suspension.

Not more than one such suspension may be issued for any source on the basis of the same set of circumstances or on the basis of the same emergency.

(3) A temporary emergency suspension issued by a Governor under this subsection shall remain in effect for a maximum of four months or such lesser period as may be specified in a disapproval order of the Administrator, if any. The Administrator may disapprove such suspension if he determines that it does not meet the requirements of paragraph (2).

(4) This subsection shall not apply in the case of a plan provision or requirement promulgated by the Administrator under subsection (c) of this section, but in any such case the President may grant a temporary emergency suspension for a four month period of any such provision or requirement if he makes the determinations and findings specified in paragraphs (1) and (2).

(5) The Governor may include in any temporary emergency suspension issued under this subsection a provision delaying for a period identical to the period of such suspension any compliance schedule (or increment of progress) to which such source is subject under section 1857c-10¹ of this title, as in effect before August 7, 1977, or section 7413(d)¹ of this title, upon a finding that such source is unable to comply with such schedule (or increment) solely because of the conditions on the basis of which a suspension was issued under this subsection.

(g) Governor's authority to issue temporary emergency suspensions

(1) In the case of any State which has adopted and submitted to the Administrator a proposed plan revision which the State determines—

(A) meets the requirements of this section, and

(B) is necessary (i) to prevent the closing for one year or more of any source of air pollution, and (ii) to prevent substantial increases in unemployment which would result from such closing, and

which the Administrator has not approved or disapproved under this section within 12 months of submission of the proposed plan revision, the Governor may issue a temporary emergency suspension of the part of the applicable implementation plan for such State which is proposed to be revised with respect to such source. The determination under subparagraph (B) may not be made with respect to a source which would close without regard to whether or not the proposed plan revision is approved.

(2) A temporary emergency suspension issued by a Governor under this subsection shall remain in effect for a maximum of four months or such lesser period as may be specified in a disapproval order of the Administrator. The Administrator may disapprove such suspension if he determines that it does not meet the requirements of this subsection.

(3) The Governor may include in any temporary emergency suspension issued under this subsection a provision delaying for a period identical to the period of such suspension any compliance schedule (or increment of progress) to which such source is subject under section 1857c-10¹ of this title as in effect before August 7, 1977, or under section 7413(d)¹ of this title upon a finding that such source is unable to comply with such schedule (or increment) solely because of the conditions on the basis of which a suspension was issued under this subsection.

(h) Publication of comprehensive document for each State setting forth requirements of applicable implementation plan

(1) Not later than 5 years after November 15, 1990, and every 3 years thereafter, the Administrator shall assemble and publish a comprehensive document for each State setting forth all requirements of the applicable implementation plan for such State and shall publish notice in the Federal Register of the availability of such documents.

(2) The Administrator may promulgate such regulations as may be reasonably necessary to carry out the purpose of this subsection.

(i) Modification of requirements prohibited

Except for a primary nonferrous smelter order under section 7419 of this title, a suspension under subsection (f) or (g) (relating to emergency suspensions), an exemption under section 7418 of this title (relating to certain Federal facilities), an order under section 7413(d)¹ of this title (relating to compliance orders), a plan promulgation under subsection (c), or a plan revision under subsection (a)(3); no order, suspension, plan revision, or other action modifying any requirement of an applicable implementation plan may be taken with respect to any stationary source by the State or by the Administrator.

(j) Technological systems of continuous emission reduction on new or modified stationary sources; compliance with performance standards

As a condition for issuance of any permit required under this subchapter, the owner or operator of each new or modified stationary source which is required to obtain such a permit must show to the satisfaction of the permitting authority that the technological system of continuous emission reduction which is to be used at such source will enable it to comply with the standards of performance which are to apply to such source and that the construction or modification and operation of such source will be in compliance with all other requirements of this chapter.

(k) Environmental Protection Agency action on plan submissions

(1) Completeness of plan submissions

(A) Completeness criteria

Within 9 months after November 15, 1990, the Administrator shall promulgate minimum criteria that any plan submission must meet before the Administrator is required to act on such submission under this subsection. The criteria shall be limited to the information necessary to enable the Administrator to determine whether the plan submission complies with the provisions of this chapter.

(B) Completeness finding

Within 60 days of the Administrator's receipt of a plan or plan revision, but no later than 6 months after the date, if any, by which a State is required to submit the plan or revision, the Administrator shall determine whether the minimum criteria established pursuant to subparagraph (A) have been met. Any plan or plan revision that a State submits to the Administrator, and that has not been determined by the Administrator (by the date 6 months after receipt of the submission) to have failed to meet the minimum criteria established pursuant to subparagraph (A), shall on that date be deemed by operation of law to meet such minimum criteria.

(C) Effect of finding of incompleteness

Where the Administrator determines that a plan submission (or part thereof) does not meet the minimum criteria established pursuant to subparagraph (A), the State shall be treated as not having made the submission (or, in the Administrator's discretion, part thereof).

(2) Deadline for action

Within 12 months of a determination by the Administrator (or a determination deemed by operation of law) under paragraph (1) that a State has submitted a plan or plan revision (or, in the Administrator's discretion, part thereof) that meets the minimum criteria established pursuant to paragraph (1), if applicable (or, if those criteria are not applicable, within 12 months of submission of the plan or revision), the Administrator shall act on the submission in accordance with paragraph (3).

(3) Full and partial approval and disapproval

In the case of any submittal on which the Administrator is required to act under paragraph (2), the Administrator shall approve such submittal as a whole if it meets all of the applicable requirements of this chapter. If a portion of the plan revision meets all the applicable requirements of this chapter, the Administrator may approve the plan revision in part and disapprove the plan revision in part. The plan revision shall not be treated as meeting the requirements of this chapter until the Administrator approves the entire plan revision as complying with the applicable requirements of this chapter.

(4) Conditional approval

The Administrator may approve a plan revision based on a commitment of the State to adopt specific enforceable measures by a date certain, but not later than 1 year after the date of approval of the plan revision. Any such conditional approval shall be treated as a disapproval if the State fails to comply with such commitment.

(5) Calls for plan revisions

Whenever the Administrator finds that the applicable implementation plan for any area is substantially inadequate to attain or maintain the relevant national ambient air quality standard, to mitigate adequately the interstate pollutant transport described in section 7506a of this title or section 7511c of this title, or to otherwise comply with any requirement of this chapter, the Administrator shall require the State to revise the plan as necessary to correct such inadequacies. The Administrator shall notify the State of the inadequacies, and may establish reasonable deadlines (not to exceed 18 months after the date of such notice) for the submission of such plan revisions. Such findings and notice shall be public. Any finding under this paragraph shall, to the extent the Administrator deems appropriate, subject the State to the requirements of this chapter to which the State was subject when it developed and submitted the plan for which such finding was made, except that the Administrator may adjust any dates applicable under such requirements as appropriate (except that the Administrator may not adjust any attainment date prescribed under part D, unless such date has elapsed).

(6) Corrections

Whenever the Administrator determines that the Administrator's action approving, disapproving, or promulgating any plan or plan revision (or part thereof), area designation, redesignation, classification, or reclassification was in error, the Administrator may in the same manner as the approval, disapproval, or promulgation revise such action as appropriate without requiring any further submission from the State. Such determination and the basis thereof shall be provided to the State and public.

(I) Plan revisions

Each revision to an implementation plan submitted by a State under this chapter shall be

adopted by such State after reasonable notice and public hearing. The Administrator shall not approve a revision of a plan if the revision would interfere with any applicable requirement concerning attainment and reasonable further progress (as defined in section 7501 of this title), or any other applicable requirement of this chapter.

(m) Sanctions

The Administrator may apply any of the sanctions listed in section 7509(b) of this title at any time (or at any time after) the Administrator makes a finding, disapproval, or determination under paragraphs (1) through (4), respectively, of section 7509(a) of this title in relation to any plan or plan item (as that term is defined by the Administrator) required under this chapter, with respect to any portion of the State the Administrator determines reasonable and appropriate, for the purpose of ensuring that the requirements of this chapter relating to such plan or plan item are met. The Administrator shall, by rule, establish criteria for exercising his authority under the previous sentence with respect to any deficiency referred to in section 7509(a) of this title to ensure that, during the 24-month period following the finding, disapproval, or determination referred to in section 7509(a) of this title, such sanctions are not applied on a statewide basis where one or more political subdivisions covered by the applicable implementation plan are principally responsible for such deficiency.

(n) Savings clauses**(1) Existing plan provisions**

Any provision of any applicable implementation plan that was approved or promulgated by the Administrator pursuant to this section as in effect before November 15, 1990, shall remain in effect as part of such applicable implementation plan, except to the extent that a revision to such provision is approved or promulgated by the Administrator pursuant to this chapter.

(2) Attainment dates

For any area not designated nonattainment, any plan or plan revision submitted or required to be submitted by a State—

(A) in response to the promulgation or revision of a national primary ambient air quality standard in effect on November 15, 1990, or

(B) in response to a finding of substantial inadequacy under subsection (a)(2) (as in effect immediately before November 15, 1990),

shall provide for attainment of the national primary ambient air quality standards within 3 years of November 15, 1990, or within 5 years of issuance of such finding of substantial inadequacy, whichever is later.

(3) Retention of construction moratorium in certain areas

In the case of an area to which, immediately before November 15, 1990, the prohibition on construction or modification of major stationary sources prescribed in subsection (a)(2)(I) (as in effect immediately before November 15, 1990) applied by virtue of a finding

of the Administrator that the State containing such area had not submitted an implementation plan meeting the requirements of section 7502(b)(6) of this title (relating to establishment of a permit program) (as in effect immediately before November 15, 1990) or 7502(a)(1) of this title (to the extent such requirements relate to provision for attainment of the primary national ambient air quality standard for sulfur oxides by December 31, 1982) as in effect immediately before November 15, 1990, no major stationary source of the relevant air pollutant or pollutants shall be constructed or modified in such area until the Administrator finds that the plan for such area meets the applicable requirements of section 7502(c)(5) of this title (relating to permit programs) or subpart 5 of part D (relating to attainment of the primary national ambient air quality standard for sulfur dioxide), respectively.

(o) Indian tribes

If an Indian tribe submits an implementation plan to the Administrator pursuant to section 7601(d) of this title, the plan shall be reviewed in accordance with the provisions for review set forth in this section for State plans, except as otherwise provided by regulation promulgated pursuant to section 7601(d)(2) of this title. When such plan becomes effective in accordance with the regulations promulgated under section 7601(d) of this title, the plan shall become applicable to all areas (except as expressly provided otherwise in the plan) located within the exterior boundaries of the reservation, notwithstanding the issuance of any patent and including rights-of-way running through the reservation.

(p) Reports

Any State shall submit, according to such schedule as the Administrator may prescribe, such reports as the Administrator may require relating to emission reductions, vehicle miles traveled, congestion levels, and any other information the Administrator may deem necessary to assess the development² effectiveness, need for revision, or implementation of any plan or plan revision required under this chapter.

(July 14, 1955, ch. 360, title I, §110, as added Pub. L. 91-604, §4(a), Dec. 31, 1970, 84 Stat. 1680; amended Pub. L. 93-319, §4, June 22, 1974, 88 Stat. 256; Pub. L. 95-95, title I, §§107, 108, Aug. 7, 1977, 91 Stat. 691, 693; Pub. L. 95-190, §14(a)(1)-(6), Nov. 16, 1977, 91 Stat. 1399; Pub. L. 97-23, §3, July 17, 1981, 95 Stat. 142; Pub. L. 101-549, title I, §§101(b)-(d), 102(h), 107(c), 108(d), title IV, §412, Nov. 15, 1990, 104 Stat. 2404-2408, 2422, 2464, 2466, 2634.)

Editorial Notes

REFERENCES IN TEXT

The Energy Supply and Environmental Coordination Act of 1974, referred to in subsec. (a)(3)(B), is Pub. L. 93-319, June 22, 1974, 88 Stat. 246, as amended, which is classified principally to chapter 16C (§791 et seq.) of Title 15, Commerce and Trade. For complete classification of this Act to the Code, see Short Title note set out under section 791 of Title 15 and Tables.

²So in original. Probably should be followed by a comma.

Section 7413 of this title, referred to in subsecs. (a)(3)(C), (6), (f)(5), (g)(3), and (i), was amended generally by Pub. L. 101-549, title VII, §701, Nov. 15, 1990, 104 Stat. 2672, and, as so amended, subsecs. (d) and (e) of section 7413 no longer relates to final compliance orders and steel industry compliance extension, respectively.

Section 1857c-10 of this title, as in effect before August 7, 1977, referred to in subsecs. (f)(5) and (g)(3), was in the original "section 119, as in effect before the date of the enactment of this paragraph", meaning section 119 of act July 14, 1955, ch. 360, title I, as added June 22, 1974, Pub. L. 93-319, §3, 88 Stat. 248, (which was classified to section 1857c-10 of this title) as in effect prior to the enactment of subsecs. (f)(5) and (g)(3) of this section by Pub. L. 95-95, §107, Aug. 7, 1977, 91 Stat. 691, effective Aug. 7, 1977. Section 112(b)(1) of Pub. L. 95-95 repealed section 119 of act July 14, 1955, ch. 360, title I, as added by Pub. L. 93-319, and provided that all references to such section 119 in any subsequent enactment which supersedes Pub. L. 93-319 shall be construed to refer to section 113(d) of the Clean Air Act and to paragraph (5) thereof in particular which is classified to section 7413(d)(5) of this title. Section 7413 of this title was subsequently amended generally by Pub. L. 101-549, title VII, §701, Nov. 15, 1990, 104 Stat. 2672, see note above. Section 117(b) of Pub. L. 95-95 added a new section 119 of act July 14, 1955, which is classified to section 7419 of this title.

CODIFICATION

Section was formerly classified to section 1857c-5 of this title.

PRIOR PROVISIONS

A prior section 110 of act July 14, 1955, was renumbered section 117 by Pub. L. 91-604 and is classified to section 7417 of this title.

AMENDMENTS

1990—Subsec. (a)(1). Pub. L. 101-549, §101(d)(8), substituted "3 years (or such shorter period as the Administrator may prescribe)" for "nine months" in two places.

Subsec. (a)(2). Pub. L. 101-549, §101(b), amended par. (2) generally, substituting present provisions for provisions setting the time within which the Administrator was to approve or disapprove a plan or portion thereof and listing the conditions under which the plan or portion thereof was to be approved after reasonable notice and hearing.

Subsec. (a)(3)(A). Pub. L. 101-549, §101(d)(1), struck out subpar. (A) which directed Administrator to approve any revision of an implementation plan if it met certain requirements and had been adopted by the State after reasonable notice and public hearings.

Subsec. (a)(3)(D). Pub. L. 101-549, §101(d)(1), struck out subpar. (D) which directed that certain implementation plans be revised to include comprehensive measures and requirements.

Subsec. (a)(4). Pub. L. 101-549, §101(d)(2), struck out par. (4) which set forth requirements for review procedure.

Subsec. (c)(1). Pub. L. 101-549, §102(h), amended par. (1) generally, substituting present provisions for provisions relating to preparation and publication of regulations setting forth an implementation plan, after opportunity for a hearing, upon failure of a State to make required submission or revision.

Subsec. (c)(2)(A). Pub. L. 101-549, §101(d)(3)(A), struck out subpar. (A) which required a study and report on necessity of parking surcharge, management of parking supply, and preferential bus/carpool lane regulations to achieve and maintain national primary ambient air quality standards.

Subsec. (c)(2)(C). Pub. L. 101-549, §101(d)(3)(B), struck out subpar. (C) which authorized suspension of certain regulations and requirements relating to management of parking supply.

Subsec. (c)(4). Pub. L. 101-549, §101(d)(3)(C), struck out par. (4) which permitted Governors to temporarily suspend measures in implementation plans relating to retrofits, gas rationing, and reduction of on-street parking.

Subsec. (c)(5)(B). Pub. L. 101-549, §101(d)(3)(D), struck out “(including the written evidence required by part D),” after “include comprehensive measures”.

Subsec. (d). Pub. L. 101-549, §101(d)(4), struck out subsec. (d) which defined an applicable implementation plan for purposes of this chapter.

Subsec. (e). Pub. L. 101-549, §101(d)(5), struck out subsec. (e) which permitted an extension of time for attainment of a national primary ambient air quality standard.

Subsec. (f)(1). Pub. L. 101-549, §412, inserted “or of any requirement under section 7651j of this title (concerning excess emissions penalties or offsets)” in subpar. (A) and in last sentence.

Subsec. (g)(1). Pub. L. 101-549, §101(d)(6), substituted “12 months of submission of the proposed plan revision” for “the required four month period” in closing provisions.

Subsec. (h)(1). Pub. L. 101-549, §101(d)(7), substituted “5 years after November 15, 1990, and every three years thereafter” for “one year after August 7, 1977, and annually thereafter” and struck out at end “Each such document shall be revised as frequently as practicable but not less often than annually.”

Subsecs. (k) to (n). Pub. L. 101-549, §101(c), added subsecs. (k) to (n).

Subsec. (o). Pub. L. 101-549, §107(c), added subsec. (o).

Subsec. (p). Pub. L. 101-549, §108(d), added subsec. (p). 1981—Subsec. (a)(3)(C). Pub. L. 97-23 inserted reference to extensions of compliance in decrees entered under section 7413(e) of this title (relating to iron- and steel-producing operations).

1977—Subsec. (a)(2)(A). Pub. L. 95-95, §108(a)(1), substituted “(A) except as may be provided in subparagraph (I)(i) in the case of a plan” for “(A)(i) in the case of a plan”.

Subsec. (a)(2)(B). Pub. L. 95-95, §108(a)(2), substituted “transportation controls, air quality maintenance plans, and preconstruction review of direct sources of air pollution as provided in subparagraph (D)” for “land use and transportation controls”.

Subsec. (a)(2)(D). Pub. L. 95-95, §108(a)(3), substituted “it includes a program to provide for the enforcement of emission limitations and regulation of the modification, construction, and operation of any stationary source, including a permit program as required in parts C and D and a permit or equivalent program for any major emitting facility, within such region as necessary to assure (i) that national ambient air quality standards are achieved and maintained, and (ii) a procedure” for “it includes a procedure”.

Subsec. (a)(2)(E). Pub. L. 95-95, §108(a)(4), substituted “it contains adequate provisions (i) prohibiting any stationary source within the State from emitting any air pollutant in amounts which will (I) prevent attainment or maintenance by any other State of any such national primary or secondary ambient air quality standard, or (II) interfere with measures required to be included in the applicable implementation plan for any other State under part C to prevent significant deterioration of air quality or to protect visibility, and (ii) insuring compliance with the requirements of section 7426 of this title, relating to interstate pollution abatement” for “it contains adequate provisions for intergovernmental cooperation, including measures necessary to insure that emissions of air pollutants from sources located in any air quality control region will not interfere with the attainment or maintenance of such primary or secondary standard in any portion of such region outside of such State or in any other air quality control region”.

Subsec. (a)(2)(F). Pub. L. 95-95, §108(a)(5), added cl. (vi).

Subsec. (a)(2)(H). Pub. L. 95-190, §14(a)(1), substituted “1977,” for “1977”.

Pub. L. 95-95, §108(a)(6), inserted “except as provided in paragraph (3)(C),” after “or (ii)” and “or to otherwise comply with any additional requirements established under the Clean Air Act Amendments of 1977” after “to achieve the national ambient air quality primary or secondary standard which it implements”.

Subsec. (a)(2)(I). Pub. L. 95-95, §108(b), added subpar. (I).

Subsec. (a)(2)(J). Pub. L. 95-190, §14(a)(2), substituted “; and” for “, and”.

Pub. L. 95-95, §108(b), added subpar. (J).

Subsec. (a)(2)(K). Pub. L. 95-95, §108(b) added subpar. (K).

Subsec. (a)(3)(C). Pub. L. 95-95, §108(c), added subpar. (C).

Subsec. (a)(3)(D). Pub. L. 95-190, §14(a)(4), added subpar. (D).

Subsec. (a)(5). Pub. L. 95-95, §108(e), added par. (5).

Subsec. (a)(5)(D). Pub. L. 95-190, §14(a)(3), struck out “preconstruction or premodification” before “review”.

Subsec. (a)(6). Pub. L. 95-95, §108(e), added par. (6).

Subsec. (c)(1). Pub. L. 95-95, §108(d)(1), (2), substituted “plan which meets the requirements of this section” for “plan for any national ambient air quality primary or secondary standard within the time prescribed” in subpar. (A) and, in provisions following subpar. (C), directed that any portion of a plan relating to any measure described in first sentence of 7421 of this title (relating to consultation) or the consultation process required under such section 7421 of this title not be required to be promulgated before the date eight months after such date required for submission.

Subsec. (c)(3) to (5). Pub. L. 95-95, §108(d)(3), added pars. (3) to (5).

Subsec. (d). Pub. L. 95-95, §108(f), substituted “and which implements the requirements of this section” for “and which implements a national primary or secondary ambient air quality standard in a State”.

Subsec. (f). Pub. L. 95-95, §107(a), substituted provisions relating to the handling of national or regional energy emergencies for provisions relating to the postponement of compliance by stationary sources or classes of moving sources with any requirement of applicable implementation plans.

Subsec. (g). Pub. L. 95-95, §108(g), added subsec. (g) relating to publication of comprehensive document.

Pub. L. 95-95, §107(b), added subsec. (g) relating to Governor’s authority to issue temporary emergency suspensions.

Subsec. (h). Pub. L. 95-190, §14(a)(5), redesignated subsec. (g), added by Pub. L. 95-95, §108(g), as (h). Former subsec. (h) redesignated (i).

Subsec. (i). Pub. L. 95-190, §14(a)(5), redesignated subsec. (h), added by Pub. L. 95-95, §108(g), as (i). Former subsec. (i) redesignated (j) and amended.

Subsec. (j). Pub. L. 95-190 §14(a)(5), (6), redesignated subsec. (i), added by Pub. L. 95-95, §108(g), as (j) and in subsec. (j) as so redesignated, substituted “will enable such source” for “at such source will enable it”.

1974—Subsec. (a)(3). Pub. L. 93-319, §4(a), designated existing provisions as subpar. (A) and added subpar. (B).

Subsec. (c). Pub. L. 93-319, §4(b), designated existing provisions as par. (1) and existing pars. (1), (2), and (3) as subpars. (A), (B), and (C), respectively, of such redesignated par. (1), and added par. (2).

Statutory Notes and Related Subsidiaries

EFFECTIVE DATE OF 1977 AMENDMENT

Amendment by Pub. L. 95-95 effective Aug. 7, 1977, except as otherwise expressly provided, see section 406(d) of Pub. L. 95-95, set out as a note under section 7401 of this title.

PENDING ACTIONS AND PROCEEDINGS

Suits, actions, and other proceedings lawfully commenced by or against the Administrator or any other officer or employee of the United States in his official capacity or in relation to the discharge of his official

duties under act July 14, 1955, the Clean Air Act, as in effect immediately prior to the enactment of Pub. L. 95-95 [Aug. 7, 1977], not to abate by reason of the taking effect of Pub. L. 95-95, see section 406(a) of Pub. L. 95-95, set out as an Effective Date of 1977 Amendment note under section 7401 of this title.

MODIFICATION OR RESCISSION OF RULES, REGULATIONS, ORDERS, DETERMINATIONS, CONTRACTS, CERTIFICATIONS, AUTHORIZATIONS, DELEGATIONS, AND OTHER ACTIONS

All rules, regulations, orders, determinations, contracts, certifications, authorizations, delegations, or other actions duly issued, made, or taken by or pursuant to act July 14, 1955, the Clean Air Act, as in effect immediately prior to the date of enactment of Pub. L. 95-95 [Aug. 7, 1977] to continue in full force and effect until modified or rescinded in accordance with act July 14, 1955, as amended by Pub. L. 95-95 [this chapter], see section 406(b) of Pub. L. 95-95, set out as an Effective Date of 1977 Amendment note under section 7401 of this title.

MODIFICATION OR RESCISSION OF IMPLEMENTATION PLANS APPROVED AND IN EFFECT PRIOR TO AUG. 7, 1977

Nothing in the Clean Air Act Amendments of 1977 [Pub. L. 95-95] to affect any requirement of an approved implementation plan under this section or any other provision in effect under this chapter before Aug. 7, 1977, until modified or rescinded in accordance with this chapter as amended by the Clean Air Act Amendments of 1977, see section 406(c) of Pub. L. 95-95, set out as an Effective Date of 1977 Amendment note under section 7401 of this title.

SAVINGS PROVISION

Pub. L. 91-604, §16, Dec. 31, 1970, 84 Stat. 1713, provided that:

“(a)(1) Any implementation plan adopted by any State and submitted to the Secretary of Health, Education, and Welfare, or to the Administrator pursuant to the Clean Air Act [this chapter] prior to enactment of this Act [Dec. 31, 1970] may be approved under section 110 of the Clean Air Act [this section] (as amended by this Act) [Pub. L. 91-604] and shall remain in effect, unless the Administrator determines that such implementation plan, or any portion thereof, is not consistent with applicable requirements of the Clean Air Act [this chapter] (as amended by this Act) and will not provide for the attainment of national primary ambient air quality standards in the time required by such Act. If the Administrator so determines, he shall, within 90 days after promulgation of any national ambient air quality standards pursuant to section 109(a) of the Clean Air Act [section 7409(a) of this title], notify the State and specify in what respects changes are needed to meet the additional requirements of such Act, including requirements to implement national secondary ambient air quality standards. If such changes are not adopted by the State after public hearings and within six months after such notification, the Administrator shall promulgate such changes pursuant to section 110(c) of such Act [subsec. (c) of this section].

“(2) The amendments made by section 4(b) [amending sections 7403 and 7415 of this title] shall not be construed as repealing or modifying the powers of the Administrator with respect to any conference convened under section 108(d) of the Clean Air Act [section 7415 of this title] before the date of enactment of this Act [Dec. 31, 1970].

“(b) Regulations or standards issued under this title II of the Clean Air Act [subchapter II of this chapter] prior to the enactment of this Act [Dec. 31, 1970] shall continue in effect until revised by the Administrator consistent with the purposes of such Act [this chapter].”

FEDERAL ENERGY ADMINISTRATOR

“Federal Energy Administrator”, for purposes of this chapter, to mean Administrator of Federal Energy Ad-

ministration established by Pub. L. 93-275, May 7, 1974, 88 Stat. 97, which is classified to section 761 et seq. of Title 15, Commerce and Trade, but with the term to mean any officer of the United States designated as such by the President until Federal Energy Administrator takes office and after Federal Energy Administration ceases to exist, see section 798 of Title 15, Commerce and Trade.

Federal Energy Administration terminated and functions vested by law in Administrator thereof transferred to Secretary of Energy (unless otherwise specifically provided) by sections 7151(a) and 7293 of this title.

§ 7411. Standards of performance for new stationary sources

(a) Definitions

For purposes of this section:

(1) The term “standard of performance” means a standard for emissions of air pollutants which reflects the degree of emission limitation achievable through the application of the best system of emission reduction which (taking into account the cost of achieving such reduction and any nonair quality health and environmental impact and energy requirements) the Administrator determines has been adequately demonstrated.

(2) The term “new source” means any stationary source, the construction or modification of which is commenced after the publication of regulations (or, if earlier, proposed regulations) prescribing a standard of performance under this section which will be applicable to such source.

(3) The term “stationary source” means any building, structure, facility, or installation which emits or may emit any air pollutant. Nothing in subchapter II of this chapter relating to nonroad engines shall be construed to apply to stationary internal combustion engines.

(4) The term “modification” means any physical change in, or change in the method of operation of, a stationary source which increases the amount of any air pollutant emitted by such source or which results in the emission of any air pollutant not previously emitted.

(5) The term “owner or operator” means any person who owns, leases, operates, controls, or supervises a stationary source.

(6) The term “existing source” means any stationary source other than a new source.

(7) The term “technological system of continuous emission reduction” means—

(A) a technological process for production or operation by any source which is inherently low-polluting or nonpolluting, or

(B) a technological system for continuous reduction of the pollution generated by a source before such pollution is emitted into the ambient air, including precombustion cleaning or treatment of fuels.

(8) A conversion to coal (A) by reason of an order under section 2(a) of the Energy Supply and Environmental Coordination Act of 1974 [15 U.S.C. 792(a)] or any amendment thereto, or any subsequent enactment which supersedes such Act [15 U.S.C. 791 et seq.], or (B) which qualifies under section 7413(d)(5)(A)(ii)¹

¹ See References in Text note below.

DECLARATION OF J. MICHAEL BROWN

1. I am the Environmental Safety and Health Director for the Ohio Valley Electric Corporation (OVEC), including its wholly-owned subsidiary, the Indiana-Kentucky Electric Corporation (IKEC)¹. I am responsible for directing corporate environmental permitting and compliance activities, corporate safety policies and procedures and certain energy scheduling functions, including the offering of OVEC's generating units into the PJM Market. I also serve as the company's Designated Representative (DR) for managing the air emission allowance accounts for each of OVEC's generating stations via USEPA's Clean Air Market Division (CAMD). I provide this declaration in support of the motion to stay the *Federal "Good Neighbor Plan" for the 2015 Ozone National Ambient Air Quality Standards*, 88 Fed. Reg. 36,654 published in the Federal Register on June 5, 2023, filed by Petitioners in Case No. _____, while legal proceedings associated with this rulemaking are ongoing.
2. This declaration is based on my personal knowledge of facts and analysis conducted by my staff.
3. I have been responsible for overseeing OVEC environmental compliance activities since 2011. During my time at OVEC, I have been responsible for directing the overall corporate environmental safety and health compliance, including environmental compliance at OVEC's two coal-fired generating stations located in Madison, Indiana and Cheshire, Ohio.
4. My utility career spans over 32 years all in the field of environmental compliance.
5. I graduated with a Bachelor of Science degree from Penn State University and earned a Master of Business Administration from Capital University.
6. I am submitting this declaration because the Environmental Protection Agency's (EPA) Good Neighbor Plan finalized by EPA on June 5, 2023, creates immediate harm in the form of compliance obligations that are likely to be moot following the outcome of this litigation and litigation addressing various state implementation plans (or SIP) disapproval appeals where "stays" of those disapprovals have been granted. These court opinions indicate that EPA's entire Good Neighbor Rule is likely to be found unlawful. See *Federal "Good Neighbor Plan" for the 2015 Ozone National Ambient Air*

¹ As used herein, the term "OVEC" refers to the combined OVEC and IKEC business.

Quality Standards, 88 Fed. Reg. 36,654 (Jun. 5, 2023) (Federal Plan). See United States Court of Appeals for the 5th Circuit (Case 23-60069), issued May 1, 2023, for the States of Texas and Louisiana as a representative example of the collective “stays” issued by the 5th, 6th, 8th, and 9th Circuit Courts for the States of Texas, Louisiana, Mississippi, Kentucky, Arkansas, Missouri, Minnesota, and Utah, to date. As further explained in this declaration, EPA’s Federal Plan will harm OVEC, particularly at its Clifty Creek Station in Madison, Indiana.

OVEC OPERATIONS

7. OVEC employs approximately 509 full-time employees in Southern Ohio and Southeast Indiana. OVEC, directly and through its wholly-owned subsidiary, IKEC, owns and operate the 5-unit 1086 MW Kyger Creek Station, in Cheshire, Ohio as well as the 6-unit 1303 MW Clifty Creek Station in Madison, Indiana. Power from these stations is ultimately provided to our utility owners or their utility affiliates, under the terms of a long-term power contract (each counterparty to this power contact, an OVEC Sponsor), for their use in meeting the electricity needs of their residential, commercial, industrial and wholesale customers.
8. The Clifty Creek Station’s six units all have electrostatic precipitators, all units have over-fire air and five of the six units have SCRs for NO_x control, in addition, Units 1, 2 and 3 and separately Units 4, 5 and 6 are scrubbed via two Jet bubbling reactor (JBR) scrubbers that came on line in 2013. The scrubber design is robust and the facility is able to meet its Mercury and Air Toxics Rule (MATS) emission limits as co-benefit via the management of the scrubber chemistry and overall performance. The cost for the pollution controls installed at this facility is in excess of 800 million dollars.
9. The end users of most of the electricity in OVEC’s Sponsors’ service territory live in rural areas with some of the lowest economic demographics in the United States. OVEC’s baseload electric generation resources power the region and Indiana, and that baseload generation sustains the grid with reliable access to energy. A balanced generation mix is essential to maintaining a safe and reliable grid.

ADDITIONAL CONTROL REQUIREMENTS UNDER EPA'S FEDERAL PLAN

10. EPA's Federal Plan imposes stringent nitrogen oxide (NO_x) emission reduction requirements on electrical generating units (EGUs) in 22 covered states during the ozone season (May 1 - September 30 annually).
11. States covered by this Federal Plan include Indiana.
12. Starting in 2023, EGUs in Indiana will be required to comply with a more restrictive NO_x emissions trading program. This is based on a state-wide emissions budget set by EPA that includes new daily emission rates that go into effect on the common stacks at Clifty Creek beginning in 2024, and declining NO_x ozone season budgets over time based on a combination of heat input calculations, as well as on the level of overall reductions EPA has determined is achievable through particular emissions controls. The Federal Plan also includes aggressive restrictions on the size of the allowance banks that provide a disincentive for both near-term and longer-term allowance trading and new forms of penalties and other enforcement provisions.
13. Under the Federal Plan, Indiana's 2023 state budget will be reduced by an additional 32% in 2026. By 2029 the Indiana state budget will be 53% lower than the 2023 budget. See 88 Fed. Reg. at 36,663.
14. By 2027, the Federal Plan requires a 50% reduction from 2021 ozone season NO_x emissions levels. See Final Good Neighbor Plan Fact Sheet.²
15. The Federal Plan effectively diminishes the fossil fuel generation capacity by ratcheting down EPA's NO_x allowance allocations to the states, which flows down to utilities, such as OVEC.
16. By 2027, the Federal Plan generally requires large coal-fired EGUs without SCRs to install SCRs and meet a daily average NO_x emissions rate of 0.14 lb/mmBtu. However, units that do not currently have SCRs that share a common stack with other units with SCRs must meet that daily emission rate beginning in 2024, or if possible, install additional expensive and redundant pollution control monitoring equipment on each individual unit sharing the common stack.
17. OVEC has determined, due to a variety of site conditions and constraints, among other reasons, that installation and/or relocation of pollution control equipment from the common stack to each individual unit is not viable.

² https://www.epa.gov/system/files/documents/2023-30/Final%20Good%20Neighbor%20Rule%20Fact%20Sheet_0.pdf

18. EPA's disapproval of Indiana's state plan and subsequent imposition of its Federal Plan will have a substantial impact on OVEC's operations. The common stack with the unit at the Clifty Creek Station without SCR controls will not be able to meet the emissions limits under the Federal Plan by the 2024 ozone season, and it is impossible to install an SCR for that unit prior to the 2024 ozone season. The unit shares a common stack with two other units with SCR control technology.
19. OVEC has used its best business judgment and experience complying with similar federal trading programs to bank unused NO_x ozone season allowances from prior compliance periods where appropriate. In addition, the company has made strategic purchases of additional allowances under prior rules as a risk-management hedge for future compliance periods. However, EPA's Federal Plan "enhancements" put a significant portion of those banked allowances at risk of confiscation due to EPA's plans to limit the size of the future allowance bank. EPA intends to confiscate any "excess" banked allowances on a prorated basis beyond the assurance level cap of 21% starting each year from 2024 through 2029. EPA will then lower that bank cap to only 10.5% of the assurance level beginning in 2030 and beyond. In addition, nearly half of the total allowance pool from the states covered by the Federal Plan will be unavailable due to the court-issued stays of interstate transport SIP disapprovals. OVEC is unsure how EPA could implement their plans to confiscate "excess" banked allowance on the sources in the remaining states while legal appeals for the states subject to the stays proceed.
20. Due to these legal issues and other concerns about long-term allowance availability and pricing, OVEC can no longer rely on a viable allowance trading market to turn to if it finds it necessary to make allowance purchases to meet future compliance obligations.
21. OVEC has evaluated compliance options (other than allowance purchases) and has determined that, for Clifty Creek Unit 6, its only options are to pursue (1) installation of SCR technology, (2) transition the unit to seasonal operations and effectively remove it as an available generating resource from May 1 through September 30 of each year going forward, or (3) contemplate other actions up to, and including, future unit retirement.
22. Utilities, including OVEC, must immediately (in 2023) decide whether to undertake NO_x control upgrade projects for specific units for which the Federal Plan dictates the installation of controls by 2026-2027.

23. As explained in more detail below, under *any* of these compliance pathways, OVEC either will be required to make commitments and incur expenses within the next 6 months to be able to comply with the Federal Plan, or effectively remove a 217 MW unit from being able to run for the ozone season, regardless of what kind of generation and or transmission reliability issues that may cause within the local regional transmission organization (RTO), PJM.
24. These costs will impact not only OVEC but also its owners and their customers. These expenditures may not be recovered by OVEC's owners if EPA's Federal Plan is ultimately overturned as a result of this litigation or the ongoing SIP disapproval litigation matters. Further, the value that Unit 6 may provide from a grid reliability standpoint will be lost. This unit has been specifically dispatched on numerous occasions in the last few years during the ozone season by PJM to aid in relieving grid reliability issues in both the PJM and the MISO RTO footprints.
25. OVEC estimates that installation of an SCR on Clifty Creek Unit 6 to meet future compliance with EPA's Federal Plan will cost approximately \$80-\$100 million.
26. Without a stay, OVEC will either need to make substantial investments to comply with EPA's Federal Plan in the interim or forgo generation opportunities for that unit due to the punitive daily emission rate and budget constraints that uniquely apply in 2024 to the subset of coal-fired units that do not have SCRs but share a common stack with other units that have SCR controls.
27. The Final Rule also sets an aggressive compliance timeframe that is difficult for the power sector to implement quickly. New state and unit-level NO_x allocations begin in the 2023 ozone season, leaving virtually no time for RTOs and generators to plan for and execute new 2023 summertime operational constraints and dispatch changes. The lack of adequate time to react to the new requirements of the Federal Plan could place the reliability of the bulk power grid in jeopardy.
28. Moreover, utilities must make immediate decisions about whether or not to reset power supply obligations with RTOs for the 2024 ozone season and future years.
29. Likewise, there is no reliability "safety valve" to address reliability concerns, which generators, including OVEC, as well as several RTOs urged EPA to incorporate in public comments.
30. Under the Final Rule, OVEC's Clifty Creek Unit 6 must conduct an expensive NO_x control upgrade project, transition to seasonal operation, limit or completely avoid generation from this unit during the summer ozone season, and ultimately evaluate

repowering or retirement options. OVEC is forced to make decisions concerning this unit almost immediately given how the rule applies to non-SCR units sharing a common stack.

31. RTOs and power generators have no time to devise a diligent plan for 2023-2024 and future years to ensure compliance while securing grid reliability and public safety.

COMPLIANCE TIMELINE FOR SCR

32. If OVEC were to install SCR controls on Clifty Creek Unit 6, it would need to begin that process immediately and will begin to incur costs within the next six months. For the other units with SCRs, installation required approximately 24-30 months to complete. Accordingly, OVEC would be required to begin the installation within the next six months to meet the stack daily emissions rate by the 2026 or 2027 ozone season. In addition, the unit would be forced to limit or eliminate near-term ozone season operations. This would result in lost revenues; a threat to grid reliability; and much lower future NO_x allocations based on the punitive heat input calculation EPA intends to use under the Federal Plan to assign unit-specific future ozone season allowances. This is because, under the Federal Plan, the “dynamic budget” provisions result in reduced allowance allocations based on lower utilization of units in preceding years.
33. Market uncertainties have created additional pressures that could impact the timing for SCR installation. EPA’s Federal Plan imposes requirements on EGUs in 22 states, which puts many sources in the same position of needing to procure SCR systems at the same time. This will not only impact material and equipment availability and price but also the engineering resources necessary to design and procure this equipment, which could complicate the process of securing these limited resources.
34. As EPA has acknowledged, “current and anticipated constraints in labor and supply markets,” “the potential collective capacity levels of SCR retrofit,” and “possible site-specific complexities” impact the installation timing for SCR. See Fed. Reg. at 36,728.
35. Due to these market and regulatory uncertainties, OVEC finds itself in the position of either incurring significant costs for SCR or artificially limiting unit operations while legal challenges to this rule play out.

CONCLUSION

44. The Federal Plan will require significant expenditures to install emission control, the curtailment of generation at OVEC units, and possibly the early closure of OVEC facilities.
45. This irreparably and immediately harms OVEC, its owners, and our owner's end-use retail customers by placing immediate restrictions on unit operations during the ozone season due to EPA's unique treatment of units sharing a common stack under this rule.
46. For the reasons described above, OVEC, its sponsors, and potentially its sponsors' customers are facing substantial harm during the next 12-18 months from the implementation of this Federal Plan.


I, J. Michael Brown, declare under penalty of perjury that the foregoing is true and correct.

Executed this 17th day of July 2023.




J. Michael Brown

Power Plant Ozone Season Emissions Reductions in 2027 Relative to 2021 Under the Final Good Neighbor Plan



The estimated emissions reductions reflect the difference between the rule's preset 2027 budgets for EGUs (this may vary based on the dynamic budget level) and adjusted current 2021 emissions for those EGUs (2021 reported emissions are adjusted to account for known or planned changes such as: retirement, planned retirement, coal-to-gas conversion, etc.). Because these estimated reductions reflect the overall change from current emissions, they are higher, on average, than the values reflected in the regulatory impact analysis (emissions reductions relative to projected future baseline emissions) and other communications materials.

Industrial Source Ozone Season Emissions Reductions in 2026 Relative to 2019 Under the Final Good Neighbor Plan



The estimated percent reductions are calculated using total 2019 non-EGU emissions, including non-EGU point source emissions, oil and gas point source emissions, and the MWC portion of EGU emissions.

June 21, 2022

Ms. Elizabeth Selbst
Air Quality Policy Division
Office of Air Quality Planning and Standards
U.S. Environmental Protection Agency
109 TW Alexander Drive
Research Triangle Park, NC 27711

SUBMITTED VIA: WWW.REGULATIONS.GOV

Re: Federal Implementation Plan Addressing Regional Ozone Transport for the 2015 Ozone National Ambient Air Quality Standard; EPA-HQ-OAR-2021-0668, 87 Fed. Reg. 20036 (April 6, 2022)

Dear Ms. Selbst:

The Portland Cement Association (“PCA”) appreciates the opportunity to submit comments to the Environmental Protection Agency on the proposed Federal Implementation Plan Addressing Regional Ozone Transport for the 2015 Ozone National Ambient Air Quality Standard (“Proposed Rule”).¹ In addition, PCA joined comments submitted by the Air Stewardship Coalition (“ASC”) in opposition to the Proposed Rule.

PCA, founded in 1916, is the premier policy, research, education, and market intelligence organization serving America’s cement manufacturers. The Association promotes safety, sustainability, and innovation in all aspects of construction, fosters continuous improvement in cement manufacturing and distribution, and generally promotes economic growth and sound infrastructure investment. The cement and concrete industry, directly and indirectly, employs more than 600,000 people in the U.S., contributes more than \$100 billion to our economy each year, and is playing a key role in President Biden’s plan to improve the nation’s infrastructure.

As outlined below, PCA opposes the Proposed Rule because, as written, it would result in arbitrary nitrogen oxide (NOx) emissions limits that the affected cement plants would be unable to meet because the emissions limits for existing kilns would be more stringent than limits for new kilns. Furthermore, the Proposed Rule would potentially require the implementation of technically and economically infeasible emissions control technologies.

The Proposed Rule is procedurally and substantively flawed, with egregious errors in the data specific to the cement industry’s existing NOx emissions controls. The Proposed Rule reflects a fundamental mischaracterization of our industry, including significantly overestimating potential NOx reductions that can be achieved by the cement industry relative to existing

¹ 87 Fed. Reg. 20036

controls. Additionally, as demonstrated by the Environmental Protection Agency's failure to provide sufficient time for stakeholders to analyze and submit comments on the Proposed Rule reflects a rush to meet a predetermined timeframe. The Proposed Rule would impact 81 kilns, which makes up approximately 66% of the United States clinker production, and the onerous emissions and potential technology control requirements could result in these 81 kilns curtailing production or shutting down, extending the current supply chain issues that are impacting the entire country in these extraordinary economic circumstances. Additionally, a reduction in domestic cement production during the ozone season would likely result in additional imported clinker with higher embedded emissions and carbon costs to replace domestic production.

Cement is the key ingredient in concrete, the second most consumed material on earth besides water, which provides sustainable, durable, and resilient construction materials. The Infrastructure Investment and Jobs Act ("IIJA") is a priority of this Administration, and concrete will be an essential element in improving our roads, bridges, buildings, water systems, and other infrastructure. Cement and concrete products provide resilient, long-lasting infrastructure that can resist damage and minimize disruption time after disasters. However, the Proposed Rule will hamper this Administration's efforts to improve the nation's infrastructure because it will potentially force cement kilns to shut down or curtail production because they cannot meet the overly stringent and arbitrary emissions requirements, increasing the costs of domestic manufacturing of cement and concrete and forcing the nation to rely on foreign cement imports. The resulting cost increases will be passed on to taxpayers, states, cities, and individual consumers.

For these reasons, EPA should withdraw the Proposed Rule. Any future considerations of setting requirements for the cement industry to reduce NO_x emissions so EPA can meet its "Good Neighbor" obligations for the 2015 National Ambient Air Quality Standards ("NAAQS") under Section 126 of the Clean Air Act ("CAA") should be done using NO_x emissions and control technology data that are reflective of the industry. After such an analysis, EPA should engage with PCA before determining any potential requirements under Section 126 of the CAA.

I. EPA Violated the Administrative Procedure Act by Providing Insufficient Time to Review Records in the Regulatory Docket and Address the Multitude of Significant Legal and Policy Issues

A. EPA did not Provide All Modeling Data Until 28 Days after the Comment Period Commenced, Resulting in Insufficient Time to Analyze EPA's Justification for the Proposed Rule

The Environmental Protection Agency (EPA) failed to provide adequate time for the public to consider the key data justifying the Proposed Rule and the significant ramifications it would have on the affected industries. A comment period of 76 days is an insufficient amount of

time to properly evaluate the Proposed Rule and associated supporting data and to correct the erroneous cement industry data in the regulatory docket.

EPA did not provide all of the modeling data and analysis underlying the Proposed Rule until May 3, 2022, when more than 37 terabytes of data were provided to stakeholders. Even with the 15-day extension, the time to evaluate the modeling data and analysis was less than the original comment period length of 60 days. It takes several days just to copy and set up files of this size so that a stakeholder could use the data and conduct a proper review. Then, to conduct a standard analysis of the source apportionment modeling would require a minimum of an additional 80 days of computer time on a high-performance computer just to assess the results.²

EPA clearly failed to provide the public a meaningful opportunity to comment on the Proposed Rule and, as such, there are sufficient grounds for reversal of the rule by the D.C. Circuit Court of Appeals, under the Administrative Procedure Act (“APA”) at 5 U.S.C. § 706.³ The most fundamental due process afforded to any stakeholder in an administrative proceeding, and as required by the APA, is the opportunity to consider the record on which an agency has based its Proposed Rule. EPA did not make all the modeling data publicly available when the Proposed Rule was published in the Federal Register on April 6, 2022. Stakeholders only received all the data on May 3, 2022, after multiple requests were submitted to the EPA. EPA clearly did not allow stakeholders time to properly evaluate data and develop meaningful comments on a key aspect of EPA’s analysis underlying the Proposed Rule.

The Proposed Rule is an interstate transport rule that is premised on modeling showing the transport of NOx emissions from upwind to downwind states. While EPA did provide limited sets of data in the regulatory docket at the beginning of the comment period, the core aspects of the Proposed Rule – the actual modeling files on which EPA based its analysis of the transport of NOx emissions and concluded that certain industries significantly contributed to ozone nonattainment in downwind states – was not made available to the public until the comment period was one-third over. As such, stakeholders did not have sufficient time to analyze the data and submit meaningful comments on a Proposed Rule that will have significant ramifications for all stakeholders, including the cement industry.

The comment period did not provide sufficient time for the cement industry to evaluate the industry source-specific contribution data and provide meaningful comments on the data. The data is utilized as the basis for EPA’s methodology for determining that the cement industry is a Tier 1 non-electric generating unit (EGU) industry, which was defined by the EPA as industries

² See ASC Comments, page 6.

³ “To the extent necessary to decision and when presented, the reviewing court shall decide all relevant questions of law, interpret constitutional and statutory provisions, and determine the meaning or applicability of the terms of an agency action. The reviewing court shall...hold unlawful and set aside agency action, findings, and conclusions found to be without observance of procedure required by law.” 5 U.S.C. § 706(2)(D).

that have a “maximum contribution to any one receptor of greater than 0.10 parts per billion (“ppb”) and contribute greater than or equal to 0.01 ppb to at least 10 receptors,”⁴ providing justification to impose further emissions reductions and potential implementation of additional emissions controls for the cement industry. The industry plans to continue reviewing the cement-specific modeling data after the comment period closes and may submit additional comments outlining errors and erroneous conclusions in the modeling data.

If EPA had further extended the comment period, beyond the 76 days provided, in response to multiple requests from Congress, state regulatory agencies, and industry, including PCA, stakeholders would have had the opportunity to properly evaluate the modeling data and submit meaningful comments. The EPA’s failure to provide the public a meaningful opportunity to evaluate the modeling data and submit meaningful comments on the Proposed Rule will be grounds for reversal by the D.C. Circuit Court of Appeals.

B. EPA did not Give Sufficient Time to Provide Meaningful Comments on the Numerous Legal and Policy Issues Specific to Industrial Sources

EPA did not provide stakeholders sufficient time to analyze the significant scope of issues in the Proposed Rule covering industrial sources, including cement, not previously covered under the Cross-State Air Pollution Rule (“CSAPR”) and the technical and legal ramifications of the potential emissions and control technology requirements. During a review of the Proposed Rule in the time allotted, it was revealed that there were numerous errors regarding the data EPA utilized for the cement industry’s existing NO_x emissions controls. This reflects a fundamental misunderstanding by EPA of the cement industry, requiring PCA to verify the data used to justify the Proposed Rule. The vast scope and ramifications for industries, including cement, not previously regulated under CSAPR and the need to evaluate and correct errors in the regulatory docket about the cement industry, require an extended comment period to ensure the ability of those industries to submit meaningful comments. As such, this constitutes grounds for reversal by the D.C. Circuit Court of Appeal under the APA.

Significant time is needed to evaluate and assess the impact of the source cap limit on cement plants that was lifted for the Dallas-Fort Worth (“DFW”) Nonattainment Area.⁵ The Proposed Rule and technical documents in the regulatory docket provide no justification for imposing the source cap limit on the cement industry in the 23 states to which the Proposed Rule applies. The only explanation given for requiring compliance with both the specific kiln-type and source cap limits was “to provide operational flexibility.”⁶ This is clearly erroneous, as compliance flexibility would only be provided if one of the limits was required, not both. EPA seemed to have copied the source cap limit specific to the DFW Nonattainment area, thinking

⁴ 87 Fed. Reg. at 20083

⁵ See Texas Administrative Code (T.A.C.) Rule § 117.3123(b).

⁶ 87 Fed. Reg. at 20144

that it could be applied more broadly to the cement industry. In the apparent rush to issue the Proposed Rule, EPA clearly did not evaluate the implications of the limit on the cement kilns in the 23 affected states, whether they could feasibly comply with such limits, and did not account for all kiln types, leaving the industry attempting to conduct such analysis during the short comment period and questioning how to comply with the limits. This insufficient time to analyze the source cap limit and submit meaningful comments provides sufficient justification for reversal of the Proposed Rule if finalized, by the D.C. Circuit Court of Appeals.

In addition, EPA is seeking comments on the feasibility of phasing out and retiring wet process kilns and replacing them with preheater/precalciner kilns and the industry's ability to implement Selective Catalytic Reduction ("SCR") to control NOx emissions. These questions are significant technical inquiries that require comprehensive data gathering and complex analysis. Potential requirements to retire wet kilns and replace them with preheater/precalciner kilns and implement SCR will require significant technical studies, capital cost estimates, and other regulatory costs (e.g., permitting) and will have significant technical, economic, and regulatory implications for the industry. This 76-day comment period is not sufficient to collect, analyze, and provide data on the feasibility and cost of replacing wet kilns with preheater/precalciner kilns and implementing SCR. Before EPA contemplates requirements for the industry to retire wet kilns or require SCR, EPA needs to do considerable fact-finding and data analysis to determine whether such requirements are even remotely feasible.

With the apparent rush to issue the Proposed Rule, the Proposed Rule and technical documents in the regulatory docket are riddled with errors about the cement industry and lack critical details on how to comply with complex provisions. As a result, significant time and effort are required to verify all the data utilized to justify regulation of the cement industry and to correct the apparent errors in the data. In light of these basic errors, the industry must look at all the data EPA is utilizing to justify regulation of the cement industry as a Tier 1 Industry under CSAPR and the 76-day comment period is not enough time to evaluate all the data and provide meaningful comments on all aspects of the Proposed Rule. EPA should have done more review of existing EPA records about the industry and engaged with PCA members before issuing this Proposed Rule and deciding to regulate the industry under CSAPR. These egregious errors would provide grounds for the D.C. Circuit to overturn the requirements for the cement industry as arbitrary and capricious in the Proposed Rule.

II. EPA's Modeling Analysis Overinflates Upwind State Contribution to Downwind Receptors

EPA's modeling and policy choices, used for Step 2 of the Proposed Rule, contain several technical issues and depart from Agency policy without the Agency providing a reasonable basis. EPA should correct its flawed analysis at Step Two. In conducting the Step Two analysis for the Proposed Rule the EPA failed to follow its own guidance to link upwind

states that are contributing above a threshold amount to and downwind state's attainment issues in reference to the 2015 ozone NAAQS. In its Step 2 analysis, EPA linked 27 upwind states to downwind attainment issues when it only applied a 1% threshold (i.e., 0.7 ppb) of contribution to downwind receptors and failed to provide an alternative threshold. For the reasons described below, we urge EPA to reconsider its decision to only use the 1% screening threshold and instead use a statistically significant threshold of not less than 1 ppb.

Additionally, we incorporate the Ramboll Report into our comments.⁷

A. EPA's analysis at Step Two is based on an inflated upwind state contribution.

At Step Two, EPA's analysis was based on tools, assumptions, errors, and omissions that overstated upwind state contributions at downwind receptors.⁸ Had EPA considered natural emissions, such as lightning, the corresponding upwind state contribution to downwind receptors would have been reduced. Additionally, EPA's use of the Anthropogenic Precursor Culpability Assessment ("APCA") probing tool similarly added to overstated upwind state contribution by accounting for ozone formed from both anthropogenic NO_x emissions and biogenic volatile organic compound ("VOC") emissions.⁹ Had EPA used a true ozone source apportionment tool, instead of the APCA, biogenic emissions would not have been allocated in this manner. Additionally, the inclusion of combined anthropogenic and biogenic emissions raises concerns over potential double-counting of ozone. Thus, EPA should conduct its analysis at Step Two using an appropriate ozone source apportionment tool.

B. EPA Failed to Follow Agency Guidance in Selecting a Screening Threshold

The 1 % screening threshold EPA applied failed to follow Agency guidance and lacked a sufficient technical basis, resulting in a minimum of nine states (AL, KY, MN, NV, TN, WY, MS, OK, and OR) where non-EGU sources should not be covered by the proposed regulation.¹⁰ EPA failed to explain its decision to depart from its own agency procedures in which a peer-reviewed analysis found 1 ppb was the appropriate screening threshold for evaluating whether a state contributes significantly to downwind emissions under the 2015 ozone NAAQS. EPA's use of a 1% threshold is arbitrary and capricious.¹¹

On August 31, 2018, EPA released a Memorandum evaluating significant contribution thresholds of 1 ppb and 2 ppb in addition to 1 % of the NAAQS, supporting the use of a 1 ppb

⁷ See Ramboll, Evaluation and Critique of EPA's Proposed Good Neighbor Plan for the 2015 Ozone NAAQS (June 2022) (Ramboll Report), submitted in support of the Air Stewardship Coalition's comments.

⁸ Ramboll Report at 48.

⁹ Id. 50.

¹⁰ Id. at 61-64.

¹¹ See *Morton v. Ruiz*, 415 U.S. 199, 235 (1974) (agency's failure to follow its own guidance documents is arbitrary and capricious).

threshold for State Implementation Plans (SIPs) addressing the 2015 ozone NAAQS.¹² This endorsement is the only technically justifiable choice among the options evaluated, given the peer-reviewed, statistical analysis EPA itself conducted. EPA's analysis established that 1 ppb was the right threshold to find a "proposed source will not cause or contribute to a violation of a NAAQS and that two ozone design values (DVs) that differ by 1 ppb or less is below 1 ppb are not statistically significantly different from each other.

In the Proposed Rule, EPA essentially only asserts that its selection of 1% is consistent with the threshold it has used in other transport rules.¹³ The mere fact that EPA may have used a certain metric in past transport rules before it analyzed the metric and subjected it to peer review is not a rational reason to continue to rely on it.

Thus, if EPA proceeds to a final rule, we request that the Agency follow its own 2018 guidance and apply a 1 ppb screening threshold and eliminate states that do not contribute emissions above that threshold.

C. EPA Step Two Screening is Premised on the Premature Disapproval of 19 Upwind States Good Neighbor SIPs.

EPA's Step Two screening included states that already had Good Neighbor SIPs for the 2015 ozone NAAQS. We understand that under current law EPA generally may issue a Federal Implementation Plan (FIP) following EPA's disapproval of a SIP or determination that a state failed to submit a complete SIP. EPA said that it will not finalize the Proposed Rule for any state for which it has not taken final action on its SIPs. However, EPA has only proposed to disapprove 19 Good Neighbor SIP submissions and issued proposed findings of failure to issue a complete SIP for NM, PA, UT, and VA. The Proposed Rule essentially prejudices the final outcome of those pending SIP actions as disapprovals or determinations that states failed to submit a completed SIP and, in the event EPA takes a different action on those SIPs than contemplated in this proposal --such as approving a SIP-- it would be required to conduct a new assessment and modeling of contribution and subject those findings to public comment. EPA's approach on those 19 SIPs defies the cooperative federalism framework rooted in the Clean Air Act, and particularly the Good Neighbor provision. Accordingly, we urge EPA to stay action on these proposals and to coordinate with the states and affected stakeholders to appropriately sequence actions.

¹² EPA, Analysis of Contribution Thresholds for Use in Clean Air Act Section 110(a)(2)(D)(i)(I) Interstate Transport State Implementation Plan Submissions for the 2015 Ozone National Ambient Air Quality Standards. Memorandum from Peter Tsirigotis, Director Office of Air Quality Planning and Standards (August 31, 2018).

¹³ 87 Fed. Reg. at 20073 col. 1.

III. EPA is using Incorrect and Flawed Data to Justify Further Regulation of Cement Facilities

A. EPA Data Mischaracterizes Emissions Controls and Monitoring Employed by the Cement Industry

In the Proposed Rule, EPA assessed the potential NOx emissions reductions from 489 non-EGU emissions units with greater than 100 tons per year of NOx emissions in the 23 states affected by the Proposed Rule. In evaluating the screening analysis, EPA made significant errors and failed to utilize existing and readily available information regarding NOx emissions and existing NOx controls at cement plants. Instead, EPA relied on false assumptions that had the effect of skewing the outcome of the screening analysis for the cement industry in the proposed Tier 1 industry categorization.

The Non-EGU Emissions Reductions PPB Impacts for the 2015 Ozone Transport FIP Final Memorandum¹⁴ indicates that the EPA used a two-step process for screening industries for inclusion in the Proposed Rule (page 2). Those steps were:

Step 1 - EPA identified industries whose potentially controllable emissions are estimated, by applying the analytical framework, to have the greatest ppb impact on downwind air quality.

Step 2 – EPA determined which of the most impactful industries and emissions units had the most emissions reductions that would make meaningful air quality improvements at the downwind receptors at a marginal cost threshold EPA determined using underlying control device efficiency and cost information.

EPA failed to do the baseline work necessary to accurately perform the screening test listed above. In Step 1 – EPA claimed that (page 3):

“By limiting the focus to potentially controllable emissions, well-controlled sources that still emit > 100 tons per year (“tpy”) are excluded from consideration. Instead, the focus is on uncontrolled sources or sources that could be better controlled at a reasonable cost. As a result, reductions from any industry identified by this process are more likely to be achievable and to lead to air quality”¹⁵

¹⁴ EPA-HQ-OAR-2021-0668-0150

¹⁵ *Id.*

Based on this reasonable approach, the highly regulated and controlled cement industry should have been excluded in Step 1.

EPA's assumption that cement plants in the affected states did not have existing controls and therefore could be controlled easily at a reasonable cost is false. The Non-EGU Screening spreadsheet¹⁶ indicated zero of 47 plants the EPA reviewed had selective non-catalytic reduction ("SNCR") installed to control NOx. However, three-quarters of those cement kilns (36 of 47 listed)¹⁷ have SNCR, installed and operating (See Exhibit A). A large number of those kilns with SNCR controls are subject to EPA consent decrees requiring the installation of controls and enforceable NOx limits that were negotiated case by case, with site-specific consideration taken into account.¹⁸ EPA should have used that publicly available information in assessing the ability of cement facilities to implement additional controls. Additionally, information on existing NOx controls can be found in the RACT, BACT, LAER Clearinghouse ("RBLC" Basic Information | US EPA)¹⁹, in Federal Title V permits that EPA receives for every cement plant, and could have been provided to the EPA if it had requested the information from the cement plants or PCA. However, EPA did not use any of these resources in developing the Proposed Rule.²⁰

In evaluating emission reductions and cost of controls to evaluate the cement industry in Step 2, EPA continued to use false assumptions in place of readily available accurate data. EPA used projected 2023 NOx emissions that are 9% higher than the 2016 baseline emissions. Actual emission trends are going down; 2019 emissions of 11% were lower than the 2016 baseline. EPA used projections that contradict real-world trends for the 2023 emission forecast. Those projections were then used to model the cement industry's impacts and determine that cement sources had a significant impact.²¹ The EPA then proposed controlling the projected elevated NOx emissions by installing SNCR on all kilns in 23 states affected by the Proposed Rule, which would result in a 50% reduction in NOx emission, or 8,000+ tons of ozone season NOx reduction. EPA's forecasted reductions are not achievable, as they are not based on real-world data and trends and should not have been used in the modeling. If SNCR were installed on all of the affected kilns, emission reductions would be significantly lower as 75% of the kilns reviewed

¹⁶ See *Screening Assessment Non-EGU Facility and Emissions Unit Lists – 3-18 -2022*, EPA-HQ-OAR-2021-0668-0191.

¹⁷ EPA only screened one kiln at the Cemex Balcones facility in New Braunfels, Texas. However, there are two kilns at that facility. There are a total of 48 kilns at the 38 cement manufacturing facilities that were screened but because EPA missed one kiln at the Cemex Balcones facility, EPA screened 47 kilns. Both kilns at Cemex Balcones have SNCR installed.

¹⁸ Information about the consent decrees is publicly available on the EPA website (<https://cfpub.epa.gov/enforcement/cases/index.cfm>).

¹⁹ <https://www.epa.gov/catc/ractbactlaer-clearinghouse-rblc-basic-information>

²⁰ Non-EGU Sectors TSD (<https://www.epa.gov/system/files/documents/2022-03/nonegu-sectors-tsd.pdf>; <https://downloads.regulations.gov/EPA-HQ-OAR-2021-0668-0145/content.pdf>) identifies three kilns in Midlothian Texas as having SNCR installed as RACT for the Dallas Ft. Worth Non-attainment area on pages 21-22. None of the kilns were listed in the attachment_1 source tab as having SNCR identified as an existing control.

²¹ Emissions in EPA-HQ-OAR-2021-0668-0105_attachment_4.xlsx

by the EPA are already controlled by SNCR, and NO_x emissions are likely to be significantly lower than the 2016 baseline. By utilizing flawed data to model 2023 emissions and overlooking the emission controls currently in place, the results of EPA's 2-step industry selection process were substantively flawed.

EPA did not screen all cement manufacturing facilities in the 23 affected states that the Proposed Rule would impact. As mentioned above, EPA screened 47 kilns at 38 cement manufacturing facilities in the 23 affected states. Five kilns were removed from the screening assessment because of a consent decree or because the existing units are planned to be replaced in 2023. However, there are 13 cement manufacturing facilities, representing 16 kilns, that were not included in the screening analysis, and EPA apparently did not attempt to determine whether they had SNCR nor estimate the associated projected NO_x emissions reductions at those facilities. EPA should have evaluated every cement manufacturing facility in the 23 affected states to determine whether the cement industry should be designated as a Tier 1 Industry and thus subject to regulation under CSAPR.

EPA, seemingly arbitrarily, removed four cement plants from its screening analysis because they were subject to a consent decree or are operating with permits modified to reflect conditions of a consent decree. There are many more cement plants under a consent decree that EPA did not eliminate from its analysis. This is further evidence that the EPA did not conduct sufficient due diligence in determining the estimated amount of NO_x emissions reductions that could be achieved through this Proposed Rule.

With the limited time that EPA afforded for the comment period, the industry identified these egregious errors, requiring correction, regarding the cement industry. The industry would likely be able to identify and correct any additional errors if more time was afforded to stakeholders. EPA has regulated the cement industry for more than 50 years, and as a result of its oversight of the industry, the EPA has access to Title V Permits associated with cement industry kilns. Those Title V Permits list NO_x emissions limits and control technologies. EPA could have easily identified the errors in the cement industry data it relied on for the development of the Proposed Rule had it reviewed the industry's Title V Permits. These errors signify that EPA knows little about the cement industry and did not do its due diligence when developing its justification to regulate the industry under the CSAPR framework. EPA should obtain accurate and up-to-date information regarding the cement industry and engage with PCA before thinking about moving forward with any NO_x emissions requirements and controls under Section 126 of the CAA.

IV. EPA Proposed Arbitrary and Capricious Emissions Standards that are Unachievable for the Industry to Meet

EPA's proposed source cap limit for the cement industry is inconsistent and not sufficiently explained. In the Proposed Rule, EPA established NOx emissions limits for all seven of the non-EGU industries, however, cement kilns are the only non-EGU industry that would be subject to an additional source cap limit expressed in a ton per day of NOx for each plant under the proposed §52.42 requirements.²² The record fails to sufficiently explain the rationale for the utilization of the source cap limit and how it is equitable for there to be a source cap limit requirement for the cement industry while other industries within the same designated grouping would not be held to the same requirement.

Additionally, in its rush to issue the Proposed Rule, it failed to recognize that the proposed source cap limit could lead to inequities across the cement industry. There is significant variability between cement plants, including the age of the plants, kiln types, clinker type available raw materials, and the fuel types utilized. All of the above factors need to be taken into account when considering the achievability of NOx limits. As mentioned above, the EPA in its haste, failed to make reasonable inquiries into the use of SNCR at cement kilns currently. In the Proposed Rule, EPA states that “[i]n order to achieve the necessary non-EGU emission reduction in the 23 states, the EPA proposes emission limitations for the most impactful units in the relevant industries that are achievable with the control technologies identified in the Step 3 Analysis.” The Step 3 Analysis identified SNCR as the achievable control technology for the cement industry. However, the EPA failed to recognize that SNCR is currently in use at many cement kilns and that a significant number of those kilns with SNCR already installed are not able to achieve the limits for total allowable NOx emissions from all cement kilns located at one cement plant that would be established with the proposed source cap limit. Failure to meet these stringent limits will likely result in production curtailment and potential cement facility closures.

A. EPA Arbitrarily Co-opted the Source Cap Limit from the Dallas-Fort Worth Nonattainment Area without Assessing the Ability of Applicable Cement Plants to Comply

EPA is proposing to impose both specific kiln-type and a source cap limit to achieve NOx emissions reductions for the cement industry to meet “Good Neighbor” requirements under Section 126 of the CAA. In its apparent rush to issue the Proposed Rule, EPA did not evaluate whether the cement industry could comply with the NOx emissions limits imposed by the source cap limit. After data gathering and analysis developed by the industry, it was determined that the source cap limit would impose emissions limits that would not be feasible for the industry to comply with and would impose limits for many existing kilns below the EPA NOx standard for new or reconstructed kilns subject to the New Source Performance Standards for Portland Cement Plants (“NSPS”).²³

²² 87 Fed. Reg. at 20179 col. 3.

²³ See 40 CFR § 60 Subpart F

EPA arbitrarily and capriciously proposed the source cap limit without evaluating the potential ability of the industry to comply with the requirement, and without following any standard regulatory procedures akin to Reasonably Available Control Technology (RACT)/Best Available Control Technology (BACT)/ Lowest Achievable Emissions Rate (LAER), and without presenting any justification for the source cap limit in the rule preamble, except for stating that the limit was to “provide operational flexibility.”²⁴ However, the Proposed Rule requiring the cement industry to comply with both the kiln-type and source cap limits does the exact opposite - would not provide any operational flexibility and potentially result in restricting production to meet the source cap limit. Therefore, the emissions cap formula is simply a mechanism to lower the effective emission rate well below the listed rate limits in § 52.42(c)(1), Table NOx Emission Limit Table.

EPA is arbitrarily co-opting the Texas Administrative Code (“TAC”) source cap limit for the DFW Ozone NAAQS nonattainment area, and it would be improper to impose similar limits on areas that are in attainment for Ozone NAAQS because EPA did not conduct a process under RACT/BACT/LAER to set a standard. For example, the kilns located in Pennsylvania in Berks, Butler, Lehigh, Northampton, and York Counties are all in areas of attainment for the 2015 Ozone NAAQS 8-hour standard, yet the Proposed Rule would impose nonattainment standards on those plants. There are also many plants located in areas of Missouri, Texas, Indiana, Ohio, Illinois, and other states that are in attainment and the Proposed Rule would impose nonattainment standards on those plants as well. Imposing a standard designed for nonattainment areas for the kilns located in attainment areas for the 2015 Ozone NAAQS would be improper.

EPA seemed to have copied and pasted the source cap limit from the DFW Ozone NAAQS Nonattainment Area²⁵ and deemed the formula sufficient for the Proposed Rule with little justification. EPA seemed to reason since the source cap limit is being applied in DFW, the source cap limit could be applied more broadly for the cement industry to address “Good Neighbor” requirements. However, imposing the source cap limit from DFW more broadly to the industry presents several legal and technical issues that EPA failed to evaluate or analyze. Had EPA done sufficient due diligence, EPA would have found that it is not feasible for the industry to comply with the proposed source cap limit.

The source cap limit was developed after protracted negotiations between cement companies with kilns in the DFW, Midlothian, Texas, and the Texas Council on Environmental Quality (“TCEQ”) to address the unique conditions in the DFW Ozone NAAQS nonattainment area, and therefore is not suitable for broader application. At the time of the adoption of TAC § 117.3123(b) on June 14, 2007, three cement plants operating in Midlothian, Texas, had the following kiln configurations:

²⁴ 87 Fed. Reg. at 20144

²⁵ See Texas Administrative Code § 117.3123(b)

Ash Grove: three wet kilns

Holcim: two preheater/precalciner kilns

TXI: one preheater/precalciner kiln and four wet kilns (two wet kilns operated as backup units)

The source cap limit was developed specifically to address the unique cement plant configurations and raw material and fuel characteristics of the three companies operating in Midlothian, Texas, and to develop a NO_x emissions limit for the unique cement plant configurations that could address Ozone NAAQS nonattainment for DFW. Additionally, it should be noted, that there are no cement plants in the 23 affected states that operate both wet and dry kilns at the same location.

The TAC preamble establishes the basis for dry preheater-precalciner or precalciner kilns (KD) NO_x emissions factor of 1.7 lb/ton and wet kiln NO_x emission factor (KW) of 3.4 lb/ton within the DFW nonattainment area but did not conduct the similar analysis to determine justifiable NO_x emissions factors for the source cap limit that could be applied to the industry more broadly. The emission factors, KD and KW, used for the source cap calculation for the DFW nonattainment area, were determined based on actual emissions data from the sources located in Ellis County, which is included in the Dallas–Fort Worth–Arlington metropolitan statistical area, per a July 14, 2004 report prepared by ERG Inc. for TCEQ.²⁶ The wet kiln NO_x emission factor, 3.4 lb/ton clinker, is based on an approximate 35% reduction from Ash Grove’s actual average pound per ton of clinker emission rate from 2003 to 2005. The 35% reduction assumes the operation of SNCR and is outlined in Tables 1-6 to 1-8 of the ERG report.²⁷ The 1.7 pounds per ton of clinker emission factor represents an approximate 45 - 50% reduction from TXI’s pound per ton of clinker emission rate for 2001. The 50% reduction assumes the operation of SNCR and is outlined in Table 1-1 of the ERG report.²⁸ The source cap limit has not been updated since it was finalized on June 14, 2007, and NO_x emissions limits for the cement kilns in Midlothian, TX remain established based on production data between 2003-2005. EPA did no such analysis of relevant NO_x emissions factors when adopting the source cap limit and did not set a specific time period for calculating the source cap limit. As a result of EPA’s lack of due diligence, the source cap limit would impose limits for the broader industry that will not be feasible to comply with based on the most recent production data.

In its apparent rush to issue the Proposed Rule, EPA did not seem to analyze the source cap limit and whether it would be feasible to comply with. After gathering annual clinker

²⁶ See *Assessment of NO_x Emissions Reduction Strategies for Cement Kilns – Ellis County*, July 14, 2006, https://www.tceq.texas.gov/assets/public/implementation/air/rules/cement_final_report.pdf (Last Visited June 8, 2022)

²⁷ *Id.* at Page 1-9

²⁸ *Id.* at Page 1-5

production data from 2019 to 2021 from PCA members and calculating the potential source cap limit for the affected existing cement manufacturing facilities, preheater/precalciner, precalciner, and long wet kilns would be subject to a NO_x emissions limit that would be infeasible to meet. The source cap limit also did not identify preheater, long dry, and semi-dry kilns in the formula, leaving PCA to estimate the potential limits for those kilns or assume no source cap limit applies to these kilns. PCA's analysis using 2019-2021 annual clinker production data, regardless of kiln type, estimated that the daily source cap limits during the ozone season, could be more stringent than the 1.5 lb/ton clinker standard for new kilns under the NSPS.²⁹ Based on technology limitations, it is infeasible for an existing kiln to comply with an emissions standard that is more stringent than a newly constructed, state-of-the-art kiln. Furthermore, there are instances where long dry kilns must meet NO_x emissions limits more stringent than preheater/precalciner kilns, which is not feasible based on technology limitations.

The short-term cap formula uses three years of annual clinker production data to generate an annualized production short-term production rate that is significantly lower than the actual peak 30-day production rates. This annualized rate includes normal production variability due to both annual and seasonal demand (including pandemic-related and other economic downturns), scheduled downtime for maintenance and turnarounds, and weather-based production slowdowns. Cement plants operate at their peak rates in the summer months (ozone season) when construction activity is highest and clinker demand is greatest. Wet and cold seasons also lower demand and therefore clinker production. This short-term variability is much greater than the one standard deviation ("SD") included in the formula using annualized production data. We believe maximum monthly short-term production rates will generally be 20-40% greater than a calculated 3-year annual average with an additional SD.

The other factor in the cap equation is the emission rates that were negotiated for the DFW non-attainment SIP for a very small and specific group of kilns. The emission cap factor of 1.7 lb NO_x/ton clinker for dry preheater-precalciner or precalciner kilns is 39% and 26% lower than the limits EPA deemed appropriate in Table VII.C-2: Summary of Proposed NO_x Emissions Limits for Kiln Types in Cement and Concrete Product Manufacturing. The emission cap factor of 3.4 lb NO_x/ton clinker for long wet kilns is 15% lower than the limit EPA listed in the rate table.

²⁹ See 40 CFR § 60.62(a)(3). The New Source Performance Standards ("NSPS") for cement kilns at 40 CFR § 60 Subpart F outlines the method for determining the standard of 1.5 lb/ton clinker for new kilns. EPA reasoned that there were numerous examples of kilns without SNCR that could feasibly meet an emissions standard of 3.0 lb/ton clinker and with the application of SNCR with expected emissions reduction of 50%, the standard was set at 1.5 lb/ton clinker. During the development of the NSPS for cement kilns, EPA considered setting the limit lower than 1.5 lb/ton clinker but believed that the data from new kilns, regardless of location and fuel and raw material inputs, showed that new kilns could not meet a standard lower than 1.5 lb/ton clinker.

Therefore, the short-term cap begins with a production rate 20-40% lower than actual ozone season production rates and uses an emission factor 15-40% lower than determined in EPA's analysis. Multiplying these two artificially low values together to get the emission cap leads to an effective emission rate limit using the emission cap that is 35-80% lower than the emission rate table EPA prepared as part of this rule. This effectively negates the emission rate table and puts in place a 1.0 to 1.5 lb NO_x /ton clinker limit, more stringent than the BACT standard for new kilns, that will not be achievable by existing well-controlled kilns without curtailing production.

EPA is proposing to impose the source cap limit for cement facilities in the 23 affected states because it incorrectly assumes that none of the kilns screened impacted by the Proposed Rule already installed and operates SNCR. As outlined above, three-quarters of kilns screened by EPA have SNCR already installed and are operating their SNCR systems to optimal efficiency to meet permitted NO_x limits for their unique kiln configurations and operational conditions. As a result, those cement facilities affected by the Proposed Rule would not be able to feasibly achieve the more stringent emissions standards required by the source cap limit. Additionally, for those kilns with SNCR that would be affected by the Proposed Rule, EPA would not achieve the assumed 50% annual emissions reduction and prorated emissions reduction during the ozone season.

Many cement kilns in the 23 affected states are already complying with a NO_x emissions limit developed through a consent decree; consent decrees finalized in the last ten years largely impose reliance on SNCR systems. The source cap limit found in the Proposed Rule would impose a more stringent NO_x emissions limit than those imposed by consent decrees. The consent decrees were carefully negotiated between EPA headquarters and regions, the U.S. Department of Justice, state governments, environmental and community groups, and industry to set achievable NO_x emissions limits and take into consideration varying kiln configurations and unique operating conditions. The proposed source cap limit would impose more stringent NO_x emissions limits for these kilns than the limits negotiated through consent decrees.

Multiple factors affect the amount of NO_x emissions at cement manufacturing facilities that were not considered in setting NO_x emissions limits in the Proposed Rule, including burnability from manufacturing different clinker types, fuel type, raw material variability, and age and design of the kiln system. In particular, for fuels, natural gas has relatively low nitrogen contents --lower than coal³⁰ or petroleum coke-- both of which are the traditional fuels used in cement manufacturing. But due to location and lack of pipeline access, many kilns do not have access to natural gas that can lower kiln NO_x emissions. In addition, EPA recognizes that older kiln designs, including long wet and long dry, are less efficient than modern kilns and

³⁰ See EPA 450/2-80-063, APTI Course 427 Combustion Evaluation

subcategorizes kilns for the kiln-type limits but the source cap limit would eliminate it as a factor when setting NOx limits.

The EPA failed to recognize that SNCR is currently in use at many cement kilns and that a significant number of those kilns with SNCR already installed are not able to achieve the limits for total allowable NOx emissions from all cement kilns located at one cement plant that would be established with the proposed source cap limit and maintained current production rates and cannot be achieved with SNCR alone. The source cap limit is the wrong approach to regulating the industry under CSAPR and EPA should not consider it appropriate to regulate industry NOx emissions on a widespread basis.

B. EPA did not Evaluate the Key Aspects of Implementing the Source Cap Limit.

In the Proposed Rule, EPA failed to consider key issues for the implementation of the source cap limit, leaving members confused as to how to comply with the source cap limit starting in 2026. In the TAC source cap limit, TCEQ and the cement companies impacted by the code negotiated that the source cap limit would be based on production between 2003-2005, years that enabled high levels of production and did not experience economic disruptions such as COVID-19. In the Proposed Rule, EPA did not identify a three-year period to base the source cap limit on for implementation of the Proposed Rule in 2026 leaving members confused regarding which years' production levels are to be used to set the limit. EPA also did not consider whether the three-year period would be fixed or change from year to year based on the three most recent production years. Changing the source cap limit every year based on the most recent three years of production will cause significant uncertainty in planning to comply with NOx emissions limits under the source cap limit in future years and could result in unreasonably low NOx emissions limits if there are similar economic disruptions in future years. As outlined above, this again shows that the source cap limit lacks a rational basis and is arbitrary and capricious.

EPA failed to conduct due diligence to determine appropriate monitoring requirements to comply with the proposed NOx emissions limits. EPA is proposing to require cement facilities to comply with 30-day source cap limits through semiannual performance testing for a 5-month compliance period, which is an obvious mismatch of compliance monitoring to compliance periods. The Proposed Rule does not provide details on how to demonstrate compliance with the 30-day rolling average through performance tests and how to report compliance with these limits. Kilns should be given the option to comply with a periodic stack testing requirement. For those kilns opting to conduct periodic stack testing, such testing should only be required during the ozone season. Since the ozone season is five months, testing should only be required once a year during the ozone season. In the Proposed Rule, EPA also seeking comments on the feasibility of requiring affected cement facilities to install continuous emissions monitoring

systems (“CEMS”).³¹ Many in the industry are already continuously monitoring NOx emissions. Without additional details about the proposed monitoring of NOx emissions requirements, we cannot provide meaningful comments on the vague requirements. However, we would like to note that it would not be appropriate for the EPA to require semiannual testing where CEMS is in operation, as those kilns should be able to comply with a NOx monitoring requirement through continuous NOx monitoring. These types of details are critical for the industry to understand how to comply with the Proposed Rule.

If EPA decides to maintain the 30-day rolling average period, EPA must ensure it is consistent with existing NESHAP, NSPS, and Prevention of Significant Deterioration (“PSD”) regulatory requirements to maintain ease of compliance. In the Portland Cement NESHAP³², the 30-day rolling average is calculated by a new average value each operating day and includes the average of all valid hourly averages of the specific operating parameter.³³ For demonstration of compliance with an emissions limit, based on pounds of pollutant per production unit (as is the case in the Proposed Rule), the 30-day rolling average is calculated by summing the hourly mass emissions over the previous 30 operating days, then dividing that sum by the total production during the same period.³⁴ If EPA maintains the 30-day rolling average for complying with both the source cap limit and kiln-type limits, EPA must be consistent with other regulations that cement manufacturing facilities must comply with. Those regulations include a 30-day rolling average that is to be calculated using Equation 6 of 40 CFR 60.64(c)(1) in the NSPS for cement kilns.³⁵ This will avoid confusion and overly burdensome regulatory requirements.

EPA did not evaluate the impact of the Proposed Rule on the cement industry and other key infrastructure commodities, including steel and glass, and the ability to meet the Biden Administration’s goal to transform U.S. infrastructure through IIA. The proposed limits would impose infeasibly stringent NOx emissions limits on the cement industry and would result in kilns having to curtail production or shut down kilns. Existing domestic cement production does not meet current U.S. demand, which is expected to only increase as federal and state governments allocate more money for infrastructure spending. According to the United States Geological Survey (“USGS”), 89 million tons of cement were produced in the U.S. and 15 million tons of cement were imported from foreign countries in 2020.³⁶ The U.S. cement industry still has not fully recovered from its peak production levels in 2005 of 99.3 million due

³² *Id.*

³³ 40 CFR § 63.1341

³⁴ *Id.*

³⁵ 87 Fed. Reg. at 20179

³⁶ Annual 2020 Cement Mineral Commodity Summary, USGS, <https://pubs.usgs.gov/periodicals/mcs2021/mcs2021-cement.pdf> (Last Visited June 10, 2022)

to the 2008 financial crisis.³⁷ If finalized, the Proposed Rule will significantly impact the industry's domestic manufacturing capacity, reducing U.S. economic growth, preventing the industry from returning to peak production levels, and resulting in the import of more cement from overseas which could result in worse environmental outcomes, including increased GHG emissions.

As EPA has recognized through multiple rulemakings and individual site-specific BACT and RACT reviews, the best technology available for NOx control at cement kilns is SNCR and it is already widely implemented across the cement industry. The cement industry would be forced to curtail production or shut down kilns to reduce facility NOx emissions in order to meet infeasible emissions control requirements beyond what is achievable with SNCR.

C. EPA did not Provide Sufficient Justification for the Specific Kiln-Type Limits to be Imposed in Conjunction with the Source Cap Limit

In addition to the source cap limit, EPA is proposing specific kiln-type limits that cement facilities in the 23 affected states would be required to comply with.³⁸ EPA developed these limits by looking at a few jurisdictions and selecting limits from those jurisdictions with no apparent analysis conducted by the EPA to determine whether the limits were feasible or the EPA inquiring into how the states developed those limits. In addition, EPA did not include limits for all types of kilns, specifically semi-dry kilns.

The 2.8 lb/ton clinker limit for preheater/precalciner kilns was taken from limits in 35 Illinois Administrative Code (IAC) § 217.224(a), the Mitsubishi Cement Corporation Lucerne Valley Federal Operating Permit issued by the Mojave Desert Air Quality Management District, and Texas 30 TAC § 117.3110(a)(4).³⁹ The limit for preheater kilns was consistent with Illinois and Texas in 30 TAC § 117.3110(a)(3) and 35 IAC 217.224(a).⁴⁰ Reviewing the Proposed Rule and the technical supporting data in the regulatory docket, EPA seems to have cherry-picked these limits and did not conduct any analysis to determine whether the specific kiln-type limits were feasible for the applicable cement facilities in the 23 affected states. The ability of a specific kiln design to meet the proposed limits was not considered and, if such limits remain, a technical exemption process must be included in the final rule to evaluate actual RACT performance at each facility. As EPA has documented in the NSPS rulemaking, the wide range of existing kiln types constructed over the past 50-plus years are not all able to control NOx emissions at the same levels, only newer kilns were designed with NOx emissions as a performance goal.

³⁷ Annual 2007 Cement Mineral Commodity Summary, USGS, <https://d9-wret.s3.us-west-2.amazonaws.com/assets/palladium/production/atoms/files/mcs-2007-cemen.pdf> (Last Visited June 21, 2022)

³⁸ 87 Fed. Reg. at 20144

³⁹ *Id.*

⁴⁰ *Id.*

Additionally, the averaging period for the proposed limits was not clearly defined, leaving additional uncertainty as to how to document compliance. If the source cap limit is included in the final rule, PCA proposes an ozone season average emission rate be used for determining compliance with the rate limits.

These state limits referenced above were the result of administrative rulemakings with analyses showing how they were feasible given the unique factors that impact cement NOx emissions at cement kilns in those states. EPA did not take into account the factors referencing burnability, clinker types, fuel types, and age of the kiln system that should be considered in an analysis of setting feasible NOx emissions limit with broader applicability. As EPA considers how to move forward and engages with PCA on determining any NOx emissions standards to meet Good Neighbor obligations under Section 126 of the CAA, EPA should conduct detailed analyses to determine feasible NOx emissions standards for the industry to meet, given the numerous factors that can affect variability in industrial NOx emissions and the existing controls employed by the cement industry.

D. EPA Should Engage the Cement Industry Prior to Developing NOx Emissions Limits to Meet Good Neighbor Requirements

EPA took the wrong approach when it sought to reduce NOx emissions for the cement industry. EPA did not conduct sufficient modeling to regulate the cement industry and incorrectly assumed that none of the kilns screened in the 23 affected states had already installed state-of-the-art SNCR NOx emissions controls and that it could impose feasible NOx emissions standards via the proposed kiln-type and source cap limits. Instead, EPA should have engaged the industry to produce a robust evaluation focused on the amount of NOx emissions reductions feasible across all the cement manufacturing facilities in the 23 affected states and then engage with PCA to determine whether impactful reductions are achievable. EPA must perform the industry screening exercise using corrected data to determine if the cement industry should be considered a Tier 1 or Tier 2 industry. At that point, EPA should work with PCA and its members to determine technically and economically feasible methods to reduce NOx emissions and address ozone transport from upwind to downwind states impacting their ability to attain the 2015 Ozone NAAQS.

Three-quarters of the kilns that EPA screened as part of its analysis under the Proposed Rule are already operating SNCR technologies to meet permitted NOx limits for their kiln configuration, with technical factors impacting the amount of NOx emissions control. According to the EPA Cost of Control Manual, SNCR Chapter, reductions for SNCR systems designed as the Best Available Retrofit Technology were estimated between 35 and 58 percent with a median

reduction of 40% compared to no NOx controls.⁴¹ Yet, in the Proposed Rule, EPA assumed each screened kiln, presumably under the incorrect assumption that all kilns are without SNCR, would see 50% reductions in NOx as a result of a retrofitted installation of SNCR.⁴² Imposing SNCR on existing kilns that do not currently have SNCR installed would have a range of NOx emissions reductions based on technical factors unique to each kiln, as recognized by the EPA Cost of Control Manual. Extensive analysis will be needed to determine an accurate estimate of the amount of NOx emissions reductions that would be expected from those kilns in the 23 affected states currently without SNCR.

Kiln type and design impact the degree of difficulty encountered when installing SNCR injection systems on cement kilns⁴³ and, for some kilns, SNCR is not feasible to install, and alternative NOx emissions controls must be explored. Industry comments⁴⁴ filed on the 2020 CSAPR Update⁴⁵, when EPA previously evaluated whether to regulate NOx emissions from the cement industry under CSAPR, explained that some cement plant configurations can mean that NOx controls are not technically feasible to install. Kiln 2 at the Lehigh Cement Company Facility in Cass County, Indiana was previously assessed for possible NOx emissions reductions. As a result of that assessment, Lehigh Cement Company and the Department of Justice (DOJ) amended a consent decree acknowledging and stating that it is not feasible to install SNCR on kiln 2, due to the “current configuration of the equipment.”⁴⁶ Lehigh Cement Company explained in a letter to DOJ that “kiln 2’s exhaust gases exit the kiln horizontally and are ducted directly into the electrostatic precipitator (ESP) used to dedust the kiln exhaust gases. A short piece of horizontal ducting connects the kiln exhaust to the ESP. An SNCR system can’t be installed in this short piece of ducting, since there is no place to install the SNCR rotary coupling.”⁴⁷ Water injection was identified as the best available control technology to control NOx emissions for that particular kiln.⁴⁸ There are other examples of unique kiln configurations where SNCR is not feasible. EPA should work with PCA’s members to identify potential alternative controls to reduce NOx for those unique kilns where SNCR is not feasible.

⁴¹ Cost of Control Manual, Section 4 – NOx Controls, Chapter 1 – Selective Noncatalytic Reduction, EPA, Page 1-5, <https://www.epa.gov/sites/default/files/2017-12/documents/sncrcostmanualchapter7thedition20162017revisions.pdf> (Last Visited June 10, 2022)

⁴² See *Screening Assessment Non-EGU Facility and Emissions Unit Lists – 3-18 -2022*

⁴³ Cost of Control Manual, Section 4 – NOx Controls, Chapter 1 – Selective Noncatalytic Reduction Reduction, EPA, Page 1-5

⁴⁴ See Comments of American Fuel & Petrochemical Manufacturers, American Petroleum Institute, Portland Cement Association, American Chemistry Council, and U.S. Chamber of Commerce on EPA’s Proposed Revised Cross-State Air Pollution Rule Update for the 2008 Ozone NAAQS, EPA-HQ-OAR-2020-0272-0132.

⁴⁵ 85 Fed. Reg. 68,964

⁴⁶ See Consent Decree, U.S. v. Esscroc Cement Corp. (No. 2:11-cv-01650-DSC), available at https://www.justice.gov/sites/default/files/pages/attachments/2017/08/08/env_enforcement-2677705-v1-lodged_3rd_mod_to_cd.pdf (Last Visited June 10, 2022)

⁴⁷ See Letter from Brian Montag, K&L Gates, to Catherine Banerjee Rojko, Senior Attorney, U.S. Department of Justice, and Susan Perdomo, Senior Attorney, U.S. Environmental Protection Agency at 2 (Oct. 12, 2016)

⁴⁸ *Id.*

Another method for potential additional NOx reductions is for EPA to explore the feasibility of kilns injecting additional ammonia in an SNCR system without resulting in ammonia slip. Ammonia slip results from excess reagent injection to overcome inherent natural system limitations to obtain the desired level of NOx reduction.⁴⁹ The level of ammonia slip will differ from one unit to the next based on the limitations inherent to each system.⁵⁰ Ammonia in the flue gas stream has several negative impacts, including health concerns with detectable ammonia odors stack plume visibility problems, and the potential to plug, foul, and corrode downstream equipment such as air heaters, ducts, and fans from ammonia-sulfur salts.⁵¹ Some cement kilns have ammonia limits that they must meet and ammonia slip must be managed to ensure kilns do not exceed those ammonia limits.

EPA must work with industry to assess the potential of reducing NOx emissions through additional ammonia injection in SNCR systems without the negative impacts of ammonia slip. In the NSPS for cement kilns, EPA based the 1.5 lb/ton clinker limit on SNCR emissions reduction of 50%.⁵² EPA found examples of SNCR systems for new kilns that achieved greater than 50 percent and as high as 80 percent or more of NOx reductions. These reductions were achieved without appreciable ammonia slip.⁵³ However, this is not the case for existing kilns that currently have SNCR installed as these systems are operating at optimal efficiency considering each kiln's unique configuration and technical factors. EPA must work with PCA and its members to determine the practical reductions that could result from additional ammonia injection in SNCR systems while not increasing ammonia slip.

Instead of imposing the infeasibly stringent source cap limit and kiln-type limits in the Proposed Rule that were cherry-picked from specific jurisdictions, EPA should work with PCA to evaluate the amount of practical emissions reductions that can be achieved and develop a menu of feasible options for the industry to implement that will further the industry's NOx emissions reductions and meet EPA's goal of addressing its Good Neighbor obligations under Section 126 of the CAA.

V. The Proposed Emissions Standards Would Exceed the Established Technology Breakpoint/Cost-Thresholds.

A. EPA's initial screening of cost-effective controls for non-EGUs at \$7,500 per ton departs from past practice and is unjustifiably high

⁴⁹ Cost of Control Manual, Section 4 – NOx Controls, Chapter 1 – Selective Noncatalytic Reduction, EPA, Page 1-18

⁵⁰ *Id.*

⁵¹ *Id.*

⁵² 75 Fed. Reg. at 54994

⁵³ *Id.*

EPA should reconsider its \$7,500 per ton average marginal cost-effectiveness threshold that departs from past practice and is unjustifiably high. EPA used data to plot curves for Tier 1, Tier 2, and Tier 1 and 2 industries, for which EPA asserts it identified a “knee in the curve” at approximately \$7,500 per ton.⁵⁴ This approach marks a major departure from prior transport rules, which EPA failed to explain.

EPA dramatically increased its proposed average marginal cost-effectiveness threshold for all non-EGUs, including cement plants, to \$7,500 per ton with little to no explanation. The Agency’s sole analysis is that there was a “knee in the curve” that identified \$7,500 per ton, but that is not obvious to a reviewer. There is no noticeable difference around \$7,500 in the plotted line for Tier 1 industries, instead, the Tier 1 line reflects a break around the \$1,600 mark.⁵⁵ While the Tier 2 and combined Tier 1 and 2 lines show some difference around the \$7,500 mark, there is no explanation for EPA’s reliance on a “break in the knee” as opposed to past transport rules that have relied upon a “clear breakpoint” at this step.

In addition, EPA fails to explain why the threshold departs from prior transport rule cost-effectiveness thresholds for non-EGUs. In particular, less than one year before EPA released the Proposed Rule, in the 2021 Revised CSAPR Update Rule, EPA said the non-EGU data demonstrated “a clear breakpoint” (versus a “knee in the curve”) at approximately \$2,000 (in \$2016) per ton.⁵⁶ According to EPA, EPA adopted “that analysis using the best available current data,” including the “identified available control technologies,” their “costs and potential emissions reductions,” and “the information it has regarding control technology implementation timeframes, including information on such timeframes provided by commenters on the proposed rule.”⁵⁷ Further, to identify levels of control for non-EGUs, EPA used the Control Strategy Tool (CoST) and the projected 2023 inventory from the 2016v1 modeling platform, just as EPA has done in this Proposed Rule. Indeed, there is no indication in the Proposed Rule that EPA collected any new information on costs or technologies, or implementation timelines that differed in any material way from the information it analyzed in the Revised CSAPR Update Rule.

As such, almost a *4-fold increase* in the alleged cost-effectiveness threshold for non-EGU sources cannot reasonably be supported, given that EPA is applying the same historical information in this proposal as in the rule this EPA issued and this Administrator signed only 14 months ago. On the contrary, every economic indicator would suggest that technology would be more costly today and there is nothing in the record to suggest that the control technologies have changed in any material way. Thus, we urge EPA to revert to and apply its already finalized metric in evaluating non-EGU sources in this proposal, unless and until it gathers new and more current information. In the Revised CSAPR Update, this threshold was used to correctly exclude certain

⁵⁴ 87 Fed. Reg. at 20083, col. 3.

⁵⁵ See EPA, Screening Assessment of Potential Emissions Reductions, Air Quality Impacts, and Costs from Non-EGU Emissions Units for 2026 at 4, Figure 1 (Feb. 28, 2022)

⁵⁶ 86 Fed. Reg. at 23098, col. 3.

⁵⁷ 86 Fed. Reg. at 23098, col. 2.

sources, such as industrial boilers, since controls necessary to reduce transport emissions from industrial boilers were more than the \$1,900 threshold.⁵⁸ Thus, absent further explanation for the change, it appears EPA arbitrarily combined the Tier 1 and 2 industries and selected a high-cost threshold to pull in as many industrial sources as possible.

The \$7,500 per ton threshold for non-EGUs also deviates from the threshold applied to EGUs in 2023, which may be considered contrary to the Supreme Court's holding in *Homer City* that reinforced the use of a uniform cost-effectiveness threshold to address transport.⁵⁹ While EPA proposes a higher threshold for EGUs in 2026, EPA should still explain how it reconciles the *Homer City* decision with its disparate threshold in 2023 as well as 2026. Indeed, if EPA were to assert it is permissible to apply different thresholds for non-EGUs and EGUs, the Agency should further explain whether this rationale would extend to the different non-EGU industries.

Further, EPA adopted the same \$7,500 per ton cost-effectiveness threshold it calculated for 2023 – for 2026 – without any explanation or analysis.⁶⁰ Given that EPA is properly recognizing that non-EGUs cannot meet any new requirements in 2023, it must prepare a cost-effectiveness analysis specific to 2026. While we certainly would not find a higher threshold to be reasonable for 2026, the Agency cannot be excused from its duty to explain its decision. Indeed, if EPA were able to adopt a cost threshold with no analysis or explanation, there may presumably be no limit on the cost threshold the Agency would set.

EPA's \$7,500 per ton is also well above approved state RACT cost controls. Based on 2018\$, EPA guidance for states setting presumptive RACT limits for NOx reflects a cost per ton range up to \$2,200.⁶¹ A sample of several states covered by EPA's proposal has an average cost per ton RACT controls that range from \$2,500 to \$5,000.⁶²

EPA also failed to explain how \$7,500 itself is reasonable, particularly given the Supreme Court in *Homer City* reinforced the importance of costs in the transport framework and found it was reasonable for EPA to select the less costly approach to address significant contribution.⁶³ EPA must reasonably explain why this cost is reasonable for determining contribution and the subsequent controls.

⁵⁸ Moreover, the \$1,900 per ton that EPA applied 14 months ago was consistent with previous interstate transport rules. The NOx SIP Call set a cost-effectiveness threshold for non-EGUs at \$2,000 per ton and the 2016 CSAPR Update had a \$1,400 per ton threshold.

⁵⁹ *EPA v. EME Homer City Generation, L.P.*, 572 U.S. 489, 519 (2014) (finding EPA's approach of uniform cost thresholds on regulated States to be equitable).

⁶⁰ 87 Fed. Reg. at 20084, col. 2; see also Non-EGU Screening Assessment Memorandum at 6.

⁶¹ ASC Comments to U.S. Envtl. Prot. Agency on New York Section 126 Petition (Sept. 24, 2018), Attachment B, Ramboll RACT Analysis at 3. EPA's 1994 guidance to use a cost range of \$160 - \$1,300 per ton of NOx removed for RACT is equivalent to an inflation adjusted cost range of \$270 - \$2,200 in 2018, using the Consumer Price Index (CPI) information available through the Bureau of Labor Statistics (BLS) to adjust for inflation.

⁶² *Id.* E.g., Wisconsin used \$2,500; Illinois \$2,500 to \$3,000; Pennsylvania used \$3,500; Maryland \$3,500 to \$5,000; and Ohio \$5,000 per ton NOx.

⁶³ *EPA v. EME Homer City Generation, L.P.*, 572 U.S. 489, 493 (2014).

B. Cost Estimates Inaccurately Assume Year-Round NOx Reductions.

EPA's cost-per-ton reduction calculations are unreasonably skewed because they assume that SCR will be run all year at cement facilities that have it installed and then calculates expected cost per ton on the basis of annual tons of NOx reduced, despite the fact that the NOx emission reductions being sought by EPA in the Proposed Rule are only to address ozone season emissions. For instance, EPA estimates that the selection of SCR in the Iron and Steel Mills and Ferroalloy Manufacturing Industry may be associated with ozone season NOx reductions, at an annual cost of \$9,886,092.⁶⁴ If EPA had calculated the cost per ozone season ton of NOx reduced, this would result in an estimate of \$10,428 per ton of NOx reduced⁶⁵ (notably above the cost threshold of \$7,500 set by EPA). But EPA instead, without justification, lists the average cost per ton as \$4,345⁶⁶, which would only be the case if the ozone season tons were extrapolated to assume continuous annual reductions.⁶⁷

EPA only has the authority to reduce ozone season emissions under the Proposed Rule and thus should limit its assessment of the cost of ozone season reductions. Furthermore, cement facilities will not operate SCR during the non-ozone season as EPA has acknowledged in the Proposed Rule is "quite typical" in the context of EGUs.⁶⁸ There are sound technical and economic reasons for not operating SCR outside the ozone season, due to the operations and maintenance costs associated with the SCR, and in order to attempt to extend the life of the catalyst given the high cost of replacing the catalyst and how quickly the catalyst can be deactivated under the process characteristics of an Electric Arc Furnace (EAF), as discussed above if the SCR were run continuously. For both reasons, cost estimates should instead only account for the cost per ozone season ton reduced, which in many cases results in estimates higher than the \$7,500/ton screening threshold set by EPA even using EPA's own cost estimates.

VI. Selective Catalytic Reduction Technology is Technically and Economically Infeasible to Implement

As EPA has determined multiple times across state implementation plan ("SIP") reviews for regional haze, NSPS updates, and PSD permitting reviews, SCR is not technically feasible to install at cement plants. PCA agrees with EPA's decision to exclude this unproven and expensive control from the CSAPR review process.

Due to unique aspects of the cement manufacturing process, the implementation of SCR at cement plants results in several difficult technical challenges that do not exist for EGUs.

⁶⁴ See Non-EGU Screening Assessment at Table 9.

⁶⁵ $\$9,886,092 / 948 = \$10,428$

⁶⁶ See Non-EGU Screening Assessment at Table 9.

⁶⁷ $\$9,886,092 / (948 \times (12 / 5)) = \$4,345$

⁶⁸ 87 FR 20078 (<https://www.federalregister.gov/d/2022-04551>)

Sulfur from EGUs can more easily be controlled than at a cement plant because sulfur at power plants can largely be controlled by adjusting the type or source of fuel that is used. Sulfur concentrations are harder to control at cement plants because the total sulfur input in the kiln is greatly impacted by the concentration of the sulfur found in the limestone, which is quarried in close proximity to the cement plant and can be highly variable within the same quarry. Additionally, sulfur concentrations in limestone vary by region. Those with limestone containing higher sulfur will have more difficulty installing SCR.⁶⁹ Cement manufacturers must use local limestone to ensure that the cement-making process is economically feasible.

When higher levels of sulfur are in exhaust flue gas, “masking” can occur. Masking occurs when calcium sulfate (“CaSO₄”) forms on the catalyst’s active pores⁷⁰. CaSO₄ is formed when calcium oxide (“CaO”), particles that are lodged in the catalyst pores, react with sulfur trioxide (SO₃) or sulfuric acid (“H₂SO₄”) present in the exhaust flue gas stream. The CaSO₄ compound is larger than the original CaO particle, thus increasing the area of the pore that is blocked. Masking also occurs when the ammonia, a reducing agent, reacts with the SO₃ or H₂SO₄ present in the exhaust stream to form ammonium sulfate (NH₄)₂SO₄ or ammonium bisulfate (NH₄)HSO₄ which can condense within the catalyst pores and block them. The area of the blocked pores then becomes inactive in the NO_x reduction reaction, decreasing efficiency⁷¹.

To mitigate the impact of sulfur on SCR efficiency, a plant might need to install a sulfur dioxide (“SO₂”) removal system prior to the SCR catalyst bed to significantly reduce the formation of SO₃ and ammonium compounds.⁷² Additionally, as a result of implementation of certain SO₂ removal processes such as a scrubber, there could be a significant system pressure drop requiring adjustment to variable speed fans or often full replacement of downstream induced draft fans. Further, to help mitigate the impact of internal corrosion due to acid formation from sulfur dioxide and sulfur trioxide, stainless steel may be necessary for construction.

Particulate Matter (“PM”) concentrations also greatly affect the ability of cement plants to reduce NO_x emissions, because an increased PM concentration causes fouling. Fouling or plugging of the SCR catalyst bed pores occurs when particulate matter enters the catalyst

⁶⁹ USEPA. Air Pollution Control Cost Manual, Section 4, Chapter 2, Selective Catalytic Reduction, NO_x Controls. June 2019. EPA/452/B-02-001.

⁷⁰ USEPA. *Alternative Control Techniques Document Update – NO_x Emissions Controls for New Cement Kilns*. November 2007. EPA-453/R-07-006.

⁷¹ Schreiber, Robert, Russell, Christa and Evers, Jeff. *Evaluation of Sustainability of Selective Catalytic Reduction and Selective Non-Catalytic Reduction for use in Portland Cement Industry*. 2006. Submitted by PCA to the Ozone Transport Commission.

⁷² USEPA. *Alternative Control Techniques Document Update – NO_x Emissions Controls for New Cement Kilns*. November 2007. EPA-453/R-07-006.

structure and deposits on the catalyst's surface and active pore sites⁷³. The blocked pores cannot participate in the NO_x reduction reaction, thus reducing the SCR effectiveness.

PM concentrations in the flue gas at cement plants are significantly greater than at coal-fired boilers, because of the sintering process. In fact, EPA's Air Pollution Control Cost Manual notes that dust loadings upstream of PM controls in preheater/precalciner cement kilns are typically more than three times higher than those seen from coal-fired boilers and at some kilns, it can be ten times higher.

In addition, both PM and sulfur flue gas concentrations impact SCR performance and are variable by the kiln and raw material input. For example, the underlying geological formations from which the majority of cement plant raw materials are sourced in the European Union ("EU") generally contain less sulfur than their United States counterparts, leading to lower flue gas sulfur concentration, including SO₃ and H₂SO₄, for EU kilns. Therefore, catalyst fouling and masking are less of a concern for EU cement kilns.

To reduce the amount of masking and fouling of the catalyst bed pores, SCR can be installed after the baghouse, i.e., downstream of PM controls, which reduces sulfur and PM concentrations. However, there are downsides to this configuration. The optimum temperature range for SCR is between 480°F to 800°F, with the rate of NO_x removal increasing as temperature increases, with the maximum removal rate at a temperature between 700°F and 750°F⁷⁴. Flue gas exhaust temperatures decrease below the SCR minimum effective operating temperature after the baghouse (exhaust temperature is also utilized as a dioxin and furan emission control) and would need to be significantly reheated upstream of the SCR to improve NO_x control efficiency. Heating the flue gas to the optimum temperature would result in more combustion emissions from the facility.

Although particle loading would be reduced by PM controls upstream of an SCR, the catalyst bed would still be subject to masking and "poisoning." Poisoning occurs when chemical reactions take place between the active catalyst sites and contaminants in the exhaust stream, thus deactivating the catalyst and rendering it ineffective. Two (2) of the most common agents known to cause SCR poisoning are alkaline metals (e.g., sodium and potassium) and CaO, both of which are present in the exhaust flue gas stream of cement kilns due primarily to the content of the raw materials used.⁷⁵

⁷³ *Id.*

⁷⁴ USEPA. *Air Pollution Control Cost Manual, Section 4, Chapter 2, Selective Catalytic Reduction, NO_x Controls*. June 2019. EPA/452/B-02-001.

⁷⁵ USEPA. *Alternative Control Techniques Document Update – NO_x Emissions Controls for New Cement Kilns*. November 2007. EPA-453/R-07-006.

Additionally, because the kiln exhaust, post-SCR control (i.e., tail end), would not pass through a baghouse for PM control, any reactions that would take place as a result of the ammonia injection application would go directly out of the stack and could result in increased air emissions from reheating the exhaust gas stream, including NO_x, VOCs, and other combustion-produced pollutants along with elevated opacity from the formation of ammonium sulfates and nitrates resulting in a detached plume.⁷⁶

Masking and fouling of the catalyst beds that could not be avoided would need to be dealt with via cleaning. Cleaning the catalyst beds is problematic and expensive. This is especially true if dry compressed air is required in order to protect the catalyst bed during the cleaning process and is dependent on a site-specific demonstration to show how the catalyst will perform over the long term for the specific gas constituent analysis of the specific kiln. It is likely that the increased sulfur in the raw materials, even with the implementation of sulfur removal controls prior to the SCR, will mask the catalyst beds more quickly, resulting in decreased NO_x control efficiency and more frequent catalyst changes to allow the catalyst to be sent offsite for regeneration. A bypass would also be required during the catalyst change period and during periods when the inlet gas is not in the appropriate temperature range. Additionally, because cement production produces larger, jagged, and irregular-shaped particles as compared to boilers, catalyst beds may erode more quickly and need replacement, reducing the active life of the catalyst bed and increasing operating costs.

Modern preheater/precalciner kilns are much more thermally efficient (exhaust in 200°F to 400°F range) than older preheater kilns and SCR would require significant supplemental fuel firing to raise the exhaust temperatures to the SCR requirements.

Given these immense technical challenges, EPA must also factor in the SCR efficiency to reduce NO_x emissions at cement plants compared to boilers. EPA assumes that SCR application on cement kilns will result in 80% control efficiency.⁷⁷ Additionally, SCR effectiveness, when applied after a well-tuned SNCR, which ¾ of the kilns in the 23 affected states utilize, would likely be significantly less efficient. NO_x concentration in the flue gas will be much lower after SNCR thus adding SCR control may not result in any significant reduction in NO_x emissions.

For further references on the technical and economic feasibility of cement plants, please see the four-factor analysis for the GCC Rio Grande⁷⁸ cement facility submitted to the Colorado Department of Public Health & Environment. Additionally, please see GCC's Rebuttal Statement outlining that ceramic catalytic filter SCR technology is neither technically nor

⁷⁶ *Id.*

⁷⁷ Cost of Control Manual, Section 4 – NO_x Controls, Chapter 2 – Selective Catalytic Reduction, EPA, Page 6, https://www.epa.gov/sites/default/files/2017-12/documents/scrcostmanualchapter7thedition_2016revisions2017.pdf (Last Visited June 12, 2022)

⁷⁸ Pueblo Plant Four-Factor Analysis, October 2019

economically feasible to implement at cement plants⁷⁹ and a letter from GCC to DPHE regarding technical infeasibility and cost and control efficiency concerns with SCR for GCC's Pueblo Plant.⁸⁰

VII. Potentially Requiring Wet Process Kilns to Retrofit to Preheater/Precalciner Kilns Would be Arbitrary and Capricious and Would Far Exceed EPA's Cost-Effectiveness Threshold

It would be arbitrary and economically and energy inefficient to require wet kilns to be retrofitted as preheater/precalciner kilns. Retrofitting wet kilns to preheater/precalciner kilns is not possible, an entirely new kiln line would need to be constructed. In a wet kiln, the ground raw materials are suspended in water to form a slurry and introduced into the kiln inlet feed.⁸¹ This process requires more thermal energy to evaporate the slurry to manufacture the cement. It would be inefficient to require wet kilns to be converted to preheater/precalciner because the limestone and other raw materials in those wet kilns still in operation in the U.S. have higher moisture contents, necessitating wet process kilns. Forcing these wet process kilns to retrofit, given the technical challenges and significant costs, would likely result in those kilns having to shut down, reducing domestic cement manufacturing production, thereby forcing the U.S. to rely more heavily on higher emission imported cement products.

Two recent examples of kiln modernizations present reasonable estimates of the exorbitant costs of converting a wet kiln to preheater/precalciner kilns. For example, the National Cement Co. of Alabama is in the process of constructing a new five-stage preheater/precalciner kiln at its facility in Ragland, Alabama with an estimated cost of \$250 million.⁸² Lehigh Hanson is in the process of constructing a modernized preheater/precalciner kiln at its Mitchell, Indiana facility and the estimated cost of construction is \$600 million.⁸³ Converting wet kilns to preheater/precalciner kilns would likely cost hundreds of millions of dollars and would be economically infeasible for the industry's remaining wet kilns.

⁷⁹ GCC's Rebuttal Statement, In the Matter of the Proposed Revisions to the Regional Haze State Implementation Plan and Regulation Number 23, October 2021

⁸⁰ Letter from GCC to Colorado DPHE, *Request for Additional Information Regarding GCC Rio Grande Plant, Pueblo, Colorado*, March 27, 2020

⁸¹ Non-EGU Sectors Technical Support Document, EPA, Page 10

⁸² <https://alabamane.wscenter.com/2019/12/20/national-cement-to-build-new-kiln-at-ragland-facility-with-250m-investment/>

⁸³ <https://www.globalcement.com/news/item/12003-lehigh-cement-commences-us-600m-mitchell-cementplant-expansion>

VIII. EPA Forbidding Industrial Sources from Participating in Trading Program is Arbitrary and Capricious

Under CSAPR, EGUs are allowed to use emissions trading to achieve required emissions reductions.⁸⁴ In the Proposed Rule, EPA does not include non-EGUs in the trading program because it would require monitoring and reporting of hourly mass emissions, including the use of CEMS, rigorous initial certification testing, and periodic quality assurance testing, such as relative accuracy test audits (“RATA”).⁸⁵ It is arbitrary and capricious to forbid cement industry facilities from participating in the emissions trading program since many cement facilities employ CEMS monitoring. We propose that non-EGU facilities be allowed to opt-in to the trading program based on the use of their existing CEMS monitoring, daily calibrations, and RATAs. Those facilities that do wish to participate may meet final emission control requirements using onsite controls and should not be discriminated against. EPA justified these requirements to be eligible for emissions trading to ensure consistent and accurate measurement of emissions and to ensure each allowance actually represents one ton of emissions and one ton of reported emissions from one source would be equivalent to one ton of reported emissions from another source.⁸⁶ In addition, EPA reasoned that these monitoring requirements would need to be in place for at least one full ozone season to establish baseline data before it would be appropriate to rely on a trading program as the mechanism to achieve the required emissions reductions.⁸⁷

Many cement industry facilities already fulfill all the criteria that EPA has outlined to be eligible for emissions trading under CSAPR. Therefore, EPA is arbitrarily excluding the many cement industry facilities from participating in an emissions trading program. It was EPA’s apparent rush to issue the Proposed Rule that prevented EPA from collecting facility data and establishing a baseline so that facilities could participate in an emissions trading program that would provide needed flexibility to achieve the NO_x emissions reductions required by the Proposed Rule. As EPA works with industry in determining feasible NO_x emissions reductions, EPA should fully evaluate the industry’s monitoring of NO_x emissions and allow for cement industry facilities that continuously monitor their NO_x emissions to be allowed to participate in an emissions trading program under CSAPR.

IX. Conclusion

PCA appreciates the opportunity to provide comments to EPA on the Proposed Rule. As outlined above, EPA should withdraw the Proposed Rule as its justification is based on incorrect data and represents a fundamental mischaracterization of the cement industry. It would arbitrarily impose infeasible NO_x emissions limits on affected cement facilities, which would

⁸⁴ 87 Fed Reg. at 20106

⁸⁵ *Id.*

⁸⁶ *Id.*

⁸⁷ *Id.*

extend the existing supply chain issues with procuring infrastructure materials, jeopardizing the Biden Administration's goal of improving the nation's infrastructure, as the Proposed Rule would force cement facilities to reduce production, EPA should engage PCA before moving forward with any future requirements for the cement industry under Section 126 of the CAA. Please feel free to contact me, Sean O'Neill, at 202-719-1974 or soneill@cement.org if you have questions.

Regards,

A handwritten signature in black ink, appearing to read "Sean O'Neill". The signature is written in a cursive style with a large, stylized "S" and "O".

Sean O'Neill
Senior Vice President
Government Affairs



June 21, 2022

EPA Docket Center
Docket ID No. EPA-HQ-OAR-2021-0668
Environmental Protection Agency
Submitted electronically to www.regulations.gov

RE: Federal Implementation Plan Addressing Regional Ozone Transport for the 2015 Ozone NAAQS: Docket ID No. EPA-HQ-OAR-2021-0668 (87 Fed. Reg. 20036, April 6, 2022)

The American Forest and Paper Association (AF&PA) submits these comments on the proposed Federal Implementation Plan Addressing Regional Ozone Transport for the 2015 Ozone National Ambient Air Quality Standard (NAAQS) (87 Fed. Reg. 20036, April 6, 2022). AF&PA serves to advance a sustainable U.S. pulp, paper, packaging, tissue and wood products manufacturing industry through fact-based public policy and marketplace advocacy. AF&PA member companies make products essential for everyday life from renewable and recyclable resources and are committed to continuous improvement through the industry's sustainability initiative, Better Practices, Better Planet 2030. The forest products industry accounts for approximately 4% of the total U.S. manufacturing gross domestic product (GDP), manufactures nearly \$300 billion in products annually and directly employs approximately 950,000 people. The industry meets a payroll of approximately \$60 billion annually and is among the top 10 manufacturing sector employers in 45 states.


Pulp, paper, packaging, and tissue (pulp and paper) industry nitrogen oxides (NO_x) emissions do not represent a significant portion of the U.S. NO_x emissions inventory, per EPA's 2017 National Emissions Inventory. EPA has, until now, declined to regulate non-electric generating unit (EGU) boilers under the Cross State Air Pollution Rule because it has incomplete and uncertain data on non-EGU boiler emissions and controls and because analyses suggested that there are relatively fewer emissions reductions available at a cost threshold comparable to the cost threshold selected for EGUs. Nothing has changed to alter these previous findings, yet EPA has proposed to impose stringent and costly ozone-season NO_x emissions limits on pulp and paper boilers. If this rule is finalized as proposed, it will be very challenging and costly for our industry to implement and it will not result in the level of emissions reductions EPA has estimated.

Our industry's NO_x emissions have decreased over the last 10 years and our facilities continue to increase their efficiency and reduce emissions as they optimize operations and reduce energy costs. Implementation of Boiler Maximum Achievable Control Technology (MACT) standards and compliance with the 2010 1-hour sulfur dioxide (SO₂) National Ambient Air Quality Standards

(NAAQS) resulted in significant boiler emissions reductions in our sector (although these rules do not directly regulate NO_x emissions, they resulted in NO_x emissions reductions due to fuel switching and combustion upgrades). NO_x controls on our units are not necessary as part of a regional control strategy such as the Cross-State Air Pollution Rule (CSAPR) but are best managed under the new source review program as facilities perform projects to update their boiler fleets or as part of a local reasonably achievable control technology (RACT) program that allows for unit-specific technical and economic feasibility analyses. EPA has incorrectly assumed that retrofit NO_x controls on our boilers will always achieve a high level of emissions reduction; the effectiveness of retrofit controls is highly specific to the individual boiler.

Thank you for your consideration of these comments. Please feel free to contact Tim Hunt of AF&PA at 202-463-2588 if you have questions about the analysis provided, the feasibility of applying controls to pulp and paper boilers, or need more information.

Sincerely,



Paul Noe
Vice President for Public Policy
American Forest & Paper Association

cc: Scott Matthias, OAQPS
Beth Palma, OAQPS
Elizabeth Selbst, OAQPS
Tim Hunt, AF&PA

Attachments

- I. AF&PA base unit cost analyses using EPA Air's Pollution Control Cost Estimation Spreadsheet For Selective Catalytic Reduction (SCR)
- II. Northwest Pulp & Paper Association comments to Oregon DEQ on Regional Haze Rule Four-Factor Analysis of Four Oregon Pulp and Paper Mills, June 2020.
- III. Northwest Pulp & Paper Association comments to Washington Department of Ecology on Reasonably Available Control Technology Analysis for Washington Pulp and Paper Mills, 12/6/2019

IV. Executive Summary

EPA's proposed requirements for pulp and paper mill boilers in this rule are not supported and should not be finalized. It is unprecedented for EPA to disapprove multiple State Implementation Plans (SIPs), without giving states a chance to remedy them, and simultaneously rush to propose a poorly justified Federal Implementation Plan (FIP) with requirements for non-EGU sources that are likely to result in no measurable impact at downwind monitors. EPA has proposed these requirements based on changes to established precedents such as the appropriate level at which to assign significant impacts and has significantly departed from previous determinations related to cost-effective control thresholds. This rushed regulatory process driven by court deadlines has resulted in a lack of quality in the overall analysis and a lack of time for industry to understand and comment on EPA's extensive background documentation and proposed requirements. We struggled to understand how EPA determined pulp and paper boilers should be included in this rule, especially when the contribution threshold of 0.01 part per billion (ppb) at a downwind receptor is not even measurable. EPA's background documents and screening analysis do not support the expansive coverage proposed in the regulatory language.

EPA has proposed to disapprove upwind state Good Neighbor Plans and proposed this FIP without consideration of the timing of the implementation of nonattainment controls by downwind states - effectively shifting the burden of additional controls to the upwind states. There are programs that will reduce NO_x emissions from sources closer to the downwind monitors at issue that are either on the way, on the books, or should be considered for implementation. What EPA is proposing amounts to over control of our boilers; EPA should investigate application of controls to sources closer to the downwind monitors and give regulations already on the books and additional regulations on the way a chance to improve air quality at the monitors of concern before it requires costly NO_x controls on industrial boilers in 23 states, located hundreds of miles away that are already subject to other federal and state emissions control requirements.

EPA has relied on an incomplete, unverified, and uncertain data set to inform its decision to regulate NO_x emissions from pulp and paper boilers. The starting point appears to be the 2017 NEI, which is full of errors and does not fully represent the inventory or emissions characteristics of the pulp and paper mill boilers in the states EPA proposes to include in the FIP. Industry was not given a chance to review the data on which EPA based its analysis (and we are not sure if the states were given a chance to review it). If a representative inventory of large fossil fuel-fired boilers at pulp and paper mills is used, our sector no longer meets EPA's criteria for inclusion as a Tier 2 industry.

EPA should drop pulp and paper boilers from the requirements of this rule. Significant NO_x emissions reductions are not available for our biomass boilers or our process units. Cost-effective NO_x reductions as EPA has defined them (\$7,500/ton) are not available for our fossil-fuel fired

boilers EPA proposes to cover with this rule. Further, we disagree with EPA's conclusion based on an incomplete, uncertain non-EGU data set that \$7,500/ton is even an appropriate cost effectiveness benchmark, especially when EPA's own analysis indicates that other emission reductions and air quality improvements can be achieved at much lower costs. Although EPA has indicated to AF&PA that this rule does not specifically require the use of any particular control technology, the emissions reductions that EPA proposes to require for uncontrolled boilers will in some cases force our mills to attempt to implement the most stringent and expensive control technologies (e.g., selective catalytic reduction [SCR]), which have not been applied in our industry.

EPA has overestimated the emissions reductions this rule could achieve and has underestimated the cost of the proposed rule. The proposed limits apply only during ozone season, yet EPA's cost analyses do not represent the ozone season cost effectiveness. The ozone season cost effectiveness must be calculated by summing the total annualized capital cost of the control to be implemented and the operating cost of the control during the ozone season by the tons of emissions reduced during the ozone season which we estimate to be over \$30,000 per ton or 4 times the threshold in the rule. The controls required to achieve the proposed emissions limits are not available for our boilers at less than \$7,500/ton, even using EPA's OAQPS Control Cost Manual spreadsheets, and if required, the controls would only be implemented to the extent required to comply with the rule. EPA's regulatory impact analysis was based on the assumption that SCR would be installed on the majority of pulp and paper boilers and would achieve a 90% reduction in mass emissions over its 2023 uncontrolled emissions projection for a unit, yet SCR has not been installed or proven cost effective for pulp and paper mill boilers. EPA significantly underestimated the overall cost to the paper sector at just \$30M for true gas and coal fired boilers. AF&PA estimates capital costs are \$660 million in capital and total annual costs of \$140 M (annualized capital plus operating costs); assuming biomass boilers are excluded. An underestimate of the real cost divided by an overly optimistic estimate of emissions reduction leads to an erroneous underestimate in cost effectiveness (i.e., gives the appearance that controls are more cost effective than they really are). The high cost combined with the low potential for emissions reductions and the fact that the reductions from our boilers will not even be measurable at the downwind ambient monitors must result in a decision to remove pulp and paper boilers from this rule.

If EPA includes ozone season emissions limits for pulp and paper mill boilers in its final rule (and we believe it should not, for all the reasons explained herein), it should make several changes to focus the rule on only those units that offer the greatest potential for cost-effective, meaningful air quality improvements without over controlling emissions. The final rule should only cover the largest fossil fuel-fired units with ozone season emissions greater than 100 tons; it should adjust the requirements to allow for case-by-case control technology analyses to identify a cost-effective level of control; it should exclude biomass boilers, cogeneration units, temporary boilers, and limited use units; and it should allow for extensions to account for the time required to design, permit, install, and shakedown required controls.

Finally, we would like to point out the disbenefits of this rule. Installation of NO_x controls on our existing boilers will come with an energy penalty, resulting in increases of greenhouse gas (GHG) and criteria pollutant emissions and fossil fuel usage. SCR installation also results in emissions of ammonia, which is a precursor to fine particulate matter emissions and is considered a toxic air pollutant in some states. Storage, handling, and use of ammonia also presents health and safety risks for facilities and communities where its use would be required. Given EPA's initiatives to reduce GHG and fossil fuel use and lower the fine particulate NAAQS, this rule seems counter to those goals. Our boilers are already subject to stringent state and federal air regulatory requirements and are operated efficiently to control emissions as well as fuel costs. Including pulp and paper boilers in this ozone transport FIP will achieve little environmental benefit at great cost to our industry.

If EPA chooses to regulate industrial boilers as part of this FIP, EPA should seek further public comment given lack of clarity on applicability and inconsistencies in underlying analysis that makes it very difficult to fully comment.

V. The Final Rule Should Not Apply to Pulp and Paper Boilers

Based on the criteria presented in the Non-EGU Screening Assessment Memo¹ for identifying sources that have large, meaningful air quality impacts from potential controllable emissions, the standards contained in proposed 40 CFR 52.45(c) are unjustified and unwarranted for boilers in the pulp, paper, and paperboard (pulp and paper) industry. EPA has based its ozone season analysis on an incomplete, uncertain, and unverified data set that lacks the resolution necessary to draw meaningful conclusions about ozone season improvements. In response to EPA's request for comment on the merits of requiring non-EGU sources within upwind states to meet control standards², we are providing the following comments.

A. EPA's Pulp and Paper Source Inventory is of Poor Quality

EPA has, until now, declined to regulate non-EGU boilers under the CSAPR because it has incomplete and uncertain data on non-EGU boiler emissions and controls and because analyses suggested that there are relatively fewer emissions reductions available at a cost threshold comparable to the cost threshold selected for EGUs. Nothing has changed to alter these previous findings, yet EPA has now proposed to impose stringent and costly ozone-season NO_x emissions limits on pulp and paper boilers based on that same incomplete, uncertain, and unverified data set. EPA began with a 2017 NEI data set to build its boiler inventory and project 2023 emissions. The data set is already of questionable suitability and quality (e.g., available emissions data are annual values not ozone season values, several units are not labeled with the correct NAICS or SCC, some units do not have a capacity associated with them, the air emissions control information is

¹ EPA-HQ-OAR-2021-0668-0150

² 87 Fed. Reg. 20097

incomplete, some states report allowable and not actual emissions, etc.), it is difficult to determine how many boilers are at a particular facility if a boiler fires multiple fuels and has one line per fuel or if multiple boilers exhaust to one stack, and EPA did not verify that the NEI data were representative of the currently operating boiler types, sizes, controls, and emissions. For example, EPA's Screening Assessment assigns boiler controls and NO_x reductions to a facility that no longer operates (Appvion in Spring, PA). The NEI contains a number of discrepancies and in several cases overestimates the number of boilers at mills.

Even if the data set were accurate, it does not include critical information, such as ozone season emissions, critical design or control features or each boiler's actual lb/MMBtu NO_x emission rate, so there is no way EPA can accurately identify which boilers may or may not be able to comply with the proposed emissions limits. EPA's analysis is inherently flawed because it did not ask states or facilities to verify existing control information, did not realistically predict efficacy of applying emissions controls to meet the proposed limits, and did not verify whether potential reduction opportunities identified from CoST would result in real reductions. The comments being submitted by the National Council for Air and Stream Improvement (NCASI) under separate cover provide more detail on the accuracy of EPA's pulp and paper mill boiler inventory, including a list of fossil fuel boilers that are no longer operating and should not be included in EPA's analysis.

B. Pulp and Paper Mill Boilers Contribute Less than Other Sources of NO_x

Pulp and paper mill boilers contribute a relatively small amount of the overall NO_x emissions from the 23 states that EPA is proposing to include in the FIP.³ Based on the 2017 NEI, point sources in those states emitted approximately 1.5 million tons of NO_x, whereas pulp and paper mill boilers in those states emitted approximately 35,000 tons of NO_x, or 2% of total point source emissions. The contribution of pulp and paper mill boilers becomes even less significant considering the additional 3.3 million tons of NO_x emissions from mobile sources in the 23 states, plus the almost 1 million additional tons of NO_x from biogenic sources, wildfires, and prescribed burning. AF&PA acknowledges that EPA has established federal programs to address NO_x emissions from mobile sources and is continuing with that effort through rulemakings such as the Cleaner Truck Initiative as described by the Agency in the preamble to the proposed rule⁴; however, in EPA's non-EGU screening assessment memo⁵, EPA estimates ozone season emissions reductions of 3,305 tpy of NO_x from pulp and paper mill boilers as a result of the proposed rule. These reductions represent approximately 0.2% of total mobile source ozone season emissions (and as described later in these comments, we believe are an overestimate). Thus, even relatively small emissions reductions from mobile sources close to the problem monitors would likely far outweigh any ambient improvement

³ 87 Fed. Reg. 20041

⁴ 87 Fed. Reg. 20087

⁵ EPA-HQ-OAR-2021-0668-0150

associated with emissions reductions from pulp and paper boilers and can likely be achieved at a lower cost than EPA's estimated \$7,500/ton (2016 dollars) for non-EGUs.

According to the information contained in the NEI, NO_x emissions from facilities in the paper manufacturing sector decreased from 199,264 tons in 2008 to 140,598 tons in 2017, a 29% reduction. Data collected by AF&PA from its member companies shows a 48% reduction in NO_x emissions since 2000. Our industry has reduced emissions significantly as various federal and state regulatory programs have been adopted and implemented (e.g., NSPS and MACT) and as we have applied RACT or BACT to various units.

Furthermore, as described later in these comments, EPA has overestimated the control efficiency and underestimated the cost of controls as they apply to pulp and paper mill boilers; as a result, EPA is overly optimistic about the cost-effectiveness of NO_x controls for these units. AF&PA's revised analysis shows that application of NO_x controls to a majority of the pulp and paper boilers 1) will be difficult to implement, 2) will not achieve the emissions reductions EPA has predicted, and/or 3) is not cost-effective based on EPA's presumptive value of \$7,500/ton.

C. A Revised Step 1 Analysis Shows Pulp and Paper Does Not Meet EPA's Stated Criteria for Inclusion as a Tier 2 Industry

In EPA's screening analysis, the Air Quality Assessment Tool (AQAT) was used to estimate the impact of state-level NO_x emissions. The tool uses a ratio approach to convert NO_x emissions into estimated ambient ozone impacts. The non-EGU inputs to the AQAT analysis were developed from the 2017 National Emissions Inventory. Based on EPA's documentation of its analysis in the Non-EGU Screening Assessment Memo, our understanding is that any units with NO_x emissions less than 100 tpy (e.g., lime kilns, engines, and certain boilers) and any units without identified controls in EPA's CoST model (e.g., recovery furnaces) should have been removed from the AQAT analysis.

EPA used the AQAT to estimate sector-level impacts, with a "Tier 2" industry having either (1) a maximum contribution to any one receptor ≥ 0.10 ppb but contribute ≥ 0.01 ppb to fewer than 10 receptors, or (2) a maximum contribution < 0.10 ppb but contribute ≥ 0.01 ppb to at least 10 receptors. The pulp and paper sector was identified as a Tier 2 industry because EPA calculated contributions greater than or equal to 0.01 ppb at 11 downwind receptors.

NCASI reviewed the AQAT pulp and paper sector inventory and identified the following problems with it:

- Several of the units are at facilities that have been closed.
- Several of the units have been shut down.
- Unit ID 135113 has been identified as burning only biomass.
- Unit ID 47545613 has been identified as burning only biomass.

- Unit ID 16713213 (a lime kiln) is no longer operational.
- Unit ID 2791613 is a duplicate entry.
- Unit ID 47092413, Unit ID 47546113, Unit ID 17957213, Unit ID 33858313 and Unit ID 20389113 are five Kraft Recovery Furnaces that should have been removed when the unit list was developed.
- A number of units have ozone season emissions less than 41.7 tons per year.

Using a corrected pulp and paper sector emissions inventory, NCASI then executed a revised AQAT analysis using EPA’s approach. Their analysis and their recommended changes to the inventory are documented in their comments being submitted under separate cover. Correcting the baseline inventory by removing non-operational boilers and removing those units inadvertently included in the analysis results in a significant change in the number of critical receptors with impacts above the 0.01 ppb threshold and on the receptor with the maximum impact. The pulp and paper sector is only predicted to impact 8 receptors and the maximum impact is 0.0322 ppb at Galveston, TX. Therefore, pulp and paper boilers no longer qualify as a Tier 2 industrial source according to the above criteria and should not be included in the rule.

D. EPA’s Predicted Receptor Improvements from Pulp and Paper Boiler Controls are Immeasurable

Even if the reductions EPA predicts for pulp and paper mill boilers were feasible, the air quality improvements EPA anticipates at individual receptors are immeasurable by current ambient air quality monitoring systems. In Table 3 on page 11 of EPA’s Non-EGU Screening Assessment Memo⁶, the maximum improvement at any receptor from controls on all Tier 2 boilers (in all proposed source categories) is 0.169 ppb. In Table 5 on page 16 the maximum estimated improvement at any receptor from controls on 25 pulp and paper boilers is listed as 0.0117 ppb. A further review of the spreadsheet “Transport Proposal – Tier 2 Boiler Analysis – 03-16-2022.xlsx⁷,” indicates that the average total improvement across all receptors from a single pulp and paper boiler is 0.0103 ppb.⁸ Current ambient air quality monitoring systems have a detection limit of approximately 0.3 ppb which is more than an order of magnitude greater than EPA’s maximum estimated improvement from controlling pulp and paper boilers.⁹ If EPA were to finalize the rule as proposed, the pulp and paper industry would be required to spend from \$30 million per year (according to the Screening Assessment Memo) to almost \$100 million per year (according to the Tier 2 boiler analysis spreadsheet EPA posted to the docket on April 27, 2022¹⁰) for results that are too insignificant to even measure. Therefore, there is no quantifiable downwind benefit to controlling pulp and paper mill boilers and because no quantifiable air quality improvement is predicted,

⁶ EPA-HQ-OAR-2021-0668-0150

⁷ EPA-HQ-OAR-2021-0668-0225.

⁸ Average of the “total ppb improvement” column in EPA’s spreadsheet. The column represents the sum of the estimated ppb improvement across all downwind monitors.

⁹ Based on a review of the most commonly used EPA certified ambient ozone monitors.

¹⁰ EPA-HQ-OAR-2021-0668-0225, Controls tab, NAICS 3221.

requiring controls on boilers is not necessary to achieve attainment in any downwind state and should clearly be recognized as over control.

E. EPA Should Re-evaluate Whether Limits on Non-EGU Boilers Constitutes Over Control

In the preamble to the proposed rule, EPA requests comment on whether the proposed requirements constitute over-control, where over-control is generally defined as (1) “ozone improvements...greater than necessary to resolve the downwind ozone pollution problem (i.e., beyond what is necessary to resolve all nonattainment and maintenance problems to which an upwind state is linked) or (2) the expected ozone improvements would reduce the upwind state’s ozone contributions below EPA’s “chosen” screening threshold (i.e., 1 percent of the 2015 ozone NAAQS).”¹¹ Over control also includes situations where an upwind state is linked to a downwind air quality problem that could have been resolved with reductions obtained at a lower cost threshold.¹²

In Section VI.4 of the preamble¹³, EPA presents the analysis the agency used to conclude that the proposed rule does not constitute over-control. However, EPA must revise its analysis on the basis that it has not considered the entire scope of the actual emissions reductions required by the proposed rule. As presented in Table VI.D.3-1 of the preamble, EPA conducted its over-control analysis assuming 6,033 tpy of NO_x emissions reductions from Tier 2 boilers. A review of the file “Tier 2 Boiler Analysis all NAICS Units EPA-HQ-OAR-2021-0668-0225_content.xlsx” reveals that these emissions reductions are attributable to 52 boilers identified by EPA in its impacts analyses (25 of which are pulp and paper mill boilers). But, in the same workbook, EPA identifies 148 boilers potentially subject to the proposed rule on the worksheet titled “Tier 2 Boilers – Contributions,” (69 of which are pulp and paper mill boilers). As described elsewhere in these comments, EPA did not analyze impacts and emissions reductions from 96 boilers because either available controls for the boiler did not meet a pre-determined cost-effectiveness criterion, or because the potential impacts from the boilers at downwind receptors did not meet certain thresholds. Thus, EPA excluded a certain group of boilers from its impacts analysis (i.e., those with little emission reduction or ambient improvement potential and high cost of controls), but for unexplained reasons did not exclude these same boilers from being subject to the proposed standard. We cannot make sense of why the underlying analysis does not match the regulatory applicability language or how EPA could claim a \$7,500/ton cost effectiveness benchmark when they disregarded the costs associated with regulating 96 boilers.

Based on our own review of pulp and paper boiler information, AF&PA has identified that about 100 fossil fuel-fired boilers would potentially be subject to the proposed standards (assuming

¹¹ 87 Fed. Reg. 20099

¹² *EPA v. EME Homer City et. al.*, 572 U.S. at 521, 2014, p. 26

¹³ 87 Fed. Reg. 20098

biomass boilers are not covered), with 48 fossil fuel-fired boilers likely to need controls (many of which EPA did not include in its analysis). Our analysis also indicates that no controls sufficient to meet the proposed emissions limits are available for the impacted boilers at an ozone season cost effectiveness of \$7,500/ton or less, and if EPA used its own recently updated OAQPS Control Cost Manual methodologies for SCR, its analysis would show this same outcome as well. We have attached the control cost estimates that form the basis of our analysis (see Attachment I).

EPA's over-control analysis is therefore invalid because it does not consider all the costs and air quality improvements of the proposed rule. AF&PA recommends that EPA re-evaluate both the impacts of the proposed rule and whether or not the Agency's proposal constitutes over-control by considering the impacts and emissions reductions for all non-EGU boilers potentially subject to the proposed emission limits.

We disagree with EPA's conclusion that non-EGU control requirements for Mississippi, Arkansas and Wyoming don't constitute unnecessary overcontrol¹⁴. Based on EPA's own analysis and supporting documentation for this rule, EPA should find that non-EGU reduction requirements for Arkansas and Mississippi should be limited to only Tier 1 industries, and Wyoming requirements should be limited to only EGU reduction strategies.

Requiring controls on Wisconsin pulp and paper mill boilers is another example of over control. The Chicago area is in the process of being redesignated to attainment for the 2008 ozone NAAQS. Without this redesignation, the area will be bumped up in classification. EPA published its Chicago area redesignation proposal on March 10, 2022 at 87 Fed. Reg. 13668 and includes this statement in footnote 5 at 87 Fed. Reg. 13679:

"While modeling is not required, Illinois cited photochemical modeling performed by EPA and LADCO in support of the interstate transport "Good Neighbor" provision of the CAA for the 2015 ozone NAAQS. These modeling results project the highest 2023 average design values to be 0.0662 and 0.0668, well below the 2008 ozone NAAQS. Compared to actual monitored 2009–2013 average design values, both sets of 2023 modeling results show large decreases in ozone concentrations, especially in the heart of the urban area and at the critical monitors at the north of the nonattainment area along the shore of Lake Michigan. These results provide evidence that ozone concentrations will continue to decrease across the entire nonattainment area."

Wisconsin and its pulp and paper mill boilers are included in the proposed 2015 ozone transport rule solely because EPA asserts they impact the Chicago area monitors. The statement above, although made in the context of the 2008 ozone redesignation, concludes that EPA and LADCO modeling demonstrate that Chicago area monitors will experience ozone concentrations much lower than the 2015 ozone NAAQS in 2023 and additional reductions are expected thereafter.

¹⁴ 87 Fed. Reg. 20099

F. EPA Should Clarify that the Tier 2 Boiler Standards Only Apply to Large Industrial Boilers Firing Exclusively Fossil Fuels

While it is clear from a review of the background/supporting documentation that EPA only contemplated and assessed emissions and impacts from controlling boilers firing exclusively coal, oil, or gas¹⁵, and in fact selected its proposed emission limits based on RACT rules for single fuel-fired boilers, it is not clear from the proposed regulatory language that the scope of the rule is limited as such. In the proposed regulatory language at 40 CFR 52.45(b), EPA states that the requirements are applicable to:

...each new or existing boiler with a design capacity of 100 mmBtu/hr or greater fueled by coal, residual oil, distillate oil, or natural gas...

and in the proposed regulatory language at 40 CFR 52.45(c), EPA sets NO_x emission limitations for “Coal-fired,” “Residual oil-fired,” “Distillate oil-fired,” and “Natural gas-fired” “industrial boilers.”

Despite our request to exclude pulp and paper sector boilers from rule applicability, if EPA finalizes the proposed requirements for industrial boilers, the Agency should make it clear that the boiler standards apply only to certain industrial boilers with allowable NO_x emissions of 100 tons or greater during ozone season firing exclusively fossil fuels, and not to units such as recovery furnaces, heat recovery steam generators, gas turbines, and biomass-fired boilers.

EPA should revise 52.45(b) to:

(1) The requirements of this section apply to each new or existing industrial boiler (as defined in this section) that is allowed to emit more than 100 tpy of NO_x during ozone season that is exclusively fueled by coal, residual oil, distillate oil, and/or natural gas....

(2) The requirements of this section do not apply to industrial boilers burning more than 10% biomass on an annual heat input basis.

Neither the proposed rule language nor the preamble discussion defines the terms “boiler,” “industrial boiler,” “fueled by coal, residual oil, distillate oil, or natural gas,” or “coal-fired, residual oil-fired, distillate oil-fired,” or “natural gas-fired industrial boilers.” AF&PA recommends that if EPA chooses to impose requirements for certain industrial boilers, it seek further public comment, and propose definitions similar to those found in the National Emissions Standards for Hazardous Air Pollutants for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters (Boiler MACT) and the 40 CFR Part 60 boiler standards to clarify the affected units. Specifically, AF&PA recommends EPA adopt the following definitions at 40 CFR 52.45:

¹⁵ For example, EPA-HQ-OAR-2021-0668-0145, Non-EGU Sectors TSD.

Industrial Boiler means an enclosed device using controlled flame combustion and having the primary purpose of recovering thermal energy in the form of steam or hot water. Controlled flame combustion refers to a steady-state, or near steady-state, process wherein fuel feed rates are controlled. Waste heat boilers as defined at §63.7575, chemical recovery boilers, commercial and residential boilers, refining kettles, ethylene cracking furnaces, and blast furnaces are not included in this definition.

Biomass includes, but is not limited to, wood residue; wood products (e.g., trees, tree stumps, tree limbs, bark, lumber, sawdust, sander dust, chips, scraps, slabs, millings, and shavings); animal manure, including litter and other bedding materials; vegetative agricultural and silvicultural materials, such as logging residues (slash), nut and grain hulls and chaff (e.g., almond, walnut, peanut, rice, and wheat), bagasse, orchard prunings, corn stalks, coffee bean hulls and grounds.

Coal means all solid fuels classifiable as anthracite, bituminous, sub-bituminous, or lignite by ASTM D388 (incorporated by reference, see § 63.14), coal refuse, and petroleum coke. For the purposes of this subpart, this definition of “coal” includes synthetic fuels derived from coal, including but not limited to, solvent-refined coal, coal-oil mixtures, and coal-water mixtures. Coal derived gases are excluded from this definition.

Distillate oil means fuel oils that contain 0.05 weight percent nitrogen or less and comply with the specifications for fuel oil numbers 1 and 2, as defined by the American Society of Testing and Materials in ASTM D396 (incorporated by reference, see § 63.14) or diesel fuel oil numbers 1 and 2, as defined by the American Society for Testing and Materials in ASTM D975 (incorporated by reference, see § 63.14), kerosene, and biodiesel as defined by the American Society of Testing and Materials in ASTM D6751-11b (incorporated by reference, see § 60.14).

Natural gas means:

(1) A naturally occurring mixture of hydrocarbon and nonhydrocarbon gases found in geologic formations beneath the earth's surface, of which the principal constituent is methane; or

(2) Liquefied petroleum gas, as defined in ASTM D1835 (incorporated by reference, see § 63.14); or

(3) A mixture of hydrocarbons that maintains a gaseous state at ISO conditions. Additionally, natural gas must either be composed of at least 70 percent methane by volume or have a gross calorific value between 35 and 41 megajoules (MJ) per dry standard cubic meter (950 and 1,100 Btu per dry standard cubic foot); or

(4) Propane or propane derived synthetic natural gas. Propane means a colorless gas derived from petroleum and natural gas, with the molecular structure C₃H₈.

Process gas, landfill gas, coal derived gas, refinery gas, biogas, and blast furnace gas are not included in this definition.

Residual oil means crude oil, fuel oil that does not comply with the specifications under the definition of distillate oil, and all fuel oil numbers 4, 5, and 6, as defined by the American Society of Testing and Materials in ASTM D396-10 (incorporated by reference, see § 63.14(b)).

As indicated in our suggested industrial boiler definition, when issuing its re-proposal (assuming that pulp and paper boilers are not excluded given that they do not meet the criteria laid out in the proposal), EPA should clarify that the proposed standards are not intended to apply to pulp and paper recovery furnaces (sometimes referred to as recovery boilers). While a recovery furnace produces thermal energy in the form of steam, the primary purpose of the furnace is to recover spent chemicals from the pulping process. As documented by NCASI in the Technical Bulletin titled “An Update on NO_x Control Limits and Technologies for Forest Products Industry Boilers, Kraft Recovery Furnaces and Lime Kilns, No. 1051,” NO_x control options are not readily available for recovery furnaces. NCASI identified staged combustion using quaternary air ports at certain large furnaces as technically feasible, but noted that the industry has only limited, short-term experience with this technology and the impact on other pollutants such as sulfur dioxide, carbon monoxide, and reduced sulfur compounds is unknown. In addition, some furnaces cannot accommodate quaternary air ports due to their physical dimensions, specifically furnace height, because shorter furnaces do not have adequate room to add a fourth level of air between the tertiary ports and the bull nose baffle arch of the furnace. Although a recovery furnace would not typically be considered a “coal-fired, residual oil-fired, distillate oil-fired,” or a “natural gas-fired industrial boiler,” these furnaces produce steam and commonly use either distillate oil, residual oil, or natural gas as auxiliary fuel for startup, shutdown, transient flame and operational stability, and occasionally to produce supplemental steam. Therefore, if EPA determines that it is necessary to regulate non-EGU boilers, AF&PA requests that EPA clearly state in the regulatory language of the re-proposal, that recovery furnaces are not subject to the standards proposed at 40 CFR 52.45.

Additionally, as indicated above and supported by our comments herein, EPA should clarify that the proposed standards do not apply to biomass boilers. Although a biomass boiler would not typically be considered a “coal-fired, residual oil-fired, distillate oil-fired, or natural gas-fired industrial boiler,” they commonly use either distillate oil, residual oil, or natural gas as supplemental or auxiliary fuel for startup, shutdown, and to ensure consistent and stable operations (e.g., when biomass fuel moisture is high, or to safely combust process gases). NO_x control technologies are not identified for biomass boilers in EPA’s CoST model and are not widely

applied to biomass boilers in our industry for reasons set out later in these comments. EPA should exclude any boiler that is in a Boiler MACT biomass subcategory from coverage by adjusting the regulatory language at 40 CFR 52.45 as suggested above.

AF&PA reviewed the list of boilers found in worksheet “Tier 2 Boilers – Contributions,” of the workbook “Transport Proposal – Tier 2 Boiler Analysis – 03-16-2022.xlsx¹⁶” and none of these boilers have biomass boiler SCCs; therefore, we believe it was EPA’s intent to exclude biomass boilers from this rule and ask EPA to make that intent clear if pulp and paper boiler requirements are finalized.

G. EPA Must Address Multi-Fueled Boilers

EPA has proposed ozone season NO_x emission limits for four types of fossil fuel-fired boilers at 40 CFR 52.45(c): coal-fired industrial boilers, residual oil-fired industrial boilers, distillate oil-fired industrial boilers, and natural gas-fired industrial boilers. The proposed regulatory language does not address how the limits might apply to situations where multiple fuels are fired simultaneously or where multiple fuels are fired during a 30-day period. Many boilers in the pulp and paper industry fire multiple fuels, depending on cost and availability. Even a biomass boiler is likely to fire varying amounts of fossil fuels either as startup, backup, or supplemental fuel. Boilers in the petroleum and coal products manufacturing or basic chemical manufacturing industries may also burn multiple fuels as startup, backup, or supplemental fuels.

To clearly address boilers that co-fire fossil fuels or fire more than one type of fossil fuel and to remove any confusion over what emission limit applies, AF&PA recommends EPA adopt a method similar to those found in the Standards of Performance for New Stationary Sources (or New Source Performance Standards [NSPS]): Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units (40 CFR Part 60, Subpart Db) and Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units (40 CFR Part 60, Subpart Dc). As in the proposed rule, emission limits in these NSPS rules vary by the fuel fired (and the configuration of the boiler). If a boiler simultaneously combusts a mixture of fossil fuels, the applicable NSPS emission limit is calculated based on the ratio of each fuel fired to the overall heat input of the unit (see for example 40 CFR 60.44b(b)). AF&PA recommends EPA incorporate a similar limit calculation methodology in the final rule to allow operators to maintain the flexibility to fire multiple and varying fossil fuel types while still demonstrating compliance with the NO_x limits on a 30-day rolling average basis. An example equation for calculating the applicable emission limit is provided below, and should be based on the average of all hourly data recorded during the previous 30 boiler

¹⁶ EPA-HQ-OAR-2021-0668-0225. Note that in the analysis described above, AF&PA excluded units with a facility name of “US Steel Gary Works,” because these units appear to be covered by the proposed “Iron and Steel Mills and Ferroalloy Manufacturing” regulations. The units appear to be included in EPA’s analysis based on a potentially incorrect NAICS code (petroleum and coal products manufacturing).

operating days (as required for calculating compliance with the 30-day average NO_x limit in NSPS Subpart Db):

$$E_{NOx} = \frac{(EL_C H_C) + (EL_{RO} H_{RO}) + (EL_{DO} H_{DO}) + (EL_G H_G)}{(H_C + H_{RO} + H_{DO} + H_G)}$$

Where:

E_{NOx} = NO_x emission limit for the previous 30 days (lb NO_x/MMBtu)

EL_C = Emission limit for coal firing (lb NO_x/MMBtu)

H_C = Heat input from combustion of coal for the previous 30 days (MMBtu)

EL_{RO} = Emission limit for residual oil firing (lb NO_x/MMBtu)

H_{RO} = Heat input from combustion of residual oil for the previous 30 days (MMBtu)

EL_{DO} = Emission limit for distillate oil firing (lb NO_x/MMBtu)

H_{DO} = Heat input from distillate oil firing for the previous 30 days (MMBtu)

EL_G = Emission limit for natural gas firing (lb NO_x/MMBtu)

H_G = Heat input from natural gas combustion for the previous 30 days (MMBtu)

For clarity, definitions of 30-day average and boiler operating day consistent with the language in NSPS Subpart Db should be added to the final rule.

As mentioned above, EPA should make it clear in the final rule that boilers burning more than 10% biomass are not covered by any emissions limit. Similar to NSPS Db at 40 CFR 60.44b(f) and (g), EPA should also allow facilities burning byproduct/waste with gas or oil to petition for an alternate NO_x emissions limit. Some pulp and paper mill boilers are used to burn process off-gases to comply with other air regulations that can increase NO_x emissions due to their ammonia content and thus need to be treated differently.

H. Applicability for Tier 2 Boilers Should be Based on Ozone Season Emissions, Not on Design Capacity

In response to EPA's request for comment¹⁷, if after considering public comments, EPA retains its proposed ozone-season emissions limits for industrial boilers in the final rule, EPA should base the applicability threshold on allowable ozone season emissions (i.e., 100 tons of NO_x per ozone season) instead of rated heat input capacity (i.e., 100 MMBtu/hr). In the supporting documentation for the proposed rule (and in the preamble at 87 Fed. Reg. 20148), EPA indicates that it set the applicability threshold for boilers at 100 MMBtu/hr because it "approximates the 100 tpy threshold used in the Screening Assessment."¹⁸ EPA's justification for the heat rate-based

¹⁷ 87 Fed. Reg. 20148

¹⁸ EPA-HQ-OAR-2021-0669-0191, pg. 4.

threshold raises the question – if ozone season NO_x emissions are the most important factor for applicability, why not set the threshold based on NO_x emissions like the Agency did for cement and concrete product manufacturing, glass and glass product manufacturing, and iron and steel mills and ferroalloy manufacturing?

For some boilers, the 100 MMBtu/hr threshold does not approximate an emissions level of 100 tpy, depending on operating schedule, fuel fired, or emission rate. In addition, as written, the proposed rule provides no exemption or flexibility for boilers with a potential to emit less than 100 tpy or for operators that limit boiler emissions to less than 100 tons during ozone season. Multiple reasons exist for why boiler NO_x emissions might be limited, including (but not limited to): 1) the boiler is operated on a seasonal basis or is a backup unit or is considered “limited use”; 2) the boiler consistently operates below its rated capacity because of reduced demand; 3) boiler operations are already limited to avoid Prevention of Significant Deterioration (PSD) or Non-attainment New Source Review (NA-NSR); or 4) the boiler is subject to an annual capacity factor limitation.

Without a mass emissions-based threshold, boilers that satisfy the proposed applicability criteria (i.e., rated at or above 100 MMBtu/hr) but that emit less than 100 tons of NO_x during ozone season would be required to comply with lb/MMBtu emissions limits and potentially forced to install and operate controls (as discussed later in this comment letter) and continuous emissions monitors despite providing little to no benefit at downwind receptors. To avoid this unjustified burden and to capture the most impactful boilers, AF&PA requests that EPA revise the applicability threshold from a heat input basis to an ozone season emissions basis for boilers in Tier 2 industries. Basing the applicability criteria on emissions during ozone season would ensure that those units actually emitting at a significant level during ozone season are the units subject to control requirements, instead of unnecessarily regulating units that are unlikely to have a significant impact on downwind receptors. If EPA concludes that an applicability threshold criterion based on heat input capacity is necessary, AF&PA recommends that EPA adopt a threshold of 250 MMBtu/hr consistent with the NO_x State Implementation Plan (SIP) Call, which applied to large non-EGU boilers and established ozone-season mass emission limits for those units instead of an across-the-board rate-based emission limit.¹⁹

I. EPA Should Exclude Limited-Use and Temporary Boilers

As described earlier in these comments, EPA based the proposed rule applicability to industrial boilers on a unit’s designed heat capacity. EPA did not, however, exclude limited-use or temporary boilers in its proposed regulatory language. Limited-use boilers are just that, units that operate for a limited amount of time each year and whose operation is generally limited by permit restrictions. Pulp and paper mills employ limited-use boilers for back up steam and power generation during

¹⁹ 83 Fed. Reg. 48751

mill outages, maintenance on a primary-use boiler, or when certain fuels fired in primary-use boilers are curtailed or otherwise not available. Limited-use boilers may also be deployed to meet additional demand during periods of increased production throughout the year. Because these units only operate for a limited amount of time each year, their overall contribution to total NO_x emissions is small. They also spend more of their time in startup, shutdown, or other low-load operating conditions than continuously operated units, which potentially affects the suitability and effectiveness of post-combustion NO_x controls on these units and makes emissions testing difficult. Furthermore, because the overall NO_x emissions from these units is relatively small, installation of controls such as SCR or low NO_x burners (LNB) and flue gas recirculation (FGR) would not be cost effective. Thus, regulation of these units under proposed 40 CFR 52.45 is unwarranted and unjustified.

Temporary boilers are exempt from major federal regulatory requirements such as Boiler MACT at 40 CFR Part 63, Subpart DDDDD, and the industrial boiler rules in 40 CFR Part 60. Limited use boilers are subject to only limited requirements under these rules.

To avoid regulating limited-use and temporary boilers, AF&PA requests that, if EPA concludes it necessary to apply ozone season emission limits to industrial boilers in the final rule, EPA revise the applicability language at proposed 40 CFR 52.45 to exclude limited-use boilers and temporary boilers. AF&PA also requests EPA add the following definitions:

Limited-Use Boiler means any boiler that burns any amount of solid, liquid, or gaseous fuels and has a federally enforceable annual capacity factor of no more than 10 percent.

Annual capacity factor means the ratio between the actual heat input to a boiler or process heater from the fuels burned during a calendar year and the potential heat input to the boiler or process heater had it been operated for 8,760 hours during a year at the maximum steady state design heat input capacity.

Temporary Boiler means any gaseous or liquid fuel-fired steam generating unit that is designed to, and is capable of, being carried or moved from one location to another by means of, for example, wheels, skids, carrying handles, dollies, trailers, or platforms. A steam generating unit is not a temporary boiler if any one of the following conditions exists:

(1) The equipment is attached to a foundation.

(2) The steam generating unit or a replacement remains at a location for more than 180 consecutive days. Any temporary boiler that replaces a temporary boiler at a location and performs the same or similar function will be included in calculating the consecutive time period.

(3) The equipment is located at a seasonal facility and operates during the full annual operating period of the seasonal facility, remains at the facility for at least 2 years, and operates at that facility for at least 3 months each year.

(4) The equipment is moved from one location to another in an attempt to circumvent the residence time requirements of this definition.

J. EPA Should Continue to Exempt Cogeneration Units

EPA has requested comment on whether cogeneration units meeting the Acid Rain Program exemption requirements should be exempt from any emissions reduction requirements under the proposed ozone transport FIP.²⁰ AF&PA supports an exemption for cogeneration units meeting the criteria described at 87 Fed. Reg. 20087. These units should not be subject to any emissions reduction requirements under this rulemaking, including standards that would apply to boilers in affected non-EGU industries. The final regulatory language should define cogeneration units and make the exemption clear. While the preamble requests comment on continuing to exempt them, such an exemption is not included in the regulatory text.

Cogeneration units offer several environmental benefits because they use the heat generated from combustion of fuel to generate both steam and electricity. EPA has recognized the benefits of combined heat and power²¹. Cogeneration units offset additional fuel combustion that would otherwise be necessary to produce electricity, and thus additional emissions, through their operation. This offset can be considered as a lower overall NO_x emissions rate than conventional production of steam and electricity using separate combustion sources. EPA has previously determined that emissions reductions and air quality gains from regulating these units in the EGU trading program would not be substantial²²; nothing has changed to alter that finding. In addition, from a review of the background documentation, we cannot see where EPA has specifically assessed the impacts of their inclusion in this rule, lacking transparency to allow for more specific comment.

K. EPA Should Continue to Exclude Boilers in the Wood Product Sector

EPA found in their contributions summary tables analysis that NO_x emissions from boilers at wood product mills (NAISC 3212 Veneer, Plywood, and Engineered Wood Product Manufacturing) do not contribute to any downwind receptors and are more than two orders of magnitude below the criteria for inclusion. We support the conclusion to exclude these boilers and sector.

VI. Available NO_x Controls and Achievability of Proposed NO_x Limits

A. Add-on NO_x Controls are not Feasible for Pulp and Paper Mill Process Units

AF&PA's understanding is that EPA initially evaluated many types of units at pulp and paper mills with NO_x emissions, including process units. These process units may have included recovery

²⁰ 87 Fed. Reg. 20087

²¹ <https://www.epa.gov/chp>

²² 87 Fed. Reg. 20084

furnaces, lime kilns, and pulp mill non-condensable gas (NCG) incinerators. The feasibility of NO_x controls for these units is discussed below. We note that existing internal combustion engines at pulp and paper mills are typically operated for emergency use only, are not significant contributors to annual NO_x emissions, and should not be candidates for control under a regional transport rule.

Recovery Furnaces

NCASI published Technical Bulletin No. 1051, “An Update to NO_x Control Limits and Technologies for Forest Products Industry Boilers, Kraft Recovery Furnaces, and Lime Kilns,” in May 2019. This technical bulletin provides an update to the NCASI 2003 Special Report 03-06, where NCASI determined that staged combustion (multiple levels of combustion air) within Kraft recovery furnaces is the only technology feasible to reduce NO_x. The liquor nitrogen content is dependent on the type of wood pulped and is the dominant factor affecting the level of NO_x emissions from black liquor combustion in recovery furnaces. Pulp mill operators cannot control this parameter. The May 2019 technical bulletin reviewed fundamental research for NO_x control in recovery furnaces over the past decade and concluded that staged combustion is still the only NO_x emission reduction strategy for recovery furnaces at this time.

Sections 3.1.6 and 3.1.7 of Technical Bulletin No. 1051 discuss the abstracts and summaries of two papers presented during the 2017 International Recovery Conference held at Halifax, Nova Scotia, Canada. The first paper was a theoretical study for the retrofit of a recovery furnace where a SCR control device could be utilized to lower NO_x from 200 to 100 mg/m³ (6% O₂, dry gas). The paper went on to identify the key challenges in deploying SCR technology as being a) maintaining flue gas temperature at the appropriate level at the SCR reactor inlet, b) potential for higher SO₂ in the flue gas, and c) potential for high particulate matter concentration after the electrostatic precipitator. The above theoretical study therefore contemplated a retrofit that included a dedicated flue gas bypass, with an ESP, for scenarios where either the flue gas temperature was too low or the dust loading and/or SO₂ was too high for the SCR.

The second paper (section 3.1.7) presented results from pilot tests and first experiences with installation of SCR at a kraft recovery furnace. This paper contemplated a tail-end application, as opposed to a high or low dust loading application, citing the above-identified issues with dust loading and the resulting catalyst poisoning. NCASI is not aware of follow-up studies or long-term performance data from full-scale installations.

The use of SCR on a kraft recovery furnace has not been demonstrated on a full scale due to the abovementioned challenges. The impact of high particulate matter concentrations in the economizer region and fine dust particles on catalyst effectiveness is a major concern, as is catalyst poisoning by soluble alkali metals in the gas stream. If an SCR were to be installed after the ESP to address the particulate concern, the additional energy penalty associated with reheating the flue gas is another aspect that makes application of SCR to a recovery furnace economically infeasible.

The only NO_x minimization techniques listed in the RACT/BACT/LEAR Clearinghouse (RBLC) database for recovery furnaces are good combustion practices and optimizing the staged combustion in the design of the existing furnace. No other control technologies have been demonstrated in practice for NO_x emissions from recovery furnaces at pulp and paper mills. EPA's CoST model does not identify any feasible NO_x control technologies for recovery furnaces at pulp and paper mills.²³ EPA has correctly concluded that pulp and paper mill recovery furnaces should not be subject to ozone transport rule requirements.

Lime Kilns

Based on a review of NCASI Technical Bulletins 847 ("Factors Affecting NO_x Generation from Burning Stripper Off-Gases in Power Boilers and Lime Kilns"), 855 ("Factors Affecting NO_x Emissions from Lime Kilns"), and 884 ("Compilation of Criteria Air Pollutant Emissions Data for Sources at Pulp and Paper Mills Including Boilers"), the two primary factors that affect NO_x emissions in lime kilns burning natural gas are the dry end lime temperature and the combustion of NCGs and/or stripper off gases (SOGs). Thermal NO_x is the primary NO_x formation mechanism in a natural gas-fired kiln and the ammonia present in SOGs will also contribute to NO_x formation. As discussed below, there are no technically feasible technologies to control lime kiln NO_x other than good combustion practices.

Because the calcination reaction requires a certain temperature and residence time within the kiln, combustion temperature cannot be reduced without changing the size of the kiln. Therefore, technologies that involve injecting cooler exhaust gas (e.g., flue gas recirculation or FGR) or water into the kiln are not feasible. Natural gas-fired kilns and calciners in other industries primarily use LNB to reduce NO_x emissions. It is uncertain whether a burner replacement would achieve lower NO_x emissions from pulp and paper mill lime kilns while still maintaining the required flame profile and temperature for calcination. Although cement kilns and calciners used in other industries have employed selective non-catalytic reduction (SNCR) and SCR, pulp and paper mill lime kilns are different because they are not equipped with a pre-calciner, pre-heater, or a separate fuel combustion chamber into which a reagent could be injected (or flue gas recirculated) for NO_x control. The temperature within the kiln is not in the SNCR effective range because of the calcination temperature. Even if it were, injecting ammonia or urea into a rotating lime kiln would be difficult to achieve and would affect product quality and the stability of kiln operation.

No operator of a pulp and paper mill lime kiln has found SCR to be technically feasible. If an attempt were to be made to install SCR, it would be on the back end of a lime kiln exhaust system, after existing PM control equipment to ensure the integrity of the catalyst. Location at the tail end of the pollution control train would require re-heating of the gases to create an ideal SCR temperature

²³ <https://www.epa.gov/economic-and-cost-analysis-air-pollution-regulations/cost-analysis-modelstools-air-pollution#control%20strategy%20tool>, CMDB for stationary sources zip file

zone (480°F – 800°F²⁴) as well, thereby increasing operating cost, energy use, and emissions of greenhouse gases and other products of combustion. Because pulp and paper mill lime kiln exhaust gas temperatures are well below the effective SCR and SNCR operating temperatures and due to design differences from other types of kilns and calciners that have employed NO_x control technologies, FGR, SNCR, and SCR are not technically feasible for pulp and paper mill lime kilns.

Good combustion practices ensure the proper excess air range in a lime kiln for controlling emissions, including NO_x, and for minimizing fuel usage. Good combustion practices also include properly monitoring the process and adjusting fuel usage to conserve energy and minimize emissions. A proper lime kiln burner design may not meet the definition of an LNB (5-7% or less of stoichiometric air to the burner) but utilizes the similar principles of sub-stoichiometric addition of primary air for a partial staging of combustion and minimization of NO_x. We do not agree with EPA's CoST model assumption that LNB are an appropriate NO_x reduction technology for a pulp and paper lime kiln and could achieve a 30% reduction.²⁵ In addition, most lime kilns emit less than 100 tpy of NO_x unless they are very large and combust SOGs. EPA has correctly concluded that pulp and paper mill lime kilns should not be subject to ozone season NO_x emission limits.

NCG Incinerators

EPA's CoST model indicates that SCR is a feasible (although categorized as "emerging") control technology for pulp and paper mill NCG incinerators.²⁶ There are no pulp mill NCG incinerators in the U.S. that have applied SCR. SCR would convert SO₂ to SO₃, causing a visible plume. Although some NCG incinerators are equipped with wet scrubbers to reduce SO₂, the low temperature and moisture content in the scrubber exhaust gas would require the gas to be reheated using fossil fuel to be effectively treated in an SCR. We do not agree that SCR should be identified as a feasible control technology for pulp mill NCG incinerators. At any rate, we would not expect NO_x emissions from an NCG incinerator to be greater than 100 tpy at any of the pulp and paper facility locations.

B. Feasibility of NO_x Controls for Pulp and Paper Mill Boilers

EPA has proposed to establish ozone season NO_x emission limits for pulp and paper mill boilers greater than or equal to 100 MMBtu/hr in size that fire coal, oil, or natural gas at 40 CFR 52.45. Pulp and paper industry boilers are subject to many air emissions regulations that limit criteria pollutants and hazardous air pollutants (HAPs), such as state-specific rules, Boiler MACT, and boiler NSPS. Many of our industry's boilers have been through rigorous air permitting, BACT analyses, RACT analyses, and regional haze four-factor analyses. Historically, these analyses have often

²⁴Air Pollution Control Technology Fact Sheet. EPA-452/F-03-032. <https://www3.epa.gov/ttnca1/dir1/fscr.pdf>. (pg. 1).

²⁵ <https://www.epa.gov/economic-and-cost-analysis-air-pollution-regulations/cost-analysis-modelstools-air-pollution#control%20strategy%20tool>, CMDB for stationary sources zip file

²⁶ Id.

shown that add-on NO_x controls are not reasonable or cost effective for our solid-fuel and multifuel boilers, particularly swing boilers.

All facilities implement good combustion practices, and any unit subject to Boiler MACT is required to conduct tune-ups at the frequency specified by the rule. Some facilities are located in states that already required tune-ups of burners at some frequency prior to implementation of Boiler MACT. Any facility located in a non-attainment area or in the ozone transport region has implemented RACT on its boilers, largely based on a unit-specific analysis and not the stringent limits EPA has proposed.

Biomass Boilers

EPA has not explicitly proposed to establish ozone season NO_x emission limits for pulp and paper biomass boilers; however, these boilers typically start up on and may co-fire either fuel oil or natural gas, so it is not clear to us in this proposal whether a biomass boiler that starts up on or co-fires a fossil fuel would be subject to ozone season NO_x emission limits under the proposed rule. EPA's CoST database does not identify available NO_x controls for biomass-fired boilers. However, our large biomass boilers do typically emit more than 100 tpy of NO_x. We urge EPA to exclude boilers firing biomass from this regulatory program because installing add-on NO_x controls on our biomass boilers has often been shown to be either infeasible or extremely problematic, as discussed below. Due to these technical challenges, some vendors have been reluctant to provide a specific emissions reduction guarantee.

LNB is not a technology that can be applied to biomass combustion. Biomass is typically combusted in suspension, in a fluidized bed, on a grate, or in a pile. It is not comparable to combustion of natural gas or oil using an LNB. If a boiler only starts up on gas or fuel oil, requiring replacement of startup burners with LNB would not result in an appreciable NO_x reduction because the startup fuels do not comprise the majority of the NO_x emissions from a biomass unit.

SNCR involves injecting ammonia or urea into a combustion chamber or the flue gas stream, which must be between approximately 1,600 and 2,000°F for the chemical reaction to occur. SNCR was developed for, and has predominantly been applied to, fossil fuel-fired utility boilers. The effectiveness of SNCR on pulp and paper mill boilers is typically on the low end of the control efficiency range because our boilers experience variable loads and the temperature profile in a pulp and paper mill boiler is not as constant as that in a base-loaded fossil fuel-fired utility boiler.

Pulp and paper mill boilers are operated to follow and track steam load demand required for facility processes and furnace temperature tracks the steam demand. At low loads, furnace temperatures may be below the optimum level required for achieving NO_x reductions. Multiple levels of reagent injectors can be installed in the furnace to attempt to inject the reagent in the optimum temperature window for a given load, but if optimal temperatures cannot be consistently

maintained, the ammonia or urea injection rate needed to reduce NO_x emissions using SNCR will result in excess ammonia being present. This ammonia will combine with chlorides and sulfur in the combustion gas and result in increased corrosion of downstream metal and heat surfaces. In addition, chlorides in the gas stream will combine with excess ammonia to create condensable particulate matter less than or equal to 2.5 microns in diameter (PM_{2.5}) in the flue gas, thereby increasing PM_{2.5} emissions. Ammonia emissions can also result in secondary formation of nitrates and sulfates and a visible detached plume. This is an unacceptable outcome.

The SNCR injectors must also be installed above any overfired air ports in the furnace, further limiting its application and effectiveness, especially in boilers with shorter furnaces (not only is the temperature window important, but residence time is also important). In addition, a small biomass boiler may not reach the required temperature window in the furnace at all.

Additional water, power, and boiler fuel are required to operate an SNCR system because the SNCR process reduces the thermal efficiency of the boiler. The reduction reaction uses thermal energy from the boiler, which decreases the energy available for power or heat generation. SNCR is difficult to apply to pulp and paper mill biomass boilers, and where it has been required, it does not achieve the same emissions reductions that would be achieved on a fossil fuel-fired, base-loaded utility boiler.

No pulp and paper mill biomass boiler uses SCR. SCR uses a catalyst to reduce NO_x to nitrogen, water, and oxygen. SCR is a NO_x control technology that uses a catalyst to react injected anhydrous ammonia, aqueous ammonia or urea to chemically convert NO_x into N₂ and H₂O. The flue gases flow into a reactor module containing the catalyst where the reagent selectively reacts with the NO_x. The reduction reactions used by SCR are effective only within a given temperature range where ammonia or urea is injected into the exhaust gases in a temperature range of 480°F – 800°F.²⁷ For a large industrial boiler, this temperature range is achievable between the generating bank outlet and the air heater or economizer, but if the SCR must be placed further downstream, a duct burner is necessary to achieve the proper temperature window or the air heater and economizer must be bypassed to keep the temperature of the flue gas elevated. At the higher end of the temperature range, with the proper amount of reducing agent and injection grid design, SCR can achieve 90% reduction of NO_x given the right operating conditions. However, ammonia slip can also occur, which refers to the emissions of unreacted ammonia due to the incomplete reaction of the reagent and NO_x. As discussed above, excess ammonia can result in formation of compounds that cause corrosion and impair visibility.

SCR has been demonstrated mostly on large coal- and natural gas-fired combustion units in the utility industry. In practice, SCR systems operate at NO_x control efficiencies in the range of 70% to

²⁷Air Pollution Control Technology Fact Sheet. EPA-452/F-03-032. <https://www3.epa.gov/tncatc1/dir1/fscr.pdf>. (pg. 1).

90% for fossil fuel utility boilers. Operating temperatures for the SCR process range from 480 to 800°F but a temperature of at least 650°F is required to achieve the maximum control efficiency. Due to potential catalyst poisoning or plugging problems associated with locating the catalyst at the economizer outlet of a solid fuel-fired boiler (i.e., prior to the particulate matter control device), an SCR system on a biomass boiler would have to be installed after an existing particulate matter control device (to avoid a significant decrease in catalyst performance and life, and an increase in ammonia slip), and would require installation of a gas-fired flue gas duct burner to achieve the optimum reaction temperature (the flue gas temperature for biomass boilers is typically less than 480°F). This would incur associated fuel costs and increases in emissions of greenhouse gases and other products of combustion, assuming there is adequate space to install the SCR reactor and the size duct burner needed to raise the temperature of the exhaust gas stream to the optimum temperature of 650°F. To summarize, no add-on control technology has been installed on a pulp and paper biomass boiler that achieves a significant reduction in NO_x emissions (SCR has not been installed and there are only a handful of SNCR installations with typical reductions of about 35%).

Coal-Fired Boilers

SCR is a well-demonstrated NO_x control technology for coal-fired utility boilers and although it is possible to utilize it on smaller industrial coal-fired boilers, it has not been widely applied. There are no pulp and paper coal-fired boilers equipped with SCR. LNB are not feasible for coal-fired stoker boilers that combust fuel on a grate. Pulp and paper mill coal-fired boilers typically rely on optimization of combustion air systems and may have overfired air installed to minimize NO_x, while maintaining compliance with applicable CO standards. EPA's CoST model identifies only SCR and SNCR as feasible NO_x control technologies for coal-fired industrial boilers.²⁸ Similar to biomass-fired pulp and paper boilers, a coal-fired pulp and paper boiler that experiences swings in load would have to be equipped with multiple levels of injectors as part of an SNCR system and the resultant NO_x reduction would likely be lower than that expected from a base loaded utility boiler. A coal-fired pulp and paper mill boiler with no post-combustion NO_x controls would likely require SCR to meet EPA's proposed ozone season NO_x emission limit.

Oil-Fired Boilers

EPA's CoST model identifies multiple feasible control technologies for oil-fired industrial boilers, including LNB, FGR, SCR, SNCR and combinations of technologies. The pulp and paper industry has few boilers left that fire only fuel oil (many converted to natural gas as a result of Boiler MACT and only fire fuel oil during periods of natural gas curtailment) and the reductions required to meet EPA's proposed ozone season NO_x limits for oil-fired boilers are not as high as they are for other fuels. Therefore, it is possible that our fuel oil-fired boilers may be able to comply with the

²⁸ <https://www.epa.gov/economic-and-cost-analysis-air-pollution-regulations/cost-analysis-modelstools-air-pollution#control%20strategy%20tool>, CMDB for stationary sources zip file

proposed limits using a combination of LNB and SCR. None of our oil-fired boilers are currently equipped with SNCR or SCR.

Gas-Fired Boilers

Retrofit with LNB is generally feasible for gas-fired boilers but is not always without technical issues. LNB burner conversion capability may be complicated by boiler age, configuration, and fire-box dimensions. When retrofitting an older existing boiler with LNB, FGR may also be required to achieve the desired level of NO_x reduction. Retrofitting LNB on a small natural gas-fired package boiler with a single burner is mostly straightforward. However, retrofitting a larger, older boiler that has multiple burners can be more complicated, due to burner positions and the potential for overlapping flames to result in NO_x hot spots within the furnace. To achieve low NO_x concentrations, a typical retrofit of a multiple burner boiler with LNB would also include FGR, some new ductwork, and a new fan, and would likely result in a NO_x level of around 50 parts per million (ppm) at 3% O₂, which would meet the proposed ozone-season emissions limit. A comparison of the AP-42 pre-NSPS uncontrolled and LNB/FGR emissions factors for large natural gas boilers in Table 1.4-1 shows a NO_x reduction of approximately 64%, but the actual NO_x reduction will vary based on the current emission rate of each boiler. Note that the design of some paper mill boilers is such that a simple burner replacement may not be straightforward. For example, the boiler may have a cyclopack burner that is integrated into the side wall of the boiler and to change the burner, tubing and refractory would have to be reconfigured.

Ultra-LNB (ULNB) do not achieve ultra-low NO_x at lower loads at which industrial boilers may sometimes operate. ULNB are typically designed for and used on package boilers and are sometimes not easily adapted for our pulp and paper boilers because (1) the burners themselves have physically separated (staged) combustion zones that are not readily incorporated into the water walls or wind box geometry and (2) the operation of the air preheater can impact their performance, so FGR must also be installed.

SCR has not been installed on pulp and paper gas-fired boilers but may be technically feasible, although challenging, assuming the exhaust met the required temperature window. Some of our natural gas boilers do not have adequate space to install an SCR reactor prior to the air heater or economizer and the exhaust gas temperature following the air heater or economizer is typically less than 450°F. Therefore, in many cases, a duct burner would be necessary for an SCR to be effective at reducing NO_x emissions, which would raise the cost of controls and increase fuel use and GHG emissions.

With respect to the feasibility of fuel switching or boiler replacement to reduce emissions, many of our facilities did either replace boilers or repower them to comply with Boiler MACT or the Regional Haze Rule. Where sufficient natural gas supply is available to a mill and it is feasible and

cost effective to combust gas rather than coal, those changes have, in most instances, been made. If sufficient natural gas is not available to a mill, a significant capital investment is required to upgrade infrastructure both external and internal to the mill. It is not reasonable to expect pulp and paper mills to replace all combustion of biomass with natural gas because forest products facilities rely on combustion of carbon neutral, biomass residuals from their processes to remain economically sustainable and to keep GHG emissions low.

C. Achievability of Proposed NO_x Limits for Pulp and Paper Mill Boilers

EPA has proposed ozone season NO_x emission limits for pulp and paper mill boilers that represent a significant reduction from uncontrolled emissions rates and are even lower than the NO_x emission limits in applicable 40 CFR Part 60 Standards of Performance for New Stationary Sources. The table below shows the reductions that EPA proposes to require from uncontrolled boilers:

Boiler Fuel	Proposed Ozone Season NO_x limit, lb/MMBtu	Applicable NSPS Subpart Db limit, lb/MMBtu²⁹	Uncontrolled AP-42 factor, lb/MMBtu³⁰	Percent Reduction from NSPS	Percent Reduction from Uncontrolled AP-42
Coal	0.20	0.50 – 0.80	0.44 – 0.88	60 – 75%	55 – 77%
Residual fuel oil	0.15	0.30 – 0.40	0.31	50 – 63%	50%
Distillate fuel oil	0.12	0.10 – 0.20	0.17	0 – 40%	29%
Natural gas	0.08	0.10 – 0.20	0.17 – 0.27	20 – 60%	53 – 70%

Pulp and paper mill boilers are well-controlled under Boiler MACT, but the small number of end of stack NO_x controls on our boilers is due in part to level of emissions, cost and practicality of controls, and location of sources relative to non-attainment areas. To meet EPA’s proposed ozone season NO_x emission limitations, all affected pulp and paper mill coal- and oil-fired boilers would require additional controls and almost half of our gas-fired boilers would require additional controls. Although EPA has indicated to AF&PA that this rule does not specifically require the use of any particular control technology, the emissions reductions that EPA proposes to require for uncontrolled boilers will indeed force our mills to attempt to implement the most stringent control technologies, which have not been applied in our industry.

Assuming an affected pulp and paper coal-fired boiler is either uncontrolled or subject to an NSPS NO_x limit, the only way the boiler would be able to comply with EPA’s proposed ozone-season NO_x limit would be to install an SCR. No other NO_x control technology would reliably achieve a control efficiency as great as EPA is requiring with any compliance margin. For example, EPA’s CoST model

²⁹ 40 CFR 60.44b

³⁰ AP-42 Sections 1.1, 1.3, and 1.4.

only applies 35% NO_x control for SNCR on industrial boilers³¹, so that technology would not satisfy the emissions limits proposed in this rule. In addition, any combustion adjustments would have to be made with meeting required CO limits (e.g., Boiler MACT or other permit limits) in mind, given the inverse relationship between the two pollutants.

For residual fuel oil-fired boilers, an SNCR would not provide the required control efficiency to meet EPA's proposed ozone-season NO_x limit. An SCR would likely be required if an evaluation showed the boiler owner could not install LNB and FGR to meet the proposed limit for a particular unit (such an evaluation would be boiler-specific).

According to AP-42 Table 1.3-1, a boiler greater than 100 MMBtu/hr firing distillate oil should be able to achieve EPA's proposed ozone-season NO_x limit using LNB and FGR. A gas-fired boiler greater than 100 MMBtu/hr should be able to achieve the proposed ozone-season NO_x limit using an LNB with FGR or a ULNB. This option would be more cost effective than installing SCR, which would also achieve the proposed limit for gas-fired boilers, but would require ammonia storage and injection. Any newer gas-fired boiler will be equipped with LNB at a minimum.

We reiterate our point above that EPA should not include pulp and paper mill boilers firing >10% biomass (annualized heat input basis) in this rule. Biomass boilers cannot meet the NO_x emissions levels proposed by EPA for other fuel types. (For example, NSPS Subpart D contains a NO_x limit of 0.3 lb/MMBtu for boilers that simultaneously burn wood and liquid or gaseous fossil fuel at 40 CFR 60.44(a)(2).) EPA acknowledged this fact when they excluded biomass boilers with an annual fossil fuel capacity factor of less than 10% from complying with NSPS Subpart Db NO_x limits. In addition, EPA also allows facilities with boilers that are subject to NSPS Subpart Db NO_x limits to petition for a facility-specific NO_x limit (and in fact, has granted such limits to pulp and paper mill boilers in the past). EPA also acknowledged that biomass boilers and multifuel boilers have a different emissions profile than boilers firing exclusively gas, oil, and coal when it established subcategories for biomass boilers in Boiler MACT that were defined based on burning a minimum 10% biomass annually.

D. Evaluation of EPA's Proposed NO_x Limits for Pulp and Paper Mill Boilers

In the document titled "Technical Support Document (TSD) for the Proposed Rule Docket ID No. EPA-HQ-OAR-2021-0668 – Non-EGU Sectors TSD³²," EPA describes that they reviewed several RACT rules to determine the proposed ozone season limits. Specifically, EPA reviewed RACT rules in Connecticut³³, Delaware, New York, Massachusetts, and New Jersey. EPA does not provide any

³¹ <https://www.epa.gov/economic-and-cost-analysis-air-pollution-regulations/cost-analysis-modelstools-air-pollution#control%20strategy%20tool>, CMDDB for stationary sources zip file

³² EPA-HQ-OAR-2021-0668-0145

³³ In Table 3 of the "Non-EGU Sectors TSD," EPA cites emission limits from Section 22a-174-22e of the Regulations of Connecticut State Agencies, paragraph (d)(2)(C) (i.e., 0.12 and 0.15 lb/MMBtu for ozone season and non-ozone

additional detail on how the proposed limits were derived from the limits identified in the state rules (e.g., by conducting any additional analysis, averaging, etc.). Even though EPA clearly explains in its Technical Support Document³⁴ that the type of NO_x control available for use on a particular unit depends primarily on the type of boiler, fuel type, and fuel firing configuration, EPA did not acknowledge or appear to take into consideration a number of key features of the state RACT rules specifically designed to account for different boiler designs, firing configurations, and fuel types. For example, many state RACT rules recognize the need to establish unique limits based on fuel firing method and fuel type and distinguish between units firing “gas only” versus “gas and/or oil” fired units. For example, when EPA concluded in the non-EGU TSD that Massachusetts rules require gas fired boilers to meet a 0.06 lb/MMBtu limit, it failed to acknowledge that their rules set different limits for face-fired gas units and high heat release boilers³⁵. Similarly, in its conclusions about RACT limits established for coal fired units in Massachusetts, Delaware, and New York, it failed to recognize provisions applicable to stoker-fired boilers (0.33 lb/MMBtu, 0.40 lb/MMBtu) and case-by-case requirements in New York.³⁶ New York rules require case-by-case RACT limits for boilers with different configurations and burning different fuels than those for which its presumptive RACT limits were established (gas only, gas/oil, or coal)³⁷. Most if not all of the state RACT rules recognize that boiler configurations and firing methods play a critical role in the technical and economic feasibility of controls and achievability of NO_x limits and therefore provide for case-by-case RACT limits and other alternative compliance options such as emission averaging.³⁸

In addition to reviewing EPA’s analysis, AF&PA analyzed information from EPA’s RBLC³⁹ to evaluate the proposed emission limits against previous RACT, BACT, and LAER determinations.⁴⁰ For coal-fired industrial boilers with a heat input rating of 100 MMBtu/hr or more, a review of the available RBLC records indicates that EPA’s proposed limit of 0.20 lb/MMBtu is generally achievable only with the installation of post-combustion controls. AF&PA identified nine entries with emission limits classified as RACT and emission limits for these units ranged between 0.45 and 1.01

season, respectively). However, paragraph (d)(2) states that the limits apply to boilers serving EGUs. The industrial/commercial/institutional boiler limit is found in paragraph (d)(3)(c), i.e., 0.15 lb/MMBtu.

³⁴ Id. page 64.

³⁵ MA Title 310 Chapter 7.19 4(b)(3)(b) and 4(b)(4)(b)

³⁶ MA: 310 CMR 7.19U(4)(b)(2), DE: 7DE Admin Code 1112,(3)(2)(1), NY 6 §227-2.4(a)(2).

³⁷ NY 6 § 227-2.4

³⁸ NY 6 §227-2.4 and 2.5; MA 310 CMR 7.19(4)c); NJ 7:27-19.3(f); DE 7 AC 1112(3.23)

³⁹ Available at <https://www.epa.gov/catc/ractbactlaer-clearinghouse-rblc-basic-information>

⁴⁰ To perform the evaluation, AF&PA queried the RBLC for entries related to coal, oil, and gas combustion in boilers permitted on or after 1/1/1990. Any records with NAICS codes not included in 31 through 33 were excluded. AF&PA also excluded any EGUs (identified by facility name), any units that did not appear to be boilers based on process description, units with a heat input capacity rating below 100 MMBtu/hr, and units with size ratings or limits not described on a MMBtu basis. If a control scheme was not indicated, AF&PA assumed the control of NO_x emissions was achieved via boiler design and/or good combustion practices. Permit notes and fuels fired were also reviewed and, in some instances, entries were reclassified or removed based on indicated fuel fired.

lb/MMBtu with an average of approximately 0.63 lb/MMBtu (all higher than EPA's proposed ozone-season limit for coal-fired boilers).

AF&PA reviewed RBLC entries for residual oil-fired industrial boilers with a heat input of 100 MMBtu/hr or more. Emission limits for all five units ranged from 0.3 to 0.7 lb/MMBtu. EPA's proposed limit of 0.15 lb/MMBtu for residual oil firing is at least 50% lower than what has previously been identified as BACT for pulp and paper facilities, which is not reasonable.

For distillate oil-fired industrial boilers with ratings of 100 MMBtu/hr or more, AF&PA identified five units with BACT emission limits ranging from 0.12 to 0.7 lb/MMBtu. The only add-on control identified was LNB for a unit with an emission limit of 0.12 lb/MMBtu, which is equivalent to EPA's proposed limit for distillate oil-fired boilers.

All the RBLC determinations for natural gas-fired industrial boilers with a heat input of 100 MMBtu/hr or more had an emission limit less than 0.08 lb/MMBtu. However, we are unsure whether these entries represent new boilers or retrofits, and we reiterate the points made in our comments above that the level of emissions reduction that can be achieved via a retrofit installation of a NO_x control will vary based on boiler configuration and operating parameters.

In summary, EPA has proposed ozone-season NO_x emissions limits for pulp and paper boilers that are more stringent than new source performance standards and most RACT programs, particularly for multi-fueled boilers. The proposed limits will result in challenging retrofit projects for many facilities.

E. EPA Overestimated NO_x Reductions from Pulp and Paper Mill Boilers It Analyzed

EPA's estimates of the NO_x reductions this rule will achieve are potentially flawed for several reasons. First, in the Agency's analysis, EPA only considered emissions reductions for those boilers meeting the criteria outlined in Step 2c of Section 3 of the non-EGU screening assessment memo, which included the requirement that available controls for the boiler cost no more than \$7,500 dollars per ton of NO_x reduced.⁴¹ However, the regulatory language at proposed 40 CFR 52.45 contains no provision for the evaluation of cost-effectiveness for control. Furthermore, EPA's criteria for evaluating emissions reductions also included the requirement that the boiler have an estimated maximum contribution at an individual receptor greater than or equal to 0.0025 ppb, or an estimated total contribution across all downwind receptors of greater than or equal to 0.01 ppb. Finally, following installation of presumed controls, the boiler must also have had a predicted maximum improvement at an individual receptor of 0.001 ppb or more. Similar to the cost-effectiveness criteria, the proposed regulatory language contains no such provisions to narrow the

⁴¹ EPA-HQ-OAR-2021-0668-0150, pg. 6.

applicability of the rule. Thus, EPA has calculated impacts from the proposed rule considering only a subset of the population of boilers subject to the control requirements.

Based on the worksheet “Tier 2 Boilers – Contributions” EPA initially identified 69 boilers in the pulp and paper industry sector subject to the rule requirements, and calculated emissions reductions and costs for 25 of these boilers in its screening assessment memo.⁴² Yet, based on AF&PA’s quick review of operating pulp and paper boilers with capacity greater than or equal to 100 MMBtu/hr operating in the states EPA proposes to cover with this FIP (based on an informal survey of AF&PA and NCASI members and a review of emissions inventory data), we identified 47 boilers that burn biomass with other fuels that should not be subject to the rule, and 101 coal-, oil-, and gas-fired boilers that would likely be subject to the rule, 47 of which would likely be required to install controls or change fuels to meet the proposed ozone-season emission limits. However, application of controls to these 47 coal-, oil-, and gas-fired boilers (and assuming a 20% compliance margin with the applicable limit) results in estimated ozone season emissions reduction of about 2,600 tons, which is less than EPA’s estimated 3,305 tons from the 25 boilers analyzed in its screening assessment memo.

In the worksheet “Boilers of Interest – Controls” in EPA’s Tier 2 analysis, the Agency applied SCR to 20 pulp and paper boilers. Based on a review of the units by AF&PA, at least six of those 20 boilers co-fire biomass in addition to either coal, natural gas, or both. As described above, SCR has not been installed on pulp and paper mill biomass or coal boilers due to space constraints in the proper temperature zone of the boiler and the potential for catalyst poisoning and blinding if installed upstream of particulate controls; thus, there would be a need to install a duct burner and the SCR downstream of the particulate control device. Furthermore, NO_x reductions of 90%, as EPA has calculated, are unlikely on pulp and paper mill boilers (including those that only fire fossil fuels) because of the variable nature of the loads they supply. Reductions of 90% are more likely for fossil fuel utility boilers that operate at relatively constant loads. Additionally, EPA applied SCR or SCR and ultra LNBS to six gas-fired pulp and paper mill boilers for NO_x reductions of 90% to 91%. As presented previously in these comments, it is likely that pulp and paper mill gas-fired boilers will only require between 53% and 70% NO_x reductions to meet the proposed standard; thus, EPA has overstated emissions reductions for gas-fired units by assuming operators will install more costly and unnecessary controls and assuming they will run the controls to achieve an emissions rate far lower than what is required.

Although our analysis indicates more units than EPA evaluated in its screening analysis would require controls under the proposed rule, our analysis also indicates that the emissions reductions

⁴² EPA-HQ-OAR-2021-0668-0225, worksheets “Tier 2 Boilers – Contributions,” and “Boilers of Interest – Controls.”

will be less than those contemplated by EPA. Additionally, as discussed below, these emissions reductions will also come at a higher cost than EPA has estimated.

F. EPA Should Allow Case-by-Case RACT

If EPA revises their analysis and determines that Tier 2 industrial boilers should be subject to NO_x emission limits in the final rule (as stated previously, we respectfully request that this not be the outcome for pulp and paper sector boilers), AF&PA requests that EPA incorporate regulatory language that allows for the application and approval of case-by-case RACT emission limits. Case-by-case RACT emission limits are necessary when sources cannot meet the prescribed emission limits cost-effectively or because of unique technical limitations specific to a particular source such as those described in Section V.B above for application of NO_x controls to pulp and paper mill boilers. Precedent for allowing case-by-case RACT analyses and emission limits is well established as illustrated in several of the rules that EPA used as the basis of the proposed standards for Tier 2 boilers⁴³ including rules adopted by Connecticut, Delaware, Massachusetts, Maryland, Maine, New Hampshire, New Jersey, and Pennsylvania.⁴⁴ Furthermore, NSPS Subpart Db allows operators to petition the Administrator for facility-specific NO_x emission limits. Thus, EPA should include case-by-case RACT provisions in the final rule language to provide a regulatory mechanism for sources to comply with the rule in situations where compliance would not otherwise be economically or technically feasible.

VII. Cost of Controls

A. EPA Underestimated the Cost of Controls and Cost-Effectiveness

AF&PA analyzed the cost analysis EPA presents in the non-EGU screening memo and determined that EPA has underestimated the annual cost of controls for industrial boilers. As described in Section V.B, SCR requires an exhaust gas stream temperature of at least 650°F to achieve maximum control efficiency. Most large pulp and paper mill boilers are equipped with air heaters and/or economizers and there is generally not adequate space to install an SCR reactor prior to these systems; thus, to install an SCR our members will be required to install and operate a duct burner to reheat the boiler exhaust gases. Based on a natural gas price of \$7.38/MMBtu⁴⁵, operation of a 50 MMBtu/hr duct burner on a 555 MMBtu/hr natural gas boiler (such as the Pixelle Specialty Solutions LLC unit identified in EPA's cost analysis for SCR) would cost over \$3.2 million annually and over \$1.3 million during ozone season, almost quadrupling the annual total cost for SCR

⁴³ EPA-HQ-OAR-2021-0668-0145, starting on pg. 63.

⁴⁴ CT: Section 22a-174-22e of the Regulations of CT State Agencies, paragraph (d)(1)(B); DE: Title 7, Natural Resources and Environmental Control, Section 112, paragraph 3.2.3; MA: Regulation 310 of the Code of MA Regulations, Section 7.19, paragraph (2)(b); MD: Code of MD Regulations 26.11.09.08 B(3); ME: ME Administrative Code, Department 6, Division 96, Chapter 138 paragraph (3)(l); NH: NH Code of administrative Rules, Chapter Env-A 1300, Part Env-A 1314.03(b); NJ: Title 7, NJ Administrative Code, Chapter 27, Subchapter 19 paragraph 3(f); PA: 25 PA Code, Section 129.99.

⁴⁵ February 2022 average U.S. industrial price, https://www.eia.gov/dnav/ng/ng_pri_sum_a_EPG0_PIN_DMcf_m.htm.

calculated by EPA for such a unit. Incorporating the operating cost of a natural gas duct burner for each of the SCR units on pulp and paper mill boilers identified by EPA in the worksheet “Boilers of Interest – Controls,”⁴⁶ increases the average cost effectiveness for units for which EPA assigned SCR control from \$4,500 per ton of NO_x to \$11,100 per ton of NO_x when assuming a duct burner size approximately 9% of the rated heat input capacity of the boiler, a natural gas cost of \$7.38/MMBtu, and 350 operating days per year. Incorporating the operating cost of an auxiliary natural gas burner for pulp and paper mill boilers for which EPA assigned an SCR or SCR combined with LNB/ULNB raises the average cost-effectiveness from \$4,600 per ton of NO_x to \$15,400 per ton of NO_x.

Furthermore, our members are unlikely to operate SCR systems year-round to avoid unnecessary operating and maintenance expenses outside of the ozone season, especially given the cost of natural gas for operating the duct burner. As such, the cost effectiveness should be calculated using only the ozone season NO_x reductions. Based on EPA’s “SCR Cost Calculation Spreadsheet.xlsm⁴⁷,” direct annual costs (which include variable and semi-variable costs such as reagent, utilities, maintenance, and labor) are approximately 25% of the total annual cost for SCR operation without considering the cost of natural gas for an auxiliary burner. Therefore, AF&PA used the following formula to recalculate the cost-effectiveness for pulp and paper mill boilers for which EPA applied an SCR for NO_x control:

$$CE = \frac{\frac{5}{12}(0.25 \times TAC + NG) + 0.75 \times TAC}{NO_{xOS}}$$

Where:

- CE = Cost-effectiveness in dollars per ton of NO_x reduced during ozone season.
- TAC = Total annual cost calculated by EPA.
- NG = Cost of supplemental natural gas for auxiliary burner.
- NO_{xOS} = Ozone season NO_x reduction calculated by EPA in tons.

By making the ozone season adjustment, AF&PA calculated a revised cost-effectiveness of \$15,900 per ton of NO_x reduced – a value more than double EPA’s marginal cost threshold of \$7,500 per ton.⁴⁸ Our members with mills in Oregon and Washington also evaluated the cost of SCR on their boilers as part of required Regional Haze Rule four-factor analyses (see attachments II and III)⁴⁹.

⁴⁶ EPA-HQ-OAR-2021-0668-0225

⁴⁷ Available: <https://www.epa.gov/economic-and-cost-analysis-air-pollution-regulations/cost-reports-and-guidance-air-pollution>

⁴⁸ EPA-HQ-OAR-2021-0668-0150, pg. 4.

⁴⁹ “Reasonably Available Control Technology Analysis for Washington Pulp and Paper Mills,” Northwest Pulp and Paper Association, December 2019, submitted to Washington Department of Ecology, and “Regional Haze Rule Four-Factor

The cost effectiveness of SCR was generally greater than \$7,500/ton (based on year round operation), using EPA's OAQPS Control Cost Manual methodologies. We have attached example cost analyses using EPA's OAQPS Control Cost Manual spreadsheets to estimate the retrofit cost of SCR for a 250 MMBtu/hr coal-fired boiler and a 250 MMBtu/hr gas-fired boiler; each shows a much higher cost than EPA has included in its analysis (see Attachment I). We can only assume that the equations being used in the CoST model for SCR do not match the equations for NO_x control costs that EPA recently updated in its OAQPS Control Cost Manual.⁵⁰

EPA also appears to have underestimated the cost of LNB technology by assuming industrial boilers, and specifically pulp and paper mill boilers would apply ULNB instead of LNB and FGR. As described earlier, boilers at pulp and paper mills can be subject to highly variable swings in steaming rate and therefore must be able to accommodate a range of turndown rates. High turndown rates are not achievable with ULNB, and certain boiler geometries may not be able to accommodate ULNB; therefore, to achieve the necessary emissions reductions, our members would likely install LNB in conjunction with FGR, which requires additional expense compared ULNB. To assess the cost of LNB combined with FGR, AF&PA reviewed the Northwest Pulp and Paper Association (NWPPA) document titled "Regional Haze Rule Four-Factor Analysis for Four Oregon Pulp and Paper Mills," submitted to the Oregon Department of Environmental Quality in June 2020 (see attachment II). In the document, NWPPA analyzed the cost of LNB and FGR for gas-fired pulp and paper mill boilers ranging from 187.5 to 560 MMBtu/hr. Capital costs ranged from \$3.1 to \$6.6 million, and annual costs ranged from \$742,200 to \$1.6 million (2019 cost basis). Costs were based on the document titled "Emission Control Study – Technology Cost Estimates" by BE&K Engineering which was originally developed for AF&PA in September 2001. Cost-effectiveness values were reported between \$7,100 and \$245,000 per ton (based on actual emissions) and NO_x reductions were calculated using a 64% control efficiency based on a comparison of EPA AP-42 natural gas pre-NSPS uncontrolled and LNB/FGR emissions factors. The average cost effectiveness presented in the report, excluding the \$245,000/ton value was \$15,700/ton, which, like SCR, exceeds EPA's marginal cost threshold of \$7,500/ton by more than two times. We have attached an example cost analyses for installing LNB/FGR on a 250 MMBtu/hr gas-fired boiler; it shows a much higher cost than EPA has included in its analysis.

Unlike SCR, our members would operate LNB and FGR systems year-round instead of just during ozone season. This is because LNB and FGR cannot simply be "turned-off" or bypassed like SCR; however, if EPA revises its analysis as part of the final rulemaking, the agency must evaluate cost-effectiveness based on total annualized capital cost, ozone season operating cost, and the ozone season tons of emissions reduced because NO_x reductions outside of ozone season are beyond the

Analysis for Four Oregon Pulp and Paper Mills," Northwest Pulp and Paper Association, June 2020, submitted to Oregon Department of Environmental Quality.

⁵⁰ <https://www.epa.gov/economic-and-cost-analysis-air-pollution-regulations/cost-reports-and-guidance-air-pollution>

scope of the rule (the proposed NO_x emission limits for industrial boilers only apply during ozone season – emissions reductions are not required outside of ozone season).

B. EPA has Further Underestimated Total Cost of the Proposed Rule by only Evaluating 25 Pulp and Paper Boilers When the Applicability Criteria Suggest Many More Would be Affected by the Rule

In its screening assessment⁵¹, EPA selected only 25 pulp and paper boilers in affected states and applied a high level of NO_x controls without having detailed information on each boiler's configuration, installed controls, and lb/MMBtu NO_x emission rate. EPA also did not take into account the level of emissions reductions that would be necessary to comply with the proposed emissions limits, it simply applied an across the board percent reduction. This approach is not reasonable. AF&PA and NCASI reviewed EPA's list of boilers in the pulp and paper industry and attempted to compile a more current list of operating boilers that are greater than or equal to 100 MMBtu/hr in size and perform our own screening analysis to estimate the emissions reductions that might be achieved and the cost of achieving those reductions.

We queried pulp and paper companies in the states EPA proposes to regulate to understand boiler sizes, existing controls (if any), and actual NO_x emissions in tpy and lb/MMBtu. We then assigned a primary fuel type to each boiler (biomass, gas, oil, or coal) and assigned the proposed gas, oil, or coal emissions limit to each boiler primarily fueled by gas, oil, or coal. For any boiler with a lb/MMBtu NO_x emission rate more than 10% higher than the proposed ozone season emissions limit, we applied controls in order to achieve a NO_x emissions rate 20% lower than the applicable limit (our facilities aim to operate in a manner that results in a reasonable margin of compliance with any applicable emissions limit). We identified 10 coal boilers and one distillate oil-fired boiler that did not meet the proposed limits (all of the coal- and oil-fired boilers in our inventory) and applied SCR to those boilers. We identified 90 gas-fired boilers, 36 of which appeared to require capital for additional control, and applied LNB/FGR if the NO_x emission rate in lb/MMBtu was from 1.1 to 2 times the proposed limit and the boiler did not already have LNB/FGR or SCR if the emission rate was more than 2 times the proposed limit. We calculated a base retrofit cost (attachment 1) for each control technology for a 250 MMBtu/hr boiler and scaled costs to each boiler in our list based on size and an 0.6 power function (e.g., if the control cost was \$10 million for a 250 MMBtu/hr boiler we assigned a cost of [$\$10 \text{ million} * (500/250)^{0.6}$] to a 500 MMBtu/hr boiler). We did not calculate any control costs for biomass boilers because it is our understanding that EPA did not intend to cover biomass boilers with this rule and there are no emissions limits for biomass firing in the proposed rule.

We did not calculate an ozone season control cost (annualized capital cost plus ozone season operating cost divided by ozone season tons reduced) less than \$7,500 for any individual boiler.

⁵¹ EPA-HQ-OAR-2021-0668-0150

Our estimated ozone season control costs averaged about \$70,000/ton and generally ranged from about \$11,000/ton to over \$200,000/ton. The estimated ozone season reduction across the boilers evaluated was about 2,600 tons, averaging less than 60 tons per boiler. We estimate a total capital cost for controls of over \$700 million, with an annual ozone season cost over \$90 million and a total annual ozone season cost of about \$38,000/ton. As our analysis shows, EPA has overestimated the emissions reductions this rule will obtain from fossil fuel-fired pulp and paper mill boilers and significantly underestimated the cost of those reductions.

C. If Non-EGUs Remain in the Rule, EPA Should Allow Non-EGUs to Opt-In to the Trading Program to Reduce the Cost of the Rule

If EPA finalizes ozone season NO_x emission limits for non-EGUs, it should also finalize regulatory language that allows non-EGUs with a NO_x continuous emissions monitoring system (CEMS) to opt into the ozone season NO_x trading program. As discussed elsewhere in these comments, EPA has proposed emissions limits that will require the application of controls on boilers where it will be much more expensive than \$7,500/ton to apply them. If EPA retains the proposed regulatory requirements for non-EGUs to avoid application of costly or potentially infeasible NO_x controls, it should allow non-EGUs the flexibility to manage their emissions in a more cost-effective manner, which may include NO_x reduction methods that are less stringent than proposed by EPA and purchase of NO_x allowances available in the current EGU trading program. Alternatively, EPA could allow non-EGUs to use a general account to purchase and retire ozone season NO_x tons to make up for any deficit between a boiler's actual performance and the non-EGU ozone season emissions limit. Finally, if pulp and paper mills generate NO_x credits, as they have done in the original NO_x SIP call, they should be able to sell them to any entity that is covered by the final rule.

D. EPA Should Consider the GHG Emissions Increases Resulting from the Proposed Rule

AF&PA notes that EPA has not addressed the resulting increases in GHG emissions from the proposed rule. AF&PA has identified at least three mechanisms that will result in additional GHG emissions from pulp and paper mill boilers if EPA finalizes the rule as proposed. AF&PA requests EPA include these additional emissions in its revised screening analysis to determine whether pulp and paper mill boilers should be subject to the emission limits in proposed 40 CFR 52.45.

As described in Sections V.B and VI.A above, if pulp and paper mill boiler owners determine that the only reasonable means of complying with the finalized emission limits is through the installation and operation of SCR (despite the previously discussed technical challenges associated with installing SCR on our boilers), in many cases operators will be required to install an additional duct burner to increase the exhaust gas temperature to an adequate level to achieve the necessary emissions reductions. Analyzing just the 25 pulp and paper mill boilers for which EPA assigned

costs in the worksheet “Boilers of Interest – Controls⁵²,” 20 of these boilers were identified by EPA as installing SCR. AF&PA estimates that these boilers would install a duct burner rated at approximately 9% of the overall unit’s heat input capacity rating to reheat exhaust gas. Assuming continuous operation of the duct burners throughout ozone season results in an additional 207,000 metric tonnes of CO₂ equivalents (CO₂e) per year. The actual GHG emissions increase from installation of SCRs would be higher than just emissions from natural gas duct burners due to the increased energy consumption required to overcome the additional pressure differential imposed by the catalyst bed. Furthermore, facilities’ scope 3 GHG emissions would also increase due to ammonia usage.⁵³

Additionally, if EPA fails to clarify that the final rule does not apply to biomass boilers, EPA should consider the additional GHG emissions that would result if biomass boilers needed to burn more fossil fuel to meet NO_x emissions limits. As described earlier in our comments, biomass boilers typically use distillate oil, residual oil, or natural gas for startup and shutdown, but there is no cost-effective add-on control technology that would result in significant NO_x reductions from a biomass boiler. Based on AF&PA’s review of data collected by our members and NCASI, there are 47 biomass boilers in the affected states that co-fire some amount of fossil fuels. Thus, if EPA does not revise the applicability language in proposed 40 CFR 52.45(b) to clarify that biomass boilers are not subject to the proposed ozone-season emission limits, depending on the format and level of the final emissions limits, facilities with biomass boilers may need to burn additional fossil fuels to meet the limits, resulting in an increase of non-biogenic GHG emissions (if this approach is economically feasible and if natural gas is available in sufficient quantity). However, displacing biomass with natural gas is generally not a preferred option because as previously stated, most forest products facilities rely on combustion of carbon neutral, biomass residuals from their processes to remain economically sustainable and keep their carbon footprint low.

VIII. Timing for Installation of Controls

A. EPA Should Defer Controls for Pulp and Paper Boilers to Determine If Further Reductions Are Needed Before Making Them Mandatory

As stated previously in these comments, pulp and paper boilers make up a very small portion of the total NO_x emissions inventory in the states EPA proposes to cover with this FIP. The emissions reductions EPA has predicted to result from ozone season NO_x limits on pulp and paper boilers are essentially too small to make a measurable impact on downwind state ozone concentrations and EPA has estimated the cost of controlling pulp and paper boilers (not just the units identified in the screening assessment memo) to be almost \$400 million in capital with an annual cost of \$100 million (and in many cases, much more than \$7,500/ton, according to EPA’s own cost

⁵² EPA-HQ-OAR-2021-0668-0225

⁵³ Ammonia production accounted for 0.2% of the US GHG emissions in 2019. Refer to Table 2-10 of US EPA’s “Inventory of U.S. Greenhouse Gas Emissions and Sinks 1990-2019,” EPA 430-R-21-005, available: <https://www.epa.gov/sites/default/files/2021-04/documents/us-ghg-inventory-2021-main-text.pdf>.

methodology).⁵⁴ Only nine pulp and paper mill boilers are estimated by EPA to impact a downwind monitor by 0.010 ppb or more⁵⁵, a number that is not even within the measurement accuracy of a monitor, and EPA's proposal, as written, will impact at least 100 pulp and paper boilers. This constitutes over control because the rule will impact many more than the nine boilers with estimated impacts over 0.010 ppb and the cost of the reductions will be much higher than EPA's \$7,500/ton threshold (in fact, our analysis described above indicates no facility will comply for a cost of \$7,500/ton or lower). There is little justification to require emissions reductions from pulp and paper boilers when their impact on downwind monitors is not measurable and there are other NO_x reduction measures that will happen in the next few years that are not as costly as what EPA is proposing. EPA should wait to determine whether EGU reductions and other "on the books" or "on the way" measures will provide the needed downwind impacts before requiring the pulp and paper industry to invest hundreds of millions of dollars to effect a non-measurable impact on a monitor many states away.

B. Three Years is not Enough Time to Achieve Compliance with Industrial Boiler NO_x Emission limits

EPA has proposed to require industrial boilers to comply with ozone season NO_x limits by May 1, 2026.⁵⁶ If EPA finalizes ozone-season NO_x emission limits for industrial boilers, there will be many facilities that will need to make modifications in order to comply with the new requirements. These modifications could include fuel switching, combustion air system changes, fuel feed system changes, burner replacements, and add on control device installation. If EPA finalizes its proposal in 2023, it may be difficult to implement controls prior to the 2026 ozone season. EPA appears to recognize that its proposed implementation schedule will be challenging because it noted "In addition, the publication of this proposal provides roughly an additional year of notice to these source owners and operators that they should begin engineering and financial planning now to be prepared to meet this implementation timetable."⁵⁷ However, what EPA does not appear to understand is that few, if any, owners will be willing to commit funds and resources to begin detailed engineering and design given the significant gaps and uncertainties in the rule as proposed, and in the absence of a more thorough technical demonstration that the proposed actions are necessary to satisfy the Clean Air Act's good neighbor provisions.

Some facilities may need a minimum of four years to implement controls after promulgation of any requirement to do so. At least four years would be required for some projects because the process to undertake a retrofitting project is complex, involving design, engineering, permitting, procurement, and installation to name only some of the necessary work streams. Also, since the start of the COVID-19 pandemic, the time necessary to implement construction projects has

⁵⁴ Per the spreadsheet provided by EPA titled "All NAICS units 2023 industry identification analysis EPA-HQ-OAR-2021-0668-0225_attachment_1.xlsx"

⁵⁵ Per the spreadsheet provided by EPA titled "Tier 2 Boiler Analysis all NAICS units EPA-HQ-OAR-2021-0668-0225_content.xlsx"

⁵⁶ 87 Fed. Reg. 20038 and proposed 40 CFR 52.45(c)

⁵⁷ 87 FR 20101, 1st column.

increased considerably. Lead times for obtaining critical parts and equipment are much longer and the ability to bring outside skilled labor on site has become more difficult than in pre-COVID-19 times. Project timelines would only increase with implementation of a regional NO_x controls rule for industrial boilers because many facilities would be competing for the same expertise and resources.

To implement any capital project, such as an emissions control project, a facility needs time to obtain corporate approvals for funding. Once funding is secured, the design, permitting, procurement, installation, and shakedown of a retrofit emissions control project can consume the remainder of a four-year period. The facility would engage engineering consultants, equipment vendors, construction contractors, financial institutions, and other critical suppliers. Lead time would be needed to procure pollution control equipment even after it is designed and a contract is finalized, and installation of controls must be aligned with facility outage schedules. Each facility would need to continue to operate as much as possible while retrofitting to meet any new requirements.

If a facility would choose to comply using fuel switching from coal to natural gas, project timelines could be even longer than four years if a firm natural gas supply is not available to the facility in the quantities necessary to repower combustion equipment. Infrastructure improvements both within and outside of the facility would be necessary. Major new source review permitting can be triggered for CO and VOC with a switch from coal to gas, depending on the boiler's size and baseline emissions rates. In addition, some facilities have long-term coal supply contracts that must be considered.

Due to supply chain issues with certain parts and instrumentation for some suppliers, a new CEMS installation may take 54 to 60 weeks if a facility was ready to start now. However, this timeline does not account for the time required to obtain capital approval, issue an RFP, engage a consultant, and make any necessary structural modifications to the stack if it cannot accommodate CEMS.

C. Permitting Timelines may not Allow for Necessary Boiler Modifications to Occur in Three Years

If EPA finalizes ozone-season NO_x emission limits for industrial boilers, there will be many facilities that will need to make modifications in order to comply with the new requirements. These modifications could include fuel switching, combustion air system changes, fuel feed system changes, burner replacements, and add on control device installation. All of these changes will require a modification to the facility's air permit. Although these modifications would be for the purposes of reducing NO_x emissions, an assessment of all changes in emissions and any new air regulatory requirements (state and federal) would be required. In some states, modifications to a boiler might trigger requirements for control of other pollutants as well under a state RACT, BACT, or air toxics program. As mentioned above, fuel switching sometimes results in a PSD significant

emissions increase for certain pollutants. In addition, SNCR and SCR use increases ammonia emissions, which is a pollutant covered by some state air toxics programs and a known precursor contributing to downwind formation of PM_{2.5}.

The timeline for getting a permit modification is not short and some states do not allow equipment to be purchased prior to issuance of a permit (depending on the type of permit modification needed). The facility must evaluate costs of each compliance option, develop a compliance strategy, engage a consultant to prepare the permit application, meet with the permitting agency, submit the permit application, wait for agency and public review of the application, and negotiate revised permit terms. It could take a facility a year to receive its revised permit especially if other pollutants like CO increase as a result of lowering NO_x emissions, and then it would begin the boiler modification project, which would likely have an even longer time frame if equipment purchase was not allowed prior to receipt of the revised permit. EPA cannot expect boiler owners and operators to be able to comply with the proposed ozone-season NO_x limits in three years in all cases.

D. The Rule Should Allow for An Extension of Up to Three Years If More Than Three Years Is Needed to Permit and Install Controls

EPA has requested comment on whether the FIP should provide time beyond the 2026 ozone season for individual non-EGU sources to meet the emission limitations and associated compliance requirements, based on a demonstration of necessity.⁵⁸ EPA must provide such a mechanism for facilities to request more time to comply. A project that involves permitting, boiler modifications, and additional monitoring will take more than three years to successfully implement. Even before the current supply chain issues being experienced during COVID-19, facilities requested and received compliance extensions for Boiler MACT projects that involved boiler replacements, fuel switching, control equipment, and/or monitoring equipment. In addition, facilities were anticipating Boiler MACT for several years and had the opportunity for advanced planning or were already controlling some of the regulated pollutants to MACT levels (e.g., our boilers have a long history of applying PM controls). Industry was not anticipating EPA would issue a FIP and require stringent ozone season NO_x emission limits with a short timeframe for compliance. Industrial boilers at facilities outside of ozone non-attainment areas do not typically have post-combustion NO_x controls unless the facility was required to install them as a result of BACT. EPA should allow for compliance extensions of more than one year based on a facility-specific demonstration of need. A few boilers completing their emissions reduction projects after the 2027 ozone season will not meaningfully impact downwind ozone attainment.

IX. Monitoring Requirements

A. EPA Should not Require NO_x CEMS for Industrial Boilers

⁵⁸ 87 Fed. Reg. 20104

EPA has proposed to require installation of NO_x CEMS⁵⁹ for industrial boilers subject to the ozone season emission limits proposed at 40 CFR 52.45(c). Many industrial boilers are not currently equipped with NO_x CEMS. Many regulatory programs (such as Boiler MACT) allow for periodic stack testing and continuous parameter monitoring to show ongoing compliance, in lieu of CEMS. Even boilers with RACT or BACT limits are not always required to install CEMS, but are sometimes allowed to demonstrate compliance via periodic stack testing or by using PEMS. Another example is the Gas Turbine NSPS at 40 CFR Part 60, Subpart KKKK, which does not require NO_x CEMS if water or steam injection is the NO_x control method. Instead, operators monitor parameters for ongoing compliance assurance between stack tests.

Several states (North Carolina and Alabama, for example) have allowed legacy NO_x SIP Call industrial boilers to remove their NO_x CEMS (if not required by another federal rule) and instead utilize fuel usage and emissions factors based on historical data to calculate ozone season NO_x emissions. It is reasonable for EPA to require periodic stack testing and continuous parameter monitoring as the demonstration method for ongoing compliance with the proposed lb/MMBtu ozone season emission limits. We would agree that CEMS would be appropriate for units participating in a trading program because it is critical to measure mass emissions accurately for participation in such a program. If EPA requires CEMS in the final rule, the rule will need to properly distinguish between obligations for newly installed CEMS and existing CEMS that have previously demonstrated conformance with Performance Specification 2 requirements and completed initial performance evaluations. Section 52.45(d) includes requirements to complete an initial 30-day compliance test within 90 days of installing pollution control equipment. The rule does not specify if the test must be complete prior to May 1, 2026 ozone season or by some later date. It also does not state whether this requirement applies only to newly installed CEMS, or if existing CEMS would also need to conduct this initial performance test.

B. EPA Should Have Included the Cost of NO_x CEMS in its Regulatory Impacts Analysis

If EPA will require NO_x CEMS for industrial boilers covered by the final rule, it should add the cost of installing, operating, and maintaining CEMS to its control cost analysis and its regulatory impacts analysis. The preamble and the Regulatory Impacts Analysis state “cost estimates do not include monitoring, recordkeeping, reporting, or testing costs.”⁶⁰ The cost of installing a NO_x CEMS depends on whether the stack was designed with CEMS in mind and the distance, availability, and accessibility of suitable locations for instrument shelters, analyzer racks and related equipment. Assuming that a suitable sampling location can be identified and is accessible, the cost to program, install, and certify the NO_x CEMS could be up to \$500,000 based on recent project quotes. Ongoing operation and maintenance costs could be up to \$150,000 per year. (Note that we have not estimated costs based on EPA’s CEMS cost spreadsheet⁶¹ because it is 15 years old and does not represent current day costs.) These costs are not insignificant to forest products industry facilities.

⁵⁹ See proposed 40 CFR 52.45(e)

⁶⁰ 87 Fed. Reg. 20089 and EPA-HQ-OAR-2021-0668-0151.

⁶¹ <https://www.epa.gov/emc/emc-continuous-emission-monitoring-systems>

NO_x emissions at facilities without CEMS are typically based on published emission factors or stack test data, especially on units that are not equipped with NO_x controls.

C. AF&PA Supports EPA's Proposed 30-day Averaging Period

EPA proposed that compliance with the industrial boiler ozone season emission limits at 40 CFR 52.45(c) would be demonstrated using a 30-day averaging period. If NO_x CEMS are used as the compliance method, a 30-day averaging period is consistent with the requirements contained in 40 CFR Part 60, Subpart Db at 60.44b(i), which states "compliance with the emission limits under this section is determined on a 30-day rolling average basis." Emissions of CO and NO_x from pulp and paper boilers vary with changes in fuel and load. A longer averaging period is also appropriate when a standard applies at all times, including periods of startup, shutdown, and malfunction, as proposed at 40 CFR 52.45(e), in order to ensure achievability of the emission limits and avoid non-compliance during short transitional periods. EPA acknowledged the variability of boiler emissions in the preamble to the December 23, 2011 Boiler MACT rule by stating:

We are aware from studies of emissions over long averaging periods that long term (e.g., 30-day) average emissions for operating in compliance will have a variability of about half of that represented by the results of short term testing. Given that short term tests are representative of distinct points along a continuum of that inherent operational variability, we believe it appropriate to propose 30-day averages in order to provide a means for the source operator to account for that variability by applying a long-term average for establishing compliance.⁶²

EPA also stated that they believed more problematic control system failures would show up in a 30-day average.⁶³

If EPA does not require NO_x CEMS for compliance with the rule, we would also support a 30-day averaging period for any parameter monitoring required by the rule, as this would be consistent with the precedent EPA established in the Boiler MACT and other rules. Compliance with the emission limits in Boiler MACT is demonstrated via periodic stack testing, continuous monitoring of operating parameters, and comparison of the 30-day average operating parameter value against a site-specific operating parameter limit. That type of methodology would be appropriate if EPA finalizes ozone season NO_x emission limits for industrial boilers.

X. We Support the Comments Being Submitted by the Midwest Ozone Group

AF&PA supports the comments on this proposal being submitted by the Midwest Ozone Group (MOG). In particular, we would like to summarize several important points made in those comments.

A. EPA Should not Promulgate a FIP at this Time

⁶² 76 Fed. Reg. 80610

⁶³ *Id.*

On February 22, 2022, EPA proposed to disapprove 19 good neighbor SIP submissions. EPA is now proposing FIP requirements to address 26 states' obligations regarding interstate transport of ozone. Section 110(c) of the Clean Air Act (CAA) states that "The [EPA] Administrator shall promulgate a Federal implementation plan at any time within 2 years after the Administrator" (1) finds that a state has failed to make a required submission or that the state plan submitted "does not satisfy" the minimum criteria in Section 110(k)(1)(A), or (2) "disapproves a State implementation plan submission in whole or in part," unless the State corrects the deficiency and the Administrator approves the correction before the Administrator promulgates the plan.⁶⁴ In the event of a justified disapproval, EPA then is required to promulgate a FIP within two years unless the State corrects the deficiency before promulgation of the FIP. However, in this case, EPA issued disapprovals of SIPs at the same time as it was developing the proposed FIP. EPA has offered no explanation or basis for not electing to work with states to address any deficiencies in their SIPs. EPA was only required to approve or disapprove interstate ozone SIPs by April 30, 2022, for the states at issue, not to propose a FIP by that time. EPA should allow states to address any deficiencies in their SIPs and resubmit them for approval. States have the best knowledge about sources for which emissions reductions are available and cost effective.

B. EPA Should Consider Other Programs and Sources for NO_x Reductions

EPA has disapproved upwind state Good Neighbor Plans and proposed this FIP without consideration of the timing of the implementation of nonattainment controls by downwind states - effectively shifting the burden of additional controls to the upwind states. There are programs that will reduce NO_x emissions from sources closer to the downwind monitors at issue that are either on the way, on the books, or should be considered for implementation. EPA has specifically invited comment on whether ozone-season NO_x mitigation technologies other than those proposed should be considered as part of the FIP proposal.⁶⁵ Examples offered by EPA include the New York Department of Environmental Conservation (NYDEC) rule adopted in January 2020 that set limits on emissions from combustion turbines that operate as peaking units and grid connected municipal waste combustors. EPA states that it has not historically considered NO_x mitigation technologies for these sources in rulemakings of this kind but invites comment on their appropriateness for this rulemaking including comment on its discussion of these additional strategies in the Mitigation technical support document (TSD). EPA would have a bigger and more cost-effective impact on ozone nonattainment at the Connecticut monitors through emission reductions at these EGUs in New York, than those proposed in the FIP. It is notable that NYDEC advanced these control requirements specifically to address their impact on nonattainment monitors in Connecticut. NYDEC has also proposed to control distributed generation sources, but not until May 1, 2025. EPA should encourage states to accelerate controls for these types of sources that will have meaningful impacts on downwind monitors rather than requiring over control of

⁶⁴ 42 U.S.C. 7410(c)(1)

⁶⁵ 87 Fed. Reg. 20082

sources in upwind states far from the monitors of concern. EPA should also more fully consider strategies to reduce mobile source emissions, which are the primary cause of remaining ozone nonattainment. Additional detail is provided in the MOG comments.

C. EPA Should Consider a Different Significance Level to Identify States that are Impacting Downwind Attainment

There can be no argument with EPA's conclusion that upwind states that contribute less than 1% to a downwind nonattainment or maintenance area are not significant contributors for purposes of the Good Neighbor provisions of the Clean Air Act. We also agree with EPA's determination that emissions from Oregon do not significantly contribute to nonattainment or interference with maintenance of the NAAQS at California monitoring sites, despite meeting the 1% significance criterion.⁶⁶ However, we do not understand EPA's refusal to consider higher significance levels than 1% of the NAAQS as allowed for in its own 2018 guidance⁶⁷. As detailed in the MOG comments, the courts have determined that EPA has latitude in defining what upwind contribution amounts count as significant and the CAA includes no specifics regarding establishment of a significance level applicable to interstate transport.

EPA's use of a 1%-of-NAAQS threshold ignores the limits of the capability of the Agency's air quality modeling techniques – and of ambient monitoring – to meaningfully detect and measure ambient-air contributions at the extremely low levels represented by 1% of current or possible future NAAQS. EPA lacks a reasonable basis to conclude that a 1%-of-NAAQS threshold can be deemed to reflect a “measurable contribution” to downwind nonattainment and maintenance problems, as required by the D.C. Circuit. *Michigan*, 213 F.3d at 684 (“ . . . EPA must first establish that there is a measurable [air quality] contribution. Interstate contributions cannot be assumed out of thin air.”) (Emphasis in original). EPA has not provided any such justification or analysis for its insistence on the use of a 1% significance threshold. EPA's use of the 1%-of-NAAQS threshold is becoming even more arbitrary and unjustified as the Agency applies that low threshold to the more stringent and numerically lower 2015 ozone NAAQS. Accordingly, we object to EPA's proposal to use a 1% air quality contribution threshold approach in the current rulemaking – or in any future interstate transport rulemaking – because of the absence of a robust technical justification that the resulting numerically low thresholds reflect meaningful, and truly measurable, air quality contributions, consistent with the D.C. Circuit's directive in *Michigan*. EPA's selection of a percentage-based criterion will result in an arbitrarily changing significance value as the NAAQS is lowered over time; EPA should select a value, not a percentage.

⁶⁶ 87 Fed. Reg. 20042

⁶⁷ Three memos issued in 2018 by Peter Tsigotis to the Regional Air Directors describing the process by which upwind states could incorporate various “flexibilities” into their Good Neighbor SIPs to attain the 2015 ozone NAAQS.

In its August 31, 2018, memo,⁶⁸ EPA compared two additional ozone concentration contribution thresholds: 1 ppb and 2 ppb. The purpose of the analysis described in the memo was to determine alternate, appropriate screening thresholds for consideration in addressing Good Neighbor provisions of the Clean Air Act. Ultimately in that memo, EPA noted that a threshold of 1 ppb may be appropriate for addressing the good neighbor provision. As detailed in the MOG comments, if EPA were to raise the threshold it considers to represent a significant contribution from 0.70 ppb to a greater than 1.0 ppb limit, several states would show no contribution linkages to any downwind monitors. EPA should re-evaluate use of a 1.0 ppb threshold, especially given the large scope and cost of the rule it is proposing.

D. Problem Monitors in Connecticut, Wisconsin, and Illinois are Not Properly Addressed by EPA's Air Quality Modeling Because They Are Located at the Interface Between Land and Water

Photochemical modeling along coastlines is complex because the temperature gradients along land/water interfaces can lead to localized on-shore/off-shore flows and the photochemical model formulation spreads the emissions in a grid cell throughout the full grid volume of the cell. Studies indicate that air quality forecast models typically predict large summertime ozone abundances over water relative to land and that meteorology around Lake Michigan and the Long Island Sound is distinctly unique; both shortcomings warrant individualized attention and a finer grid resolution to best explore actual conditions. The MOG comments provide a detailed analysis of the flaws in EPA's analysis related to this issue. EPA must consider finer grid resolution modeling to adequately capture ozone formation and assess significant contribution at receptors located on complex land-water interfaces because the model evaluation shows that the model fails to adequately characterize ozone production at these monitors. EPA should not use modeling with poor performance at critical monitors to establish linkages under Step 2 of EPA's 4-step interstate transport framework.

E. The Comment Period was not Adequate to Fully Evaluate and Understand EPA's Analysis and Provide Detailed Feedback

EPA published the proposed rule on April 6, 2022 and requested comments on it no later than June 6, 2022. MOG and AF&PA submitted a request to extend the comment period on April 9, 2022, for various reasons. EPA is seeking comment on no less than 53 specific issues raised in the proposed rule, including an omnibus issue styled "Request for Comment on All Aspects of the Proposal." EPA granted a 15-day extension until June 21, 2022, but even so, 75 days is not sufficient time to analyze and develop meaningful comments on 53 different elements of this 181-page proposed rule. The proposed rule is dramatically broader in scope than previous ozone transport rules, proposes to regulate several types of industrial combustion sources never before covered,

⁶⁸ https://www.epa.gov/sites/production/files/2018-09/documents/contrib_thresholds_transport_sip_subm_2015_ozone_memo_08_31_18.pdf

and includes a request for comment on what other sources should be included, forcing industry to evaluate almost 200 supporting documents in the docket and develop extensive comments on both what EPA has done and why EPA shouldn't cover even more emissions units.

AF&PA sent various questions to EPA after the proposal was published in the Federal Register in an attempt to understand the analysis that led to the proposed coverage of pulp and paper mill boilers and EPA posted additional information to the docket on April 27, 2022, three weeks after it opened, to aid us in understanding exactly what industrial sources it evaluated. Although EPA granted a 15-day extension, it is still not enough time to review and understand all of the information provided in the docket, especially when some of the information in the docketed memos does not match information presented in the preamble, and the preamble discussion does not always comport with what ended up in the proposed regulatory language. For example, reading the Non-EGU Screening Assessment Memo⁶⁹ and the Regulatory Impact Analysis⁷⁰ might lead one to believe that only 25 pulp and paper boilers are impacted by the rule, when clearly there are more because the methodology used in the screening analysis to identify "impactful boilers" with opportunity for ostensibly cost-effective reductions does not line up with EPA's proposed regulatory applicability language.

Because of the significant differences between the proposed rule language and EPA's discussion and explanation in the preamble and supporting background documents, we simply don't know how to effectively comment on this proposal. We are left with the decision of whether to assume that EPA intended to adopt regulatory criteria that align with the impacts and benefits analyses in the supporting documents and discussed in the preamble and focus our comments on closing gaps in the proposed regulatory language, or alternatively to assume that EPA intended to cover all boilers regardless of configuration or fuel type and focus our comments on the significant flaws in the control technology feasibility, efficacy, and cost estimates. These substantive gaps and inconsistencies prevent us from being able to provide meaningful comments on many aspects of this proposed rulemaking. For these reasons, EPA must address these issues, publish a re-proposed rule, and provide adequate time for public comment.

XI. Summary

In summary, the evaluation we have been able to perform in the limited amount of time available on the AQAT, NOx control assumptions, and costs shows that EPA has based its proposed requirements for pulp and paper mill boilers on information of low quality and a rushed analysis that contains many flaws. The proposed ozone season emissions limits for pulp and paper mill boilers are not supported, constitute over control, and would require a huge investment for a

⁶⁹ EPA-HQ-OAR-2021-0668-0150

⁷⁰ EPA-HQ-OAR-2021-0668-0151

downwind impact that is not measurable. EPA should not finalize ozone season requirements for pulp and paper mill boilers in this rule.

DECLARATION OF PAUL NOE

Paul Noe declares, pursuant to 28 U.S.C. § 1746, as follows:

1. I am the Vice President of Public Policy for the American Forest & Paper Association (“AF&PA”). I have extensive regulatory, legislative, and technical experience, including in environmental regulation, regulatory reform, renewable energy, chemicals and product stewardship, workplace health and safety and sustainability. This includes decades of experience working on Clean Air Act regulations, and specifically working on and testifying before the United States Senate Committee on Environment and Public Works on the United States Environmental Protection Agency’s (“EPA”) Good Neighbor Plan.

2. I provide this declaration to demonstrate the need for a stay of the EPA Good Neighbor Plan. The purpose of this declaration is to state that this regulation will have irreparable impacts on the operations of forest products manufacturers that AF&PA represents. This declaration is based on my personal knowledge of facts and analysis conducted by AF&PA staff, consultants, and myself.

A. AF&PA’s Organizational Mission

3. AF&PA represents manufactures of nearly 87% of the pulp, paper, paper-based packaging, and tissue products made in the United States. Our forest products industry employs 925,000 skilled workers and produces 5% of our nation’s GDP.

4. Our members and their products support both sustainability and the American workforce. AF&PA's sustainability initiative – Better Practices, Better Planet 2030 – is one of the most extensive quantifiable sets of sustainable goals for a U.S. manufacturing industry. This is only one example of our members' proactive dedication to the long-term success of our industry, our communities, and our planet.

5. Many of AF&PA's 2020 sustainability goals have been met. We reduced greenhouse gas emissions 24.1% during 2005-2020. We improved purchased energy efficiency by 13.3%. In 2020, renewable bioenergy provided, on average, about 64% of member facility energy needs. As a whole, the paper industry has cut its nitrogen oxides ("NO_x") emissions in half since 2000. NO_x reduction is the very goal of the Good Neighbor Plan. AF&PA is proud of these achievements and our status as a leader in environmental stewardship, particularly on the renewable energy and emissions reduction fronts.

6. AF&PA has a history of providing data to EPA to inform the rulemaking process and to support a constructive relationship with the Agency and achievable, cost-effective regulations. Our industry benefits where EPA crafts achievable, cost-effective emissions reduction rules, based on best available evidence and that can be successfully implemented even where compliance is costly.

B. Overview of the Good Neighbor Plan

7. On March 15, 2023, EPA issued its final Good Neighbor Plan, which requires significant reductions in NO_x from powerplants and other industrial

facilities. The emissions reductions are to happen quickly to align with deadlines for twenty-three states to meet Clean Air Act “Good Neighbor” requirements by reducing pollution that significantly contributes to problems attaining and maintaining the 2015 Ozone National Ambient Air Quality Standards (“NAAQS”) in downwind states.

8. The NO_x emissions reductions which apply to non-EGUs such as paper mills will begin in 2026, to meet the August 3, 2027, attainment date for areas classified as Serious Nonattainment.

9. The NO_x emissions reductions will come from several sources, including pulp, paper, and paperboard mills. This implicates members of AF&PA.

C. AF&PA’s Concerns Regarding the Good Neighbor Plan

10. One of the foremost concerns for AF&PA membership is EPA’s inclusion of paper boilers in the rule despite them being far above the cost threshold. EPA’s proposed rule set out a \$7,500/ton of NO_x threshold in its screening analysis, indicating that would be a reasonable cost to include a source category. EPA erroneously estimated that the cost for including paper boilers would be \$3,800 per ton, but the actual cost of reductions would be about ten times higher, at about \$37,900 per ton, while the amount of emissions reductions would be about 25% lower than EPA estimated. In the final rule, EPA acknowledges that the cost-effectiveness is far higher than projected in the proposed rule -- \$33,900/ton during the ozone season, an amount more than eight times the original estimation and much more costly than threshold stated in the proposed rule. However, instead of removing industries that exceeded the

cost threshold, EPA fundamentally changed its rationale and procedure for determining whether an industry should be in or out of the final rule -- without providing notice or an opportunity for public comment. Under the rule, an industry may only rebut its inclusion through a vague promise of a case-by-case alternative emission limit – but even then only if a facility can prove “technical impossibility” or “extreme economic hardship” sufficient to appease EPA. This undermines the Congressionally delegated authority for EPA to consider costs as a factor in designing such rules. In the case of paper boilers, the exorbitant costs should have met even this impossibility/hardship standard, yet paper boilers remain included in the final rule. EPA’s failure to properly estimate and then reasonably consider costs on source categories, such as those represented by AF&PA, and neglecting AF&PA’s comments, has created an unfair process, which in turn has produced an erroneous and unsustainable rule. Further, the heavy, undue burden of compliance with this rule requires investment and planning immediately given the three-year compliance timeframe.

11. Similarly, AF&PA questions EPA’s conclusion as to the significance of emissions by our membership. After EPA included the pulp and paper industry in the proposed rule because paper boilers as a group were modeled to “significantly impact” eleven ozone non-attainment areas with more than 0.01 parts per billion contributions (relative to the seventy parts per billion NAAQS), AF&PA provided EPA corrections, utilizing EPA’s own modeling tools, to the boiler inventory. The corrections illustrated that only nine areas at most were impacted, and only eight

areas if the boilers not currently in operation were excluded. We were very concerned that the inventory was erroneous and did not represent the emissions characteristics of the pulp and paper mill boilers in the covered states. Our data shows that paper boilers no longer qualify as a Tier 2 non-electric generating unit (“EGU”) source category, and therefore should not be included in the rule at all. However, EPA abandoned the criteria for inclusion in the rule without notice or an opportunity for public comment —instead lumping together all non-EGU sources and finding a total average non-EGU impact of 0.19 parts per billion. EPA claims this average is significant, despite it making up only 0.27% of the seventy parts per billion ozone NAAQS. Our analysis does not show that the inclusion of paper mill boilers in the final rule would result in a single non-attainment area coming into attainment. While AF&PA acknowledges the discretion that EPA has to reduce emissions, this instance appears to be an unreasonable exercise of moving the administrative goalposts, with extremely high costs and at best de minimis benefits, and even environmental disbenefits from increased greenhouse gas emissions, as explained below.

12. EPA has made unrealistic control technology assumptions by making over-generalizations in its Fact Sheet that the rule utilizes “proven, cost-effective control technologies,” which is untrue for paper mill boilers. To my knowledge, EPA’s determination that Selective Catalyst Reduction (“SCR”) is the Reasonably Available Control Technology (“RACT”) that should be implemented across industries does not hold up for paper boilers. SCR has never been required for

existing paper mill boilers in the U.S. because it is not cost-effective operationally for NOx reduction¹: it would require reheating of flue gas to even function, additional space for installation, and it would likely result in higher greenhouse gas emissions (120,000 metric tons of carbon dioxide annually, the equivalent of over 26,000 gasoline powered automobiles) with a net present value cost of over a billion of dollars.² Implementation of this technology at our member facilities would undermine AF&PA's sustainability program and our goal to reduce our greenhouse gas emissions by 50% by 2030 by requiring us to increase our carbon footprint, rather than decreasing it. The tremendous costs of the rule place a major financial burden on source categories, without any certainty that it will achieve the goals it is intended for.

13. Further, EPA did not thoughtfully consider alternative approaches by industry stakeholders. AF&PA attempted to have an open dialogue about its concerns with the rule with EPA by offering substantial data and comments regarding many of the points above. EPA failed to reach out to AF&PA to understand our findings or analysis, especially as they relate to the economic infeasibility of SCR. EPA did not respond to our key concerns, including EPA's misclassification of units that would result in paper boilers contribution to non-attainment areas being below the proposed threshold. AF&PA strives for open communication and transparency and

¹ I am aware that a few new gas fired boilers have installed SCR when it is designed into the combustion system when built for areas with significant air quality issues.

² AF&PA's June 2022 comments calculated 166,000 metric tons of carbon dioxide which is equivalent to 35,000 gas powered vehicles. We adjusted the numbers based on the scope of the final rule which excludes paper mills in Wisconsin and Minnesota.

wishes for EPA to have access to the most updated and best available information to support its rulemaking process. While AF&PA has sought to collaborate and cooperate wherever possible, the rulemaking process seemed rushed and broke down, and EPA has failed to fulfill its obligations to the public in the creation of the Good Neighbor Plan.

14. Each of these concerns shows that this broken regulation will continue to result in irreparable harm to AF&PA, our members, and their employees. It is important to note that this harm will not be felt in 2026, rather, the high costs and planning of compliance with the Good Neighbor Plan requires our members to act now in 2023. Additionally, EPA has provided no mechanism for cost recovery for the installation of SCR should this regulation be found invalid at a later date. Irreparable harm has already occurred. A stay is required to prevent more harm to facilities subject to the Good Neighbor Plan, including AF&PA members.

Conclusion

15. AF&PA has asked EPA to reconsider the Good Neighbor Plan as it relates to the forest products industry. It is clear that the rule was rushed based on the faulty cost estimations, unexplained changes in source category inclusion rationale -- without an opportunity for public notice and comment, and the blanket statements about SCR that simply are not applicable to the AF&PA membership. It is unfair, unjust, arbitrary, and unlawful. A regulation under these circumstances warrants a

court's review. Further, in this instance, a stay is necessary to prevent further irreparable harm to paper mill boilers and other source categories subject to this broken regulation.

16. The rule is a threat to both U.S. manufacturing and the American worker. EPA should carefully consider the potential unintended outcomes that will negatively impact high-paying, high-skilled union jobs across the country. We have a shared goal: the implementation of sustainable regulation that addresses environmental, health, and economic concerns. A goal as important as this requires bipartisan work and most importantly, time. The Good Neighbor Plan rulemaking process felt rushed, and the men and women working in American manufacturing will pay the price. A stay of the Good Neighbor Plan is necessary to keep and create more sustainable manufacturing jobs in the United States. These jobs are critical, now more than ever, for our country's future success. If the rule is not stayed, our members will find it difficult to maintain the same levels of productivity while budgeting for the exorbitant costs of installation of SCR technology to meet the 2026 attainment date. Further, AF&PA members, employees, families, and communities will bear the burden of significant hardship whilst managing periods of unemployment and decreased economic growth leading up to and following the 2026 attainment date.

17. For the reasons set forth above, AF&PA supports a stay of the Good Neighbor Plan until the Court has opportunity to determine its legality to avoid imminent irreparable harm.

I, Paul Noe, declare under penalty of perjury under the laws of the United States of America that the foregoing is true and correct. Executed on July 14, 2023.



Paul R. Noe
Vice President of Public Policy
American Forest & Paper Association

DECLARATION OF AMERICAN IRON AND STEEL INSTITUTE

Paul Balserek declares, pursuant to 28 U.S.C. § 1746, as follows:

1. I am Vice President for Environment of the American Iron and Steel Institute (“AISI”). Prior to my current role, I served as the deputy director of the regulatory policy division of in the Administrator’s Office at the U.S. Environmental Protection Agency and in several other positions at the agency for over 26 years. I hold a Master of Science in Biology from George Mason University and a Bachelor of Science in Civil Engineering from Virginia Polytechnic Institute and State University.

2. AISI serves as the voice of the American steel industry with membership comprised of steel producing companies, including integrated and electric arc furnace steelmakers, and associate members who are suppliers to or customers of the steel industry. The steel industry’s steel products serve a key role as a material of choice for infrastructure improvements and other applications, important to our nation.

3. AISI is a member of the Midwest Ozone Group (“MOG”). MOG is an affiliation of companies and associations that draws upon its collective resources to seek solutions to the development of legally and technically sound air quality programs that may impact on their facilities, their employees, their communities, their contractors, and the consumers of their products.

4. I am providing this declaration in support of a stay of the United States Environmental Protection Agency’s (“EPA”) Federal Implementation Plan (FIP) regulation known as the Good Neighbor Plan for the 2015 Ozone National Ambient

Air Quality Standards (“Good Neighbor FIP”), published in the Federal Register on June 5, 2023 at 88 Fed. Reg. 36654. This regulation will have immediate and significant irreparable impacts on the operations of facilities owned and operated by members of the AISI if a stay is not granted and compliance dates are not similarly stayed pending a final judicial decision on the merits. This declaration is based on my personal knowledge of facts and analysis conducted by AISI.

5. AISI membership is impacted by the regulated industrial source sector for Iron and Steel Mills addressed by the Good Neighbor FIP. Iron and Steel Mills located and operated within states that are located in Alabama, Arizona, Arkansas, Colorado, Florida, Georgia, Illinois, Indiana, Iowa, Kentucky, Michigan, Minnesota, Mississippi, Missouri, Nebraska, New Jersey, New York, North Carolina, Ohio, Oklahoma, Oregon, Pennsylvania, South Carolina, Tennessee, Texas, Utah, Virginia, Washington, West Virginia, Wisconsin. Disapproval of a SIP is a legal prerequisite for EPA to impose a FIP. To date, we have operations 13 states that have not been granted or have not sought a stay of the SIP disapprovals as follows: Illinois, Indiana, Michigan, New Jersey, New York, Ohio, Oklahoma, Pennsylvania, Utah, Virginia, Washington, West Virginia, and Wisconsin.

6. The Good Neighbor FIP implements controls on reheat furnaces in the form of Low NOx Burners, technology that was not proposed in the rule and therefore not assessed by AISI regulated members relative to cost effectiveness prior to promulgation and implementation. Reheat furnace 40% NOx reductions plans must be

in place by August 2024 allowing inadequate time for engineering, procurement, installation and operation or for EPA approval of such.

7. The Good Neighbor FIP arbitrarily requires NO_x CEMs on boilers rated at 250 MMBtu/hr or greater unless initial performance test indicates the unit's emission rate is 70% or less below the applicable NO_x limits of 0.08 lb/MMBtu which percentage is established resulting in arbitrary and capricious over controls.

8. If the Good Neighbor FIP is not stayed and proceeds forward on the schedule that EPA intends, the FIP will require AISI industrial regulated boilers and furnaces to comply with unit-specific NO_x limits during the ozone season (from May 1 – September 30 annually) starting in 2026, accordingly regulated sources will need to immediately make a decision in 2023 on whether to upgrade or retire reheat furnaces and natural gas fired boilers, in advance of a decision by the Court on the merits of the FIP.

6. The preliminarily estimated capital costs to achieve the 40% reduction required will be at least \$3 to 5 million dollars per reheat furnace as illustrated by recent Reasonably Available Control Technology analyses.

7. Without a stay, and with the tight timeframe established in the FIP, which requires compliance with the new limits by May 2026, AISI members have been forced to begin the process of initiating engineering, design and procurement of the equipment projected to be required as described above, in order for the furnace or boiler modifications or shutdowns to be completed in time to comply with the new

requirements by May 2026. All of this capital, time, and other resources would be unnecessary if the Good Neighbor FIP is ultimately determined on the merits to be unlawful as petitioners state in their petition(s) for review.

8. For the reasons set forth above, AISI supports a stay of the Good Neighbor FIP to avoid immediate, significant, and irreparable harm pending a final decision by the Court on the merits regarding its lawfulness under applicable statutes.

I, Paul Balsarak, declare under penalty of perjury under the laws of the United States of America that the foregoing is true and correct. Executed on July 19, 2023.



Paul Balsarak
Vice President, Environment
American Iron and Steel Institute

No. 23-1183 (consolidated with 23-1157)

**IN THE UNITED STATES COURT OF APPEALS
FOR THE DISTRICT OF COLUMBIA CIRCUIT**

State of Ohio, et al.,
Petitioners,

v.

Environmental Protection Agency and Michael S. Regan, in his official capacity,
as Administrator of the U.S. Environmental Protection Agency
Respondents.

On Petition for Review of Action by the U.S. Environmental Protection Agency

**DECLARATION OF GEORGE J. FARAH IN SUPPORT OF
PETITIONERS' MOTION FOR STAY PENDING REVIEW AND FOR
AN ADMINISTRATIVE STAY**

I, George J. Farah, hereby make the following declaration pursuant to 28 U.S.C. § 1746:

1. I am the Vice President, Utility Services for FirstEnergy Service Company which provides various services to Monongahela Power Company, a West Virginia electric utility operating subsidiary of FirstEnergy Corp. (hereinafter, "Mon Power" or "FirstEnergy"). Mon Power owns and operates two coal-fired power stations in West Virginia and is headquartered in Fairmont, West Virginia. I have been employed by FirstEnergy or its predecessors since May 1986. I earned a Bachelor of Science degree in Mechanical Engineering from the University of Pittsburgh in 1986. In 2007 I earned a Master's degree in Business Administration from Indiana University of Pennsylvania. I have worked in various corporate and

power station roles for over 37 years. I am over the age of 18 and am competent to testify concerning the matters in this declaration based on my personal knowledge, my experience with Mon Power, and information provided to me by Mon Power personnel.

2. I am providing this declaration in support of the State of West Virginia's motion for a stay Federal Implementation Plan, or "FIP," published by the U.S. Environmental Protection Agency ("EPA") as a Final Rule titled "Federal 'Good Neighbor Plan' for the 2015 Ozone National Ambient Air Quality Standards," 88 Fed. Reg. 36,654 (June 5, 2023). I am aware that EPA published the FIP following EPA's disapproval of the West Virginia State Implementation Plan ("SIP") addressing interstate transport for the 2015 ozone National Ambient Air Quality Standards ("NAAQS") on February 13, 2023. *See* Air Plan Disapprovals; Interstate Transport of Air Pollution for the 2015 8-Hour Ozone National Ambient Air Quality Standards, Final Rule, 88 Fed. Reg. 9336 (Feb. 13, 2023). EPA's FIP will result in imminent, irreparable harm to the State and its citizens

3. In the operation of its business, Mon Power generates electric power at its power stations for the benefit of its and Potomac Edison's approximately 550,000 customers located in West Virginia. As Vice President of Utility Services for FirstEnergy Service Corporation, I am charged with overseeing engineering,

environmental, fuel and reagent procurement, and other duties for Mon Power's generating plants.

4. Mon Power owns and/or operates over 3,000 megawatts of installed generation capacity in West Virginia; employs approximately 2,000 full-time employees; and spends approximately \$1.5 billion annually in the form of taxes, fuel, maintenance, and other operating and capital expenditures, and its impact on gross state product and gross domestic product is substantial.

5. I am aware that the State of West Virginia, through the West Virginia Department of Environmental Protection ("WVDEP"), submitted to EPA a proposed SIP to comply with the interstate transport requirements for the 2015 8-hour ozone National Ambient Air Quality Standards ("NAAQS").

6. Mon Power engaged with and provided comments to the WVDEP regarding the proposed SIP during West Virginia's public comment period from September 7, 2018 to October 8, 2018.

7. On February 22, 2022, EPA announced its proposed disapproval of West Virginia's SIP for noncompliance with the CAA's "Good Neighbor" provision. *See* Air Plan Disapproval; West Virginia; Interstate Transport of Air Pollution for the 2015 8-Hour Ozone National Ambient Air Quality Standards, 87 Fed. Reg. 9516. On April 25, 2022, Mon Power, by virtue of its membership in the

Midwest Ozone Group, submitted comments on the proposed rule disapproving West Virginia's SIP. *See* EPA Docket R03-OAR-2021-0873-0007.

8. I am aware that, on April 6, 2022, EPA issued another proposed rule that would impose a FIP for West Virginia and 26 other states whose SIPs did not receive EPA's approval. *See* Federal Implementation Plan Addressing Regional Ozone Transport for the 2015 Ozone National Ambient Air Quality Standard, 87 Fed. Reg. 20,036. On June 21, 2022, Mon Power, by virtue of its membership in the Midwest Ozone Group, submitted comments on the proposed rule to implement the FIP. *See* EPA Docket HQ-OAR-2021-668-0323.

9. I am also aware that as a result of the EPA's disapproval of West Virginia's SIP on February 13, 2023, the agency promulgated a final rule on June 5, 2023, imposing a FIP on West Virginia and 22 other states with an effective date of August 4, 2023. *See* Federal "Good Neighbor Plan" for the 2015 Ozone National Ambient Air Quality Standards, 88 Fed. Reg. 36,654.

10. The FIP will cause immediate, detrimental, and irreversible harm to Mon Power as well as its affiliate, The Potomac Edison Company, who contracts for all of its power supply requirements for its West Virginia customers from Mon Power. Our other customers, suppliers, vendors, and contractors will be negatively impacted as well. When vendors are impacted, communities and local business are

impacted as well as local and state governments and their respective employees, vendors, and communities in which they operate.

11. The annual allocations of seasonal NOx allowances have decreased and are expected to decrease more in the future. In 2022, Mon Power had to purchase thousands of seasonal NOx allowances from the market in order to be able to operate its Fort Martin Power Station. The prices for these allowances increased dramatically to over \$40,000 per credit causing an additional cost burden on our customers of over \$50 million for just the five month period of May through September 2022.

12. Options at Fort Martin for compliance with the FIP are still under review and consideration, but all compliance options result in additional costs which would be borne by our customers. Options include upgrades of existing combustion systems, enhancements to the selective non-catalytic reduction (“SnCR”) equipment, lowering generation output, and/or installing selective catalytic reduction (“SCR”) equipment that EPA assumes in the FIP will be installed at many power stations by 2026. The impacts could range into the hundreds of millions of dollars in capital compliance and construction costs.


13. Additionally, the cost of reagents, if either the option of enhancing SnCR or installing SCR equipment is chosen, would be in the millions of dollars per year, and there are additional Operation & Maintenance costs annually estimated for

equipment and operations. Power generation will be reduced and/or lost at times in order to perform installation of and periodic maintenance of the equipment, which is difficult to estimate but can be substantial. Finally, additional capital is typically required in future years to replace equipment and catalysts.

14. Regardless of which option is chosen for compliance, rates would increase to West Virginia customers as a result. Rate increase estimates could be in the range of \$50-\$85 million per year depending on the option chosen for compliance.

15. Absent a stay, Mon Power will need to take imminent action in order to comply with the FIP. In order to comply with the FIP beginning in 2026, when state budgets reduce substantially based on the assumption that SCRs are installed on many existing units, Mon Power will need to make a decision in the near future regarding installation of equipment for compliance. Without a stay of the FIP, Mon Power must incur engineering, design, procurement, and construction expenditures on an option that may ultimately not be necessary if the FIP is held unlawful. Issuance of a stay would avoid wasteful expenditures on rule compliance that may be altered and thereby would avoid unnecessary customer rate increases.

I declare under penalty of perjury that the foregoing is true and correct to the best of my knowledge. Executed on this 18th day of July, 2023, in Fairmont, West Virginia.



George J. Farah

Vice President

FirstEnergy Service Company

Monongahela Power Company

DECLARATION OF JEFF MAULE

Jeff Maule declares, pursuant to 28 U.S.C. § 1746, as follows:

1. I am the Environmental Director for Billerud N.A. I have worked for this organization for 33 years in different capacities that deal with environmental compliance.

2. I am providing this declaration in support of a stay of the United States Environmental Protection Agency's ("EPA") Federal Implementation Plan (FIP) regulation known as the Good Neighbor Plan for the 2015 Ozone National Ambient Air Quality Standards ("Good Neighbor FIP"), published in the Federal Register on June 5, 2023 at 88 Fed. Reg. 36654. This regulation will have immediate and significant irreparable impacts on the operations of facilities owned and operated by Billerud North America (Billerud) if a stay is not granted and compliance dates are not similarly stayed pending a final judicial decision on the merits. This declaration is based on my personal knowledge of facts and analysis conducted by my company and myself.

3. Our operations fall within the regulated industrial source sector for Pulp, Paper and Paperboard Mills addressed by the Good Neighbor FIP. Billerud has boilers located and operated within Michigan, a state that is targeted by the Good Neighbor FIP and for which there is not a stay of the rule. Disapproval of a SIP is a legal prerequisite for EPA to impose a FIP.

4. If the Good Neighbor FIP is not stayed and proceeds forward on the schedule that EPA intends in the final rule, the FIP will require industrial sources

such as Billerud's fossil fuel-fired boilers to comply with unit-specific NO_x limits during the ozone season (from May 1 – September 30 annually) starting in 2026. This would impact two natural gas boilers at Billerud's two Michigan pulp and paper mills – Escanaba and Quinnesec.

6. With respect to the impacted boiler at Billerud Escanaba it appears based on current information that such units will require installation of new controls to operate and achieve the emissions requirements. This will require boiler modifications and the installation of new, low NO_x burners for Escanaba's No. 8 Boiler. The estimated capital costs for this compliance strategy will be \$5 million. These additional costs will significantly increase the operating costs of the boiler in question and thereby harm Billerud's competitiveness in the marketplace.

7. Without a stay, and with the tight timeframe established in the FIP, which requires compliance with the new limits by May 2026, Billerud has begun the process of initiating engineering, design and procurement planning for the equipment projected to be required as described above, in order for the boiler modifications to be completed in time to comply with the new requirements by May 2026. All of this capital, time, and other resources would be unnecessary if the Good Neighbor FIP is ultimately determined on the merits to be unlawful as petitioners state in their petition(s) for review.

8. For the reasons set forth above, Billerud North America supports a stay of the Good Neighbor FIP to avoid immediate, significant, and irreparable harm pending a final decision by the Court on the merits regarding its lawfulness under applicable statutes.

I, Jeff Maule, declare under penalty of perjury under the laws of the United States of America that the foregoing is true and correct. Executed on July 19, 2023.



Jeff Maule
Environmental Director
Billerud N.A.

DECLARATION OF JOHN PIOTROWSKI

I am John Piotrowski, the Vice President of Environmental Operations for Packaging Corporation of America (“PCA”). My business address is 1 North Field Court, Lake Forest, IL 60045. I have worked in Operations for PCA since 1995 and have served in my current position since May of 2019. In my roles at PCA, I have obtained experience and knowledge regarding the costs of installing emission controls, as well as the ongoing costs of operating and maintaining emission controls for the equipment involved in pulp and paper production, such as the industrial boilers regulated under 40 C.F.R. Part 63, Subpart DDDDD and 40 C.F.R. Part 60 New Source Performance Standards, Subparts D and Db, including the costs of testing, monitoring, recordkeeping, and compliance reporting pursuant to federal and state regulations.

1. I am providing this declaration in support of Petitioner’s Motion for Stay of the United States Environmental Protection Agency’s (“EPA”) Federal Implementation Plan (FIP) regulation known as the Good Neighbor Plan for the 2015 Ozone National Ambient Air Quality Standards (“Good Neighbor FIP”), published in the Federal Register on June 5, 2023 at 88 Fed. Reg. 36654. This regulation will have immediate and significant irreparable impacts on the operations of facilities owned and operated by PCA if a stay is not granted and compliance dates are not similarly stayed

pending a final judicial decision on the merits. This declaration is based on my personal knowledge of facts and analysis conducted by my company and myself.

2. Our operations fall within the regulated industrial source sector for Pulp, Paper and Paperboard Mills addressed by the Good Neighbor FIP. PCA has boilers located and operated within states that are targeted by the Good Neighbor FIP, namely Louisiana and Michigan. Disapproval of a SIP is a legal prerequisite for EPA to impose a FIP.

3. PCA's boilers that are subject to the Good Neighbor FIP and that will need to undergo testing, engineering, design, and capital spending, include the following units:

Boiler No. 1, Filer City, Michigan, 240 MMBtu/Hr., Constructed 1950

Boiler No. 3, DeRidder, Louisiana, 228 MMBtu/Hr., Constructed 1986

4. If the Good Neighbor FIP is not stayed and proceeds forward on the schedule that EPA intends in the final rule, the FIP will require industrial sources such as PCA's fossil fuel-fired boilers to comply with unit-specific NO_x limits during the ozone season (from May 1 – September 30 annually) starting in 2026. Both the No. 1 Boiler at Filer City Michigan and the No. 3 Boiler at DeRidder Louisiana would be impacted by emissions reductions requirements.

5. With respect to the No. 1 Boiler at PCA's Filer City Michigan paper mill, it appears (based on currently available information) that the Good Neighbor FIP will require installation of a NO_x continuous emissions monitoring system (CEMS) as well

as new controls to achieve the rule's emissions reduction requirements. Boiler No. 1 add-on control includes retrofitting the boiler with flue-gas recirculation (FGR) to augment existing low NO_x burner (LNB) technology. If NO_x reductions from the combination of FGR and LNB are insufficient to achieve compliance, the installation of SNCR or SCR technology will also be required. The estimated capital costs for this compliance strategy will be in the range of \$4 to 5.5 million. Additionally, absent the requested stay, extensive stack testing and engineering must be initiated within the next several months at the Filer City Michigan paper mill in order to timely meet the current compliance deadline.

With respect to the No. 3 Boiler at PCA's DeRidder Louisiana paper mill, it appears (based on currently available information) that PCA will need to conduct extensive stack testing under various representative conditions in order to determine statistical averages and emissions variability and assess the sufficiency of compliance margins necessary to meet the requirements of the Good Neighbor FIP rule. If diagnostic testing finds that compliance margins are too marginal to reliably achieve compliance, installation of SNCR or SCR technology will be required. Additionally, installation of NO_x CEMS equipment is mandatory under the rule. The estimated capital costs for this compliance strategy will be in the range of \$4.5 to 6 million for the boiler.


6. Collectively, for the impacted boilers located in the states of Michigan and Louisiana, for which a durable legal stay has not been granted, PCA estimates that the total projected capital costs related to the FIP's new requirements will be \$8.5 to \$11.5

million. These additional costs will significantly increase the operating costs at these boilers in question and thereby harm their competitiveness in the marketplace. Given the uncertainty regarding the compliance timeline, and pending the outcome of various state and federal legal challenges, advance spending of capital for source testing and engineering design represents irreparable harm to the company.

7. Without a stay, and with the tight timeframe established in the FIP, which requires compliance with the new limits by May 2026, PCA will soon need to initiate comprehensive testing, engineering, design and procurement of the equipment projected to be required as described above, in order for the boiler modifications to be completed in time to comply with the new requirements by May 2026. Such modifications will impact the market competitiveness of these facilities, impacting future revenues that will be lost without a stay. The expenditures of capital, time, and other resources would be unnecessary if the Good Neighbor FIP is ultimately determined on the merits to be unlawful as petitioners state in their petition(s) for review.

8. For the reasons set forth above, PCA supports a stay of the Good Neighbor FIP to avoid immediate, significant, and irreparable harm pending a final decision by the Court on the merits regarding its lawfulness under applicable statutes.

I, John Piotrowski, declare under penalty of perjury under the laws of the United States of America, that the foregoing is true and correct. Executed on July 19, 2023.

A handwritten signature in blue ink that reads "John Piotrowski". The signature is written in a cursive style with a large, looped initial "J".

John Piotrowski
Vice President – Environmental Operations
Packaging Corporation of America

DECLARATION OF MASSIMO TOSO

I, Massimo Toso, hereby declare as follows:

1. I am the Chief Executive Officer of the Buzzi Unicem USA (“BUU”). As Chief Executive Officer, I oversee BUU activities related to cement manufacturing. I provide this declaration in support of the motion to stay filed by the Portland Cement Association (and others) of the “Federal ‘Good Neighbor Plan’ for the 2015 Ozone National Ambient Air Quality Standards” (“Federal Plan” or the “Rule”). This Rule will have impacts on several BUU plants, including those that operate in Indiana, Missouri, Pennsylvania, and Texas, but most significantly, the Rule will have highly damaging and irreparable impacts on BUU’s Pryor, Oklahoma (“BUU–Pryor”) cement plant operations, as described below.
2. This declaration is based on my personal knowledge of facts and analysis conducted by my staff.
3. I have been responsible for overseeing BUU’s activities related to cement manufacturing and operations since I joined the company in 2014. Previous to my current role, I was the Chief Operations Officer for Buzzi Unicem in Italy.
4. I am submitting this declaration because the Environmental Protection Agency’s (“EPA”) promulgation of the Rule addressing interstate transport obligations under the 2015 ozone National Ambient Air Quality Standard (“NAAQS”) will likely result in imminent, irreparable harm to BUU-Pryor and may threaten the viability of the plant.

BUU OPERATIONS

5. BUU-Pryor plant has been manufacturing and distributing bulk cement in Northeastern Oklahoma since 1961.
6. Currently, BUU-Pryor manufactures all-purpose Type I/II low alkali cement, Type II Portland-limestone cement, Class H oil well cement and a specialty calcium sulphoaluminate cement (“CSA cement”). The company can only currently produce the CSA cement using the type of production equipment at Pryor (long-dry kiln). BUU – Pryor produces and distributes approximately five hundred thousand tons of cement annually and is the only producer of 100% made in the USA CSA cement.

7. BUU-Pryor directly employs approximately 125 people at its plant.
8. BUU-Pryor is composed of three cement kilns—Kilns 1 and 2 are similarly sized long dry rotary kilns and were commissioned in 1960 and 1962, respectively. Kiln 3, which is the largest of the three kilns, is also a long dry rotary kiln; it was commissioned in 1980.
9. BUU-Pryor typically plans one major outage per kiln each year, each spanning 2-3 weeks, to address routine maintenance issues. During these outages, BUU-Pryor employs up to 75 contractors to perform this labor.
10. Much of the capital infrastructure at BUU-Pryor's operations was installed during the early 1960's and has been in operation since. The age of the kilns along with the long dry technology result in high maintenance and operating costs compared to more modern kiln technology. This technology also requires large amounts of fuel, electrical power, hydrated lime, and numerous other commodity inputs in the manufacturing process. As a result, BUU-Pryor's production costs are significantly higher than remaining BUU plant profile, at nearly two times the average of the company's other more modern facilities.
11. BUU-Pryor's already exceedingly high production costs mean that additional substantial capital and operating expenditures may significantly alter the viability of the facility and potentially jeopardize the continued operation of the plant.

ADDITIONAL CONTROL REQUIREMENTS UNDER EPA'S FEDERAL PLAN

12. EPA's Rule will impose emissions limits for the first time on certain industrial sources, including cement kilns, in 20 covered states under the Clean Air Act's interstate transport provision.
13. These industrial sources will be required to comply with unit-specific NO_x limits during the 2026 ozone season (from May 1 – September 30 annually).
14. Oklahoma is one of the states covered by this Federal Plan.
15. Starting May 1, 2026, BUU-Pryor will be required to meet emission limits of 3.0 pounds of NO_x per ton clinker on all three cement kilns during the ozone season.
16. If EPA's Federal Plan is implemented, it will have a dramatic impact on BUU-Pryor. Following well-documented control efficiency assumptions, BUU does not believe that BUU-Pryor will be able to meet the Rule's emission limits by installing selective non-catalytic reduction ("SNCR") controls.
17. The only other available technology that may be capable of achieving the Rule's limits at BUU-Pryor is selective catalytic reduction ("SCR") technology.

18. However, based on limited application of SCR in the cement industry and known technical issues, it is unknown if SCR will be capable of meeting the Rule's NOx emission limits.
19. Per EPA in its Cost Control Manual, "SCRs have not seen widespread use in the U.S. cement industry mainly due to industry concerns regarding potential problems caused by high-dust levels and catalyst deactivation by high SO₃ concentrations from pyritic sulfur found in the raw materials used by U.S. cement plants." Air Pollution Cost Control Manual, Section 4, Chapter 2, Selective Catalytic Reduction, NOx Controls, at 2-3, 2-4 (Jun. 2019), https://www.epa.gov/sites/default/files/2017-12/documents/scrcostmanualchapter7thedition_2016revisions2017.pdf.
20. Further, according to EPA, only two cement kilns in the United States currently use SCR. *See* Memorandum from Brian Storey, OAQPS, to Mark Bahner & Mike Laney, RTI International, *Technology Review for the Portland Cement Production Source Category*, EPA-HQ-OAR-2016-0442, at 4 (Jun. 5, 2017).
21. The feasibility of installing SCR depends on kiln- and facility-specific considerations, such as dust loading, sulfur content of raw materials, the risk of catalyst poisoning, levels of ammonia, production rates, and production capacity.
22. BUU-Pryor produces three types of clinker, including two specialty clinkers. This is a rather unique situation and introduces an even greater amount of variability in raw materials over a typical cement plant. This additional variability could substantially affect the expected performance of the SCR.
23. Thus, BUU remains uncertain as to whether BUU-Pryor can meet the Rule's NOx limits for long dry kilns even with the installation of SCR.

TIMELINE OF CONTROL INSTALLATION

24. Even if SCR controls could achieve the emissions limits required under the Federal Plan, it would be extremely costly to install them in the best of circumstances, much less on a tight timeline and in a setting like a cement plant.
25. SCR installation requires extensive preparation, including an initial feasibility study, an engineering and technical analysis, an environmental assessment and permitting process, equipment procurement, and construction.
26. If BUU determines that SCR is feasible to control NOx from both an economic and technological standpoint, the company would need to begin incurring unrecoverable costs immediately. A conservative estimate for designing, procuring and installing an SCR system is 156 weeks, at minimum. This means the earliest possible project completion is early August 2026. This date already extends beyond BUU-Pryor's compliance date under the Federal Plan of May 1, 2026.

27. Generally, process evaluation and engineering analysis requires 6-9 months, after identifying and selecting a qualified vendor. Environmental permitting may take another 6 months, possibly longer due to the Oklahoma Department of Environmental Quality ODEQ requiring 45 days for EPA review for all air permits.
28. Under normal circumstances, equipment procurement and installation are estimated to require approximately 18 months.
29. Under this typical timeline, BUU would have needed to begin engineering work and incurring unrecoverable costs by May 1, 2023, before the Rule was even finalized (on June 5, 2023), in order to have had any chance of meeting the Federal Plan's emissions limits by May 1, 2026.
30. However, market uncertainties have created additional pressures that will impact the timing for SCR installation. EPA's Final Rule disapproving state plans for 20 states and subjecting these states to the Federal Plan's requirements will put many industrial sources in the same position of needing to procure SCR systems at the same time.
31. Current supply chain and labor shortage issues have exacerbated these circumstances further. As EPA has acknowledged, "labor shortages, supply shortages, or other circumstances beyond the control of source owner/operators" may impact the timing for SCR installation. *See Federal "Good Neighbor Plan" for the 2015 Ozone National Ambient Air Quality Standards*, EPA-HQ-OAR-2021-0668, at 359 (Mar. 15, 2023), https://www.epa.gov/system/files/documents/2023-03/FRL%208670-02-OAR_Good%20Neighbor_Final_20230314_Signature_ADMIN%20%281%29.pdf.
32. Due to these market uncertainties, BUU finds itself in the position of having to start the SCR feasibility study and design process immediately and incur significant costs in doing so if it has any hope of having the controls in place by EPA's May 1, 2026 deadline.

COST OF CONTROL INSTALLATION

33. BUU based cost estimates to install SCR on the average of two relatively recent publically available SCR cost estimates. Based on those estimates, BUU determined that it will cost approximately \$20 million per kiln to install SCR systems on both Kilns 1 and 2, for a total cost of \$40 million. The SCR system for Kiln 3 is estimated to cost another \$30 million. This brings the total capital costs to at least \$70 million.
34. In addition to capital costs, BUU estimates that SCR will require over \$1.24 million in operating and maintenance costs annually, based on additional ammonia and power needs, catalyst replacement requirements, and estimated maintenance.
35. Using EPA's Cost Control Manual, and assuming an SCR has an expected useful life of 20

years, the annual expenditure due to installing three SCR systems is estimated to be \$8.7 million. Accordingly, BUU's annual expenditure related to SCR (*i.e.*, its annualized capital costs plus operating and maintenance costs) would amount to nearly \$2.5 million each for Kilns 1 and 2 annually, and another \$3.7 million for Kiln 3 over this 20-year period. These additional costs would impact the average annual operating costs by nearly 17%.

36. Given BUU-Pryor's already exceeding high operating cost, and the additional cost the SCR will impose, BUU will need to evaluate the economic viability of installing SCR and continuing to operate. BUU cannot say with certainty what the results of the evaluation will be, but the preliminary available data indicates a real chance that BUU may decide to cease operations rather than proceed with the SCR installation.
37. As detailed above, BUU must begin its process evaluation and engineering analysis immediately, in order to assess whether installing SCR is economically feasible within the deadline set by the Federal Plan.
38. Further, as detailed above, BUU must make a final, irrevocable decision on whether to cease operations or begin the SCR installation process in the next 12-18 months in order to comply with EPA's May 1, 2026 compliance date.

CONCLUSION

39. For the reasons described above, BUU-Pryor faces imminent and substantial harm from the Federal Plan.

I, Massimo Toso, declare under penalty of perjury that the foregoing are true and correct. Executed on this 1st day of August, 2023.



Massimo Toso
President & CEO

D. C. CIRCUIT
UNITED STATES COURT OF APPEALS

WABASH VALLEY POWER ASSOCIATION, INC. d/b/a
WABASH VALLEY POWER ALLIANCE,

Petitioner,

v.

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY, et al.,

Respondents.

DECLARATION SUPPORTING A MOTION TO STAY
THE U.S. ENVIRONMENTAL PROTECTION AGENCY'S
"GOOD NEIGHBOR PLAN" FOR THE 2015 OZONE
NATIONAL AMBIENT AIR QUALITY STANDARDS

I, Jason Marshall hereby declares as follows:

I am the Executive Vice President, Risk, Compliance & Regulatory Affairs at Wabash Valley Power Association, Inc. d/b/a Wabash Valley Power Alliance (WVPA), and I have been employed by WVPA since April 2017.

WVPA is a not-for-profit generation and transmission electric cooperative with its headquarters in Indianapolis, Indiana. WVPA is owned by twenty-three members, all of whom are rural electric cooperatives that use the energy and services WVPA provides. These member-owners supply the energy provided by WVPA to more than 330,000 homes, businesses, farms, and schools across 50 counties in Indiana, 30 counties in Illinois and four counties in Missouri, impacting more than a million people. WVPA's purpose is to generate electricity and transmit energy to 23 member-owner cooperatives that distribute it to retail, end use members.

As a not-for-profit member-owned electric cooperative, WVPA does not have any shareholders to help shoulder the financial burden of this rule. As a result, the full financial burden will be borne by the consumer at the end of the line, many of whom cannot afford another cost increase, especially in times of high inflation, rising interest rates, and recessionary pressures.

WVPA and its members serve some of the poorest and most economically challenged areas in the states of Indiana, Illinois, and Missouri. The per capita income of 32 counties that our cooperative members serve is below \$30,000, and the poverty rate for 13 of these counties for children under 18 years-old exceeds 20 percent. For the average end-user of each of WVPA's 23 distribution cooperatives, the primary concern is affordability, followed by reliability, and then sustainability.

WVPA shares all of these concerns, specifically with respect to the impacts of the Good Neighbor Plan on our members.

WVPA solely and jointly owns electric transmission facilities and electric generation plants located in Indiana, Illinois, and Missouri for the benefit of its members. These plants use coal, pipeline natural gas, and landfill gas as fuels, and the plants provide a variety of services, including base-load, intermediate (cycling), and peak-load production. WVPA also purchases the energy output of several solar and wind farms and operates a community solar program for the benefit of our members. The coal-fired and natural gas-fired plants are subject to the Good Neighbor Plan.

The grid needs more dispatchable generation due to the transformation of the generation fleet to non-dispatchable resources which is evidenced by the increasing reliance on the diminishing existing fleet of dispatchable resources and this rule will further jeopardize reliability by decreasing the availability of these dispatchable resources. Because of the transformation of the generating fleet to more renewables and distributed energy resources due to many factors—such as environmental compliance and retirement of coal-fired base loaded electric generator units (EGUs)—our generating resources, along with those of other utilities, are already being stretched to operate above their design parameters. With the increased demand due to additional beneficial electrification (i.e. replacing direct fossil fuel use with electricity in a way that minimizes overall emissions, for example in electric vehicles, home heating and industrial processes), this transformation has created grid congestion, capacity shortages, and a significant increase in starts and run-time for many peaking gas-powered EGUs. This increase in operating time and starts changes these peaking units into “cycling” generating units causing them to need even more emission allowances. For 2023, WVPA owns a peaking gas-powered EGU that is on course to have a capacity factor of 40 percent for the year. For a peaking unit, this is a very high-capacity factor in the industry. The Good Neighbor Rule jeopardizes the ability of WVPA to run this unit as frequently as is required to support reliability.

This increase in operational hours for WVPA's units means they will need additional NOx allowances under the Good Neighbor Plan. The Final Rule impacts our ability to acquire these additional allowances. Market prices are already rising, and reasonable financial transactions are becoming scarce. Our economically challenged end-users will be harmed, and we have a significant concern that sufficient allowances will not be available in the market to meet the load required by our demand.

First, due to court decisions finding EPA's underlying actions likely unlawful for a number of jurisdictions, a significant number of states have been removed from the allowance market, at least in the immediate future. Allowances associated with those states are now unavailable to anyone needing to comply with EPA's rule. The reduction of supply will significantly impact the price of allowances, and the demand for these allowances will increase as our EGUs see an increase in operating hours. EGUs that cannot acquire allowances to cover their emissions will be held liable for continuing to provide power, as they are required to do.¹ All of this jeopardizes reliability, and none of it was considered during EPA's rulemaking process.

Second, the Final Rule imposes new restrictions on banked allowances. This limits an EGU's ability to respond to any increase in the need for allowances due to the increase in operational hours, completely neglecting possible future demand for dispatchable generation. Without this

¹ 2022 OWS-MISO Survey Results, <https://cdm.comenergy.org/20230714/OWS-MISO-MISO-Survey-Results-Presentation629607.pdf>, Slide


safety margin, WVPA cannot be sure that it will not need to reduce generating hours to meet emission restrictions (or the absence of necessary allowances).

The industry does not have confidence in the enforcement of regulations being “relaxed” if there is a reliability need for generation. In the North American Electric Reliability Corporation’s (“NERC”) 2023 Summer Reliability Assessment, NERC states “[c]oal and natural-gas-fired generators in states affected by the Good Neighbor Plan will likely meet tighter emission restrictions primarily by limiting hours of operation in this first year of implementation rather than through adding emission control equipment.” This raises serious public health concerns. When the country is experiencing hotter than normal summer temperatures or a very cold winter, people need to be able to count on their HVAC working to keep them safe and not experience health issues or even death² from being extremely hot or cold.

WVPA is committed to providing environmentally friendly, affordable, reliable power to our members and is an early adopter of solar and wind power. In fact, WVPA’s exposure to coal is down to 35 percent, the lowest in its operating region. Despite these actions, the Final Rule impacts our low-cost and reliability needs of our end-users. Our residential customers will suffer real consequences if their electrical bill increases due to the costs of this Final Rule. Some customers may have to reduce their operations or family expenses to cover their electrical expense, significantly impacting their quality of life and their safety. For our business and commercial customers, an increase in their electrical bill could prevent them from expanding their businesses, which means less economic development and fewer jobs.

Because WVPA operates in two markets, PJM and MISO, we are concerned that if WVPA and other utilities have to curtail the operation of peaking resources due to the unavailability of emission allowances, there will not be enough energy supply to meet load. MISO is already forecasting a capacity shortage in Planning Years 2025 and 2026.³ We know from Winter Storm Uri and other similar events that people can die under these types of conditions, and these conditions are most likely to occur during the ozone seasons, when the Good Neighbor Plan will restrict WVPA’s operations.

WVPA will suffer clear harm from this rule. Our customers will suffer harm. A stay will provide real support for our mission to serve our members and to care for our communities.


Jason Marshall

Dated: July 25, 2023

² The Texas Department of State Health Services (DSHS) attributed the deaths of 246 people to Winter Storm Uri. <https://www.kvue.com/article/news/local/winter-storm-uri-report-deaths-texas-austin/269-bb023e53-5b35-492c-9baf-270c32a79cbd#:~:text=AUSTIN%2C%20Texas%20%E2%80%94%20The%20Texas%20Department,a%20result%20of%20the%20storm.>

³ 2023OMS-MISO Survey Results, <https://cdn.misoenergy.org/20230714%20OMS%20MISO%20Survey%20Results%20Presentation629607.pdf>, Slide 6

D. C. CIRCUIT
UNITED STATES COURT OF APPEALS

OHIO VALLEY ELECTRIC CORPORATION (OVEC)

Petitioner,

v.

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY, et al.,

Respondents.

DECLARATION SUPPORTING MOTION TO STAY THE FINAL "GOOD NEIGHBOR" OZONE
SEASON TRANSPORT RULE ISSUED BY THE U.S. ENVIRONMENTAL PROTECTION
AGENCY

Declaration of Harm

- 1. My name is Thomas Alban, Vice President of Generation for Buckeye Power, Inc. (“Buckeye”). I have worked at Buckeye for 19 years. I am currently responsible for power generation and all supporting functions at Buckeye’s generating facilities. I am also the Designated Representative for managing emissions allowance accounts for Buckeye’s generating facilities.**
- 2. This Declaration of Harm is based on my personal knowledge and experience, formed after reasonable inquiry and due diligence.**

Buckeye Power, Inc.

- 3. Buckeye is an Ohio nonprofit corporation operating on a cooperative basis. Buckeye is owned and governed by its twenty-five member-owners, which includes all of the electric distribution cooperatives engaged in the sale of electricity within the state of Ohio.**
- 4. Buckeye provides wholesale electric service to its members, who in turn distribute electricity to their retail, end use consumers.**
- 5. The retail service area of Buckeye’s members covers a substantial part of the land area of the state of Ohio and extends into portions of 77 of Ohio’s 88 counties.**
- 6. Buckeye’s members currently serve approximately 400,000 consumers, around 91 percent of whom are classified as residential (farm and non-farm), while the remaining 9 percent are classified as commercial, industrial, or other.**

- 7. Buckeye owns and operates Units 1, 2 and 3 at Cardinal Plant located near Brilliant, Ohio, with nominal generating capacities of 600 MW, 600 MW and 630 MW, respectively. Buckeye purchased Unit 1 from AEP Generation Resources Inc. in August 2022. Cardinal is a baseload, coal-fired electric generating facility.**
- 8. Buckeye owns and operates the Greenville Station located near Greenville, Ohio, with a nominal generating capacity of 200 MW. The Greenville Station is a natural gas-fired peaking generating facility. It consists of four units of 50 MW each.**
- 9. Buckeye owns and operates the Robert P. Mone Station located near Convoy, Ohio, with a nominal generating capacity of 510 MW. The Mone Station is a natural gas-fired peaking generating facility. It consists of three units of 170 MW each.**
- 10. Buckeye's wholly-owned subsidiary, Buckeye Power Generating, LLC ("BPG"), owns an 18 percent interest in the Ohio Valley Electric Corporation ("OVEC") and has the right to 18 percent of the output of OVEC's two base-load, coal-fired electric generating facilities, the Kyger Creek and Clifty Creek facilities. Buckeye has the right to BPG's entitlement to the output of the Kyger Creek and Clifty Creek facilities.**
- 11. Buckeye's generation assets provide critical support to the reliable operation of the electric grid.**
- 12. Buckeye is fully committed to environmental stewardship. In recent years, Buckeye has spent nearly \$1 billion installing state of the art, high-performing selective catalytic reduction ("SCR") and jet bubbling reactor flue gas**

desulfurization (“JBR FGD”) equipment on its coal-fired units at Cardinal. In 2003, SCR equipment was placed in commercial operation on Units 2 and 3 at a total capital cost of approximately \$185 million. In 2008, construction of JBR FGD equipment was completed and placed into service on Unit 2. The capital cost of the equipment was approximately \$266 million. In 2012, JBR FGD equipment was installed on Unit 3 at a capital cost of approximately \$489 million. These recent capital investments represent approximately 50 percent of Buckeye’s total investment at Cardinal Plant to date.

13. Buckeye Power has also spent significant time and money ensuring compliance with Mercury Air Toxics Standards (“MATS”) requirements.
14. The Environmental Protection Agency’s (“EPA”) Federal Implementation Plan (“FIP”) for the 2015 Ozone National Ambient Air Quality Standard (“NAAQS”) will irreparably harm and cause injury to Buckeye, its investments, its 25 member-owners, and the 400,000 consumers they serve in the state of Ohio.

Immediate Impact of FIP on Buckeye

15. Ohio submitted the ozone state implementation plan (“SIP”) to the US EPA on September 28, 2018.
16. The US EPA published the final denial of Ohio’s SIP on February 22, 2022.
17. The US EPA’s FIP, called the Good Neighbor Plan, was finalized on March 15, 2023, and published on June 5, 2023. The US EPA has stated that the FIP will take effect during the summer of 2023.

- 18. Stays of SIP disapprovals have been issued by the Fifth, Sixth, Eighth, and Ninth Circuit Courts for the following states: Texas, Louisiana, Mississippi, Kentucky, Arkansas, Missouri, Minnesota and Nevada.**
- 19. US EPA issued an Interim Rule as a response to the judicial stays of SIP disapproval actions. This Interim Rule removes the above-mentioned states from the Good Neighbor Plan trading program, and significantly decreases the number of trading options available to the remaining states subject to the FIP. All aspects of the Good Neighbor Plan rulemaking, including modeling, emissions impacts, bank recalibration, and dynamic budgeting, were developed assuming participation from all 22 states subject to the FIP.**
- 20. The FIP will have substantial and immediate impacts on the operations of Buckeye's generation fleet and will have substantial and immediate cost and reliability impacts to Buckeye and its members.**
- 21. The Federal rule requires almost immediate reductions in NO_x emissions from generating units. A daily backstop of 0.14 lb/mmBtu for NO_x will go into effect starting in 2024 for coal-fired units equipped with SCRs. OVEC, of which Buckeye is an owner and relies upon to meet its members' generation needs, will be immediately impacted by these reductions. OVEC will have to make significant investments or limit generation output due to the punitive daily emission rate. These impacts to the Clifty Creek Station are further detailed in OVEC's Declaration of Harm.**
- 22. The Good Neighbor Plan also implements a new emissions allowance program with an aggressive timeline that ultimately punishes utilities for emitting lower levels of NO_x. If the generating unit has a lower season-long emission rate or a temporary lower capacity factor (*i.e.*, lower output which**

could be caused by an outage or simply less demand for a limited period), the unit is at risk of receiving a lower number of allowances in the future.

23. Utilities have been able to accumulate allowances over the years by efficient NOx control, purchasing from the market, or banking allowances in times of lower generation output. Beginning immediately with the implementation of the Good Neighbor Plan, the electric generation industry can no longer count on these factors for its operations, as the Good Neighbor Plan allows EPA to confiscate allowances if banks exceed the 21% assurance level cap. The Good Neighbor Plan will thus require immediate changes to generating plant operations.

24. The immediate implementation of the Good Neighbor Plan leaves utilities with very little time to develop power supply plans and environmental compliance plans to meet the new rule. This Rule will result in immediate and significant cost increases that will ultimately be borne by Ohio consumers.

25. The Good Neighbor Plan will also have an immediate impact on reliability, as it will require owners of generation assets that are necessary to maintain stable electric supply, including Buckeye, to either reduce their output or retire the assets early.

26. Units that may be called on for reliability (*i.e.* to prevent blackouts on the electric grid) will have to take punitive allowance penalties under the Good Neighbor Plan into consideration. On December 23 and 24, 2022, PJM Interconnection, LLC (“PJM”) (the regional transmission organization in which Buckeye and all of Ohio operates) experienced significant demand on the electric system. PJM had to take extreme measures to ensure sufficient

generation was available to prevent a black out on the grid that could have affected 13 states and the District of Columbia. During this event, PJM instituted a Maximum Generation Action directing generation resources, including Buckeye's resources, to operate above their normal maximum output levels. With many coal plants and other baseload generation already expected to retire, reliability issues will increase and similar situations are expected year-round – including during ozone season (May-September). As allowance quantities significantly decrease over the years, generating units like Buckeye's may be required to run by the applicable regional transmission organization in situations where no allowances are available. Despite the US EPA and US Department of Energy signing a Memorandum of Understanding on March 9, 2023, to help ensure environmental regulations will not impact grid reliability, the Good Neighbor Plan provides no relief of allowance penalties for emergency situations as described above.

27. The Good Neighbor Plan will likely force many baseload generation assets to retire and does not give utilities adequate time to assess and build replacement generation. Due to significant rulemakings at the US EPA in addition to this FIP, retirement dates for coal-fired units are being expedited.

28. As electrification increases and a reliable electric grid becomes increasingly critical, the Good Neighbor Plan places grid reliability at immediate risk.

Conclusion

29. The US EPA's FIP, and its selective implementation, during ongoing legal challenges irreparably harms Buckeye, its member cooperatives, and consumers in Ohio.

DECLARATION OF HARM

Comes now the Affiant, Jerry Purvis, in his capacity as Vice President of Environmental Affairs for East Kentucky Power Cooperative, Inc. ("EKPC"), and after being duly sworn, does hereby swear and affirm as follows:

- 1. My name is Jerry Purvis. I am the Vice President of Environmental Affairs for EKPC. Prior to being involved in the environmental area, I worked in various capacities in EKPC's electric production team for 29 years.**
- 2. This Declaration of Harm is based upon my personal knowledge and experience, formed after reasonable inquiry and due diligence.**

EKPC and its Service Areas

- 3. EKPC is a generation and transmission rural electric cooperative corporation with its headquarters near Winchester, Kentucky.**
- 4. EKPC is owned, operated, and governed by sixteen owner-members, all of whom are rural electric cooperative corporations that use the energy and services EKPC provides.**
- 5. These owner-member cooperatives supply the energy provided by EKPC to approximately 1.1 million customers located in 520,000 homes, farms, and businesses across 87 counties in Kentucky.**
- 6. EKPC's purpose is to generate electricity and transmit it to 16 owner-member cooperatives that distribute it to retail, end use consumers.**
- 7. The end users of electricity in EKPC's service territory live in rural areas with some of the lowest economic demographics in the United States. Having grown up and worked in some of these areas, I am aware that many families, literally, are faced with a regular choice between food, electricity and medicine.**

8. **Of the eastern Kentucky counties that EKPC’s owner-member cooperatives serve, 40 counties experience persistent poverty, as reported by the USDA.**
9. **Baseload electric generation resources power the region, and Kentucky as a whole, and sustain the grid with reliable access to energy. A balanced generation mix is essential to maintaining a safe and reliable grid.**
10. **As a rural electric cooperative, EKPC’s principal source of capital is the Rural Utilities Service, an agency within the United States Department of Agriculture.**
11. **EKPC is bound by its mission to ensure it can provide reliable power to its end users in all circumstances, even in the face of challenging weather events.**
12. **Coal-fired generation assets continue to be important safety nets during these times – as they provide proven, dependable and available power generation.**
13. **EKPC and its 16 owner-member cooperatives have invested over \$1.6 Billion dollars of a \$3.5 Billion dollar asset company to protect human health and the environment to reduce environmental impacts at its fossil generation facilities.**
14. **For instance, EKPC previously installed state-of-the art emissions control technology to control NOx, SO2, and PM emissions at its Spurlock and Cooper Stations near Maysville and Somerset, Kentucky, respectively.**
15. **Those efforts extend to significantly lower SOx (95%), NOx (78%), PM (over 98%), and CO₂ (5.5%) since 2005.**
16. **Since 2015, EKPC has devoted substantial resources to ensure compliance with stringent Mercury Air Toxics (“MATS”) requirements.**
17. **Many of the units in EKPC’s coal-fired fleet have qualified for low emitting electric generating unit (“EGU”) status for HCl.**

18. **Despite these investments in best available control technology, the Environmental Protection Agency’s (“EPA”) Federal Implementation Plan (“FIP”) for the 2015 Ozone National Ambient Air Quality Standard (“NAAQS”) (the “Final Rule” or the “FIP”) will irreparably harm and cause injury to EKPC’s fleet, EKPC’s investments, EKPC’s owner-members and the 1.1 million Kentuckians they serve.**

Immediate Impacts of the FIP on EKPC

19. **Prior to the Kentucky ozone state implementation plan (“SIP”) denial in January 2023, EKPC worked with Kentucky Energy and Environment Cabinet (“EEC”) as part of the Commonwealth’s outreach efforts to stakeholders.**

20. **Kentucky submitted its SIP to EPA on January 11, 2019.**

21. **EPA subsequently denied the SIP, basing its disapproval on what it claimed was new information and modeling that was not available when the plan was submitted in 2019.**

22. **This information was not made available to Kentucky or EKPC.**

23. **Neither Kentucky nor EKPC was given the opportunity to review either the EPA’s new information or the modeling used by EPA to disapprove the SIP, nor was Kentucky given an opportunity to revise its SIP based on the new information and modeling.**

24. **EKPC, utilities in the state, and Kentucky relied on EPA’s guidance in submitting the SIP.**

25. **Now, EPA leaves Kentucky and its stakeholders in a quandary facing economic development, electrification of infrastructure while federal regulations diminish our abilities to generate safe, reliable and affordable service to Kentuckians.**

26. **EPA released the pre-publication Final Rule on March 15, 2023. EPA has stated that the FIP will take effect this summer of 2023. The Final Rule will substantially impact the operations of EKPC coal-fired and gas-fired units immediately.**

27. **The Final Rule applies during the high electricity load summer season, which coincides with the ozone season (May-September) each year.**
28. **The Final Rule effectively diminishes the fossil fleet capacity by ratcheting down EPA's NOx allocations to the states, which flow down to utilities, such as EKPC.**
29. **These allocations are not sufficient to allow EKPC to respond to increased electricity demand projected in Kentucky during a peak summer season.**
30. **The Final Rule also sets an aggressive time frame that is difficult for the power sector and our system, in particular, to implement quickly. New state and unit-level NOx allocations begin in ozone season 2023 leaving virtually no time for regional transmission organizations (RTOs) and generators to plan and execute for new 2023 summer time operational constraints and dispatch changes. The lack of adequate time to react to the new requirements of the Final Rule places the reliability of the bulk power grid in jeopardy.**
31. **Moreover, utilities must make immediate decisions about whether or not to sell, trade, or use allocations to bolster power supply, and possibly reset power supply obligations with RTOs for 2023.**
32. **While 2023, 2024 and 2025 NOx allocations are known, the Final Rule leaves little time to develop power supply planning models and environmental compliance plans to transition, invest, permit, build, and retire as prudent utilities.**
33. **The Final Rule's environmental compliance costs will create a significant risk of energy reliability and economic hardship for Kentucky citizens.**
34. **The Final Rule's requirements are likely to raise rates to the end user due to the increased costs of NOx allocation pricing, premature asset retirements, environmental controls projects, and the likely potential of unhedged power purchases.**

35. It is **my** opinion the Final Rule will also have **negative financial repercussions** on states, the nationwide utility sector – including EKPC, end users, small businesses, EGUs and non-EGUs.
36. The Final Rule does not incorporate any **meaningful flexibility** to address more stringent unit budgets for 2023 or future projected retirements.
37. During the 2023 year, the Final Rule provides **no mechanism** to address demand increases or generation needs due to severe weather events.
38. Likewise, there is no reliability “safety valve” to address reliability concerns, which generators, including EKPC, urged EPA to incorporate in public comments.
39. Utilities, including EKPC, must immediately (in 2023) decide whether to undertake NOx control upgrade projects for specific units for which the Rule dictates the installation of controls by 2026-2027.
40. EKPC’s Cooper Unit 1 must conduct an expensive NOx control upgrade project or retire. EKPC is forced to make a decision concerning this unit almost immediately to meet the Final Rule’s time frames.
41. RTOs and power generators have no time to devise a diligent plan for 2023 and for the overall Rule’s glide path to ensure compliance while securing grid reliability and public safety.
42. Each of these immediate impacts from the Final Rule are harmful to EKPC, its owner-members and the end-use retail customers they serve throughout the Commonwealth of Kentucky.

Future Impacts Beyond 2023

43. Customer demand for power is projected to increase, both nationally and within EKPC's service area.
44. For instance, the National Renewable Energy Laboratory, which is affiliated with the United States Department of Energy, models nationwide increases in future electricity demand due to the growing United States population and economy.
45. I am aware that Kentucky had a record year in 2021 for economic investment and job creation with 264 private-sector new-location and expansion projects committed to invest over \$11.2 billion and create over 18,100 full-time jobs.
46. EKPC's economic development team projects continued economic growth in Kentucky, which will increase the need for electricity.
47. The Final Rule, however, reduces the flexibility necessary to operate to meet this demand, especially for smaller generation fleets such as EKPC's units.
48. Previously, EKPC could rely on banked surplus NOx allowances to react to increased demands. However, generator allowance banks will be "recalibrated" annually beginning in 2024. The recalibration removes allowances from banks, which minimizes the allowance head room to safely operate and generate power in 2024, 2025 and beyond.
49. EKPC's owner members and cooperatives find themselves sacrificing hard-earned allowances from NOx overcontrol but receive no benefit from those efforts and even receive fewer allocations under this FIP. This means that prudent decisions to reduce NOx emissions in prior years are actually being punished by the Final Rule.
50. The Final Rule also creates uncertainty for EKPC and other utilities because the Rule does not present the unit-specific allocations for 2026, 2027, 2028, 2029 and beyond but

provides a new calculus of rebalancing, ratcheting downward based on each year's operating heat input and declining States allocations.

- 51. There is vagueness associated with the new allocation process. The lack of allocation budget specificity combined with the dwindling number of state-wide allocations will assuredly create confusion and controversies in future years. Fewer allowances must be allocated across a statewide fleet without regard to the unique operating profiles of individual units.**
- 52. EKPC's coal fleet is projected to have even fewer unit-level allocations beginning in 2030. The Final Rule provides for the removal of pre-set budget floors and will apply dynamic budgeting to squeeze any remaining gap between operation, based on heat input, and allowance allocations.**
- 53. Concurrently, the Final Rule will recalibrate banks tighter such that EKPC and other generators may only keep a maximum of 10.5% based on an EPA calculation of a preset percentage of the sum of the state emissions budgets for each control period.**
- 54. The Final Rule does not give utilities adequate time to build replacement generation for retiring coal-fired assets, which is crucial to maintain reliability.**

Conclusion

- 55. To summarize, EPA's rejection of the SIP collaboratively developed by EKPC, EEC and others and the EPA's adoption of the Final Rule in the SIP's place, has imposed a severe injury to EKPC's RUS-funded investments.**
- 56. The FIP also unnecessarily disrupts the process for enforcing environmental regulations through state agencies, which has proven itself to result in massive reductions in SO_x, NO_x and PM over the past two decades.**

57. The EPA's reliance upon data and modeling not available to EEC and EKPC is incompatible with past precedent and upends the existing process for enforcing the Clean Air Act.

58. All this irreparably and immediately harms EKPC, its owner-members and their end-use retail customers.

59. Further, the Affiant sayeth naught.

Subscribed, sworn to and acknowledged by me, Jerry Purvis, in my capacity as Vice President of Environmental Affairs for East Kentucky Power Cooperative, Inc. on this ___ day of May, 2023.

Jerry Purvis
Jerry Purvis, Vice President of
Environmental Affairs of East Kentucky
Power Cooperative, Inc.

COMMONWEALTH OF KENTUCKY)
COUNTY OF CLARK)

This will certify that the foregoing Declaration of Harm was subscribed, sworn to and acknowledged before me, the NOTARY PUBLIC, by Jerry Purvis, in his capacity as Vice President of Environmental Affairs for East Kentucky Power Cooperative, Inc. on this 19 day of May, 2023

Lisa G. Stanfield
NOTARY PUBLIC

Commission No. 11141

Commission Expires: 8/15/2024

8/15/24



DECLARATION OF BRYANT T. CHAMPION

Bryant T. Champion, pursuant to 28 U.S.C. §1746, states as follows:

1. I am the Senior Vice President of Environmental Affairs and Product Safety for Georgia-Pacific LLC (“Georgia-Pacific” or “GP”). I have been employed at Georgia-Pacific for over 39 years, primarily in environmental management positions at increasing levels of responsibility over the years, and have been in my current position for approximately 15 years. I have extensive regulatory, legislative, and technical experience, including in environmental regulation and policy, regulatory reform, and product stewardship, and manage a staff of environmental professionals who are expert in various environmental disciplines including Clean Air Act regulations and air permitting.

2. I am providing this declaration to demonstrate the need for a stay of the United States Environmental Protection Agency’s (“EPA”) Federal Implementation Plan (FIP) regulation known as the Good Neighbor Plan for the 2015 Ozone National Ambient Air Quality Standards (“Good Neighbor Plan” or “Good Neighbor FIP”), published in the Federal Register on June 5, 2023 at 88 Fed. Reg. 36654. This regulation will have immediate and significant irreparable impacts on the operations of certain Georgia-Pacific facilities if it is not stayed pending a final judicial decision on the merits. This declaration is based on my personal knowledge of facts and analysis conducted by GP staff and myself.

3. Georgia-Pacific's businesses include the manufacturing and sale of pulp, paper, paper-based packaging, and tissue products at 21 pulp and paper mills in the United States. GP has pulp and/or paper mills in several of the states that would be affected by the Good Neighbor FIP, including Arkansas, Mississippi, and Oklahoma. I am focusing primarily on Oklahoma in this Declaration because the 8th Circuit Court of Appeals has stayed EPA's disapproval of the Good Neighbor State Implementation Plans in Arkansas and Mississippi, effectively also staying EPA's implementation of the Good Neighbor FIP in those states, as disapproval of a SIP is a legal prerequisite for EPA to impose a FIP.

4. GP's mills operate biomass-fired boilers and fossil fuel-fired boilers to provide all of the required steam, and at least some of the electricity, needed to power the manufacturing processes and otherwise operate the facilities. At GP's non-integrated paper mill in Muskogee, Oklahoma, GP operates 4 fossil fuel-fired boilers to serve these functions, two of them fueled by coal and natural gas and two of them fueled by natural gas only.

5. If the Good Neighbor FIP is not stayed and proceeds forward on the schedule that EPA intends in the final rule, the FIP will require industrial sources such as GP's fossil fuel-fired boilers to comply with unit-specific NO_x limits during the ozone season (from May 1 – September 30 annually) starting in 2026. For coal-fired units such as the two coal-fired boilers at GP's Muskogee, OK mill, the NO_x limit applicable to coal burning will be 0.20 lbs NO_x/MMBtu. For natural gas-

fired boilers such as the other two boilers at GP's Muskogee, OK mill, the new NOx limit will be 0.08 lbs NOx/MMBtu.

6. With respect to the four fossil fuel-fired boilers at GP's Muskogee Mill, one is a relatively new natural gas-fired unit which should be able to comply with the new NOx limit without any significant new capital investments. That is not the case for the other three. It appears likely based on current information that these three boilers would not be able to comply with the new limits using existing equipment and NOx controls. For each of the two coal-fired units, GP would likely have to eliminate coal burning entirely and, to comply with the new limit applicable for natural gas combustion, replace the existing burners with new low-NOx burners and install new flue gas recirculation (FGR) technology, or replace the boilers altogether. For the other, existing natural gas-fired boiler, the Mill would likely need to replace the existing burners with new low-NOx burners and install FGR. GP currently estimates that the capital costs of these compliance options for the three boilers at Muskogee alone would be between \$25MM and \$90MM.

7. Even though this declaration focuses on Oklahoma, as EPA's disapproval of the Oklahoma Good Neighbor SIP has not been stayed to date, GP also has fossil fuel-fired boilers in Mississippi and Arkansas that would be subject to the lower NOx limits imposed by the FIP. For those three natural gas-fired units, modifications similar to those described above for the natural gas-fired boiler at

Muskogee would likely be required in order for GP to ensure compliance. Based on GP's current estimates, the capital costs for these boiler modifications would be between \$20 MM and \$35 MM.

8. Altogether, for the three affected mills in Arkansas, Mississippi and Oklahoma, GP projects total estimated capital costs of \$45 to \$125 MM to comply with the FIP's new requirements. These additional costs will significantly increase the operating costs at the three mills in question and thereby harm their competitiveness in the marketplace, negatively impacting future revenue.

9. Without a stay, and with the tight timeframe established in the FIP, which requires compliance with the new limits by May 2026, GP believes it would need to start contracting immediately for engineering, design and procurement of the equipment projected to be required as described above, in order for the boiler modifications to be completed in time to comply with the new requirements by May 2026. All of this capital, time, and other resources would be unnecessary if the Good Neighbor FIP is ultimately determined on the merits to be unlawful as petitioners state in their petition(s) for review.

10. For the reasons set forth above, Georgia-Pacific supports a stay of the Good Neighbor FIP to avoid immediate, significant, and irreparable harm pending a final decision by the Court on the merits regarding its lawfulness under applicable statutes.

I, Bryant T. Champion, declare under penalty of perjury under the laws of the United States of America that the foregoing is true and correct to the best of my knowledge and belief. Executed on July 20, 2023.



Bryant T. Champion
Senior Vice President
Georgia-Pacific LLC

DECLARATION OF CHRIS F. KOTARA

Chris F. Kotara, pursuant to 28 U.S.C. § 1746, as follows:

- I am Director of Global Environmental Services at International Paper where I set company expectations related to environmental compliance and environmental performance. I direct a team of subject matter experts who support manufacturing operations to ensure ongoing environmental compliance and advance environmental improvements consistent with company sustainability goals. I have held various positions of increasing responsibility related to Manufacturing and Environmental, Health and Safety since joining the company in 1987 and have held my current position of Global Environmental Director since 2016. I graduated with a Bachelor's degree in Civil Engineering from Texas A&M University.

1. I am providing this declaration in support of a stay of the United States Environmental Protection Agency's ("EPA") Federal Implementation Plan (FIP) regulation known as the Good Neighbor Plan for the 2015 Ozone National Ambient Air Quality Standards ("Good Neighbor FIP"), published in the Federal Register on June 5, 2023 at 88 Fed. Reg. 36654. This regulation will have immediate and significant irreparable impacts on the operations of facilities owned and operated by International Paper if a stay is not granted and compliance dates are not similarly stayed pending a

final judicial decision on the merits. This declaration is based on my personal knowledge of facts and analysis conducted by my company and myself.

2. Our operations fall within the regulated industrial source sector for Pulp, Paper and Paperboard Mills addressed by the Good Neighbor FIP. International Paper has boilers located at Pulp and Paper manufacturing facilities operating in five states that are targeted by the Good Neighbor FIP, including Kentucky, Louisiana, Mississippi, Texas and Oklahoma. International Paper has two affected boilers located and operated within Oklahoma, a state that is targeted by the Good Neighbor FIP and for which there is not a stay of the rule. Disapproval of a SIP is a legal prerequisite for EPA to impose a FIP.

3. If the Good Neighbor FIP is not stayed and proceeds forward on the schedule that EPA intends in the final rule, the FIP will require industrial sources such as International Paper's fossil fuel-fired boilers to comply with unit-specific NO_x limits during the ozone season (from May 1 – September 30 annually) starting in 2026. Four natural gas fired boilers located at International Paper's mills in Mississippi, Oklahoma and Texas would be impacted by emissions reduction requirements and one natural gas fired heat recovery steam generating unit in Louisiana would be required to install a new continuous emission monitoring system.

4. Based on evaluations completed to date, installation of new or upgraded controls will be required for a natural gas/distillate fired 945 MMBtu/hr boiler at our Oklahoma mill. A second 220 MMBtu/hr natural gas fired boiler at the same

Oklahoma location will either require capital improvements to meet the emission requirements or boiler operations will need to be curtailed in order to qualify for a low use exemption from the rule. Similarly, both a 302 MMBtu/hr natural gas fired boiler at our Texas mill and a 400 MMBtu/hr natural gas fired boiler at one of our Mississippi mills will either require capital improvements or curtailed operations to qualify for exemptions. A new continuous emission monitoring system will be required at one of our Louisiana facilities. The estimated capital costs for satisfying FIP requirements for all affected sources will be between \$15 and 30 million dollars with a total annualized cost in the \$3-5 million dollar range. These additional costs will adversely affect our competitiveness in the marketplace.

5. Without a stay, and with the tight timeframe established in the FIP, which requires compliance with the new limits by May 2026, International Paper has begun the process of evaluating the cost and effectiveness of alternative compliance strategies including evaluation of supply chain, equipment lead times and project management needed to comply with the new requirements. All of these internal and external resources, including engineering study costs and project management and planning would be unnecessary if the Good Neighbor FIP is ultimately determined on the merits to be unlawful as petitioners state in their petition(s) for review.

6. For the reasons set forth above, International Paper supports a stay of the Good Neighbor FIP to avoid immediate, significant, and irreparable harm pending a

final decision by the Court on the merits regarding its lawfulness under applicable statutes.

I, Chris Kotara, declare under penalty of perjury under the laws of the United States of America that the foregoing is true and correct. Executed on July 19, 2023.



Name: Chris F. Kotara
Title: Director Global Environmental Services
Company: International Paper

**DECLARATION OF JEFFREY D. BROCK IN SUPPORT OF PETITIONER
NATIONAL MINING ASSOCIATION'S MOTION TO STAY THE FINAL
OZONE SEASON TRANSPORT RULE OF THE U.S. ENVIRONMENTAL
PROTECTION AGENCY**

I, Jeffrey D. Brock hereby declare as follows:

1. I am over eighteen (18) years of age, suffer from no disability that would preclude me from providing this declaration, and make this declaration based upon personal knowledge.
2. I am the Vice President of Business Development for Alliance Coal, LLC ("Alliance"). I have a business address of 1146 Monarch Street, Suite 350, Lexington, Kentucky 40513.
3. Alliance is a member of the National Mining Association ("NMA").
4. I am offering this declaration in support of the National Mining Association's Motion to Stay in the above-captioned case.
5. In the operation of its business, Alliance provides certain support services to various wholly-owned, independent operating subsidiaries engaged in the mining, preparation, and processing of coal.
6. Alliance's independent operating subsidiaries engaged in the mining, preparation, and processing of coal in Kentucky include, without limitation: River View Coal, LLC ("River View") and Warrior Coal, LLC ("Warrior"). Alliance's independent operating subsidiaries engaged in the mining, preparation, or processing of coal

in West Virginia include Tunnel Ridge, LLC (“Tunnel Ridge”) and Mettiki Coal (WV), LLC (“Mettiki”).

7. I have a Bachelor’s Degree from the University of Kentucky, in mining engineering, and have worked with Alliance (or its predecessors) since September 1994. I have more than thirty (30) years of experience working in and around the energy and mining industries.
8. On February 13, 2023, the EPA published its Final Disapproval of Kentucky’s State Implementation Plan (“SIP”) entitled, “Air Plan Disapprovals; Interstate Transport of Air Pollution for the 2015 8-hour Ozone National Ambient Air Quality Standards,” 88 Fed. Reg. 9336 (“Final Disapproval”). The Final Disapproval also disapproved the state plans of Indiana and West Virginia.
9. As a direct result of the Final Disapproval, these states’ authority to enact a reasonable state-specific plans has been nullified.
10. The EPA’s Final Disapproval, results in the application of EPA’s Federal Implementation Plan (“FIP”), which will have a detrimental and irreversible impact on Alliance and the independent subsidiaries referenced in this declaration, as well as their respective employees, vendors, and communities in which they operate.
11. One example of the detrimental and irreversible impact is observed in the request of Kentucky Utilities to prematurely close one (1) coal-fired generating unit at the Ghent power plant and in the request of Louisville Gas & Electric Company

to prematurely close two (2) coal-fired generating units at the Mill Creek power plant. These requests are part of current proceedings before the Kentucky Public Service Commission (“PSC”), in *Electronic Joint Application of Kentucky Utilities and Louisville Gas & Electric Company For Certificates of Public Convenience and Necessity and Site Compatibility Certificates and Approval of a Demand Side Management Plan*, Case No. 2022-00402 and *Electronic Joint Application of Kentucky Utilities Company and Louisville Gas & Electric Company For Approval of Fossil Fuel-Fired Generating Unit Retirements*, Case No. 2023-00122 (consolidated with Case No. 2022-00402, by Order of the Kentucky PSC on May 16, 2023).

12. In the event the EPA’s Final Disapproval and corresponding rush to adoption of the Proposed FIP results in the afore-mentioned premature retirement of three (3) coal-fired generating units, the cost of replacement electricity generation sources will result in substantial increases to Alliance, River View and Warrior’s electricity rates.

13. In particular, River View and Warrior are energy intensive businesses, relying upon affordable and reliably available energy.

14. Substantial increases to electricity rates, caused by unnecessary, premature and disruptive replacement of electricity generation sources will make it more difficult for Alliance, River View, and Warrior to retain current customers and compete economically, particularly against businesses that are less energy

intensive and/or operated in states that are not engaged in costly replacement of electricity generation sources.


15. In the event the EPA's Final Disapproval and FIP result in the afore-mentioned premature retirement of three (3) coal-fired generating units, the loss of coal sales to the Mill Creek power plant would jeopardize the viability of Warrior's Cardinal Mine and its approximately five hundred (500) direct jobs, and substantially more indirect jobs. Consequently, the cascading impact to Warrior's Cardinal Mine is likely to result in significant economic hardship and damage to the local communities in and around Madisonville, Kentucky, due to the lost economic activity and destruction of the tax base.

16. I have reviewed the Declaration of J. Michael Brown in this case challenging the FIP and understand that the Ohio Valley Electric Corporation ("OVEC") will be forced to modify electric generating operations at the Clifty Creek Station in Madison, Indiana as a result of the FIP. Specifically, OVEC will be forced to limit or eliminate near-term ozone season operations (i.e., the use of coal to generate electricity in the summer) of the Clifty Creek Station and, in the long-term, potentially further reduce operations or retire this coal-powered generating station altogether. In the event the EPA's Final Disapproval and FIP result in the aforementioned limitations or eliminations of near-term ozone season operations of the Clifty Creek Station or the reduction of operations or premature retirement of the coal-powered generating station, the loss of coal

sales to Clifty Creek Station would economically harm River View and Tunnel Ridge.

17. I have reviewed the declarations of George J. Farah and Charlotte R. Lane in the matter of *West Virginia v. EPA*, No. 23-1418, Doc. 23-13 & 23-15 (4th Cir. July 18, 2023). I understand these declarations to state that, as a result of the FIP, Monongahela Power Company may be forced to reduce operations or prematurely retire its Fort Martin Power Station. In the event the EPA's Final Disapproval and Proposed FIP result in the reduction of operations or premature retirement of the Fort Martin Power Station, the loss of coal sales to Fort Martin Power Station would economically harm Tunnel Ridge.

I declare under penalty of perjury that the foregoing is true and correct to the best of my knowledge. Executed on this 28th day of July, 2023, at Fayette County, Kentucky.


Jeffrey D. Brock

UNITED STATES COURT OF APPEALS
FOR THE D.C. CIRCUIT

NATIONAL MINING
ASSOCIATION,

Petitioner,

No. _____

v.

UNITED STATES
ENVIRONMENTAL
PROTECTION AGENCY, et al.,

Respondents.

**DECLARATION OF MATTHEW ADAMS IN SUPPORT OF
PETITIONER NATIONAL MINING ASSOCIATION'S
PETITION FOR REVIEW OF AND MOTION TO STAY FINAL RULE**

I, Matthew Adams, declare as follows:

1. My name is Matthew Adams, and I am the Vice President and Senior Tax Counsel for Navajo Transitional Energy Company ("NTEC"). I am over the age of eighteen, have personal knowledge of the subject matter, and am competent to testify concerning the matters in this declaration.

2. I have worked for NTEC since October 19, 2019. I have substantial experience in and understanding of NTEC's operations, business and mining law.

3. NTEC is the largest Native American-owned coal producer in the United States and the third largest coal producer in the United States overall. NTEC's sole shareholder is the Navajo Nation. NTEC was founded to promote the responsible development of the Navajo Nation's resources and new sources of energy, power, and transmission. It is committed to the development of the economic, financial, social and cultural well-being of the Navajo People and the Navajo Nation. NTEC operates four coal mines and serves energy customers across the country. NTEC has over 1,300 employees pays hundreds of millions of dollars in annual wages and pays hundreds of millions more in taxes and royalties, many paid directly to the Navajo Nation. NTEC is a member of the National Mining Association ("NMA").

4. I am providing this declaration in support of NMA's petition for review of and motion to stay the EPA's Final Action in publishing its Final Rule titled "Federal 'Good Neighbor Plan' for the 2015 Ozone National

Ambient Air Quality Standards,” 88 Fed. Reg. 36,654 (June 5, 2023). EPA’s Final Rule will result in imminent, irreparable harm to NTEC and the companies, employees, and communities which rely on NTEC.

5. The Final Rule will require new and extremely burdensome emissions controls for NO_x emissions. The most onerous of these controls are directed at coal-fired electricity generating plants. The Final Rule’s effects on these plants, if implemented, will severely harm NTEC.

6. The Final Rule establishes stringent new emissions allowance budgets. The only way for coal-fired power plants to limit their emissions to what those budgets permit will be to install selective catalytic reduction (“SCR”) equipment on existing units. SCR equipment is highly expensive. The Final Rule therefore forces power plants that do not currently have SCR equipment to either (1) retrofit highly expensive SCR equipment; (2) significantly reduce coal-fired generation; or (3) permanently close.

7. Retrofitting SCR equipment will cost hundreds of millions of dollars per unit. The cost of installing SCR will therefore mean that continued operation of many plants will not be economically viable. That is

especially true of plants already scheduled to retire in the foreseeable future, as the costs of installing SCR will not be recouped before the plant retires.

8. Given those costs, many coal-fired plants will have no choice but to permanently close. For select plants, it may be possible to operate at an economically viable level by significantly reducing coal-fired generation.

9. In either case, the Final Rule will seriously decrease demand for coal as units must either shut down completely or decrease generation. The consequences for NTEC's customers will be dire: power producers will be eliminated from the market entirely or they will, at the very least, spend significantly less on coal.

10. For example, NTEC supplies coal to Alabama Power Company. I have reviewed the declaration of Brandon Dillard, a Senior Production Officer at Alabama Power. *Alabama v. EPA*, No. 23-11173, Doc. 18, Attachment B (11th Cir. June 13, 2023). Mr. Dillard explains that under the Final Rule, Alabama Power will have a 53% reduction in emissions allowances for 2023. *Id.* ¶ 12. Accordingly, individual Alabama Power plants will be required to reduce their emissions by 50% or more to satisfy the Final

Rule. *Id.* ¶ 14. Some plants will be required to reduce their emissions even further. *Id.* ¶ 16.

11. Alabama Power therefore attests that all possible compliance options will impose severe compliance costs. Installing new SCR controls would take months and cost hundreds of thousands, if not millions, of dollars. *Id.* ¶¶ 18-19. Alabama Power might alternatively transition increased generation to non-coal fired generators. *Id.* ¶ 29. Either option will result in Alabama Power purchasing less coal.

12. NTEC also supplies power to other US coal fired generation facilities and industrial generators that will face the same compliance options (and costs) that Alabama Power does.

13. If NTEC's customers shut down coal-fired plants or reduce operation of coal-fired units, they will buy less coal from NTEC. That will irreparably harm NTEC.

14. If NTEC loses customers, that would jeopardize the economic viability of its own operations. NTEC employs more than 1,600 people,¹ pays over \$200 million in wages annually and another \$200 million in taxes and royalties.² NTEC is wholly owned by the Navajo Nation, and NTEC contributes tens of millions of dollars to the Navajo Nation's general fund.³ Financial harms to NTEC will therefore harm the Navajo Nation as well.

15. I, Matthew Adams, declare under penalty of perjury under the laws of the United States that the foregoing is true and correct to the best of my knowledge.

A handwritten signature in black ink that reads "Matthew Adams". The signature is written in a cursive style and is centered within a light gray rectangular box.

Dated: July 31, 2023.

¹ Elena Vasilyeva, *Q&A: NTEC Expects Another 'Strong' Year For Coal* (Jan. 19, 2022), <https://navenergy.com/qa-ntec-expects-another-strong-year-for-coal/>.

² Navajo Transitional Energy Company, *2021 Operational Review* (2021), <https://navenergy.com/wp-content/uploads/2022/07/NTEC-Operational-Report-2021-FINAL-DIGITAL.pdf>.

³ Navajo Transitional Energy Company, *NTEC History*, <https://navenergy.com/timeline/>.

Comments by

American Forest & Paper Association, Inc., American Iron and Steel Institute, America's Power, Associated Electric Cooperative, Inc., Deseret Electric Power Cooperative, Midwest Ozone Group, National Mining Association, the National Rural Electric Cooperative Association, Ohio Valley Electric Corporation, the Portland Cement Association, and Wabash Valley Power Alliance

on the U.S. Environmental Protection Agency's Proposed Federal "Good Neighbor Plan" for the 2015 Ozone National Ambient Air Quality Standards; Response to Additional Judicial Stays of SIP Disapproval Action for Certain States

**88 Fed. Reg. 67,102 (Sept. 29, 2023)
Docket ID No. EPA-HQ-OAR-2021-0668**

October 30, 2023

Attachment C Part 2

Appendix to Emergency Application for Immediate Stay of Final Agency Action Pending Disposition of Petition for Review

Pages 445 - 505

UNITED STATES COURT OF APPEALS
FOR THE D.C. CIRCUIT

NATIONAL MINING
ASSOCIATION,

Petitioner,

No. _____

v.

UNITED STATES
ENVIRONMENTAL
PROTECTION AGENCY, et al.,

Respondents.

**DECLARATION OF CHRIS HAMILTON IN SUPPORT OF
PETITIONER NATIONAL MINING ASSOCIATION'S
PETITION FOR REVIEW OF AND MOTION TO STAY FINAL RULE**

I, Chris R. Hamilton, declare as follows:

1. My name is Chris Hamilton, and I am the President and Chief Executive Officer of the West Virginia Coal Association ("WVCA"). I am over the age of eighteen, have personal knowledge of the subject matter, and am competent to testify concerning the matters in this declaration.

2. The WVCA is a membership association comprised of companies that mine coal in West Virginia as well as companies providing a variety of support services to the West Virginia coal mining industry. The WVCA's purpose is to advance the interests of its members through well-crafted law and policy.

3. I am providing this declaration in support of NMA's petition for review of and motion to stay the EPA's Final Action in publishing its Final Rule titled "Federal 'Good Neighbor Plan' for the 2015 Ozone National Ambient Air Quality Standards," 88 Fed. Reg. 36,654 (June 5, 2023). EPA's Final Rule will result in imminent, irreparable harm to the coal mining industry in West Virginia and to WVCA's members.

4. The Final Rule will require increased and highly onerous emissions controls for NOx emissions, and the most onerous restrictions will be imposed on coal-fired electricity generating plants. In turn, the entire coal mining industry in West Virginia will be severely impacted.

5. The Final Rule will force regulated coal-fired electricity generating units to install costly emission control technologies to comply

with newly imposed emissions allowance budgets. These budgets are based on an assumption that coal-fired power plants can install selective catalytic reduction (“SCR”) equipment on existing units before the 2026 ozone season. But power plants that are not currently equipped with SCR equipment will be forced to either (1) retrofit extremely expensive SCR equipment; (2) significantly reduce capacity utilization; or (3) permanently retire.

6. In West Virginia alone, 18 electricity generating units across 9 facilities will be impacted by the Final Rule. All of these units are coal fired. West Virginia coal producers and WVCA member companies supplied over 19 millions of coal to these plants in 2022, representing over 23 percent of the state’s total coal production. Another 20.5 million tons of coal was delivered to coal fired units around the country (24 percent of the state’s total coal production) that may be impacted by the Final Rule.

7. Retrofitting new SCR equipment on plants costs hundreds of millions of dollars per square unit—which will call into question the economic viability of any unit that is not currently so equipped. This is

especially true for units that are already scheduled to retire in the next few years.

8. The Final Rule will also impose immediate compliance costs in the form of new software and the reconfiguration of compliance systems, as well as the development of monitoring, reporting, and automation systems that would otherwise not be needed if the FIP is stayed.

9. Faced with bleak options—none of which are economically feasible for continued operation, many coal-fired plants will permanently retire. And of those that stay in operation, many will be forced to substantially reduce capacity utilization.

10. In either case, the Final Rule will significantly decrease the demand for coal as units are either retired or forced to decrease capacity. The consequences for this decreased demand on coal industry and for WVCA's members will be dire, as WVCA members' customers will be eliminated from the market or will reduce their budgets for coal.

11. West Virginia is the second largest coal-producing State, after Wyoming.¹ The State produced 84.5 million tons of coal in 2022.² Nearly 27,000 people are employed in the West Virginia coal mining industry at an average wage of \$89,300 annually, which is significantly above the average wage for blue collar workers in the State and double the average wage for all private industries in West Virginia.³ The estimated aggregate value of coal mined West Virginia in 2020 was conservatively over \$4 billion.⁴ In 2019, coal mining generated \$9.1 billion in economic activity in West Virginia, providing \$2.1 billion in employee compensation and creating \$514 million in severance tax, and other state and local tax revenue for West Virginia.⁵

12. Three WVCA member companies supplied 1 million tons of coal to the Fort Martin power station owned and operated by Monongahela

¹ Priscila Borges Marques Dos Santos, et al., *The Economic Impact of Coal and Coal-Fired Power Generation in West Virginia*, BUREAU OF BUS. & ECON. RESEARCH, W. VA. UNIV. COLL. OF BUS. AND ECON. (2021), at 3.

² *2022 Coal Production Data & Directory of Mines*, W. VA. COAL ASSOC. (2023), at 3.

³ Dos Santos, *supra* note 1, at v, 6.

⁴ 2021 Coal Facts, *supra* note 2, at 3.

⁵ Dos Santos, *supra* note 1, at v.

Power Company in 2022.⁶ I have reviewed the declarations of George J. Farah and Charlotte R. Lane in the matter of *West Virginia v. EPA*, No. 23-1418, Doc. 23-13 & Doc. 23-15 (4th Cir. July 18, 2023). I understand these declarations state that, as a result of the FIP, the Monongahela Power Company may be forced to reduce operations or retire prematurely its Fort Martin Power Station. Because these members supply coal to the Fort Martin Power Station, lowering generation output or early retirement of the coal-fired plant forced by the FIP will significantly harm these WVCA members' revenues and operations.

13. Three members of WVCA shipped 463,453 tons of West Virginia thermal coal in 2022 to East Kentucky Power Cooperative, Inc. (EKPC).⁷ I understand from the declaration of Jerry Purvis that, as a result of the Final Rule, EKPC may be forced to retire its Cooper Unit 1 generating station prematurely. Because these members supplies coal to Cooper Unit 1, this

⁶ See generally U.S. Energy Information Administration, monthly utility generation and fuel reports (Form 923), available at <https://www.eia.gov/electricity/data/eia923/>

⁷ See generally U.S. Energy Information Administration, monthly utility generation and fuel reports (Form 923), available at <https://www.eia.gov/electricity/data/eia923/>

early retirement and resulting elimination of a major recipient of coal will severely harm these WVCA members' revenues.

14. 400,743 tons of West Virginia coal was shipped by a WVCA members to the Ohio Valley Electric Cooperative (OVEC) in 2022.⁸ I understand from the Declaration of J. Michael Brown that OVEC will be forced to modify electric generating operations at the Clifty Creek Station in Madison, Indiana as a result of the FIP. Specifically, OVEC will be forced to limit or eliminate near-term ozone season operations (i.e. the use of coal to generate electricity in the summer) of the Clifty Creek Station, and, in the long-term, potentially further reduce operations or retire this coal-powered generating station altogether. Because these members supply coal to the Clifty Creek Station, the operational changes at Clifty Creek forced by the FIP will significantly harm these WVCA members' revenues and operations.

⁸ See generally U.S. Energy Information Administration, monthly utility generation and fuel reports (Form 923), available at <https://www.eia.gov/electricity/data/eia923/>

15. I, Chris Hamilton, declare under penalty of perjury under the laws of the United States that the foregoing is true and correct to the best of my knowledge.

Dated: July 28, 2023



Chris R. Hamilton

**IN THE UNITED STATES COURT OF APPEALS
FOR THE D.C. CIRCUIT**

NATIONAL MINING)	
ASSOCIATION,)	
)	
Petitioner,)	
)	
v.)	
)	No. _____
UNITED STATES)	
ENVIRONMENTAL PROTECTION)	
AGENCY, <i>et al.</i> ,)	
)	
Respondents.)	

**DECLARATION OF TAWNY BRIDGEOFORD IN SUPPORT OF
PETITIONER NATIONAL MINING ASSOCIATION'S
PETITION FOR REVIEW OF AND MOTION TO STAY FINAL RULE**

I, Tawny Bridgeford, declare as follows:

1. My name is Tawny Bridgeford. I am the General Counsel & Senior Vice President, Regulatory Affairs for the National Mining Association (“NMA”). I make this declaration in support of NMA’s petition for review of and motion to stay the U.S. Environmental Protection Agency’s (“EPA”) Final Rule titled “Federal ‘Good Neighbor Plan’ for the 2015 Ozone National Ambient Air Quality Standards,” 88 Fed. Reg. 36,654 (June 5, 2023).

I am over the age of eighteen and have personal knowledge of the facts set forth below.

2. NMA is the national trade association that represents the interests of the mining industry, including every major coal company operating in the United States. In 2022, our member companies represented 74 percent of U.S. coal production in 18 states. NMA has approximately 280 members, whose interests it represents before Congress, the administration, federal agencies, the courts, and the media. As part of its core mission and purpose of representing NMA's members' interests, it advocates for sound regulatory policy decisions by the EPA and regularly participates in court cases challenging rules that harm the mining industry, such as the Final Rule.

3. Mining occupies a crucial place in America's economy and energy infrastructure. In 2022, the coal mining industry fueled 20 percent of the Nation's electricity net generation,¹ providing affordable and reliable

¹ 2023 *Mining Facts*, NMA, <https://nma.org/wp-content/uploads/2022/04/FINAL-NMA-Mining-Facts-2023.pdf>.

baseload power to households, businesses, manufacturing facilities, transportation and communications systems, and services throughout our economy. Likewise, the coal mining industry directly employs 97,000 people with 217,000 indirect coal mining jobs,² and provides high-paying jobs to American workers. For example, the average annual wage for all U.S. coal miners is \$102,855—46 percent above the average wage for all U.S. workers, which is \$70,343.³ Coal mining directly contributed over \$20 billion to GDP in 2021.⁴

4. I am familiar with NMA's preparation and submission of detailed comments on EPA's proposed Rule. *See* Docket ID No. EPA-HQ-OAR-2021-0668 (comments on proposed Rule), and the impacts the Final Rule will have on NMA's members.

5. Unless it is stayed, the Final Rule will inflict significant, costly, and irreparable damage to NMA's members.

² *Id.*

³ *Annual Coal Mining Wages vs. All Industries, 2022*, NMA, https://nma.org/wp-content/uploads/2022/06/annual_coal_mining_wages_22.pdf.

⁴ *The Economic Contributions of U.S. Mining, 2021*, NMA, <https://nma.org/wp-content/uploads/2021/02/Economic-Contributions-of-Mining-in-2021.pdf>.

6. The Final Rule provides for ozone season nitrogen oxides (“NO_x”) reductions from electric generating units (“EGU”). It imposes EGU unit technology requirements and subjects EGUs to an emissions allowance trading program that includes “dynamic budget setting” and daily emissions rates for many coal-fired EGUs, as well as unit-specific secondary emission limits. Together, these requirements will reorder the American power sector, threaten access by millions of Americans to reliable and affordable electricity, and cause grave harm to the coal industry, including NMA’s members.

7. The Final Rule assumes many coal-fired EGU’s will install costly emission control technologies to comply with newly imposed emissions allowance budgets. These budgets are based on the assumption that coal-fired power plants will operate selective catalytic reduction (“SCR”) equipment on existing units before the 2026 ozone season. But power plants that are not currently equipped with SCR equipment will be forced to (1) retrofit extremely expensive SCR equipment; (2) significantly reduce generation of electricity and utilization of coal; (3) purchase allowances,

which may be prohibitively expensive or unavailable, or (4) permanently retire.

8. Faced with this choice, many plants will retire prematurely. And many others will reduce utilization of coal. In either case, this will drastically impact NMA's members, as its members' customers will either prematurely close or otherwise reduce their purchasing of coal as they reduce power generation.

9. The Final Rule reflects an attempt by EPA to radically reduce or eliminate coal-fired generation. Under the Final Rule, allocation budgets would plummet by 2026. Even well-controlled coal-fired units that already have SCR controls may be required to operate at reduced capacity due to the dearth of NO_x allowances.

10. EPA has also included "dynamic budgeting" and bank recalibration, which will further penalize coal-fired generation by imposing increasingly lower emissions budgets and forcing early retirements of EGUs that cannot afford costly retrofits.

11. The Final Rule will effectively force the retirement of up to 48.5 gigawatts of capacity within a relatively short window of time. Under the Final Rule, coal-fired units with capacities of 100 megawatts or greater must install SCR equipment by 2026, as they will not have adequate NO_x allowances during the ozone season to continue running, and adequate credits will not be available due to the restrictive nature of the revised trading program. But installation of SCR technology on smaller units is cost prohibitive, and if these non-SCR units cannot run during the ozone season, they will likely retire, as the overhead of running units for only seven months of the year (the non-ozone season) will not justify continued operation. And even for utilities that can afford to undertake expensive retrofits, the Final Rule does not provide enough time for them to do so.

12. Indeed, EPA's Regulatory Impact Analysis concedes that the Final Rule will result in early retirement of approximately 13 percent of the national coal-fired electric generation capacity. OFFICE OF AIR QUALITY PLANNING AND STANDARDS, U.S. E.P.A., REGULATORY IMPACT ANALYSIS FOR THE FINAL FEDERAL GOOD NEIGHBOR PLAN ADDRESSING REGIONAL OZONE


TRANSPORT FOR THE 2015 OZONE NATIONAL AMBIENT AIR QUALITY STANDARD
(2023) at 13.

13. These onerous restrictions on regulated EGUs, which will force early retirements and reduce coal-fired generation, will severely impact NMA's members and the coal mining industry generally by reducing coal sales and shipments and increasing electricity costs.

14. Similarly, many other industrial sources critical to the economy also use coal as a primary fuel source, including cement kilns and industrial boilers. The Final Rule's restrictions on those sources may also lead to early retirement or curtailed operations. This will negatively impact NMA's members both by increasing the price of necessary materials to their operations and decreased fuel sales.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on July 28, 2023, in Washington, DC.


Tawny Bridgeford

DECLARATION OF HARM - NORTH AMERICAN STAINLESS

I, Cristobal Fuentes hereby declare as follows:


1. I am the President and Chief Executive Officer of North American Stainless (“NAS”), have been employed by NAS for thirty-one years; I hold the degree of Masters of Metallurgical Engineering from the Madrid Industrial Engineering School and my experience in industry qualifies me to make this declaration.
2. NAS is the largest fully integrated manufacturer of commodity-grade stainless steels in the Western Hemisphere and competes in international markets with other stainless steel manufacturers world-wide; NAS is a wholly-owned subsidiary of Acerinox, S.A., a Spanish corporate entity, shares of which are publicly traded on the Madrid Stock Exchange.
3. Acerinox chose to locate NAS in Kentucky in the early 1990s due in large part to its readily available and competitively priced electrical energy supply, which is among the very most important of all costs of manufacturing stainless steels; electricity is consumed in melting the steel in electric arc furnaces as well as all phases of rolling, forming, gauging thickness and cutting stainless steel for sale to industrial customers who build myriad products using stainless steel due to its ability to remain inert and withstand attack by hostile elements such as corrosion, chemical reactivity and other adverse conditions. A steady supply of

stainless steels is absolutely necessary to the functioning of the world's economy and to the security of the United States of America, both physically as well as economically.

4. This declaration addresses the impact on NAS of the denial of Kentucky's State Implementation Plan ("SIP") and the imposition of the Federal Implementation Plan ("FIP") contested herein by Kentucky and against the United States Environmental Protection Agency ("EPA") and is offered in support of the petition of the Commonwealth of Kentucky to stay EPA's actions pending the outcome of this litigation.
5. EPA's actions will substantially and fundamentally increase the costs to NAS of doing business in the form of increased costs and reduced reliability of supply of electricity.
6. As the largest customer on the system, NAS will incur increased costs of production and distribution of electricity from its exclusive, franchised and regulated provider, Kentucky Utilities ("KU"), as demonstrated by its case currently before the Kentucky Public Service Commission ("KPSC") Case No. 2022-00402, which seeks to restructure electrical generating capacity to comply with the "Good Neighbor" plan.
7. Increased costs resulting from EPA's actions will reduce NAS's competitiveness in the marketplace as it competes with subsidized imports.

8. Of greater importance is that NAS's electric arc furnaces must power without significant interruptions. Any disruption outside the controlled parameters of curtailable power has severe consequences both operationally and financially. Reliability of the power supply and grid distribution is a primary concern for NAS.

I declare under penalty of perjury that the foregoing is true and correct to the best of my knowledge. Executed on this 18th day of July, 2023 in Carroll County, Kentucky.



Cristobal Fuentes
President & Chief Executive Officer
North American Stainless

Declaration of Dudley Zahn, Vice President, NRG Energy, Inc.

IN THE UNITED STATES COURT OF APPEALS
FOR THE FIFTH CIRCUIT

STATE OF TEXAS; TEXAS COMMISSION)	
ON ENVIRONMENTAL QUALITY;)	
LUMINANT GENERATION COMPANY)	
LLC; COLETO CREEK POWER, LLC;)	
ENNIS POWER COMPANY, LLC; HAYS)	
ENERGY, LLC; MIDLOTHIAN ENERGY,)	
LLC; OAK GROVE MANAGEMENT)	
COMPANY LLC; WISE COUNTY POWER)	
COMPANY, LLC; ASSOCIATION OF)	
ELECTRIC COMPANIES OF TEXAS; BCCA)	
APPEAL GROUP; TEXAS CHEMICAL)	
COUNCIL; TEXAS OIL & GAS)	
ASSOCIATION)	
)	
Petitioners,)	
)	Case No. 23-60069
v.)	
)	
UNITED STATES ENVIRONMENTAL)	
PROTECTION AGENCY and MICHAEL S.)	
REGAN, Administrator, United States)	
Environmental Protection Agency,)	
)	
Respondents.)	

DECLARATION OF DUDLEY ZAHN

1. I am a Vice President at NRG Energy, Inc (NRG), which owns NRG Texas Power LLC (“NRG Texas”), which in turn owns power plants in Texas. NRG Texas is a member of the Association of Electric Companies of Texas (AECT), and I am providing this declaration in support of AECT’s motion to stay the disapproval of the Texas State Implementation Plan (SIP) rule promulgated by the U.S. Environmental Protection Agency (EPA or the Agency) on February 13, 2023. *See Air Plan Disapprovals; Interstate Transport of Air Pollution for the 2015 8-Hour Ozone National Ambient Air Quality Standards*, 88 Fed. Reg. 9,336 (Feb. 13, 2023) (“Final Rule”).

This declaration is based on my personal knowledge and analysis conducted by my colleagues and me.

2. The Final Rule, if not stayed, would impose substantial costs on NRG Texas during the next 12-18 months and would further impact the long-term economic viability of several of NRG Texas's electric generating units. The impact of the rule and the harm it will cause NRG Texas are detailed below.

MY BACKGROUND

3. As Vice President, Gulf Asset Management at NRG, I am familiar with the Texas electricity market and NRG Texas's business, day-to-day operations, financial matters, the value of its assets, and its underlying books and records.

SUMMARY OF IRREPARABLE HARMS CAUSED BY EPA'S FINAL RULE

4. On February 13, 2023, EPA published the Final Rule, clearing the path for the Agency to implement the proposed Federal Implementation Plan (FIP), *see* 87 Fed. Reg. 20,036 (Apr. 6, 2022), to expand and make more stringent its Group 3 NO_x Ozone Season Trading Program. According to the proposed FIP, EPA would “not finalize a FIP for any of these states unless and until the EPA formally finalizes disapprovals of their SIP submittals.” *Id.* at 20,058; *see also* 42 U.S.C. § 7410(c)(1). In other words, but for the Final Rule, the FIP would not apply to Texas. EPA has treated the proposed FIP as if it is a foregone conclusion that requires expenditures even before being promulgated in final form. In it, EPA explained that to achieve the lower emission budgets in 2026, “source owners and operators . . . **should begin engineering and financial planning now** to be prepared to meet this implementation timetable.” 87 Fed. Reg. at 20,101 (emphasis added).

5. Texas is currently part of EPA's Group 2 NO_x Ozone Season Trading Program. The proposed FIP, if adopted and upheld, would move Texas to a revised Group 3 NO_x Ozone Season Trading Program with more stringent budgets (developed by assuming the rapid installation of additional control mechanisms for electric generating units (EGUs)), including the imposition of a daily "backstop" emissions rate for certain large coal-fired EGUs in 2024 and all large coal-fired EGUs in 2027.

6. Starting May 1, 2023, Texas EGUs would be subject to a NO_x ozone season budget 27% less than under the current Group 2 Trading Program—from 52,301 tons to 38,284 tons. EPA bases Texas's 2023 budget on generation shifting and on NO_x reductions that EPA assumes can be achieved through "optimization" on certain units' existing NO_x controls. If this requirement is adopted and upheld, units that cannot conduct the work in the minimal time allotted by EPA, or cannot achieve the level of reduction that EPA requires, will be required to purchase additional allowances to cover any shortage (if they are available) or reduce their thermal generation in a market that is actively reviewing various mechanisms to ensure sufficient thermal dispatchable resources are available to maintain a standard of reliability, or a combination of both.

7. For 2026, EPA's SIP disapproval and proposed FIP relies on EPA's assumption that dozens of units in Texas will be able to achieve NO_x reductions through the installation and operation of new and costly selective catalytic reduction (SCR) controls and selective non-catalytic reduction (SNCR) controls or by shifting generation from higher emitting units to lower emitting units or renewables (if they are available). If this requirement is adopted and upheld, units that cannot conduct the work in the time allotted by EPA, or cannot achieve the level of reduction EPA anticipates, would be required to purchase additional allowances to cover any shortage (if they are available) and/or reduce the thermal generation of electricity (*i.e.*, de-rate or retire) in a market that

is actively reviewing various mechanisms to ensure sufficient thermal dispatchable resources are available to maintain a standard of reliability.

8. The Final Rule, if upheld, will have significant impacts on NRG Texas's operations and the cost to service retail customers in Texas. As detailed below, these harms will occur in 2023 and 2024 without a stay. In summary, EPA's rule would:

- a. Require substantial compliance costs to operate under restricted NO_x budgets.
- b. Place significant financial burden on generators that seek to comply with the Final Rule by fast tracking large-scale, capital-intensive construction projects to meet EPA's exceedingly stringent NO_x budgets in 2026 and daily backstop limits.
- c. Exacerbate the current strain on ERCOT and the need for thermal generation by requiring hundreds of millions of dollars of capital investment which operate in a competitive wholesale market with no guarantee of cost recovery or rate of return on investment.

9. These harms would be irreversible if generating units retired in anticipation of or as the result of the Final Rule. Likewise, NRG Texas would be irreparably harmed if forced to take actions to continue operations with no reasonable means of recovering those costs and no feasible means to implement those projects by the compliance deadline. NRG Texas cannot recover these costs from EPA or through regulated rates. Capital investment decisions such as those needed to comply with environmental regulations are risk-adjusted and justified based on competitive wholesale market prices. Without a stay of the Final Rule, irreparable harm could occur well in advance of the deadlines for meeting the mandated emission limitations.

10. The ability to maintain a reliable portfolio of thermal generation resources is set by market forces, not by regulated rates. NRG Texas operates in the Texas market overseen by the Electric Reliability Council of Texas (ERCOT). The ERCOT market is unique in its competitive market design. Lying wholly within the boundaries of the state, Texas restructured the electric market to

convert Texas’s investor-owned utilities from a traditional rate-regulated structure into a “deregulated” competitive market at both the wholesale and retail levels. NRG Texas does not have captive customers and no assurance it can recover the costs associated with the Final Rule from “ratepayers.” Instead, those costs are borne by NRG and directly impact the economic viability and ability to operate the electric generating units at issue.

NRG TEXAS’S OPERATIONS AND ECONOMIC IMPACT

11. NRG Texas is the second largest power generation company in Texas. NRG Texas’s generating portfolio is made up of a combination of coal, nuclear, and natural gas. NRG Texas’s nuclear and coal units are considered “baseload” units that operate at high capacity throughout the year. NRG Texas’s natural gas units include steam boilers, combined cycle, and simple cycle turbine units that are typically used as supply when demand is greater than the baseload units’ capabilities. Thus, due to these unique physical and economical characteristics, the electricity generated by NRG Texas’s coal and gas-fired units without SCR installed—which are affected by the Final Rule—cannot simply be replaced by NRG Texas’s other units.

12. NRG Texas’s coal and gas-fueled generating units significantly affected by the Final Rule are located at five generating plants (W.A. Parish, Limestone, T.H. Wharton, Cedar Bayou, and Greens Bayou) in multiple counties.

13. NRG Texas provides electricity to Texas consumers and businesses within ERCOT, the independent system operator, which manages the state’s unique competitive power market and the electric power grid that serves the majority of the state. The ERCOT market is a “power island” contained within Texas and separated from neighboring interconnections by asynchronous ties that limit imports and exports to and from the ERCOT market.

14. Texas's economic growth (as measured by gross state product year-over-year growth) has been one of the highest in the United States, and Texas's electric consumption has followed its growth. The state of Texas relies upon access to affordable, reliable generation to continue to fuel its economic expansion. NRG Texas's generating units are critical to the reliable operation of the ERCOT grid, and ERCOT relies heavily on NRG Texas to meet the area's increasing demand. In the summer of 2022, for example, the hourly demand on the ERCOT system broke the all-time peak record three times in one week, and NRG Texas plants was a major contributor in supplying electricity critical to the grid at the time.

THE FINAL RULE'S REQUIREMENTS FOR TEXAS

Installation of Costly Controls

15. EPA assumes that the EGU owners will make investment decisions and begin incurring costs now, even before finalization of the FIP, to install post-combustion controls to meet the stricter environmental limits by 2026.

16. Retrofit of SCRs as proposed in the FIP would likely take more than three years. This minimum lead-time does not provide for potential delays in equipment fabrication and delivery due to high demand, weather-related delays due to high winds, storms, or extreme weather conditions, or site-specific conditions. In other words, retrofits may not be possible within the timeframe set forth in the proposed FIP.

17. The installation of SCRs on the affected NRG units would cost over \$1 billion. A substantial portion of that cost would be required to be expended in 2023 in order to meet EPA's unrealistic compliance timeframe.

NRG TEXAS ALLOWANCE ALLOCATIONS AND CAPACITY REDUCTIONS

18. The proposed FIP provides for an allocation of 3,336 allowances to NRG Texas’s facilities in 2026, **4,938 allowances fewer** than actual emissions in 2022. The facilities most affected are:

Account Name	2022 Ozone Season NOx (tons)	4-Year Max	2023 Group 3 Allocation	2026 Group 3 Allocation	2023 Capacity Reduction	2026 Capacity Reduction
Limestone	3679.1	3679.1	2267	888	-38%	-76%
Cedar Bayou	866	866	576	359	-33%	-59%
Greens Bayou	262	262	79	31	-70%	-88%
T H Wharton	480	480	176	104	-63%	-78%
W A Parish	2603	3192	3063	1607	-4%	-50%

19. In the proposed FIP, EPA incorrectly assumed that Limestone was equipped with SNCR and assumed that Limestone will “optimize” its non-existent SNCR by the 2023 ozone season. As a result, EPA greatly overestimated Limestone’s ability to achieve the proposed 2023 and 2026 Group 3 Allocations.

20. The cost to “optimize” existing controls is also significant and potential recovery of investments highly speculative. EPA assumes reductions from these optimizations will be complete by the start of the 2023 ozone season. Specifically, such reductions are built into Texas’s ozone season NO_x budget that will begin to apply on May 1, 2023. EPA’s assumptions regarding emission rates are unrealistic, with EPA assuming that NRG Texas units can reduce its NO_x by an additional 26% compared to 2022 emission rates and relying on those rates when setting budgets.

21. To meet EPA’s proposed FIP timeline, optimization efforts have already begun. If EPA’s disapproval of Texas’s SIP is not stayed, NRG Texas must continue to take significant and costly steps, even prior to the FIP being finalized, to achieve the reductions identified by EPA by May 1, 2023. If EPA’s SIP disapproval is later vacated by the Court, the cost of this work cannot be recovered because of the structure of the deregulated competitive energy market in which NRG Texas operates.

22. EPA has identified six of NRG Texas's units for optimization of their SCRs. To perform this optimization, NRG Texas must evaluate existing permit limits, the units' existing ammonia injection systems, and the units' current SCR catalyst activity levels. Testing must be performed to determine whether additional ammonia injection effectively reduces NO_x rates and can be maintained without exceeding existing ammonia slip permit limits. It could take months to perform an SCR optimization assessment, which includes gathering design and operational information and completing testing. Through that assessment, NRG Texas may determine that hardware changes are necessary for the existing ammonia injection systems or that layers of catalyst must be replaced to meet the emission rates EPA has assumed in establishing Texas's budget. Given the 2023 ozone season is less than two months away, any hardware or catalyst changes that have not already been started are not feasible to be completed before the expected compliance date.


23. Even if it were possible to perform all optimization efforts that EPA has assumed for the 2023 ozone season (which NRG Texas maintains is not possible), other flaws in the EPA's budget-setting process for 2023, in addition to EPA's assumed generation shifting, results in a shortage of NO_x allowances based on what is necessary for anticipated generation needs. This shortage will particularly harm NRG Texas's units that operate during critical peak demand periods.

24. Costs resulting from EPA's significantly more stringent emission budgets, including new SCR costs, the cost of "optimizing" existing SCRs or SNCRs, or the cost of purchasing additional allowances, cannot be recovered from EPA or others if EPA's SIP disapproval is later determined to be unlawful. Because of the deregulated nature of the ERCOT market, there is no mechanism for NRG Texas to recover costs it spends in the near-term in preparation for compliance with the

FIP (which would not apply but for EPA's disapproval of Texas's SIP) even if the Court ultimately vacates EPA's disapproval.

I, Dudley Zahn, declare under penalty of perjury under the laws of the United States of America that the foregoing is true and correct.

Executed this 3rd day of March 2023.



Dudley Zahn,
Vice President, Gulf Asset Management
NRG Energy, Inc.

**Declaration of Randall J. Talley, Vice President, Solid Fuels and
Environmental Trading, Vistra Corp.**

**IN THE UNITED STATES COURT OF APPEALS
FOR THE FIFTH CIRCUIT**

**STATE OF TEXAS; TEXAS COMMISSION
ON ENVIRONMENTAL QUALITY;
LUMINANT GENERATION COMPANY
LLC; COLETO CREEK POWER, LLC;
ENNIS POWER COMPANY, LLC; HAYS
ENERGY, LLC; MIDLOTHIAN ENERGY,
LLC; OAK GROVE MANAGEMENT
COMPANY LLC; WISE COUNTY POWER
COMPANY, LLC; ASSOCIATION OF
ELECTRIC COMPANIES OF TEXAS; BCCA)
APPEAL GROUP; TEXAS CHEMICAL)
COUNCIL; TEXAS OIL & GAS)
ASSOCIATION,)**

Petitioners,

v.

**UNITED STATES ENVIRONMENTAL
PROTECTION AGENCY and MICHAEL S.
REGAN, Administrator, United States
Environmental Protection Agency,)**

Respondents.

Case No. 23-60069

DECLARATION OF RANDALL J. TALLEY

1. I am the Vice President of Solid Fuels and Environmental Trading at Vistra Corp. (Vistra), a leading Fortune 500 integrated retail electricity and power generation company based in Irving, Texas. I have worked for Vistra and its predecessors for 22 years, with roles in risk management, structuring and quantitative analysis, and commercial trading prior to my current role.

LUMINANT'S OPERATIONS IN THE STATE OF TEXAS

5. Luminant currently owns and/or operates 15,793 megawatts (MW) of installed fossil generation capacity in Texas, which includes approximately 11,293 MW fueled by natural gas and 4,500 MW fueled by coal. This capacity is located at a total of 55 electric generating units (EGUs) at 17 sites in Texas. All 55 of these EGUs are subject to additional regulation, and thus increased compliance costs, as a result of EPA's disapproval of Texas's SIP, as discussed below. Since 2018, Luminant has retired approximately 4,100 MW of coal-fueled generation capacity in ERCOT, including the Monticello, Big Brown, and Sandow power plants, which resulted in the reduction of over 8,000 tons of ozone season NO_x emissions in Texas.

6. Luminant's entire generating portfolio in Texas is 18,791 MW, which includes 2,400 MW of nuclear generation and 498 MW of solar and energy storage. Luminant is also one of the largest wind purchasers in Texas. Luminant employs approximately 3,500 full-time employees and contracts with independent contractors to work at Luminant's facilities in the State of Texas. Luminant spends approximately \$2 billion annually in the form of salaries, taxes, fuel, maintenance, and other operating and capital expenditures, and its impact on gross state product and gross domestic product is substantial.

7. In 2022, Luminant provided approximately 18.7% of the electricity dispatched to Texas consumers and businesses by the Electric Reliability Council of

Texas (ERCOT), the independent system operator that manages the state's unique competitive power market and the electric power grid that serves the majority of the state. The ERCOT market is a "power island" contained within Texas and separated from neighboring interconnections by asynchronous ties that limit imports and exports to and from the ERCOT market. The State of Texas relies upon access to affordable, reliable generation to continue to fuel its economic expansion and that of the United States. Luminant's generating units are critical to the reliable operation of the ERCOT grid, and ERCOT relies heavily on Luminant to meet the area's demand. Just this past summer, for example, the hourly demand on the ERCOT system broke the all-time peak record ten times in the span of two months. Demand ultimately peaked at 80,038 MW on July 20, 2022,² with Luminant plants making over 18,000 MW available to the grid at the time.

TEXAS'S SIP ADDRESSES THE 2015 OZONE NAAQS

8. In October 2015, EPA revised the primary and secondary ozone NAAQS to establish a new 8-hour standard of 70 parts per billion (ppb). Under the Clean Air Act, the State of Texas was required to submit a revised SIP to address the new ozone NAAQS within three years, by October 2018. As part of this obligation,

² ERCOT, *Item 6: Summer 2022 Operational and Market Review*, at 2 (Oct. 18, 2022), available at

<https://www.ercot.com/files/docs/2022/10/11/6%20Summer%202022%20Operational%20and%20Market%20Review.pdf>.

Texas was required to ensure that its SIP contained adequate provisions to prohibit emissions from the State of Texas from contributing significantly to nonattainment in, or interference with maintenance by, any other state with respect to the revised NAAQS. This is commonly referred to as the “good neighbor” provision. Texas satisfied this requirement, submitting its SIP to EPA on August 17, 2018.

9. To support Texas’s SIP, Texas performed extensive modeling based on all available data, including modeling emissions from Luminant’s EGUs. Texas’s comprehensive modeling demonstrated that emissions from Texas, including Luminant’s EGUs, do not contribute significantly to nonattainment or interfere with maintenance of the 2015 ozone NAAQS at any downwind monitors. Accordingly, Texas’s SIP submittal did not require any further reductions from sources in Texas; however, as Texas explained in its SIP submittal, many limitations and controls are already in place to address ozone precursor emissions at sources in Texas, including Luminant’s EGUs.

10. For example, among other things, EGUs in Texas are currently subject to EPA’s Cross-State Air Pollution Rule (CSAPR) Group 2 Ozone Season NO_x budgets. EPA established this CSAPR Group 2 allowance trading program through a Federal Implementation Plan in October 2016 to address states’ “good neighbor” obligations with respect to the 2008 ozone NAAQS. Under this obligation, EPA established an emission budget for sources in Texas of 52,301 tons of NO_x to ensure

such sources were not contributing significantly to nonattainment in, or interfering with maintenance by, any other state with respect to the 2008 ozone NAAQS. 40 C.F.R. § 97.810(a)(20)(i). Therefore, under Texas's most recent SIP, sources would continue to operate in compliance with the existing requirements applicable to ozone precursors, such as EPA's CSAPR Group 2 ozone season NO_x budgets.

11. Despite Texas's legally and technically sound SIP addressing the interstate transport requirements for the 2015 ozone NAAQS, EPA has unlawfully disapproved Texas's SIP. If EPA had approved Texas's SIP, sources in Texas would continue to be subject to their existing NO_x limitations, and additional reductions would not be required. However, because EPA has disapproved Texas's SIP, EPA now has the legal obligation to promulgate a Federal Implementation Plan (FIP) for Texas. In fact, EPA presupposed the outcome of its SIP review process by proposing a FIP well before the outcome of its SIP review process. EPA says it will finalize a FIP after it finalizes disapproval of a SIP, as it has now done for Texas. *See* 87 Fed. Reg. 20,036, 20,058 (Apr. 6, 2022). EPA's FIP would impose substantial additional emission restrictions and costly compliance measures at Texas sources, including Luminant's EGUs. That proposed FIP made clear that "source owners and operators . . . should begin engineering and financial planning now," even before the FIP was finalized. *Id.* at 20,101. EPA will finalize that FIP in March 2023 and impose these new requirements starting just two months later in May 2023.

EPA'S FIP FOR TEXAS

12. In its proposed FIP, EPA establishes more restrictive ozone season NO_x budgets for Texas starting in May 2023 with further reductions beginning in 2026. EPA's new NO_x emission budget for Texas starting in May 2023 is a 27% reduction from Texas's existing ozone season NO_x budget—from 52,301 tons to 38,284 tons. *Id.* at 20,044. EPA bases this 2023 budget in part on the amount of NO_x reductions that EPA projects can be achieved by Texas units by conducting “optimization” work on their existing NO_x controls. Units that cannot conduct the work, or cannot achieve the reductions projected by EPA, will be forced to purchase additional allowances on the open market, if available, or reduce the generation of electricity (*i.e.*, de-rate) or a combination of both.

13. EPA's FIP would further require a 58% reduction from Texas's existing NO_x budget in 2026, down to 21,946 tons. *Id.* EPA bases this budget in part on the amount of NO_x reductions that EPA projects will be achieved at Texas units by the installation of new and exorbitantly costly post-combustion emission controls—namely, the installation and operation of new selective catalytic reduction (SCR) controls and selective non-catalytic reduction (SNCR) controls—or the shifting of generation from higher emitting units to lower emitting units or renewables and thus the loss of revenue. Units that cannot conduct the work, or cannot achieve the reductions projected by EPA, will be forced to purchase additional allowances on

the open market, if available, and/or reduce the generation of electricity (*i.e.*, de-rate or retire).

14. The following table shows the 17 Luminant plants in Texas that would be regulated by EPA's FIP as a result of EPA's SIP disapproval and the remedy for each plant that EPA assumes in its FIP.

COST OF INSTALLING SCR

36. If OVEC moves forward with the SCR compliance option, it will be required to spend between \$80-\$100 million in the next two years. Those costs would be borne by OVEC's Sponsor's in the first instance and presumably by such Sponsor's customers.
37. This process will require OVEC to enter into contracts that may include cancellation fees and termination penalties if this court later overturns EPA's Federal Plan.

IMPACTS BEYOND 2023

38. Under the Federal Plan, OVEC will be required to sacrifice hard-earned allowances obtained by making early, excess NO_x reductions. This means that OVEC's prudent decisions to reduce NO_x emissions and bank allowances in prior years will result in punishment via "excess" allowance confiscation.
39. The Federal Plan also creates uncertainty for OVEC and other utilities because it does not provide unit-specific allocation forecasts for 2026 and beyond. Instead, the Federal Plan requires increasingly stringent state/utility NO_x budgets based on each year's unit operating heat input.
40. The lack of specific allowance allocations combined with increasingly stringent statewide budgets will create confusion in future years. Fewer allowances must be allocated across a statewide fleet without regard to the unique operating profiles of individual units.
41. OVEC's coal fleet will have even fewer unit-level allocations beginning in 2030 and beyond. The Federal Plan does not provide pre-set budget floors for those years and instead will apply dynamic budgeting to further limit the number of available allowances based on prior year heat input.
42. The Federal Plan will also recalibrate banked allowances to further tighten allowable emissions. OVEC and other generators may only keep a maximum of 10.5% of the sum of the state emission budgets in 2030 and beyond.
43. The Final Rule does not give utilities adequate time to build replacement generation for retiring coal-fired assets, which is crucial to maintain reliability.

Luminant Power Plants Impacted by EPA's Texas SIP Disapproval

Facility	Number of Units	Type of Units	Capacity (in MW)³	EPA FIP Remedy
Coletto Creek	1	Existing Coal Steam	648	New SCR
Decordova	4	Existing Combustion Turbine	282	Generation Shifting
Ennis	1	Existing Combined Cycle	359.5	Optimize SCR
Forney	6	Existing Combined Cycle	1,786	Generation Shifting
Graham	2	Existing Oil/Gas Steam	624	New SCR
Hays	4	Existing Combined Cycle	844	Optimize SCR
Lake Hubbard	2	Existing Oil/Gas Steam	915	Optimize SCR
Lamar	4	Existing Combined Cycle	1,036	--
Martin Lake	3	Existing Coal Steam	2,410	New SCR
Midlothian Energy	6	Existing Combined Cycle	1,602	Optimize SCR
Morgan Creek	6	Existing Combustion Turbine	402	Generation Shifting
Oak Grove	2	Existing Coal Steam	1,710	Generation Shifting
Odessa-Ector	4	Existing Combined Cycle	1,043	--
Permian Basin	5	Existing Combustion Turbine	321	Generation Shifting
Stryker Creek	2	Existing Oil/Gas Steam	669	Generation Shifting
Trinidad	1	Existing Oil/Gas Steam	235	Generation Shifting
Wise County	2	Existing Combined Cycle	680	Optimize SCR
Total			15,567	

15. In addition to the significant reduction in allowances that would be imposed on Texas in the FIP, operations of Texas units are further limited by other aspects of

³ These capacity values are taken from EPA's Integrated Planning Model (IPM), with the exception of Trinidad, which is not included in EPA's IPM. See EPA, *IPM Runs: Air Quality Modeling Base*

the FIP. The State of Texas has an “assurance level” equal to its budget plus a 21% variability limit⁴—that is, sources in Texas would be penalized if emissions from the State as a whole exceed 46,323 tons of NO_x during the 2023 ozone season. This represents a significant reduction from the assurance level of 63,284 tons under the State’s current obligations.⁵ Under the FIP, in the event emissions from the State exceed 46,323 tons, operators whose sources exceeded their respective share of the assurance level would be penalized and required to surrender three allowances for every one ton emitted above that level. Moreover, EPA’s FIP includes multiple other new draconian “enhancements” beyond the existing regulations. Specifically, EPA has added unit-specific backstop daily emission rates, a revised emissions budget-setting process (called “Dynamic Budgeting”), secondary emission limits, and an annual recalibration of banked allowances. These new requirements will further limit operations of Texas units and further ratchet down the emissions budget allocated to Texas units.

Case Overview File, Doc. No. EPA-HQ-OAR-2021-0668-0157 (Apr. 5, 2022) (unit-specific information provided in “ParsedFile EPA620 BC 1k 2023 06 07 2021”).

⁴ 87 Fed. Reg. at 20,209.

⁵ 40 C.F.R. § 97.810(b)(20).

EPA’S DISAPPROVAL OF TEXAS’S SIP IS CAUSING IMMEDIATE AND IRREPARABLE HARM TO LUMINANT AS A RESULT OF 2023 BUDGET IMPACTS

16. Under EPA’s FIP, which EPA will issue in March 2023 as a result of its disapproval of Texas’s SIP, sources in Texas will be moved from CSAPR Group 2 to the more restrictive CSAPR Group 3, with a NO_x budget that has been reduced by 27% starting less than two months from now. EPA assumes immediate reductions for the 2023 ozone season will be available through the optimization of SCRs and SNCRs at units in Texas as well as generation shifting from higher emitting units to lower emitting units or renewables.

17. As a result of this immediate budget reduction, Luminant’s ability to plan for its summer 2023 operations is severely limited. Luminant and other Texas generators are faced with the choices of scrambling to attempt to “optimize” existing emissions control equipment over the next few months, purchasing costly emission allowances, limiting their operations during the ozone season (*i.e.*, de-rating), or a combination of all three.

18. If operators seek to purchase emission allowances rather than undertake changes at the source, they face a significant cost of compliance. The cost of emission allowances has skyrocketed, at least partially as a result of EPA’s FIP. When EPA issued the proposed FIP in early 2022, market participants anticipated dramatic changes to operations in order to comply with EPA’s actions and the price

of allowances spiked. For example, on December 30, 2021, before EPA proposed to disapprove Texas's SIP or proposed a FIP, Group 2 and Group 3 ozone season NO_x allowances traded at \$166.25 per ton and \$3,175 per ton, respectively. However, allowance prices increased substantially during 2022 in large measure due to limitations in the trading market and uncertainty over the upcoming regulations. Group 2 and 3 allowance prices traded as high as approximately \$5,000 per ton and \$47,000 per ton, respectively, in August 2022. Therefore, by acquiring additional allowances rather than seeking to undertake costly optimization measures—if allowances are even available in the market—the cost of compliance for sources radically increases.

19. The dramatic increase in allowance costs is illustrated by EPA's treatment of Luminant's Martin Lake Plant. Martin Lake has an operating capacity of 2,250 MW—enough to power about 1.125 million homes in normal conditions and 450,000 homes in periods of peak demand. Martin Lake's ozone season NO_x emissions from 2017 (the year the current budgets went into effect) to 2022 averaged 4,237 tons per year,⁶ but Martin Lake's 2023 NO_x budget under EPA's FIP is expected to be only 3,248 tons.⁷

⁶ EPA's Clean Air Markets Database, <https://campd.epa.gov/>.

⁷ EPA, *Unit-level Allocations and Underlying Data for the Proposed Rule* (Apr. 2022), available at <https://www.epa.gov/csapr/good-neighbor-plan-2015-ozone-naaqs> ("Proposed 2015 NAAQS Allocations" tab).

20. The cost to seek to “optimize” existing controls is also substantial and cannot be recovered. EPA claims that 14 EGUs at Luminant’s facilities are able to optimize their SCR, and EPA relies on reductions from these optimizations when establishing Texas’s ozone season NO_x budget that will begin to apply in May.⁸ EPA makes unrealistic assumptions that all units can achieve very stringent rates and is setting budgets assuming that Luminant units can reduce their NO_x emissions by an additional 16 to 54% compared to 2021 emission rates.

21. If EPA’s disapproval of Texas’s SIP is not stayed, Luminant must take steps, even prior to the FIP being finalized, to achieve the reductions identified by EPA by May 1, 2023. If EPA’s SIP disapproval is later vacated by the Court, the cost of this work cannot be recovered from EPA. And, because ERCOT is a deregulated competitive energy market, versus a regulated rate-recovery system, Luminant cannot recover these costs from ratepayers either.

22. Specifically, to optimize the SCRs at the 14 units, Luminant is evaluating all applicable emission limits, existing ammonia injection systems, and overall SCR catalyst activity levels. Testing is necessary to validate whether increased ammonia usage is effective and can be maintained without exceeding ammonia slip limits in permits and state regulations. The assessment phase of SCR optimization could take

⁸ See EPA, *Appendix A: Proposed Rule State Emission Budget Calculations and Engineering Analytics* (Mar. 2022), available at <https://www.epa.gov/csapr/good-neighbor-plan-2015-ozone-naaqs> (“Unit 2023” tab).

20. The cost to seek to “optimize” existing controls is also substantial and cannot be recovered. EPA claims that 14 EGUs at Luminant’s facilities are able to optimize their SCR, and EPA relies on reductions from these optimizations when establishing Texas’s ozone season NO_x budget that will begin to apply in May.⁸ EPA makes unrealistic assumptions that all units can achieve very stringent rates and is setting budgets assuming that Luminant units can reduce their NO_x emissions by an additional 16 to 54% compared to 2021 emission rates.

21. If EPA’s disapproval of Texas’s SIP is not stayed, Luminant must take steps, even prior to the FIP being finalized, to achieve the reductions identified by EPA by May 1, 2023. If EPA’s SIP disapproval is later vacated by the Court, the cost of this work cannot be recovered from EPA. And, because ERCOT is a deregulated competitive energy market, versus a regulated rate-recovery system, Luminant cannot recover these costs from ratepayers either.

22. Specifically, to optimize the SCRs at the 14 units, Luminant is evaluating all applicable emission limits, existing ammonia injection systems, and overall SCR catalyst activity levels. Testing is necessary to validate whether increased ammonia usage is effective and can be maintained without exceeding ammonia slip limits in permits and state regulations. The assessment phase of SCR optimization could take

⁸ See EPA, *Appendix A: Proposed Rule State Emission Budget Calculations and Engineering Analytics* (Mar. 2022), available at <https://www.epa.gov/csapr/good-neighbor-plan-2015-ozone-naaqs> (“Unit 2023” tab).

months to gather all design and operational information and complete testing. This assessment could lead to the determination that ammonia injection system hardware changes are needed or replacement catalyst is necessary to meet the assumptions that EPA has used to establish budgets. Any hardware or catalyst changes are not feasible to complete before the expected compliance date less than two months away.

23. Even if it was feasible to fully optimize the SCRs at Luminant's units by May 1, 2023, EPA's budget-setting process for 2023, including flaws in model inputs and generation shifting, directly leads to a shortage of NO_x allowances as compared to what is necessary for anticipated generation needs and specifically impairs Luminant's units that operate during critical peak demand periods. For the 2023 ozone season, fifteen of Luminant's peaking units are allocated 43 to 97% fewer allowances than what was needed for the 2022 ozone season due EPA's projected generation shifting. These units are increasingly being relied on by ERCOT for reliability purposes during periods of extreme cold in the winter or heat in the summer, and often times are required to run. Additionally, with the increase of wind and solar (renewable, non-dispatchable) units, these units have had increased requirements to sit at their lowest output for ERCOT's grid reliability. If Luminant's peaking units are called on to run in 2023 in a manner similar to how they operated in 2022, each of these units would run out of allowances well before the end of the

ozone season, which is also the critical summer period in Texas, as shown in the table below:

Plant	Unit	Ozone Season NOx Tons		Date Allocations Run Out in 2022 if 2023 Budget in Place
		2022 Actual	Proposed 2023 Budget ⁹	
Lake Hubbard	1	97.25	48	7/15/2022
Graham	1	90.35	31	7/11/2022
Graham	2	115.80	66	8/5/2022
Morgan Creek	CT1	23.59	1	5/13/2022
Morgan Creek	CT2	20.79	1	5/13/2022
Morgan Creek	CT3	19.15	1	5/13/2022
Morgan Creek	CT4	20.09	1	5/13/2022
Morgan Creek	CT5	18.90	1	5/13/2022
Morgan Creek	CT6	19.77	1	5/13/2022
Stryker Creek	1	66.67	16	7/1/2022
Trinidad	9	68.93	31	7/19/2022
Decordova	CT1	86.18	3	5/11/2022
Decordova	CT2	43.37	2	5/13/2022
Decordova	CT3	75.52	2	5/6/2022
Decordova	CT4	53.13	2	5/13/2022
Total		819.49	207	

24. Absent a stay, Luminant will be forced to undertake efforts immediately to mitigate the impacts from the significant budget reductions. This includes

⁹ EPA, *Unit-level Allocations and Underlying Data for the Proposed Rule* (Apr. 2022), available at <https://www.epa.gov/csapr/good-neighbor-plan-2015-ozone-naaqs> (“Proposed 2015 NAAQS Allocations” tab).

combustion tuning activities at many of the units in question, as well as other units, to help mitigate the impact. The cost of the combustion tuning activities alone will be approximately \$700,000. Additional costs are expected to be incurred, as it is likely some of these units will need to operate during periods in which they are uneconomic (*i.e.*, when costs to operate exceed energy revenues) to perform the tuning activities.

25. Moreover, Luminant is currently making and will continue to make irreversible trading decisions as a result of EPA's disapproval of Texas's SIP. As noted above, there is significant uncertainty in the trading market resulting from the new regulatory obligations and limitations in the proposed FIP. Not only has this uncertainty arisen as a result of the more stringent budgets, but EPA's draconian "enhancements" to its new program cause even greater uncertainty. Specifically, EPA's "dynamic budgeting," wherein EPA will readjust state budgets every year beginning in 2025 based on a prior year's operations, prevents any source from knowing with certainty what its allocations in 2025 and future years will be. Therefore, operators are incentivized not to sell allowances to ensure a sufficient supply for future years; however, operators face an opposing force from EPA's "allowance bank recalibration." EPA's recalibration will "reset the total quantity of banked allowances for the Group 3 trading program" held in all allowance accounts to 10.5% of the total of all states' emission budgets each year. 87 Fed. Reg. at

20,109. As a result, sources may lose allowances held in their account if the total amount of banked Group 3 allowances nationwide exceeds EPA's 10.5% threshold. As a result, operators are in an untenable situation—attempting to navigate these competing interests while being forced to make irreversible trading decisions now as a result of these new requirements.

26. None of these costs—the cost of “optimization,” the cost of additional boiler tuning, the cost of additional allowances, or costs associated with foregone opportunities—can be recovered from EPA, rate payers, or others if EPA's SIP disapproval is later determined to be unlawful. Because Luminant operates in a deregulated competitive energy market, there is no way that Luminant can recover costs expended now to prepare for compliance with a FIP or costs to comply during the 2023 ozone season, even if EPA's disapproval of Texas's SIP is later overturned.

EPA'S DISAPPROVAL OF TEXAS'S SIP IS ALSO CAUSING IMMEDIATE AND IRREPARABLE HARM TO LUMINANT AS A RESULT OF EVEN MORE STRINGENT BUDGET REDUCTIONS IN 2026

27. There are additional unrecoverable costs as a result of EPA's even more stringent 2026 emission budgets if EPA's SIP disapproval is not stayed. EPA's FIP will require sources to immediately begin taking steps to prepare for significant changes to compliance obligations that EPA has proposed for the 2026 ozone season. Specifically, EPA projects its FIP would produce an ozone season NO_x budget of 21,946 tons for Texas in 2026, a 58% reduction from Texas's 2022 ozone season

NO_x budget of 52,301 tons and a 43% reduction from Texas's 2023 ozone season NO_x budget of 38,284 tons. Texas's further reduction in budget is primarily driven by EPA's assumption of the installation of new SCRs.

28. As shown in the table below, EPA has targeted five units at Luminant's facilities that it assumes will have to install a new SCR to comply with its FIP, and EPA relies on reductions from these retrofits when establishing Texas's ozone season NO_x budget that will begin to apply in May 2026. Specifically, EPA identifies a reduction from 2021 actual emissions of 3,914 tons of NO_x attributable to these retrofits in establishing the 2026 budget. Although these significant reductions are not expected to take place for three years, EPA explained in its proposed FIP that to achieve the lower emission budgets in 2026 source owners must "begin engineering and financial planning *now* to be prepared to meet [EPA's] implementation timetable." *Id.* at 20,101 (emphasis added). Therefore, sources are faced with a Hobson's choice: begin steps now to install costly emission control equipment that may not be necessary, make plans to cease operations of certain sources during the ozone season, or purchase costly allowances, if any such allowances are even available. Any of these would be unrecoverable sunk costs if EPA's SIP disapproval is overturned by the Court.

29. To rely on the first option and install a new SCR, sources must begin initiating design studies now. EPA itself previously found it may take between 2 and 4 years

to retrofit a single EGU with a new SCR and, in its proposed FIP, EPA explains sources should start taking engineering and financial planning steps now to ensure compliance on EPA's timeline. First, a feasibility study would be necessary, which would cost hundreds of thousands of dollars and take at least six months to perform. The study would result in conceptual designs, preliminary cost estimates, and an estimate of the timelines to complete final design, procure equipment, construct the new systems, and commission the equipment. If found to be an economically viable option, detailed engineering studies and permitting activities would then commence.

30. According to EPA's own cost evaluation,¹⁰ installation of SCRs on the Luminant units identified by EPA for retrofit would, in EPA's estimation, exceed one billion dollars in total project costs, as shown in the table below.

¹⁰ EPA, *NO_x Control Retrofit Cost Tool Fleetwide Assessment Proposed CSAPR 2015 NAAQS*, Doc. No. EPA-HQ-OAR-2021-0668-0113 (Apr. 2022).

**Cost Evaluation of SCR at Luminant Units
Identified by EPA for Retrofit**

Unit	Type of Unit	EPA FIP Remedy	EPA's Projected Total Project Cost Estimate of Remedy
Coletto Creek Unit 1	Coal Steam	New SCR	\$227.4 million
Graham Unit 2	O/G Steam	New SCR	\$65.2 million
Martin Lake Unit 1	Coal Steam	New SCR	\$312.5 million
Martin Lake Unit 2	Coal Steam	New SCR	\$309.9 million
Martin Lake Unit 3	Coal Steam	New SCR	\$310.5 million
Totals			\$1.2 billion

Luminant believes that these estimates are low especially given the age of these units, the site-specific challenges of installing SCRs on the three side-by-side units at Martin Lake, and the lost generation that would be incurred by additional or extended plant outages needed to incorporate the new SCR systems. Further, EPA's evaluation projects over \$20 million per year in operation and maintenance costs for the SCRs at these units.

31. Even if EPA's SIP disapproval is overturned by the Court one year from now, initial costs would likely amount to millions of dollars in unrecoverable costs. It is clear that sources cannot wait until litigation over EPA's disapproval of Texas's SIP is resolved before they must begin making costly, unrecoverable compliance decisions.

32. In the event sources do not take steps now to install costly SCRs, companies may be required to idle certain sources during the ozone season; however, this option also requires immediate planning. If forced to idle units, substantial planning would be needed with varying implementation costs based upon the expected length that the unit would be idled and the individual unit design. Some considerations that must be addressed are the steps necessary to protect the boilers, turbines, and generation from corrosion and electrical damage while the unit is not operating. Planning would also include proper handling and long-term storage of water, chemicals, fuel and other commodities. Finally, plant labor expenses would continue regardless of whether generation or revenue was being produced. All of the items listed above are just a small fraction of the details that would need to be evaluated and planned for if a unit were to idle over the ozone season. Ozone season in Texas is generally peak demand season, with the highest prices for generation. Therefore, idling during the ozone season—from May through September—would likely make many units uneconomic and force their early retirement, which appears to be EPA’s goal with this disapproval of Texas’s SIP and issuance of the FIP as shown by EPA’s modeling discussed further below.

33. Further, even though CSAPR has historically been a trading program, and sources could acquire additional allowances rather than install new controls, such an approach will be significantly more limited under EPA’s FIP. Due to the increasing

stringency of the ozone season NO_x budgets, in addition to the new, restrictive features introduced in EPA's FIP, operational flexibility through the trading program will be severely limited. Luminant has to plan for a limited allowance market and high allowance costs, and this must be accounted for in the dispatch planning of the fleet. Additionally, if allowances are unavailable and insufficient allowances are held by Luminant, penalties could come into play that strip allocations from future years and limit future operations.

34. Therefore, Luminant is taking steps now to comply with near-term and long-term obligations under EPA's FIP, which sources in Texas would not be subject to but for EPA's disapproval of Texas's SIP. Even if the disapproval of Texas's SIP is ultimately overturned, Luminant faces immediate and irreparable harm, as Luminant will have undertaken significant compliance efforts and costs that cannot later be recovered.

35. EPA's modeling projects the retirement of many of Luminant's units in the near-term. EPA modeled the proposed rule scenario using its Integrated Planning Model (IPM), and that model projects significant shutdowns of units in Texas even before 2026. IPM, in EPA's words, is "a state-of-the-art, peer-reviewed, dynamic linear programming model that can be used to project power sector behavior under future business-as-usual conditions and to examine prospective air pollution control policies throughout the contiguous United States for the entire electric power

system.”¹¹ EPA used IPM to project likely future electricity market conditions with and without the proposed FIP for the 2015 ozone NAAQS. Luminant is unable to run the proprietary IPM model itself and, thus, can only review the modeling results that EPA has made available and EPA’s conclusions.

36. As to Luminant in particular, EPA’s IPM modeling for its “Proposed Rule Case”¹² shows that eight facilities cease operating by 2025, with 3,091 MW of Luminant’s units no longer operating in 2023 and an additional 3,133 MW no longer operating by 2025 as shown below:

¹¹ EPA, *Regulatory Impact Analysis for Proposed Federal Implementation Plan Addressing Regional Ozone Transport for the 2015 Ozone National Ambient Air Quality Standard*, at 4-11 (Feb. 2022).


¹² See EPA, *IPM Runs: Proposed Rule Files*, Doc. No. EPA-HQ-OAR-2021-0668-0161 (Apr. 5, 2022) (unit-specific information provided in “Proposed Rule RPE File”).

Luminant Facilities That Cease Operation By 2025
Under EPA's Modeling of FIP

Plant (Unit ID from IPM)	Dispatchable Capacity per IPM (in MWs)	Cease Operation by 2023	Cease Operation by 2025
Coletto Creek (2716)	648	X	
Graham (2443 and 2444)	624	X	
Lake Hubbard (2312 and 2549)	915	X	
Martin Lake (2623)	2,410		X
Morgan Creek (1073)	402		X
Permian Basin (1074)	321		X
Stryker Creek (2317 and 2321)	669	X	
Trinidad (not listed in IPM)	235	X	
Total MW:	6,224		

This means that—according to EPA—over 30% of Luminant's existing Texas generation will be shuttered within the next few years. This only emphasizes the immediate and irreparable harm that Luminant—and the Texas economy and consumers in ERCOT—face as a result of EPA's disapproval of Texas's SIP.

I, Randall J. Talley, declare under penalty of perjury under the laws of the United States of America that the foregoing is true and correct. Executed this 2nd day of March, 2023.



Randall J. Talley
Vice President, Solid Fuels and
Environmental Trading
Vistra Corp.

Declaration of Dwayne W. “Woody” Rickerson, Vice President of System Planning & Weatherization, Electric Reliability Council of Texas (ERCOT)

**DECLARATION OF
DWAYNE W. “WOODY” RICKERSON**

1. I am the Vice President of System Planning & Weatherization for Electric Reliability Council of Texas, Inc. (ERCOT), where I am responsible for transmission planning, generator interconnection activities, weatherization inspections, and resource adequacy analyses. I have worked at ERCOT for the past 22 years. I have a Bachelor of Sciences degree in Electrical Engineering from New Mexico State University and a Master of Engineering in Engineering Management from the University of Colorado. I am providing this declaration on behalf of ERCOT.
2. I am submitting this declaration because it is my understanding that the Environmental Protection Agency (EPA)’s disapproval of the Texas state implementation plan (SIP) for addressing regional ozone transport under the 2015 National Ambient Air Quality Standard (NAAQS) could allow EPA to implement the federal implementation plan (FIP) that EPA proposed in April 2022 and that is expected to be adopted by EPA in final form on March 15, 2023. As further explained in this declaration, I am concerned that the implementation of the EPA’s FIP could result in imminent harm to the reliability of the ERCOT grid for the 2023 Ozone Season (defined to be May 1, 2023 through September 30, 2023).

Background: ERCOT’s Role in Managing Texas’s Electric Grid and Electricity Market

3. ERCOT is the independent system operator (ISO) designated by the Public Utility Commission of Texas for the purpose of managing the ERCOT transmission grid, which serves approximately 26 million customers in the State of Texas.
4. In its role as the ISO, ERCOT is tasked with a number of critical functions, including “ensur[ing] the reliability and adequacy of the regional electrical network” and administering the wholesale electricity market. Texas Utilities Code section 39.151(a)(2), (4). One of the most important ways ERCOT ensures system reliability is by managing the flow of electric power on the grid every moment of every day. ERCOT performs this function by dispatching each of hundreds of generators located across the system to match the system demand of these customers at all times, while also observing the physical limits of the transmission lines that transport that power.
5. ERCOT is also registered with the North American Electric Reliability Corporation (NERC) as the sole Reliability Coordinator and Balancing Authority for the ERCOT region under the reliability framework in section 215 of the Federal Power Act. In these roles, ERCOT has the ultimate responsibility to direct the operation of the ERCOT power grid to ensure generation and load are balanced and to take all appropriate actions needed to ensure the security of the grid during emergency conditions.
6. ERCOT does not engage in advocacy except where its core functions, including electric grid reliability, may be affected. ERCOT’s interests in this matter are limited to the reliable operation of the ERCOT grid.
7. Under the statutory design of the ERCOT wholesale electricity market, generation owners bear the risk of investment when deciding the timing and location of new generation or the retirement of existing generation based on market conditions. ERCOT cannot mandate construction of new generation. Rather, the ERCOT market is designed to provide financial signals to generation companies to develop adequate generation capacity. As part of its responsibilities, ERCOT evaluates the impacts to grid reliability of possible and pending changes in generation capacity.

Risks Associated with Growth in Renewable Generation

8. Because the ERCOT wholesale market relies on market forces to ensure generation sufficiency, investment dollars tend to favor investments that have the greatest rates of return. For at least the past decade, federal tax incentives for investment in renewable generation have been the primary factor leading investors to strongly favor wind and solar projects to meet the growing demand in the ERCOT region.
9. Whereas wind and solar generators accounted for less than 1% of the total generating capacity in 2007, those generators now account for a combined 40% of the total generating capacity and produce 39% of the energy in the ERCOT region.
10. Wind and solar generation also account for approximately 21,683 MW, or 69%, of the approximately 31,287 MW in generation capacity that is currently proposed to interconnect in the ERCOT region within the next three years, while gas-fired generating units account for only 5%, and coal units account for zero percent of the generation capacity that is proposed to interconnect.
11. Increases in generation capacity from renewables alone are not adequate to supply the future electric energy demands of a growing 26 million customer base in ERCOT. Wind and solar generating units are intermittent sources of generation. During daylight hours, cloud cover can cause fluctuations in solar energy production. Solar energy production also dissipates rapidly in the evening and is nonexistent at night. Wind generation will also vary with weather patterns, time of day, and seasons.
12. Together, the variability of wind and solar power production creates the need for replacement energy that must come from dispatchable sources such as gas and coal units. Battery energy storage devices do not currently have enough installed capacity in the ERCOT grid to provide this replacement energy. The forecasted installation of new batteries in the next three years will not meet the projected demand.
13. Replacement energy from dispatchable sources must also be able to increase and decrease quickly. This ramping capability is needed to match the variability associated with wind and solar energy production. If the amount of dispatchable generation capacity is reduced due to increased emissions limits, the risk that ERCOT will not be able to meet its load demands increases.

Imminent Harm to ERCOT Reliability for Ozone Season 2023

14. It is my understanding that the EPA's proposed FIP will reduce the availability of allowances for nitrogen oxides (NOx) emissions from electric generation facilities for the Summer 2023 Ozone Season, which is defined as May 1, 2023 through September 30, 2023. This reduction in NOx emission allowances will impact the operation of the gas and coal facilities that are needed to manage the reliability of the grid because gas and coal units produce NOx as a byproduct of generating electricity.
15. Based on data provided to ERCOT by a subset of owners of coal and gas-fired generating units regarding the impacts in the reductions of these allowances, those units would need to reduce their capacity by 26% during summer of 2023.
16. The units for which these owners provided data collectively represented units that have already installed Selective Catalytic Reduction (SCR) technology as well as units that do not currently have SCR technology. Consequently, for this data sample, while some lower-emitting units would be expected to increase generation for summer of 2023 in order for higher-emitting units to run less, a

26% total reduction in capacity was predicted for this subset of units as a whole.

17. ERCOT extrapolated the data from this subset of coal- and gas-fired generating unit owners to understand possible system-wide impacts. ERCOT evaluated the roughly 12,281 megawatts (MW) of generation in the ERCOT footprint that have been identified as being required to install SCR technology by 2026 to meet the EPA's proposed FIP emissions for that year. Assuming those units that currently lack SCR technology are units that would need to reduce emissions in 2023, using the 26% reduction in capacity noted above, ERCOT calculated that under EPA's proposed FIP, there could be a 3,193 MW reduction in thermal capacity for summer of 2023 for the ERCOT system (26% of 12,281 MW.)
18. For Ozone Season 2022, the tightest reserve capacity margin in ERCOT occurred on July 13, 2022 at 3:23 p.m. At that time, ERCOT had 2,408 MW of capacity reserves. If the July 13, 2022 conditions were to occur again in 2023, it is expected that a 3,193 MW reduction in thermal capacity would require ERCOT to direct at least 1785 MW of firm load-shedding in order to maintain 1000 MW of operating reserves. When ERCOT directs firm load-shedding, utilities are required to disconnect customers from the power grid in order to avoid a system-wide blackout.
19. With 3,193 MW less thermal capacity available in summer of 2023, ERCOT estimates that during the 4 p.m. hour on a peak load day, the likelihood that ERCOT would need to direct firm load-shedding would be five times greater than it would be without the reduction of capacity. (The peak load day is the day in ERCOT's long-term load forecast for summer 2023 that ERCOT has the highest load. The 4 p.m. hour is the hour forecasted to be the peak demand hour in that same forecast for summer 2023. Therefore, if load meets or exceeds that forecasted peak demand, the chance of load-shedding would be five times greater than it would be without the reduction in capacity.)
20. With 3,193 MW less thermal capacity available in summer of 2023, ERCOT estimates that during the 7 p.m. hour on a peak load day, the likelihood that ERCOT would need to direct firm load-shedding would be two and a half times greater than it would be without the reduction of capacity.
21. With 3,193 MW less thermal capacity available in summer of 2023, ERCOT estimates that during the 4 p.m. hour on a peak load day, the likelihood that ERCOT would enter Emergency Energy Alert 1 (EEA1)—which means that operating reserves for the Texas grid have dropped below 2,300 megawatts and are not expected to recover within 30 minutes—would be four times as large. Note that during EEA1, there are no controlled outages, but ERCOT can acquire additional resources during capacity scarcity conditions as well as issue calls for conservation.
22. With 3,193 MW less thermal capacity available in summer of 2023, ERCOT estimates that during the 7 p.m. hour on a peak load day, the likelihood that ERCOT would enter EEA1 would double.
23. EPA uses an Integrated Planning Model (IPM) to project future conditions in the electricity market, including unit-specific summer generation expectations. The EPA model results that take into account the impacts of the proposed FIP for 2023 are located on EPA's website at <https://www.regulations.gov/document/EPA-HQ-OAR-2021-0668-0161m> under the spreadsheet labeled "Proposed Rule RPE File." Column A of that spreadsheet can be filtered for only the year 2023. Column B, "Region Group," can be filtered for only the ERCOT region. Column V "Generation Summer GWh," shows many units for which EPA has assumed will have zero output under the 2023 FIP. When units that have a non-zero output, and therefore are assumed to be operating in summer 2023, are deleted from the sum of column AW "Dispatchable Capacity MW," the remainder for column AW, and therefore what is assumed by EPA to *not* operate in summer 2023 because of the FIP, sums to 17,611 MW. However, this number appears to double-count three units

with a total output of 2,568 MW. Subtracting this apparent error from the 17,611 MW amount results in a total of 15,044 MW.

24. Therefore, while ERCOT has evaluated the effects of a reduction in capacity of 3,193 MW for summer 2023, this number actually appears to be quite conservative. EPA's own data indicates a 15,044 MW reduction in capacity for ERCOT for summer 2023.
25. If ERCOT were to have 15,044 MW less thermal capacity available in summer of 2023, it is even more likely that ERCOT would need to direct firm load-shedding. ERCOT estimates that under this scenario during the 4 p.m. hour on a peak load day, the likelihood of needing to direct firm load-shedding would be 77 times greater than it would be without the reduction of capacity.
26. If ERCOT were to have 15,044 MW less thermal capacity available in summer of 2023, ERCOT estimates that under this scenario during the 7 p.m. hour on a peak load day, the likelihood that ERCOT would need to direct firm load-shedding would be eight times greater than without the reduction of capacity.
27. While paragraphs 19-26 address impacts on a single peak load day, it should be noted that numerous non-peak load days from May 1, 2023 through September 30, 2023 will experience similar probabilities that ERCOT would need to direct firm load-shedding.
28. While the above impacts have addressed 2023 system-wide impacts that can be extrapolated from the data provided or available to ERCOT, a reduction in capacity from generators, even when ERCOT has a large enough reserve margin to meet demand, can cause additional stress on the system, leading to operational problems. In effect, this additional stress can mean that even when ERCOT has sufficient generation to meet demand, it may be unable to deploy power to the customers that need it because there are not sufficient available transmission paths to deliver that energy.
29. Based on data provided by a subset of owners of coal- and gas-fired generating units regarding the impacts in the reductions of these allowances, ERCOT determined that the reductions in generating capacity would also cause local and regional reliability issues due to overloads of multiple transmission elements. ERCOT's analysis showed that some of these overloads could not be addressed by existing generation redispatch and would result in some amount of regional firm load-shedding to address these reliability issues. Regional firm load-shedding is used to address specific transmission overloads. This differs from firm loadshedding that may be directed to balance generation and load across an entire grid.
30. These overload issues would also limit ERCOT's ability to deliver available generation capacity using the existing transmission system to address the unavailability of the coal- and gas-fired generating units. This, in turn, would exacerbate the system-wide impacts that are described in paragraphs 14-27.

Harm to ERCOT Reliability beyond Ozone Season 2023

31. ERCOT has been informed by owners of coal- and gas-fired generating units that the proposed FIP's mandate that owners of certain generating units must install SCR technology by 2026 would be prohibitively expensive and would therefore lead these generation owners to retire their units.
32. ERCOT understands that as much as 10,800 MW of capacity in the ERCOT region—8,200 MW of coal-fired generation and 2,600 MW of gas-fired generation—is at risk of retirement due to the SCR mandate, a loss of thermal capacity that could have catastrophic consequences for the electric grid in

2026.

33. The risks associated with the retirements of these units include but are not limited to: the increase in probability that ERCOT will need to direct utilities to shed firm load (i.e., to disconnect customers from the grid) to ensure the reliability of the remaining electric system; the reduced availability of outages for the remaining thermal generation fleet; the reduction in system inertia; and the impact on transmission flows and associated reliability problems.
34. ERCOT performed a study to quantify this risk for summer 2026, assuming the retirement of 10,800 MW of coal and gas generation. In this assessment, ERCOT used its Operating Reserve Risk Model to run 10,000 simulations of conditions during this period. ERCOT's assessment concluded that the probability of the supply of generation being inadequate to serve the demand on the grid during the 7 to 8 p.m. window at some point in summer 2026 increased from 4.5% to 40%.
35. Therefore, while solar energy is dissipating fairly rapidly in the evening, ERCOT will have an approximately nine times greater risk of having insufficient generation to meet demand in 2026 if the proposed FIP is finalized. This vulnerability is most pronounced between 7 to 8 p.m. but extends to other hours of the day.
36. While ERCOT has produced the above data for 2026, ERCOT anticipates that the mandate that owners of certain units must install SCR technology by 2026 could lead to retirement of coal- and gas-fired generating units prior to 2026, causing a gradual increase in the risk of having insufficient generation to meet demand.

Conclusion

37. In my opinion, the proposed FIP poses an imminent harm to the reliability of the ERCOT grid in summer of 2023 and in later years.

I declare, under penalty of perjury, that the foregoing is true and correct.

Executed on March 2, 2023.

/s/ D. W. Rickerson

Dwayne W. "Woody" Rickerson
Vice President of System Planning & Weatherization
Electric Reliability Council of Texas, Inc.